NRC FORM 366 (7-77) UPDATE REPORT-PREVIOUS REPORT DATE FEBRUARY 23, 1978 U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NEFCS1 (2) | 0000000000 (3) | 41111 (4) | (5)
LICENSEE CODE (9–14) | LICENSE NUMBER (15–25) | LICENSE TYPE (26–30) | CAT (57–58)

CON'T
01 | REPORT SOURCE L (6) | 05000285 (7) | 021478 (8) | 012979 (9)
(60) | DOCKET NUMBER (61–68) | EVENT DATE (69–74) | REPORT DATE (75–80)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 CH-1C charging pump was out for maintenance on leaking end cap. Machinists discovered
03 crack in valve block. Current leak rate does not render pump inoperative, therefore,
04 pump was returned to service and subsequently passed ISI test for operability.
05
06
07
08

09 SYSTEM CODE PC (11) | CAUSE CODE B (12) | CAUSE SUBCODE C (13) | COMPONENT CODE PUMPXX (14) | COMP. SUBCODE E (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 78 | — | SEQUENTIAL REPORT NO. 005 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 1

ACTION TAKEN F (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER M075 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Cause undetermined other than heavy usage at normal high pressure and vibration
11 excessive. Installed new block on January 5, 1979, using approved procedure MP-CH-1
12 and Maintenance Order 21292. Addition of suction stabilizer and discharge pulsation
13 damper with associated piping completed January 22, 1979, per Design Change Request
14 75A-24.

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Maintenance Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 NUMBER 012 (37) | TYPE E (38) | DESCRIPTION (39) 9 Maintenance 340 mrem; 2 Quality Assurance 10 mrem;1 Engineer 5 mrem

PERSONNEL INJURIES
18 NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY
19 TYPE Z (42) | DESCRIPTION (43) NA

PUBLICITY
20 ISSUED N (44) | DESCRIPTION (45) NA

7902060319

NRC USE ONLY

NAME OF PREPARER J. Stevens/D. Jones PHONE: 402-426-4011