

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
LICENSEE CODE														LICENSE NUMBER												LICENSE TYPE												CAT																																																													

47T

1 8
REPORT SOURCE L 6 0 5 0 0 0 1 2 6 6 7 0 1 1 7 7 9 3 0 2 0 2 7 9 9
60 61 DOCKET # 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

[2] With the unit in cold shutdown, while performing HNP-2-3820, switches 2B21-N301 F.

[3] H, & L did not actuate. These switches are on the Safety-Relief valve tail pipe.

4 Technical Specifications requires the setpoint to be 20 + 5 psig. There were no

5) significant consequences to this event.

6

7

8

9	SYSTEM CODE I B		11	CAUSE CODE E		12	CAUSE SUBCODE E		13	COMPONENT CODE I N S T R U				14	COMP. SUBCODE S		15	VALVE SUBCODE Z		16
8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	
17		LER/RO REPORT NUMBER		EVENT YEAR 7 9		23	SEQUENTIAL REPORT NO. 0 1 0		27	OCCURRENCE CODE 0 3		REPORT TYPE L		REVISION NO. 0						
33	34	35	36	37	38	39	40	41	42	43	44	45	46	47						
ACTION TAKEN C		FUTURE ACTION Z		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0		ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. Y		PRIME COMP. SUPPLIER Z		COMPONENT MANUFACTURER S 3 8 2				

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

10 The cause of the failure was switch diaphragm failure of 2B21-N301 F, H, & L.

7 The switches were replaced and recalibrated per HNP-2-5240. There were satis-

factorily tested per HNP-2-3820.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION		
5	G	23	0	0	0	29	NA	B	31	Surveillance Test
8	9	10	11	12	13	44	45	46	47	80
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE				
6	Z	33	Z	34	NA	44	45	46	47	80
8	9	10	11	12	13	44	45	46	47	80
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION				
7	0	0	0	0	Z	39	NA	40	41	80
8	9	10	11	12	13	44	45	46	47	80
PERSONNEL INJURIES		NUMBER		DESCRIPTION						
8	0	0	0	0	40	NA	41	42	43	80
8	9	10	11	12	13	44	45	46	47	80
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION						
9	Z	42	NA	43	44	45	46	47	48	80
8	9	10	11	12	13	44	45	46	47	80
PUBLICITY		ISSUED		DESCRIPTION						
0	N	44	NA	45	46	47	48	49	50	80
8	9	10	11	12	13	44	45	46	47	80
										NRC USE ONLY

NRC USE ONLY

NAME OF PREPARER R. T. Niy
Superintendent of Maintenance

PHONE: (912) 367-7791

7902150384

●
●
●
●
●
●
●
●