NRC FORM 366
(7 77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A R A N O 2 (2) | 0 0 - 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 8 (7) | 1 2 0 7 7 8 (8) | 0 2 0 8 7 9 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Review revealed that the semi-annual surveillance on Triaxial
03 | Response - Spectrum Recorders (OP 2304.58) was not performed
04 | on 10/5/78 as scheduled. No seismic events had occurred;
05 | therefore, no consequences. This occurrence similar to
06 | 50-368/78-24. Reported per T.S.6.9.1.9.b.
07 |
08 |

09 | SYSTEM CODE I E (11) | CAUSE CODE A (12) | CAUSE SUBCODE C (13) | COMPONENT CODE Z Z Z Z Z Z (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 3 1 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION H (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

13 | The failure to perform the surveillance was caused by
14 | personnel error. The Triaxial Response - Spectrum Recorder
15 | 2XR-2350 was tested on 12/8/78 satisfactorily.
16 |
17 |

FACILITY STATUS B (28) | % POWER 0 0 0 (29) | OTHER STATUS (30) Low Power Phy. Test | METHOD OF DISCOVERY D (31) | DISCOVERY DESCRIPTION (32) NRC Inspection

ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

790215 0432