

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	G	A	E	I	H	I	2	0	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	1	4			5	
7	8	9	LICENSEE CODE					14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT 58	

CON'T

REPORT SOURCE L 6 0 5 0 0 0 3 2 1 7 0 1 2 4 7 9 8 0 2 0 9 7 9 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in cold shutdown, plant personnel inadvertently opened both doors of the
03 reactor bldg., 130 ft. elevation, airlock # R106 violating secondary containment.
04 The standby gas treatment system was proven operable, insuring secondary contain-
05 ment integrity to comply with technical specification Section 4.7.C.2. Previous
06 occurrences of this type were reported in LER's 76-75, 77-27, 77-39, 77-63,
07 77-66, 77-73, 77-82, 77-95, 77-97, 78-7, 78-16, 78-25, & 79-1.

[illegible]

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The bracket into which the dead bolt projects was found to be bent. The bracket
11 was found to be bent to the extent it could only catch the tip end of the dead
12 bolt. This condition prevented the interlock from performing its intended func-
13 tion. The bracket was repaired, thus restoring the interlocking function to oper-
14 able status.

FACILITY STATUS		% POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	G	28	0	0	0	29	N/A	30
7	8	9	10	11	12	13	14	15	16
ACTIVITY		CONTENT		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	33	Z	34	N/A	35	N/A	36
7	8	9	10	11	12	13	14	15	16
PERSONNEL EXPOSURES		NUMBER		TYPE		DESCRIPTION			
1	7	0	0	0	37	Z	38	N/A	39
7	8	9	10	11	12	13	14	15	16
PERSONNEL INJURIES		NUMBER		DESCRIPTION					
1	8	0	0	0	40	N/A	41	N/A	42
7	8	9	10	11	12	13	14	15	16
LOSS OF OR DAMAGE TO FACILITY		TYPE		DESCRIPTION					
1	9	Z	42	N/A	43	N/A	44	N/A	45
7	8	9	10	11	12	13	14	15	16
PUBLICITY		ISSUED		DESCRIPTION					
2	0	Z	14	7902150443	N/A	46	47	48	49
7	8	9	10	11	12	13	14	15	16

NAME OF PREPARER Tom Greene, Supt. Plt. Eng. Services PHONE 912-367-7781