

LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 L Q A D 1 2 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5

REPORT SOURCE L 6 0 5 0 0 0 2 5 4 7 0 1 1 9 7 9 8 0 2 1 6 7 9 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

While performing the Main Steam Isolation Valve Local Leak Rate test, procedure

QTS 100-3, valves A0 1-203-1A, A0 1-203-2A, A0 1-203-1B, A0 1-203-2B, A0 1-203-1C,

A0 1-203-2C, and A0 1-203-1D were found to have leakage rates in excess of the

11.5 SCFH allowable limit as specified by Technical Specification 4.7.A.2.i.c.

SYSTEM CODE

CAUSE CODE

CAUSE SUBCODE

COMPONENT CODE

COMP. SUBCODE

VALVE SUBCODE

C D 11

E 12

B 13

V A L V E X 14

F 15

D 16

LER/RO REPORT NUMBER 17

EVENT YEAR 7 9

- 23

SEQUENTIAL REPORT NO. 0 0 3

/ 27

OCCURRENCE CODE 0 3

REPORT TYPE L 30

- 31

REVISION NO. 0 32

ACTION TAKEN B 18

FUTURE ACTION Z 19

EFFECT ON PLANT Z 20

SHUTDOWN METHOD Z 21

HOURS 0 0 0 0 22

ATTACHMENT SUBMITTED N 23

NPRD-4 FORM SUB. Y 24

PRIME COMP. SUPPLIER N 25

COMPONENT MANUFACTURER C 6 6 5 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

Not all the Main Steam Isolation Valves have been repaired at this date. A supplemental

report will be sent upon completion of all testing and when all corrective actions

regarding these valves have been completed.

FACILITY STATUS

% POWER

OTHER STATUS 30

METHOD OF DISCOVERY

DISCOVERY DESCRIPTION 32

H 28

0 0 0 29

NA 30

B 31

Local Leak Rate Testing 32

ACTIVITY CONTENT RELEASED OF RELEASE

AMOUNT OF ACTIVITY 35

LOCATION OF RELEASE 36

Z 33

Z 34

NA 35

NA 36

PERSONNEL EXPOSURES

NUMBER

TYPE

DESCRIPTION 39

0 0 0 37

Z 38

NA 39

PERSONNEL INJURIES

NUMBER

DESCRIPTION 41

0 0 0 40

NA 41

LOSS OF OR DAMAGE TO FACILITY

TYPE

DESCRIPTION 43

Z 42

NA 43

PUBLICITY

ISSUED N 44

DESCRIPTION 45

NA 45

NRC USE ONLY

NAME OF PREPARER

J. Kopacz

PHONE: 309-654-2241, ext. 248

7903070354