

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

716 Edney Building

March 23, 1979

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - SUPPLEMENTAL INFORMATION
TO REPORTABLE OCCURRENCE REPORT BFRO-50-259/768

The enclosed report is a supplement to my letter dated January 25, 1979,
concerning an analysis based on inplant measurements of actual real and
reactive loads which indicate that for certain postulated, degraded
conditions in the offsite power supply, technical specification 3.9.A.1
could not be met for 3-unit operation. This report is submitted in
accordance with Browns Ferry unit 1 technical specification 6.7.2.a.(9).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox
Director of Power Production

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

R. F. Sullivan, NRC Inspector, Browns Ferry

7903290002