

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	2	5	9	7	0	3	1	8	7	8	8	0	3	2	3	7	9	9
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | Analysis based on inplant measurements of actual real and reactive loads indicate that
0 3 | for certain postulated, degraded conditions in the offsite power supply, technical
0 4 | specification 3.9.A.1 could not be met for 3-unit operation. Unit 2 is in the refueling
6 5 | mode with its units boards backfeeding from the 500-kV system. A safety analysis
9 6 | has concluded that acceptable voltage can be maintained for 2-unit operation. There
0 7 | is no hazard to the public.

08									80					
7	8	9	SYSTEM CODE E G ⑪		CAUSE CODE B ⑫	CAUSE SUBCODE A ⑬	COMPONENT CODE X X X X X X ⑮						COMP. SUB CODE Z ⑯	VALVE SUBCODE Z ⑰
7	8		9	10	11	12	13	14	15	16	17	18	19	20
(17) LER RD REPORT NUMBER		EVENT YEAR 7 8 ⑲		(18)	SEQUENTIAL REPORT NO. 0 0 8 ⑳		OCCURRENCE CODE / ㉑		REPORT TYPE T ㉒		REVISION NO. 1 ㉓			
ACTION TAKEN X ㉔		FUTURE ACTION X ㉕	EFFECT ON PLANT Z ㉖	SHUTDOWN METHOD Z ㉗	HOURS 0 0 0 ㉘	ATTACHMENT SUBMITTED N ㉙		NPRD-4 FORM SUB N ㉚	PRIME COMP. SUPPLIER Z ㉛	COMPONENT MANUFACTURER Z 9 9 9 ㉜				
13	14	15	16	17	18	19	20	21	22	23	24	25	26	27

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Interim corrective measures to allow 3-unit operation and alleviate a potential detri-
1 1 mental voltage drop across the high impedance common service transformers include in-
1 2 stallation of devices to provide power factor correction, undervoltage protection, and
1 3 an alternate power supply. A supplemental report will be issued. (See letter from
1 4 H. S. Fox to James P. O'Reilly dated January 25, 1979.)

FACILITY STATUS (1) 5 (E) (28) POWER (0) 9 8 (29) OTHER STATUS (30) NA
 METHOD OF DISCOVERY (C) (31) Special testing DISCOVERY DESCRIPTION (32)
 ACTIVITY CONTENT RELEASED OF RELEASE (1) 6 (Z) (33) AMOUNT OF ACTIVITY (35) NA
 LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES

NUMBER			TYPE	DESCRIPTION
1	2	3	4	5
0	0	0	Z	NA

[illegible]

LOSS OR DAMAGE TO FACILITY (43)
LEVEL OF PROTECTION
[Z] (42) [NA]

7908290003

PURCHASE

ISSUED DESCRIPTION (45)

NA

NHC USE ONLY

NAME OF PREPARER

PHONE