

## (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N	Y	J	A	F	1	2	0	0	-	0	0	0	0	-	0	0	0	3	4	1	1	1	1	4			5	
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

0	1
---	---

REPORT SOURCE

L	6	0	5	0	0	0	3	3	3	7	0	18	0	5	7	8	8	0	8	3	0	7	8	9
---	---	---	---	---	---	---	---	---	---	---	---	----	---	---	---	---	---	---	---	---	---	---	---	---

DOCKET NUMBER

EVENT DATE

REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0	2	During routine surveillance testing of the RHR system primary containment
0	3	pressure suppression pool level exceeded technical specification limits by
0	4	2 inches.
0	5	
0	6	
0	7	
0	8	

7 8 9 80

SYSTEM CODE S A		CAUSE CODE A		CAUSE SUBCODE A		COMPONENT CODE Z Z Z Z Z Z				COMP. SUBCODE Z		VALVE SUBCODE Z			
9 10		11 12		12 13		13 14 15 16 17 18				19 20		21 22			
7 8															
17		EVENT YEAR 7 8		SEQUENTIAL REPORT NO. 0 5 9		OCCURRENCE CODE 0 3				REPORT TYPE L		REVISION NO. 0			
21 22		23 24		25 26		27 28 29				30 31		32 33			
ACTION TAKEN H		FUTURE ACTION H		EFFECT ON PLANT Z		SHUTDOWN METHOD Z		HOURS 0 0 0 0				ATTACHMENT SUBMITTED N		NPRD-4 FORM SUB. N	
33 34		35 36		37 38		39 40				41 42		43 44			
18 19		20 21		22 23		24 25				26 27		28 29			
34 35		36 37		38 39 40 41 42 43 44 45 46 47				48 49		50 51		52 53			
18 19		20 21		22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47				48 49		50 51		52 53			

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

Operator failed to isolate the RHR system from the "keep full" subsystem during test which allowed condensate transfer system to raise pressure suppression pool level. Pump down was initiated immediately with normal level restored in approximately 40 minutes.

FACILITY STATUS (1) 5 (2) E (3) 28 (4) 0 (5) 9 (6) 2 (7) 29 (8) NA (9) 30  
 METHOD OF DISCOVERY (1) A (2) 31 (3) Operator Observation (4) 32

ACTIVITY CONTENT  
RELEASED OF RELEASE

1 6 Z 33 Z 34

7 8 9 10 11

AMOUNT OF ACTIVITY NA 35

44

LOCATION OF RELEASE 36

NA

45 80

PERSONNEL EXPOSURES									
NUMBER				TYPE		DESCRIPTION		(39)	
1	2	3	4	5	6	7	8	9	10
0	0	0	0	(37)	Z	(38)			NA

PERSONNEL INJURIES

PERSONNEL INJURIES		NUMBER		DESCRIPTION (41)	
1	3	0	0	0	NA

7	8	9	11	12	
LOSS OF OR DAMAGE TO FACILITY (43)					2237 252
TYPE DESCRIPTION					

1 9 Z 42 NA

ISSUED DESCRIPTION (45) NRC USE ONLY

2	0	N	(44)	NA																					
7	8	9	10											68	69										

NAME OF PREPARER W. Verne Childs

PHONE: (315) 342-3840

7906040288