



Commonwealth Edison
Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242
Telephone 309/654-2241

DSB

NJK-79-179

May 11, 1979

J. Keppler, Regional Director
Office of Inspection and Enforcement
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Reference: Quad-Cities Nuclear Power Station
Docket No. 50-254, DPR-29, Unit 1
Appendix A, Sections 3.1 (Table 3.1-1) and 6.6.B.2.a

Enclosed please find Reportable Occurrence Report No. R0 79-09/03L for Quad-Cities Nuclear Power Station.

This report is submitted to you in accordance with the requirements of Technical Specification 6.6.B.2.a, as a reactor protection system setting which was found to be less conservative than established by the Technical Specifications.

Very truly yours,

COMMONWEALTH EDISON COMPANY
QUAD-CITIES NUCLEAR POWER STATION

N. J. Kalivianakis
Station Superintendent

NJK/JCV/cag

cc: R. F. Janecek

2274 287

17 1979

7906060240,

A002/S
11

MSIV LIMIT SWITCH TRIP POSITIONS

INBOARD VALVES

valve number	<u>SCRAM CHANNEL "A"</u>			<u>SCRAM CHANNEL "B"</u>		
	as found	corrected	% error	as found	corrected	% error
2-203-1A	14.5%	9.6%	4.5%	14.4%	8.2%	4.4%
2-203-1B	18.0%	9.4%	8.0%	16.0%	8.4%	6.0%
2-203-1C	11.3%	8.8%	1.3%	13.5%	8.5%	3.5%
2-203-1D	16.0%	9.8%	6.0%	12.7%	8.8%	2.7%

OUTBOARD VALVES

valve number	<u>SCRAM CHANNEL "A"</u>			<u>SCRAM CHANNEL "B"</u>		
	as found	corrected	% error	as found	corrected	% error
2-203-2C	20.8%	8.5%	10.8%	11.7%	6.9%	1.7%
2-203-2D	4.9%	8.9%	0.0%	6.0%	7.9%	0.0%

2274 288