

(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONT

REPORT SOURCE L 6 0 5 0 - 0 3 2 5 7 0 5 1 9 7 9 5 0 6 1 8 7 9 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During normal operator surveillance of the control panel, the operator noticed that the

0 3 CAD tank level was less than 4,350 gallons. When another operator went to investigate

0 4 the level locally, he noticed that the relief valve on the CAD tank was relieving.

0 5 (Technical Specifications 3.6.6.2, 6.9.1.9b

0 6

0 7

0 8

0 9

SYSTEM CODE S E 11 CAUSE CODE E 12 CAUSE SUBCODE X 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE F 15 VALVE SUBCODE H 16

17 LER/RO REPORT NUMBER 7 9 EVENT YEAR 7 9 SEQUENTIAL REPORT NO. 0 1 4 OCCURRENCE CODE 0 3 REPORT TYPE L REVISION NO. 0

ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER C 6 5 0 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 A frozen pressure control valve to the pressure buildup coils is believed to have

1 1 caused the problem. The buildup coils were isolated so that all frozen components

1 2 could be thawed out. The CAD tank was filled to its normal level. The regulator on

1 3 the pressure control valve was found out of adjustment, allowing excessive liquid

1 4 nitrogen flow, which froze the valve. The regulator was adjusted and the (con't)

FACILITY STATUS E 28 % POWER 0 4 6 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION 32

1 5 Operator Surveillance

ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 NA 35 AMOUNT OF ACTIVITY 36 LOCATION OF RELEASE 36

1 6

PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

1 7

PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

1 8

LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

1 9

PUBLICITY ISSUED N 44 DESCRIPTION NA 45

2 0

7906220294

2348 237

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-6701

NRC USE ONLY

GPO 91 7-826

LER CONTINUATION -- RO# 1-79-14

Facility: BSEP Unit No. 1

Event Date: 5-19-79

system returned to service. As this has only happened one time in the past, (5-26-77), this is considered an isolated incident and no further action is required.

2348 238