

NRR-DRMAPEm Resource

From: Singal, Balwant
Sent: Monday, September 30, 2019 8:04 AM
To: Nicole Good
Subject: Acceptance Review - License Amendment Request to Revise Technical Specification 3.7.5, "Auxiliary Feedwater (AFW) System," (EPID L-2019-LLA-0189)

By letter dated August 29, 2019 (Agencywide Access and management System (ADAMS) Accession No. ML19247C062), Wolf Creek Nuclear Operating Corporation submitted a license amendment request for Wolf Creek Generating Station for revision to the Technical Specification (TS) 3.7.5, "Auxiliary Feedwater (AFW) System." The amendment would add additional conditions to the Limiting Conditions for Operation for TS 3.7.5 such that one supply of Essential Service Water to the turbine driven AFW pump (TDAFW) can be inoperable up to 72 hours while still considering the TDAFW pump train operable. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 250 hours to complete. The NRC staff expects to complete this review by September 30, 2020. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates, will be communicated during the routine interactions with the assigned project manager.

These estimates are based on the NRC staff's initial review of the application and they could change, due to several factors including complexity and uniqueness of the review, requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities.

If you have any questions, please contact me.

Balwant K. Singal
Senior Project Manager (Diablo Canyon and Wolf Creek)
Nuclear Regulatory Commission
Division of Operating Reactor Licensing
Balwant.Singal@nrc.gov
Tel: (301) 415-3016
Fax: (301) 415-1222

Hearing Identifier: NRR_DRMA
Email Number: 226

Mail Envelope Properties (MWHPR09MB153688DCBA20EA6E3CE3F41D86820)

Subject: Acceptance Review - License Amendment Request to Revise Technical Specification 3.7.5, "Auxiliary Feedwater (AFW) System," (EPID L-2019-LLA-0189)
Sent Date: 9/30/2019 8:03:49 AM
Received Date: 9/30/2019 8:03:00 AM
From: Singal, Balwant

Created By: Balwant.Singal@nrc.gov

Recipients:
"Nicole Good" <Nicole.Good@WCNOC.com>
Tracking Status: None

Post Office: MWHPR09MB1536.namprd09.prod.outlook.com

| Files | Size | Date & Time |
|---------|------|----------------------|
| MESSAGE | 2918 | 9/30/2019 8:03:00 AM |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: