

CONTROL BLOCK:

							(1)
--	--	--	--	--	--	--	-----

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	M	A	P	P	S	1	2	0	0	0	0	0	0	0	0	0	3	4	1	1	1	1	4			5			
7	8	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57	CAT	58

CON'T

REPORT SOURCE: 01 L 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80
 DOCKET NUMBER: 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80
 EVENT DATE: 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80
 REPORT DATE: 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | On 2-12-79, while performing surveillance test 8.7.4.3, Test (Open and Close)

0 3 | Isolation Valves Except MSIV's, the following valves failed to give proper position

0 4 | indication when cycled: AO-5033A, CV-5065-10, 16 & 17, CV-5065-15 failed to close

0 5 | within the specified tolerance. A similar occurrence was reported in LER 78-046/

0 6 | 03L-0.

0 7 |

0 8 |

SYSTEM CODE S D 11		CAUSE CODE E 12		CAUSE SUBCODE X 13		COMPONENT CODE I N S T R U 14		COMP. SUBCODE S 15		VALVE SUBCODE Z 16	
EVENT YEAR 7 9 21 22		SEQUENTIAL REPORT NO. C 0 7 24 26		OCCURRENCE CODE 0 3 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32			
ACTION TAKEN E 18 33		FUTURE ACTION G 19 34		EFFECT ON PLANT Z 20 35		SHUTDOWN METHOD Z 21 36		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 41	
NPRD-4 FORM SUB. N 24 42		PRIME COMP. SUPPLIER A 25 43		COMPONENT MANUFACTURER M 3 0 2 26 44 47							

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 Investigation revealed that the situation was not an alignment problem. Each valve

1 1 was cycled several times and each operated properly. Proper indication was veri-

1 2 fied as each valve was subsequently cycled. The surveillance frequency for these

1 3 valves has been increased from quarterly to monthly.

1 4

7 8 9

80

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
1	5	E	1	0	0	N.A.			B	Surveillance Test				
7	8	9	10	11	12	13	14	15	16	17	18	19	20	

ACTIVITY CONTENT
RELEASED OF RELEASE

1 6 2 33 34

AMOUNT OF ACTIVITY (35)
N.A.

LOCATION OF RELEASE (36)
N.A.

PERSONNEL EXPOSURES									
NUMBER			TYPE		DESCRIPTION				
1	7	0	0	0	37	Z	38	N.A.	

PERSONNEL INJURIES		DESCRIPTION	
NUMBER			
1	8	0	0
0	0	0	40
N.A.			

8		9		11		12		80	
LOSS OF OR DAMAGE TO FACILITY				(43)					
TYPE		DESCRIPTION							
1	9	Z	(42)	N.A.					

7 8 9 10 80

PUBLICITY

ISSUED DESCRIPTION (45)

2 0 N (44)

7903020370

NRC USE ONLY

N.A.

16 John M. Fulton
NAME OF PREPARER _____

PHONE: 617-746-7900