

# LICENSEE EVENT REPORT

Update Report--Previous Report Date February 10, 1979

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | 1LQAD | 120001-000-000 | 3411111 | 4 | 5  
 7 8 9 14 15 25 26 30 57 CAT 58  
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T  
 REPORT SOURCE L | 05000254 | 7020579 | 8031579 | 9  
 9 50 51 52 53 54 55 56 57 58 59 60  
 DOCKET NUMBER EVENT DATE REPORT DATE

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

The 1/2A diesel fire pump was taken out of service longer than the seven day Technical Specification limit (3.12.B.2). Redundancy was provided in that the 1/2B diesel fire pump was operable. In addition the service water system was operable and capable of supplying water to the Fire Suppression Water System. Also, if need required, the 1/2A diesel fire pump could have been promptly returned to service and utilized.

SYSTEM CODE AB | CAUSE CODE A | CAUSE SUBCODE A | COMPONENT CODE PUMPXX | COMP. SUBCODE B | VALVE SUBCODE Z  
 9 10 11 12 13 14 15 16 17  
 LER/RO REPORT NUMBER 79 | EVENT YEAR 79 | SEQUENTIAL REPORT NO. 010 | OCCURRENCE CODE 03 | REPORT TYPE L | REVISION NO. 1  
 21 22 23 24 25 26 27 28 29 30 31 32  
 ACTION TAKEN H | FUTURE ACTION Z | EFFECT ON PLANT Z | SHUTDOWN METHOD Z | HOURS 0000 | ATTACHMENT SUBMITTED N | NPR-4 FORM SUB. N | PRIME COMP. SUPPLIER A | COMPONENT MANUFACTURER L095  
 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

Because the original intent was not to have the 1/2A fire pump out-of-service longer than the allowable seven days, the cause code for this LER has been changed to personnel error. The 1/2A fire pump was taken out-of-service at 5:35 a.m. on January 29, 1979, and returned-to-service at 11:30 a.m. on February 8, 1979 to allow a diver to work in the intake bay associated with the fire pump suction.

FACILITY STATUS H | % POWER 000 | OTHER STATUS NA | METHOD OF DISCOVERY Z | DISCOVERY DESCRIPTION NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
 ACTIVITY RELEASED Z | CONTENT OF RELEASE Z | AMOUNT OF ACTIVITY NA | LOCATION OF RELEASE NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
 PERSONNEL EXPOSURES  
 NUMBER 000 | TYPE Z | DESCRIPTION NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
 PERSONNEL INJURIES  
 NUMBER 000 | DESCRIPTION NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
 LOSS OF OR DAMAGE TO FACILITY  
 TYPE Z | DESCRIPTION NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50  
 PUBLICITY  
 ISSUED N | DESCRIPTION NA  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50

7903280347

NAME OF PREPARER J. Vahrenwald

PHONE 309-654-2241 Ext. 244