



On March 12, 1979, the subject Prompt Reportable Occurrence was transmitted to your Headquarters. The following information provides the written followup report required by the Technical Specifications, Appendix A, Paragraph 6.11.A.4.1.

Subsequent to the Prompt Report submitted on March 12, 1979, the Regulatory Commission issued an Order to Show Cause on March 13, 1979, which required that the James A. FitzPatrick Nuclear Power Plant be shut down until the seismic calculations in piping stress analysis be redone and problem areas, if any, resolved. The calculations are being accomplished by the Authority's architect engineer on an accelerated basis.

A final report involving this matter will be made directly by the Headquarter's Office of the Power Authority of the State of New York to the Director of the Office of Nuclear Reactor Regulation.