



October 3, 2019

PG&E Letter DCL-19-078

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

10 CFR 50.46

Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model  
Changes for Peak Cladding Temperature for 2018

Reference:

1. PG&E Letter DCL-18-071, "10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model Changes for Peak Cladding Temperature for 2017," dated September 25, 2018

Dear Commissioners and Staff:

Pursuant to 10 CFR 50.46, Pacific Gas and Electric Company (PG&E) hereby submits this annual report of changes in the Westinghouse emergency core cooling system evaluation models that affect peak cladding temperature (PCT) calculations for Diablo Canyon Power Plant, Units 1 and 2.

Because there are no changes from the results provided in Reference 1, there are no enclosures provided in this letter. The sum of the PCT from the most recent analysis of record using an acceptable evaluation model and the estimates of the net PCT effect for changes and errors remains within the 2200°F limit specified in 10 CFR 50.46.

PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this letter.

If you have questions regarding this submittal, please contact Mr. Mark Frauenheim at 805-545-3744.

Sincerely,

Paula Gerfen

dqmg/6192/50871345-08

cc: Diablo Distribution  
Scott A. Morris, NRC Region IV Administrator  
John P. Reynoso, Acting NRC Senior Resident Inspector  
Balwant K. Singal, NRC Senior Project Manager