

INSERVICE INSPECTION
TEN-YEAR PROGRAM PLAN BOOK
NINE MILE POINT UNIT 1

Prepared For
NIAGARA MOHAWK POWER CORPORATION
Syracuse, New York

By
NUCLEAR ENERGY SERVICES, INC.
Danbury, Connecticut 06810

Prepared by: *[Signature]*
A. Ziel G. Gasco

Approved by: *A. H. Yoli*
A. Yoli Proj. Mgr.

Approved by: *[Signature]*
L.A. Johnson, ISI Prog. Mgr.

Approved by: *[Signature]*
V.J. Manion, Dir. QA

Date: September 17, 1976

APPENDIX N

NRC REGULATORY GUIDE 1.26

REGULATORY GUIDE

OFFICE OF STANDARDS DEVELOPMENT

REGULATORY GUIDE 1.26

QUALITY GROUP CLASSIFICATIONS AND STANDARDS FOR WATER-, STEAM-, AND RADIOACTIVE-WASTE-CONTAINING COMPONENTS OF NUCLEAR POWER PLANTS

A. INTRODUCTION

General Design Criterion 1, "Quality Standards and Records," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, "Licensing of Production and Utilization Facilities," requires that structures, systems, and components important to safety be designed, fabricated, erected, and tested to quality standards commensurate with the importance of the safety functions to be performed. Section 50.55a, "Codes and Standards," of 10 CFR Part 50 requires that components of the reactor coolant pressure boundary be designed, fabricated, erected, and tested in accordance with the requirements for Class 1¹ components of Section III of the ASME Boiler and Pressure Vessel Code or equivalent quality standards. This guide describes a quality classification system related to specified national standards that may be used to determine quality standards acceptable to the NRC staff for satisfying General Design Criterion 1 for other safety-related components containing radioactive material, water, or steam in water-cooled nuclear power plants. The Advisory Committee on Reactor Safeguards has been consulted concerning this guide and has concurred in the regulatory position.

B. DISCUSSION

After reviewing a number of applications for construction permits and operating licenses and after discussions with representatives of professional societies and industry, the NRC staff has developed a quality classification system for safety-related components containing radioactive material, water, or steam in water-cooled nuclear power plants. The system consists

¹ Editions prior to 1971 of the ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," use the term Class A in lieu of Class 1.

* Lines indicate substantive changes from previous issue.

of four quality groups, A through D, methods for assigning components to these quality groups, and the specific quality standards applicable to each quality group. The initial portion of this system is described in §50.55a of 10 CFR Part 50, which requires that components of the reactor coolant pressure boundary be designed, fabricated, erected, and tested to the highest available national standards; this corresponds to the quality standard required for quality Group A of the NRC system. This guide describes a method for determining acceptable quality standards for the remaining safety-related components containing radioactive material, water, or steam, i.e., quality Group B, C, and D components. Other systems not covered by this guide, such as instrument and service air, diesel engine and its generators and auxiliary support systems, diesel fuel, emergency and normal ventilation, and fuel handling, should be designed, fabricated, erected, and tested to quality standards commensurate with the safety function to be performed. Evaluation to establish the quality group classification of these other systems should include consideration of the guidance provided in regulatory positions C.1 and C.2 of this guide.

C. REGULATORY POSITION

1. The Group B quality standards given in Table 1 of this guide should be applied to water- and steam-containing pressure vessels, heat exchangers (other than turbines and condensers), storage tanks, piping, pumps, and valves that are either part of the reactor coolant pressure boundary defined in §50.2(v) but excluded from the requirements of §50.55a² pursuant to footnote 2 of that section or are not part of the reactor coolant pressure boundary but part of:

² Group A quality standards that are required for pressure-containing components of the reactor coolant pressure boundary are specified in Section 50.55a of 10 CFR Part 50.

USNRC REGULATORY GUIDES

Regulatory Guides are issued to describe and make available to the public methods acceptable to the NRC staff of implementing specific parts of the Commission's regulations, to delineate techniques used by the staff in evaluating specific problems or postulated accidents, or to provide guidance to applicants. Regulatory Guides are not substitutes for regulations, and compliance with them is not required. Methods and solutions different from those set out in the guides will be acceptable if they provide a basis for the findings requisite to the issuance or continuance of a permit or license by the Commission.

Comments and suggestions for improvements in these guides are encouraged at all times, and guides will be revised, as appropriate, to accommodate comments and to reflect new information or experience. This guide was revised as a result of substantive comments received from the public and additional staff reviews.

Comments should be sent to the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Docketing and Service Section.

The guides are issued in the following ten broad divisions:

- | | |
|-----------------------------------|------------------------|
| 1. Power Reactors | 6. Products |
| 2. Research and Test Reactors | 7. Transportation |
| 3. Fuels and Materials Facilities | 8. Occupational Health |
| 4. Environmental and Siting | 9. Antitrust Review |
| 5. Materials and Plant Protection | 10. General |

Copies of published guides may be obtained by written request indicating the divisions desired to the U.S. Nuclear Regulatory Commission, Washington, D.C. 20555, Attention: Director, Office of Standards Development.

a. Systems or portions of systems³ important to safety that are designed for (1) emergency core cooling, (2) postaccident containment heat removal, or (3) postaccident fission product removal.

b. Systems or portions of systems³ important to safety that are designed for (1) reactor shutdown or (2) residual heat removal.

c. Those portions of the steam systems of boiling water reactors extending from the outermost containment isolation valve up to but not including the turbine stop and bypass valves⁴ and connected piping up to and including the first valve that is either normally closed or capable of automatic closure during all modes of normal reactor operation. Alternatively, for boiling water reactors containing a shutoff valve (in addition to the two containment isolation valves) in the main steam line and in the main feedwater line, Group B quality standards should be applied to those portions of the steam and feedwater systems extending from the outermost containment isolation valves up to and including the shutoff valve or the first valve that is either normally closed or capable of automatic closure during all modes of normal reactor operation.

d. Those portions of the steam and feedwater systems of pressurized water reactors extending from and including the secondary side of steam generators up to and including the outermost containment isolation valves and connected piping up to and including the first valve (including a safety or relief valve) that is either normally closed or capable of automatic closure during all modes of normal reactor operation.

e. Systems or portions of systems³ that are connected to the reactor coolant pressure boundary and are not capable of being isolated from the boundary during all modes of normal reactor operation by two valves, each of which is either normally closed or capable of automatic closure.

2. The Group C quality standards given in Table 1 of this guide should be applied to water-, steam-, and radioactive-waste-containing pressure vessels, heat exchangers (other than turbines and condensers), storage tanks, piping, pumps, and valves not part of the reactor coolant pressure boundary or included in quality Group B but part of:

³The system boundary includes those portions of the system required to accomplish the specified safety function and connected piping up to and including the first valve (including a safety or relief valve) that is either normally closed or capable of automatic closure when the safety function is required.

⁴The turbine stop valve and turbine bypass valve, although not included in quality Group B, should be subjected to a quality assurance program at a level generally equivalent to quality Group B.

a. Cooling water and auxiliary feedwater systems or portions of these systems³ important to safety that are designed for (1) emergency core cooling, (2) postaccident containment heat removal, (3) postaccident containment atmosphere cleanup, or (4) residual heat removal from the reactor and from the spent fuel storage pool (including primary and secondary cooling systems). Portions of these systems that are required for their safety functions and that (1) do not operate during any mode of normal reactor operation and (2) cannot be tested adequately should be classified as Group B.

b. Cooling water and seal water systems or portions of these systems³ important to safety that are designed for functioning of components and systems important to safety, such as reactor coolant pumps, diesels, and control room.

c. Systems or portions of systems³ that are connected to the reactor coolant pressure boundary and are capable of being isolated from that boundary during all modes of normal reactor operation by two valves, each of which is either normally closed or capable of automatic closure.⁵

d. Radioactive waste treatment, handling, and disposal systems,⁶ except those portions of these systems whose postulated failure would not result in conservatively calculated potential offsite doses that exceed 0.5 rem to the whole body or its equivalent to any part of the body. For those systems located in Seismic Category I structures, only single component failures need be assumed. (However, no credit for automatic isolation from other components in the system or for treatment of released material should be taken unless the isolation or treatment capability is designed to the appropriate seismic and quality group standards and can withstand loss of offsite power and single failure of an active component.) Parts of these systems beyond the processing steps (such as monitoring tanks) may be classified as Group D if the plant Technical Specifications limit inventories to levels which, if released, would not result in conservatively calculated potential offsite doses that exceed 0.5 rem to the whole body or its equivalent to any part of the body.

⁵Components in influent lines may be classified as Group D provided they are capable of being isolated from the reactor coolant pressure boundary by an additional valve which has high leaktight integrity.

⁶The regulatory position regarding quality group classifications for these systems is under review. In the proposed revision specific components may be assigned to appropriate quality groups commensurate with the need to protect the health and safety of the public and operating personnel. A separate regulatory guide will be developed and issued to replace this subsection of Regulatory Guide 1.26.

e. Other systems not covered by items 2.a through 2.d above that contain or may contain radioactive material and whose postulated failure would result in conservatively calculated potential offsite doses (using meteorology as recommended by Regulatory Guides 1.3 (Revision 2), "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Boiling Water Reactors," and 1.4 (Revision 2), "Assumptions Used for Evaluating the Potential Radiological Consequences of a Loss of Coolant Accident for Pressurized Water Reactors") that exceed 0.5 rem to the whole body or its equivalent to any part of the body. For those systems located in Seismic Category I structures, only single component failures need be assumed. (However, no credit for automatic isolation from other components in the system or for treatment of released material should be taken unless the isolation or treatment capability is designed to the appropriate seismic and quality group standards and can withstand loss of offsite power and a single failure of an active component.)

3. The Group D quality standards given in Table 1 of this guide should be applied to water- and

steam-containing components not part of the reactor coolant pressure boundary or included in quality Groups B or C but part of systems or portions of systems that contain or may contain radioactive material.

D. IMPLEMENTATION

The purpose of this section is to provide information to applicants and licensees regarding the staff's plans for utilizing this regulatory guide.

Except in those cases in which the applicant proposes an alternative method for complying with specified portions of the Commission's regulations, the quality group classifications and standards described herein will be used in the evaluation of submittals for operating license or construction permit applications docketed after January 1, 1975.

If an applicant wishes to use this regulatory guide in developing submittals for applications docketed on or before January 1, 1975, the pertinent portions of the application will be evaluated on the basis of this guide.

TABLE 1

Components	QUALITY STANDARDS		
	Quality Group B	Quality Group C	Quality Group D
Pressure Vessels	ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," ^{a,b,c} Class 2	ASME Boiler and Pressure Vessel Code, Section III, "Nuclear Power Plant Components," ^{a,b,c} Class 3	ASME Boiler and Pressure Vessel Code, Section VIII Division 1
Piping	As above	As above	ANSI B31.1 Power Piping
Pumps	As above	As above	Manufacturer's standards
Valves	As above	As above	ANSI B31.1
Atmospheric Storage Tanks	As above	As above	API-650, AWWA D 100, or ANSI B96.1
0-15 psig Storage Tanks	As above	As above	API-620

^aSee Section 50.55a for guidance with regard to the Code and Addenda to be applied.

^bASME Code N—symbol need not be applied.

^cThe specific applicability of code cases will be covered separately in other regulatory guides or in Commission regulations, where appropriate. Applicants proposing the use of code cases not covered by guides or regulations should demonstrate that an acceptable level of quality and safety would be achieved.

DOCUMENT/ PAGE PULLED

ANO. 8005130359

NO. OF PAGES 4 oversize drawings

REASON:

☐ PAGE ILLEGIBLE

☐ HARD COPY FILED AT: PDR CF

OTHER _____

☐ BETTER COPY REQUESTED ON ____/____/____

☒ PAGE TOO LARGE TO FILM:

☐ HARD COPY FILED AT: PDR

☒ CF

OTHER _____

☐ FILMED ON APERTURE CARD NO. 8005130359

Through


8005130359-03

THIS DRAWING CONTAINS CONFIDENTIAL INFORMATION AND IS SUPPLIED BY AUTOMATION INDUSTRIES INC. THE OWNER OF SUCH INFORMATION. IN ACCEPTING THE DRAWING, THE USER AGREES THAT IT IS FOR THE USER'S SOLE USE, THAT IT WILL NOT BE REPRODUCED OR DISTRIBUTED TO OTHERS, AND THAT THE DRAWING OR THE INFORMATION CONTAINED THEREIN WILL NOT BE USED IN ANY MANNER DETRIMENTAL TO AUTOMATION INDUSTRIES INC.

3/8" DIA. X 'A' DEEP,
FLAT BOTTOMED HOLE

3/8" DIA. X 'B' DEEP,
FLAT BOTTOMED HOLE

EXAMINATION
SURFACE



NOTES:

- 1- MATERIAL: ALLOY STEEL PER SA-193.
- 2- SPARE NUTS FROM NINE MILE STORE ROOM CAN BE USED.

NEXT ASSY	USED ON
APPLICATION	

REVISIONS					
ZONE	LTR	DESCRIPTION	CHK'D	DATE	APPROVED
	1	CRA # 227	ca	03-10-77	AHy

**APPROVED
ISSUE**

3/8" DIA. X'C' DEEP,
FLAT BOTTOM HOLE

IDENTIFICATION ALONG EDGE
METAL STAMP WITH .12 HIGH CHARACTERS

REFERENCE STANDARD	D	D ₁	D ₂	T	A (3/4T)	B (1/2T)	C (1/4T)	MAT'L
PIN-6.25	7 3/4"	9 3/8"	6"	7"	5 1/4"	3 1/2"	1 3/4"	NOTE 1
PIN-2.0	1 1/2"	3"	-	2"	1 1/2"	1"	1/2"	NOTE 1

TERA
APERTURE
CARD

ITEM	QTY	CODE IDENT	PART NUMBER	DESCRIPTION	MAT'L	MAT'L SPEC
------	-----	------------	-------------	-------------	-------	------------

PARTS LIST

UNLESS OTHERWISE SPECIFIED
DIM ARE IN INCHES TOL FRAC. ± 1/64
HOLDING ± .01 XX ± .010 XXX ± .005
ANGLES ± 1°. SURFACE FINISH 83
DEBURN AND BREAK SHARP EDGES

SIGNATURES	DATE
DRAWN <i>W. HATCH, JR</i>	12/11/75
CHECKED <i>A. OUEL</i>	12/11/75
APPROVED <i>G. Bance</i>	12/15/75
ENGINEER <i>W. J. Mason</i>	12/14/75
APPROVED DESIGN ACTIVITY	
5530-300	
APPROVED	
<i>A Hy</i>	12/12/75


AUTOMATION INDUSTRIES, INC.
NUCLEAR ENERGY SERVICES



CALIBRATION REFERENCE
STANDARDS, NUTS
NMPC, NINE MILE

SIZE	CODE IDENT NO.	DRAWING NO.	REV
B	78446	80B0827	1
SCALE			SHEET

THIS DRAWING CONTAINS CONFIDENTIAL INFORMATION AND IS SUPPLIED BY AUTOMATION INDUSTRIES INC. THE OWNER OF SUCH INFORMATION IN ACCEPTING THE DRAWING, THE USER AGREES THAT IT IS FOR THE USER'S SOLE USE, THAT IT WILL NOT BE REPRODUCED OR DISTRIBUTED TO OTHERS, AND THAT THE DRAWING OR THE INFORMATION CONTAINED THEREIN WILL NOT BE USED IN ANY MANNER DETRIMENTAL TO AUTOMATION INDUSTRIES INC.



NEXT ASSY	USED ON
APPLICATION	

REVISIONS					
ZONE	LTR	DESCRIPTION	CHK'D	DATE	APPROVED
	1	CRA # 227	20	03-10-76	attg

IDENTIFICATION ALONG EDGE
METAL STAMP WITH .12 HIGH CHARACTERS

NOTES:


- 1- MATERIAL: ALLOY STEEL PER SA-193.
- 2- STANDARD DESIGNATION P15-2.5.



**APPROVED
ISSUE**

ITEM	QTY	CODE IDENT	PART NUMBER	DESCRIPTION	MAT'L	MAT'L SPEC
PARTS LIST						
UNLESS OTHERWISE SPECIFIED DIM ARE IN INCHES. TOL: FRAC. $\pm 1/64$ DEC X = $\pm .01$ XX = $\pm .010$ XXX = $\pm .005$ ANGLES $\pm 1^\circ$. SURFACE FINISH 83 ✓ DEBURR AND BREAK SHARP EDGES			SIGNATURES DRAWN <i>W. HATCH, JR.</i> 12/11/75 CHECKED <i>A. UZIEL</i> 12/14/75 APPROVED <i>J. Rance</i> 12/15/75 ENGINEER <i>W. J. Mannon</i> 12/12/75		DATE 12/11/75 12/14/75 12/15/75 12/12/75	
MATERIAL <i>H</i>			AUTOMATION INDUSTRIES, INC. NUCLEAR ENERGY SERVICES			
FINISH <i>H</i>			TITLE CALIBRATION REFERENCE STANDARD FOR VALVE STUDS NMPC, NINE MILE			
APPROVED DESIGN ACTIVITY 5530-300			SIZE B	CODE IDENT NO. 78446	DRAWING NO. 80B0828	REV 1
APPROVED <i>a H yde</i> 12/12/75			SCALE <i>H</i>		SHEET	

THIS DRAWING CONTAINS CONFIDENTIAL INFORMATION AND IS SUPPLIED BY AUTOMATION INDUSTRIES INC. THE OWNER OF SUCH INFORMATION, IN ACCEPTING THE DRAWING, THE USER AGREES THAT IT IS FOR THE USER'S SOLE USE, THAT IT WILL NOT BE REPRODUCED OR DISTRIBUTED TO OTHERS, AND THAT THE DRAWING OR THE INFORMATION CONTAINED THEREIN WILL NOT BE USED IN ANY MANNER DETRIMENTAL TO AUTOMATION INDUSTRIES INC.



3/8" DIA. FLAT-
BOTTOM HOLE

IDENTIFICATION ALONG EDGE
METAL STAMP WITH .12 HIGH CHAR

NEXT ASSY	USED ON
APPLICATION	

REVISIONS					
ZONE	LTR	DESCRIPTION	CHK'D	DATE	APPROVED
	1	CRA # 227	21	03-10-77	AMG


NOTES:

- 1- MATERIAL: ALLOY STEEL PER SA-194.
- 2- STANDARD I.D. P15-2.0.




**APPROVED
ISSUE**

ALTERS

ITEM	QTY	CODE IDENT	PART NUMBER	DESCRIPTION	MAT'L	MAT'L SPEC
PARTS LIST						
UNLESS OTHERWISE SPECIFIED DIM ARE IN INCHES. TOL: FRAC. $\pm 1/64$ DEC X = $\pm .03$ XX = $\pm .010$ XXX = $\pm .005$ ANGLES $\pm 1^\circ$, SURFACE FINISH 63 DEBURN AND BREAK SHARP EDGES				SIGNATURES DATE DRAWN <i>W. HATCH, JR.</i> 12/12/75 CHECKED <i>A. UZIEL</i> 12/12/75 APPROVED <i>J. Lance</i> 12/15/75 ENGINEER <i>W. J. Monroe</i> 12/12/75 APPROVED DESIGN ACTIVITY 5530-300 APPROVED <i>A. J. Yule</i> 12/12/75		
MATERIAL <i>H</i>				AUTOMATION INDUSTRIES, INC. NUCLEAR ENERGY SERVICES 		
FINISH <i>H</i>				TITLE CALIBRATION REFERENCE STANDARD, VALVE STUDS NMPC, NINE MILE		
				SIZE B	CODE IDENT NO. 78446	DRAWING NO. 80B0830
				SCALE <i>H</i>	SHEET	
				REV 1		

THIS DRAWING CONTAINS CONFIDENTIAL INFORMATION AND IS SUPPLIED BY AUTOMATION INDUSTRIES INC. THE OWNER OF SUCH INFORMATION. IN ACCEPTING THE DRAWING, THE USER AGREES THAT IT IS FOR THE USER'S SOLE USE, THAT IT WILL NOT BE REPRODUCED OR DISTRIBUTED TO OTHERS, AND THAT THE DRAWING OR THE INFORMATION CONTAINED THEREIN WILL NOT BE USED IN ANY MANNER DETRIMENTAL TO AUTOMATION INDUSTRIES INC.



APPROVED
ISSUE

NEXT ASSY	USED ON
APPLICATION	


OTTOM HOLE
ATED FOR CLARITY

REVISIONS				
ZONE	LTR	DESCRIPTION	DATE	APPROVED

IDENTIFICATION ALONG EDGE
METAL STAMP WITH .12 HIGH CHARACTERS
SEE NOTE 3

NOTES:

- 1- MATERIAL: ALLOY STEEL PER SA-193.
- 2- STANDARD I.D. P15-6.25.
- 3- IDENTIFICATION TO INCLUDE HEAT NO.,
SPEC. NO., GRADE & BLOCK I.D. STAMPED
ON SAMPLE HALF W/O HOLE.
- 4- SPARE STUD FROM NINE MILE STORE ROOM TO BE USED.

ITEM	QTY	CODE IDENT	PART NUMBER	DESCRIPTION	MAT'L	MAT'L SPEC
PARTS LIST						
UNLESS OTHERWISE SPECIFIED DIM ARE IN INCHES. TOL: FRAC. $\pm 1/64$ DEC X = $\pm .03$ XX = $\pm .010$ XXX = $\pm .005$ ANGLES $\pm 1^\circ$. SURFACE FINISH 43/ DEBURN AND BREAK SHARP EDGES.		SIGNATURES		DATE	AUTOMATION INDUSTRIES, INC. NUCLEAR ENERGY SERVICES	
DRAWN		W. HATCH, JR.		12/12/75	 TITLE CALIBRATION REFERENCE STANDARD, C.H. STUD NMPC, NINE MILE	
CHECKED		A. UZEL		12/12/75		
APPROVED		J. Rance		12/15/75		
ENGINEER		W. J. Mauer		12/12/75		
MATERIAL		APPROVED DESIGN ACTIVITY		5530-300	SIZE B	CODE IDENT NO. 78446
FINISH		APPROVED		A. H. Yule 12/12/75	DRAWING NO. 80B0831	REV 0
SCALE				—#—	SHEET	