

## NRR-DRMAPEm Resource

---

**From:** Lee, Samson  
**Sent:** Friday, October 4, 2019 6:59 AM  
**To:** Williams, Christian D:(Exelon Nuclear)  
**Subject:** FitzPatrick Emergency amendment public conference call discussion points - 4

In the draft LAR dated October 2, 2019, Attachment 1, Section 2.0, the following is stated: “*Each Reserve Station Service Transformer (RSST) is fed from the **cross-tied** 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4. Each of these offsite 115KV sources are capable of providing power to either division 1 or 2 busses through the respective RSST.*”

Also in the JAF UFSAR, Section 8.3.2.4, the following is stated: “*Under normal operation, the sectionalizing disconnect switches and all breakers at both JAF Plant and NMPNS Unit 1 **are operated in the closed position**, thereby providing two sources of 115 kV power for the JAF Plant.*”

*During conference call yesterday, the licensee stated that 115 kV Motor Operated Disconnect (MOD) switch (cross-tie) between 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4 at JAF 115 kV switchyard is normally kept open.*

**The LAR (and later UFSAR) should be revised to clarify that the above cross-tie (MOD switch) is normally kept open. Also, clarify that with the RSST 71T-3 under maintenance, whether this MOD switch would remain open.**

Thanks,  
Sam

**Hearing Identifier:** NRR\_DRMA  
**Email Number:** 242

**Mail Envelope Properties** (BL0PR0901MB318527BC45DEA7838F3F1AFB9A9E0)

**Subject:** FitzPatrick Emergency amendment public conference call discussion points - 4  
**Sent Date:** 10/4/2019 6:59:10 AM  
**Received Date:** 10/4/2019 6:59:00 AM  
**From:** Lee, Samson

**Created By:** Samson.Lee@nrc.gov

**Recipients:**  
"Williams, Christian D:(Exelon Nuclear)" <Christian.Williams@exeloncorp.com>  
Tracking Status: None

**Post Office:** BL0PR0901MB3185.namprd09.prod.outlook.com

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	1143	10/4/2019 6:59:00 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**