

## NRR-DRMAPEm Resource

---

**From:** Williams, Christian D:(Exelon Nuclear) <Christian.Williams@exeloncorp.com>  
**Sent:** Friday, October 4, 2019 7:15 AM  
**To:** Lee, Samson  
**Subject:** [External\_Sender] RE: FitzPatrick Emergency amendment public conference call discussion points - 4

Sam,  
We got confirmation from the site yesterday that the statement in the FSAR is accurate. **Normal position is with the sectionalizing disconnect switches in the closed position.** This is an accurate statement. I will confirm with the site the current configuration with the transformer out of service.

Christian

P.s. I expected to have an unsigned copy to you by 0800 and the signed copy by 0900

---

**From:** Lee, Samson  
**Sent:** Friday, October 4, 2019 6:59 AM  
**To:** Williams, Christian D:(Exelon Nuclear)  
**Subject:** [EXTERNAL] FitzPatrick Emergency amendment public conference call discussion points - 4

In the draft LAR dated October 2, 2019, Attachment 1, Section 2.0, the following is stated: *"Each Reserve Station Service Transformer (RSST) is fed from the **cross-tied** 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4. Each of these offsite 115KV sources are capable of providing power to either division 1 or 2 busses through the respective RSST."*

Also in the JAF UFSAR, Section 8.3.2.4, the following is stated: *"Under normal operation, the **sectionalizing disconnect switches** and all breakers at both JAF Plant and NMPNS Unit 1 **are operated in the closed position**, thereby providing two sources of 115 kV power for the JAF Plant."*

*During conference call yesterday, the licensee stated that 115 kV Motor Operated Disconnect (MOD) switch (cross-tie) between 115 KV power lines Lighthouse Hill Line #3 and Nine Mile Point Line #4 at JAF 115 kV switchyard is **normally kept open**.*

**The LAR (and later UFSAR) should be revised to clarify that the above cross-tie (MOD switch) is normally kept open. Also, clarify that with the RSST 71T-3 under maintenance, whether this MOD switch would remain open.**

Thanks,  
Sam

This Email message and any attachment may contain information that is proprietary, legally privileged, confidential and/or subject to copyright belonging to Exelon Corporation or its affiliates ("Exelon"). This Email is intended solely for the use of the person(s) to which it is addressed. If you are not an intended recipient, or the employee or agent responsible for delivery of this Email to the intended recipient(s), you are hereby notified that any dissemination, distribution or copying of this Email is strictly prohibited. If you have received this message in error, please immediately notify the sender and permanently delete this Email and any copies. Exelon policies expressly prohibit employees from making defamatory or offensive statements and infringing any copyright or any other legal right by Email communication. Exelon will not accept any liability in respect of such communications. -EXCIP

**Hearing Identifier:** NRR\_DRMA  
**Email Number:** 243

**Mail Envelope Properties** (SN6PR05MB56645B2EDD901D4481FA5649F99E0)

**Subject:** [External\_Sender] RE: FitzPatrick Emergency amendment public conference call discussion points - 4  
**Sent Date:** 10/4/2019 7:15:06 AM  
**Received Date:** 10/4/2019 7:15:55 AM  
**From:** Williams, Christian D:(Exelon Nuclear)

**Created By:** Christian.Williams@exeloncorp.com

**Recipients:**  
"Lee, Samson" <Samson.Lee@nrc.gov>  
Tracking Status: None

**Post Office:** SN6PR05MB5664.namprd05.prod.outlook.com

Files	Size	Date & Time
MESSAGE	2672	10/4/2019 7:15:55 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**