

NRR-DRMAPEm Resource

From: Lee, Samson
Sent: Friday, October 4, 2019 10:25 AM
To: Williams, Christian D:(Exelon Nuclear)
Subject: FitzPatrick Emergency amendment public conference call discussion points - 6

The licensee should check the last paragraph of page 4 of 15 of the draft attachment. In that paragraph, it stated that, for a DBA LOCA with only offsite power available through the remaining transformer, 71T-2, "Reserve Station Service Transformer T2," the LOCA analysis is dependent on the full complement of equipment served by the 10600 bus. It may imply that the AC power via 71T-2 is required. However, the DBA LOCA was performed with the assumption of Lost of Offsite Power (see, for example, Fitzpatrick UFSAR Sec. 6.5). This statement should be consistent with the UFSAR.

Thanks,
Sam

Hearing Identifier: NRR_DRMA
Email Number: 245

Mail Envelope Properties (BL0PR0901MB3185D1C5A77464013EE233E79A9E0)

Subject: FitzPatrick Emergency amendment public conference call discussion points - 6
Sent Date: 10/4/2019 10:25:06 AM
Received Date: 10/4/2019 10:25:00 AM
From: Lee, Samson

Created By: Samson.Lee@nrc.gov

Recipients:
"Williams, Christian D:(Exelon Nuclear)" <Christian.Williams@exeloncorp.com>
Tracking Status: None

Post Office: BL0PR0901MB3185.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	601	10/4/2019 10:25:00 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: