

From: [Jordan, Natreon](#)
To: [Zaremba, Arthur H.](#)
Subject: Draft Requests for Additional Information for H.B. Robinson LAR to Revise TS 3.8.2, "AC Sources - Shutdown," SR 3.8.2.1
Date: Thursday, September 26, 2019 3:46:00 PM
Attachments: [Robinson TS SR 3.8.2.1 EEOB RAI \(draft\) \(004\).docx](#)

Mr. Zaremba,

By letter dated June 4, 2019 (Agencywide Documents Access and Management System Accession No. ML19155A037), Duke Energy (the licensee) submitted a license amendment request (LAR) to the U.S. Nuclear Regulatory Commission (NRC) to amend the Renewed Facility Operating License No. DPR-23 for the H.B. Robinson Steam Electric Plant, Unit 2 Facility (Robinson). The LAR proposes to revise Technical Specification (TS) 3.8.2, "AC Sources – Shutdown," Surveillance Requirement (SR) 3.8.2.1. The SR change would reflect that SR 3.8.1.18 for Robinson is not required to be met in the TS 3.8.2 Applicability. To complete its review, the U.S. Nuclear Regulatory Commission (NRC) staff has prepared the attached requests for additional information (RAIs) in DRAFT form.

If a clarification call is needed by the licensee to discuss the attached draft RAIs and the due date for the RAI responses, please contact me at 301-415-7410. The NRC request response to the RAIs within 30 days of this email in order to support your license amendment request. If you do not believe you can meet the response date, please provide an acceptable alternate date and justification for extending the response date.

Thanks,
-Nate

Natreon (Nate) Jordan

Nuclear Engineer (Project Manager)
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Mail Stop O-8B1A
Washington, DC 20555
301-415-7410
natreon.jordan@nrc.gov