

Attachment 2

OQAM Revision 33a mark-up, identifying changes
through the use of strikeouts and inserts

Affected OQAM Sections are provided in their entirety.
Unaffected sections are omitted.

58 pages follow



CALLAWAY ENERGY CENTER

***OPERATING QUALITY ASSURANCE MANUAL
(OQAM)***

Rev. 033a

File Code A210.0012

OQAM

Interim Revision 033a

This interim revision incorporates the change notices listed below:

OQAMCN 19-001

OQAMCN 19-002

OQAMCN 19-003

All changes are annotated with the change notice number in the margin and reflect the original information (lined-through) and the change notice information.



CALLAWAY ENERGY CENTER

OPERATING QUALITY ASSURANCE MANUAL

REVISION: 033a
DATE: 06/19

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>No. of Pages</u>
	Table of Contents	1
	Policy/Introduction	2
1.	Organization	5
2.	Quality Assurance Program	Not Provided - No Changes Affect this Section 4
3.	Design Control	4
4.	Procurement Document Control	5
5.	Instructions, Procedures, and	Not Provided - No Changes Affect this Section 3
6.	Document Control	2
7.	Control of Purchased Material, Equipment, and Services	5
8.	Identification and Control	Not Provided - No Changes Affect this Section 1
9.	Control of Special Processes	Not Provided - No Changes Affect this Section 1
10.	Inspection	Not Provided - No Changes Affect this Section 2
11.	Test Control	Not Provided - No Changes Affect this Section 2
12.	Control of Measuring and	Not Provided - No Changes Affect this Section 2
13.	Handling, Storage, and	Not Provided - No Changes Affect this Section 1
14.	Inspection, Test, and	Not Provided - No Changes Affect this Section 1
15.	Nonconforming Material	Not Provided - No Changes Affect this Section 2
16.	Corrective Action	Not Provided - No Changes Affect this Section 2
17.	Quality Assurance Records	Not Provided - No Changes Affect this Section 3
18.	Audits	4
Appendix A	OQAM Conformance to Applicable NRC Regulatory Guides	28
Appendix B	Dry Cask Storage System	Not Provided - No Changes Affect this Section 6



CALLAWAY ENERGY CENTER

OPERATING QUALITY ASSURANCE MANUAL

REVISION: 033

DATE: 06/18

OQAP POLICY/INTRODUCTIONS

It is the policy of Union Electric Company (Ameren Missouri¹) to develop, implement, and maintain an Operating Quality Assurance Program (OQAP) for Callaway Plant as required by provisions of a Nuclear Regulatory Commission (NRC) operating license and amendments thereto. The QA Program shall be applied to those activities affecting quality (safety-related) regarding structures, systems, and components necessary to assure:

- 1) The integrity of the reactor coolant pressure boundary,
- 2) The capability to shut down the reactor and maintain it in a safe shutdown condition, or
- 3) The capability to prevent or mitigate the consequences of accidents which could result in off-site exposures comparable to the guideline exposures of NRC Regulations 10 CFR 100.

These activities include operational testing, operations, maintenance, refueling, and modifications. Control over these activities as they affect quality shall be to the extent consistent with their importance to safety.

Ameren Missouri¹ has established an organization to implement the OQAP as documented in policies, manuals, and procedures. Specific OQAP requirements and corresponding organizational responsibilities are specified in the Operating Quality Assurance Manual (OQAM).

The OQAP involves the proper functioning of many disciplines and activities. Functions, departments, groups, committees and other organizational subdivisions shall control activities affecting quality through implementation of appropriate written procedures or instructions. Documentation shall be maintained to provide objective evidence of program implementation and effectiveness.

The OQAP shall comply with 10 CFR 50 Appendix B - "Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants" and follow the guidance of the Regulatory Position of Regulatory Guide 1.33. Clarifications, alternatives, and exceptions to this Regulatory Position are described in Appendix A of the OQAM. An eighteen (18) section format is employed with a discussion of how corresponding criteria of 10 CFR 50 Appendix B are satisfied.

The OQAM Appendix B contains the Quality Assurance Program requirements for the Dry Cask Storage System. The requirements and controls for the Dry Cask Storage System are applied in a graded approach to the systems, structures and components important-to-safety as defined in 10 CFR 72.

The responsibility for formulating, authorizing, and assuring implementation of the Ameren Missouri¹ OQAP rests with the Senior Vice President and Chief Nuclear Officer. The policy and resultant QA Program are mandatory for Callaway Plant operational phase activities. Accordingly, personnel shall be made cognizant of QA Program requirements and responsibilities applicable to their individual activities and interfaces.

¹ Effective December 31, 1997, Union Electric (UE) and Central Illinois Public Services Company (CIPSCO) completed a merger into a new operating company – Ameren Corporation. With this merger, some reorganization has occurred with several of the functions and divisions previously within Union Electric being redistributed either to AmerenUE (new operating company for the power generation portion of the company previously within UE) or Ameren Services (new operating company for the non-power generation side of the newly created Ameren Corporation). Note: As of October 1, 2010 the name of AmerenUE was changed to Ameren Missouri.


By the signatures of the undersigned, this OQAM is approved and those Ameren¹ personnel whose activities are within the purview of the OQAP are responsible for its implementation in accordance with the requirements described herein.



Mark A. Hillstrom
NOS Audit Supervisor

6/11/18


Date



Sarah G. Kovaleski
Director, Nuclear Oversight

6/11/18


Date



Fadi M. Diya
Senior Vice President and Chief Nuclear Officer

6/12/18


Date

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 1
	REVISION: 033a
	DATE: 06/19

1. ORGANIZATION


- 1.1 Ameren Missouri has established an organization for Quality Assurance activities. This Section identifies the organizational structure; management positions and responsibilities; and delegation of authority for the development, implementation and maintenance of the Operating Quality Assurance Program (OQAP). Ameren Missouri shall retain responsibility for the establishment and execution of the OQAP, although certain Program activities may be delegated to others. The organization responsible for implementing appropriate portions of the OQAP is shown in Chapter 13 of the FSAR. The Callaway Plant operating organization is also shown in Chapter 13 of the FSAR.
- 1.2 The Senior Vice President and Chief Nuclear Officer is responsible for initiating the Quality Assurance Program, formulating the policy, and authorizing and assuring Program implementation. This individual is responsible for directing activities within Nuclear Generation⁴ which support the engineering, construction, testing, and operation of the Callaway Plant and coordinating support activities performed by others who are not under their direct administrative control. This individual has corporate responsibility for the operation and physical control of the Callaway Plant. This individual reports to the President and Chief Executive Officer – Ameren Missouri, who in turn reports to the Chairman and Chief Executive Officer. The Chairman and Chief Executive Officer has ultimate responsibility for the Callaway Plant.
- 1.2.1 The Senior Vice President and Chief Nuclear Officer is responsible for the activities of all Nuclear Generation departments. This responsibility includes:
- assuring a high level of quality is achieved in Plant operations and support activities,
 - the execution of the administrative controls and quality assurance program,
 - the safe, legal and efficient operation and maintenance of the Plant,
 - protecting the health and safety of the public and Plant personnel
- 1.2.2 The Senior Vice President and Chief Nuclear Officer is responsible for ensuring an independent review of matters involving safe operation of the plant is conducted at least once per twelve months. The review addresses matters that management determines warrant special attention, such as plant programs, performance trends, employee concerns, or other matters related to safe plant operations. The review is performed by a team consisting of personnel with experience and competence in the activities being reviewed, but independent (from cost and schedule considerations) from the organizations responsible for those activities. The review is supplemented by outside consultants or organizations as necessary to ensure the team has the requisite expertise and competence. Results are documented and reported to the Senior Vice President and Chief Nuclear Officer.

⁴ Organization titles “Nuclear Division,” “Nuclear Function,” “Nuclear Business Line” and “Nuclear Segment” used in written instructions are equivalent to the generic title “Nuclear Generation” used in the FSAR and this OQAM.


 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 1
	REVISION: 033a
	DATE: 06/19

- 1.3 The Director, Nuclear Oversight (NOS)⁵ reports to the Senior Vice President and Chief Nuclear Officer (CNO) on Quality Assurance Program and administrative matters. The Director, Nuclear Oversight has direct access to the Senior Vice President and CNO on significant Nuclear Oversight matters. The Director, Nuclear Oversight-is responsible to the Senior Vice President and Chief Nuclear Officer for assuring the OQAP is being effectively implemented for operating activities; directing the overall Quality Assurance Program for Ameren Missouri including Program development, maintenance, and verification of implementation; and providing a constant independent overview of nuclear plant safety. The Director, Nuclear Oversight has sufficient authority, organizational freedom, and independence to effectively assure compliance with OQAP requirements as they control Callaway Plant and offsite quality activities; and shall bear no cost, schedule, or production responsibilities which unduly influence attention to quality matters. A communication path shall exist between the Director, Nuclear Oversight, Supervisors, NOS, and the Senior Vice President and Chief Nuclear Officer, as well as the other Nuclear Generation management, thus providing a direct path to inform management regarding conditions affecting quality and nuclear plant safety. The qualifications of the Director, Nuclear Oversight are at least equivalent to those specified in ANSI/ANS-3.1-1978, "Selection, Qualification, and Training of Nuclear Power Plant Personnel," Sections 4.2.4 and 4.4.5. The Director, Nuclear Oversight is located at Callaway Plant and provides technical direction and administrative guidance, to the Nuclear Oversight staff.
- 1.3.1 The Director, NOS directs Supervisors NOS, and Supervisor QC, who have primary duties for assuring implementation of the OQAP and who devote full attention to this effort. They provide for maintenance of the Operating Quality Assurance Manual (OQAM); for audit, surveillance, and evaluation of nuclear supplier quality activities; and for performing those procurement document reviews assigned to their personnel. The activities of the NOS staff assure implementation of the OQAP. The Director, Nuclear Oversight is responsible to evaluate Callaway Plant operations from a safety perspective.
- 1.3.2 The Quality Control Group reports to the Director, NOS. They are responsible for work activities, inspections, receipt inspections as described in Section 7.0 and non-destructive examinations.
- 1.3.3 The Director, Supervisor QC and Supervisors in the Nuclear Oversight Department are authorized by the Senior Vice President and Chief Nuclear Officer to stop work on ongoing quality activities in accordance with approved procedures. During the operating phase they have the authority to stop unsatisfactory work during repair, maintenance, and refueling activities and the authority to recommend to the Senior Director, Nuclear Operations stop work affecting the continuation of Plant operation. Other stop work authority shall be delineated in procedures. The continuance of an activity which would cover up a deficiency and preclude identification and correction, or increase the extent of the deficiency is subject to stop work action by the Nuclear Oversight Department. The Director, Nuclear Oversight has no duties or responsibilities unrelated to NOS that would prevent full attention to NOS matters.
- 1.4 The authorities and duties of persons and organizations performing quality assurance functions shall be clearly established. Such persons have sufficient authority and organizational freedom to identify quality problems; to initiate, recommend, or provide solutions; and to evaluate corrective action. Assurance of quality by checking, auditing, inspecting, or otherwise verifying Program activities shall be by personnel other than the individual or group performing the specific activity.

⁵ Organizational title "Quality Assurance" used in written instruction is equivalent to the title "Nuclear Oversight" as used in the FSAR and this OQAM.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 1
	REVISION: 033a
	DATE: 06/19

- 1.5 Other Ameren Services or Ameren Missouri divisions may provide safety-related services which augment and support selected Program activities. These organizations shall be required to implement controls consistent with the OQAP requirements applicable to their scope of activities. The coordination of these activities is the responsibility of the Senior Vice President and Chief Nuclear Officer.
- 1.6 The Onsite Review Committee (ORC) and NOS shall provide independent review of those items required below.
- 1.7 The ORC shall function to advise the Senior Director, Nuclear Operations on all matters related to nuclear safety. The Senior Director, Nuclear Operations shall be Chairman of the ORC.
- 1.7.1 ORC membership shall include a minimum of six additional members appointed by the Chairman. Selected members shall include, at a minimum, management responsible for the following areas of expertise and who collectively possess competence in Quality Assurance Practices:
- a) Operations
 - b) Maintenance
 - c) Chemistry
 - d) Radwaste
 - e) Health Physics
 - f) Nuclear Engineering
- 1.7.2 All alternate members shall be appointed in writing by the ORC Chairman to serve on a temporary basis.
- 1.7.3 The ORC shall meet at least once per calendar month and as convened by the ORC Chairman or designated alternate.
- 1.7.4 The quorum of the ORC necessary for the performance of the ORC responsibility and authority provisions shall consist of the Chairman or designated alternate and four members of which no more than two shall be alternates.
- 1.7.5 The ORC shall maintain written minutes of each ORC meeting that, at a minimum, document the results of all ORC activities. Copies shall be provided to the Senior Vice President and Chief Nuclear Officer.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 1
	REVISION: 033a
	DATE: 06/19

1.7.6 The ORC shall be responsible for:

a) Deleted.

CN 19-001

b) Review of 10CFR50.59 and 10CFR72.48 evaluations⁶ regarding:

- procedures,
- changes to procedures, equipment, systems or facilities, and
- tests or experiments completed under the provision of 10CFR50.59 and 10CFR72.48 to verify that such actions did not require prior NRC approval.

CN 19-001

c) Review of proposed procedures and changes to procedures, equipment, systems or facilities which may involve prior NRC approval as defined in 10CFR50.59 and 10CFR72.48⁶;

CN 19-001

d) Review of proposed test or experiments which may involve prior NRC approval as defined in 10CFR50.59 and 10CFR72.48⁶;

e) Review of proposed changes to Technical Specifications or Operating License;

f) Investigation of all violations of the Technical Specifications including the forwarding of reports covering evaluation and recommendations to prevent recurrence to the Senior Vice President and Chief Nuclear Officer.

g) Review of report of operating abnormalities, deviations from expected performance of plant equipment and of unanticipated deficiencies in the design or operation of structures, systems or components that affect nuclear safety;

h) Review of all REPORTABLE EVENTS;

i) Review of the plant Security Plan;

j) Review of the Radiological Emergency Response Plan;

k) Review of changes to the PROCESS CONTROL PROGRAM, the OFFSITE DOSE CALCULATION MANUAL, and Radwaste Treatment Systems;

l) Review of any accidental, unplanned or uncontrolled radioactive release including the preparation of reports covering evaluation, recommendations, and disposition of the corrective action to prevent recurrence and the forwarding of these reports to the Senior Director, Nuclear Operations.

m) Review of Unit operations to detect potential hazards to nuclear safety;

n) Investigations or analysis of special subjects as requested by the Senior Vice President and Chief Nuclear Officer.

o) Review of Unit Turbine Overspeed Protection Reliability Program and revisions thereto;

p) Review of the Fire Protection Program.

CN 19-001

⁶ Consistent with 10CFR72.210 and the requirements of 10CFR72.212(b)(5) through (b)(8), 10CFR72.48 evaluations performed by the CoC holder under their quality program do not require ORC review.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 1
	REVISION: 033a
	DATE: 06/19

1.7.7 The ORC shall:

- a) Deleted.
- b) Recommend in writing to the Senior Director, Nuclear Operations approval or disapproval of documents, and changes thereto, considered under Section 1.7.6.e), 1.7.6.i), 1.7.6.j), 1.7.6.k), 1.7.6.l), 1.7.6.o), and 1.7.6.p) above.
- c) Render determinations in writing with regard to whether or not each item considered under Sections 1.7.6.b) through 1.7.6.e), and 1.7.6.m), above, require a license amendment-per 10 CFR 50.59 or an NRC Certificate of Compliance (CoC) Amendment per 10CFR72.48; and
- d) Provide written notification within 24 hours to the Senior Vice President and Chief Nuclear Officer of disagreement between ORC and the Senior Director, Nuclear Operations; however, the Senior Director, Nuclear Operations shall have responsibility for resolution of such disagreements.
- e) Each REPORTABLE EVENT shall be reviewed by the ORC and submitted to the Senior Vice President and Chief Nuclear Officer.

1.8 Deleted

1.8.1 Deleted

1.8.2 Deleted

1.8.3 Deleted

1.8.4 Deleted

1.8.5 Deleted

1.8.6 Deleted

1.8.7 Deleted

1.8.8 Deleted

1.8.9 Deleted

1.8.10 Deleted

1.9 Deleted


1.9.1 Deleted

1.9.2 Deleted

1.9.3 Deleted

1.9.4 Deleted

1.9.5 Deleted


 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 3
	REVISION: 033a
	DATE: 06/19

3. **DESIGN CONTROL**


- 3.1 The design, modification, addition, and replacement of safety-related structures, systems, and components shall be controlled to assure appropriate design control measures are implemented. Procedures, Design Guides and Policies shall establish requirements; assign responsibilities; and provide control of activities regarding design in a planned, controlled, and orderly manner.
- 3.2 The Plant design is defined by those NSSS, A/E and selected supplier design drawings and specifications which illustrate the general arrangement and details of safety-related structures, systems, and components and define the requirements for assuring their continued capability to perform their intended operational or safety design function.
- 3.3 As the result of operating experience, or as necessitated by regulatory requirements, Plant systems and equipment may have to be changed. Design changes and configuration changes are modifications in Plant design or operation and are accomplished in accordance with requirements and limitations of applicable codes, standards, specifications, licenses, and predetermined safety restrictions.
 - 3.3.1 A design change is a modification where a function changes or a new failure mode is introduced.
 - 3.3.2 A configuration change is a change in configuration that can be either physical or in documentation that preserves the design functions and does not introduce new failure modes. This includes a change to the configuration of a replacement item which is not a like-for-like replacement of the present design.
- 3.4 Maintenance or modifications which may affect functioning of safety-related structures, systems, or components shall be performed in a manner to ensure quality at least equivalent to that specified in original design bases and requirements, materials specifications and inspection requirements. A suitable level of confidence in structures, systems, or components on which maintenance or modifications have been performed shall be attained by appropriate inspection and performance testing.
- 3.5 Design, including related procurement efforts, may be carried out by Nuclear Engineering, Fuel Cycle Management Department, or outside organizations.
- 3.6 Control of design shall be specified in procedures, design guides and policies. These documents shall include instructions for defining typical design requirements; communicating needed design information across internal and external interfaces; preparing, reviewing, approving, releasing, distributing, revising, and maintaining design documents; performing design reviews and reviews of design; and controlling field changes.
- 3.7 Design control shall involve measures which include a definition of design requirements; a design process which includes design analysis and delineation of requirements through the issuance of drawings, specifications, and other design documents (design outputs); and design verification or review of design to verify the adequacy of design or to become acquainted with design features.

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	SECTION NO. 3
	REVISION: 033a
	DATE: 06/19

- 3.8 Design requirements and changes thereto shall be identified, documented, reviewed and approved to assure incorporation of appropriate quality standards in design documents and to control departures from these standards. Modifications to structures, systems, and components shall consider, as a minimum, the design bases described in the Callaway-SP and the Callaway-SA FSAR and the Technical Specifications. Design criteria documents, which are newly issued or modified in the course of design or design/configuration changes, shall be reviewed by a Supervising Engineer in Engineering Design or Projects for seismic and quality group classification and selection of quality standards. Design criteria documents consist of original Plant design criteria, system descriptions and other documents defining design input which changes the Plant as described in the FSAR. The design input shall be specified on a timely basis and to the level of detail necessary to permit the design activity to be carried out in a correct manner and provide a consistent basis for making design decisions, accomplishing design verification measures, and evaluating design changes.
- 3.9 Design activities shall include the correct translation of regulatory requirements and design bases into specifications, drawings, written procedures, and instructions (design outputs) that define the design. Design analyses regarding reactor physics, stress, thermal, hydraulic, radiation, and accident analyses used to produce design output documents, shall be sufficiently detailed to permit an independent review by a technically qualified person. Analyses shall specify purpose, method, assumptions, design requirements, references, and units. When computer codes are employed, only codes that have been verified and/or validated (V&V) shall be used in safety-related design and design/configuration changes.
- 3.10 Procedures shall specify requirements for the review and approval of design changes by the organizations or individuals that performed the original design or Engineering Design or Projects. Design control activities, including design/configuration changes, may be delegated to others provided they have access to background and technical information. Design control measures for design revisions shall be commensurate with those applied to the original design.
- 3.11 Design activities shall also include: 1) reviewing the applicability of standards; 2) reviewing commercial or previously approved materials, parts or equipment for suitability of application; 3) reviewing the compatibility of materials used in the design; 4) reviewing the accessibility of equipment and components for inservice inspection, maintenance, and repair; 5) specifying criteria for inspection and test/retest; and 6) reviewing and approving procedures for special processes.
- 3.12 The design process shall establish controls for releasing design documents which are technically adequate and accurate in a controlled manner with a timely distribution to responsible individuals and groups. Design control procedures govern the design documents that reflect the commitments of the FSAR, which include, but are not limited to, calculations, computer programs, FSAR system descriptions, SAR when used as a design document, and drawings including piping and instrument diagrams, control logic diagrams, electrical single line diagrams, structural systems for major facilities, site arrangements, and equipment locations. Engineering change control procedures also establish controls for maintaining other as-built drawings, such as flow diagrams, and for maintaining software configuration. Procurement specifications are maintained in accordance with Section 4. Documents are controlled and used in accordance with Section 6.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 3
	REVISION: 033a
	DATE: 06/19

- 3.13 The design interfaces between Ameren Missouri organizations performing work affecting quality of design and between Ameren Missouri and outside organizations shall be identified and controlled by procedures. These procedures shall address control of the interface, responsibilities, lines of communication, and documentation of internal and external interface activities.
- 3.14 Design changes and calculations shall include design verification. Configuration change shall include a design review. Design verification assures that design is adequate and meets specified design inputs. Design control procedures shall specify requirements for the selection and accomplishment of a design Verification program. The program depth shall be commensurate with the importance of the system or component to safety, complexity of the design, and similarity of the design to previously proven designs. Design verification shall be conducted in accordance with procedures, which identify the responsibilities of the verifier and the documentation required and which, through adherence to the procedures, provide for the identification of the areas, features, and pertinent considerations to be verified. Design verification shall be by either design review, alternate calculation, qualification testing, or by a combination of these. Where alternate calculations are performed to verify the correctness of a calculation, a review shall be performed to address the appropriateness of assumptions, input data, and the code or other calculation method used. Ameren Missouri shall perform "reviews of design" of selected documents for subcontracted design to become familiar with design features. An independent third-level review must be employed as an additional verification when Ameren Missouri judges that the design involves unique or special design features. The organization performing design shall have the responsibility for design control unless specified otherwise. Design verification shall be performed by competent personnel other than those who performed the original design and who shall not have specified a singular design approach, have ruled out certain design considerations, or have established the design inputs for the particular design aspect being verified. A designer's supervisor may perform design verification when this individual is the only technically qualified individual and in such instances the need for design verification by the designer's immediate supervisor shall be individually documented and approved in advance by the supervisor's management. Nuclear Oversight Department audits shall examine the frequency and the effectiveness of use of supervisors as design verifiers to guard against abuse.
- 3.15 Design verification, if other than by qualification testing of a prototype or lead production unit, shall be completed prior to release for procurement, manufacturing, construction or to another organization for use in other design activities. In those cases where this timing cannot be met, the design verification may be deferred, providing the justification for this action is documented and the portions of the design output documents based on the unverified data are appropriately identified and controlled. Without verification, site activities associated with a design or design change must not proceed past the point where the installation would become irreversible (i.e., require extensive demolition and rework). The design verification shall be complete prior to relying upon the component, system, or structure to perform its safety-related function.
- 3.16 Action shall be initiated to correct errors found in the design process. Errors and deficiencies identified in approved design documents shall be documented and the process of their correction (i.e., review and approval) shall be controlled. These actions shall assure that changes to design or installed components are controlled.
- 3.17 Requests for design/configuration changes affecting safety-related structures, systems, and components may be originated by Nuclear Generation personnel. Design changes shall be processed by Engineering. Design/configuration changes engineered by Nuclear Engineering organizations shall be the responsibility of Nuclear Engineering. Design/configuration changes engineered by the Fuel Cycle Management Department shall be the responsibility of Fuel Cycle Management.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 3
	REVISION: 033a
	DATE: 06/19

- 3.18 Independent of the responsibilities of the design organization, the requirements of the Onsite Review Committee (ORC) as defined in OQAM Section 1.0 shall be satisfied.

CN 19-001


Safety Related Design changes shall be reviewed by the ORC and approved by the Senior Director, Nuclear Operations. ~~In addition, design/configuration changes that require a change in the Callaway Plant Technical Specifications, a License Amendment per 10CFR50.59, or an NRC CoC Amendment per 10CFR72.48 require review by the ORC. (NRC approval of the License Amendment is required prior to implementation of the design/configuration change.)~~

When design is performed by an outside organization, Ameren Missouri shall perform or coordinate a review of the design for operability, maintainability, inspectability, FSAR commitment compatibility, test and inspection acceptance criteria acceptability, and design requirements imposed by Plant generating equipment.

- 3.19 10CFR50.59 and 10CFR72.48 evaluations, which consider the effect of the design as described in the design documents, shall be performed by the responsible Ameren Missouri engineering organization or outside organization(s). These evaluations shall include the basis for the determination that the design/configuration change does not involve prior NRC approval via a License Amendment or CoC Amendment. As deemed necessary by the evaluating organization, detailed analyses shall be performed to support the bases of 10CFR50.59 and 10CFR72.48 evaluations. ~~All 10CFR50.59 and 10CFR72.48 evaluations are submitted to the ORC.~~ Changes involving the substitution of equivalent hardware require the 10CFR50.59 and 10CFR72.48 process (in addition to the appropriate requirements of this OQAM) to assure that the design requirement changes are consistent with and do not alter the design criteria specified in existing design documents. When an outside organization ~~performs the 10CFR50.59 and 10CFR72.48 process or~~ prepares design documents under its QA program, review and approval per ANSI N45.2.11 will be included. ~~Ameren Missouri will approve all outside organizations' design documents and 10CFR50.59 and 10CFR72.48 evaluations, and will perform appropriate reviews necessary for final approval.~~

CN 19-001

- 3.20 Design/configuration changes which require an amendment of the license shall be submitted on an application to the Nuclear Regulatory Commission for approval in accordance with 10CFR50.90.
- 3.21 Procedures and instructions related to equipment or systems that are modified shall be reviewed and updated in accordance with Appendix A to this OQAM (Regulatory Guide 1.33, Section 5.2.15 of ANSI N18.7), to reflect the modification prior to placing the equipment or systems in operation to perform safety-related functions. Plant personnel shall be made aware of changes affecting the performance of their duties through procedure revisions, or specific training in the operation of modified equipment or systems, or other appropriate means.
- 3.22 Records of design and configuration control activities are maintained in accordance with Section 17.
- 3.23 Drawings shall be prepared under a drawing control system which provides for checking methods and review and approval requirements. Drawings shall be subject to reviews by the responsible design organization for correctness, conformance to design criteria, and compliance with applicable codes and standards.


 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 4
	REVISION: 033a
	DATE: 06/19

4. **PROCUREMENT DOCUMENT CONTROL**


- 4.1 Safety-related procurements shall be documented. Procurement document control applies to documents employed to obtain safety-related materials, parts, components, and services required to support Plant activities. Written procedures establish requirements and assign responsibility for measures to assure applicable regulatory requirements, design bases, and other requirements necessary to assure quality are included in procurement documents.
- 4.2 Written procedures shall include controls, as applicable, for preparation, content, review, approval, and processing of the following related procurement documents:
- 1) Purchase Requisitions
 - 2) Purchase Orders
 - 3) Letters of Intent
 - 4) Engineering Service Agreements (agreements for engineering, construction, or consultant services) (ESAs)
 - 5) Contracts
 - 6) Specifications
 - 7) Drawings

Collectively, these procedures shall assure that technical and quality requirements are correctly stated, inspectable, and controllable; there are adequate acceptance and rejection criteria; and procurement documents have been prepared, reviewed, and approved in accordance with QA Program requirements.

- 4.3 Consideration of the verification activities to be employed for item or service acceptance should begin during the purchase requisition, ESA, or contract preparation and review stage. Planning of verification activities shall include a review of the established acceptance criteria and identified documentation. Verification methods which may be employed include certifications (certificates of conformance and material certificates or test reports), source verification, receiving inspection, and post-installation tests established by Ameren Missouri. Selected verification methods may be indicated as inspections, examinations, tests, or documentation reviews. The extent of the acceptance methods and associated verification activities is a function of the purchased item's or service's complexity and relative safety significance, as well as the supplier's past performance.
- 4.4 Acceptance by source verification should be considered when the item or service is vital to Plant safety; or the quality characteristics are difficult to verify after receipt; or the item or service is complex in design, manufacture, inspection or test. Verification in this sense involves a physical presence to monitor, by observation, designated activities for the purpose of evaluating supplier performance and product acceptability

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 4
	REVISION: 033a
	DATE: 06/19

- 4.5 Purchase requisitions must be employed to initiate the procurement of safety-related materials, parts, components, and services while ESAs must be used to contract for safety-related engineering, construction, or consultant services. Contracts, purchase orders generated from purchase requisitions, and ESAs must be employed to procure certain goods and services associated with the nuclear fuel cycle. Purchase requisitions for safety-related materials, parts, components, and services and ESAs for professional services may be initiated by personnel in the Nuclear Oversight Department; Nuclear Engineering; Fuel Cycle Management Department; or the unit staff.
- 4.6 The procurement of spare or replacement parts for safety-related structures, systems, and components shall be subject to the QA Program controls in effect at the time the order is issued; and to codes, standards, and technical requirements which are equal to or better than the original requirements or as may be required to reduce the probability for repetition of defects. Procurement document control preparation measures shall further assure that safety-related components, piece parts, materials, and services are purchased to specifications and codes equivalent to those specified originally or those specified by a properly reviewed and approved revision; packaged and transported in a manner to assure the non-degradation of quality during transit; and properly documented to show compliance with applicable specifications, codes, and standards.
- 4.7 Each item or service to be procured is evaluated by the procurement document originator to determine whether it performs a safety-related function or involves activities which affect the function of safety-related materials, parts, or components and to appraise the importance of this function to Plant or public safety. For those cases where it is unclear if an individual piece (part of a safety-related structure, system, component or service) is governed by the OQAP, an engineering evaluation shall be conducted. The evaluation shall be conducted by Nuclear Engineering and shall classify the safety relationship of the service or questionable component, parts or items of safety-related structures, systems, and components. Evaluations shall be documented for future reference.
- 4.8 Provisions for the following shall be included in procurement documents as applicable. These provisions may be addressed by invoking a supplier's approved quality program in the procurement document.
- 1) The scope of work and basic administrative and technical requirements including drawings, specifications, regulations, special instructions, and applicable codes and industrial standards and procedural requirements identified by titles and revision levels. Procurement documents shall also include special process instructions; identification of inspection, test and acceptance requirements; and any special requirements for activities such as designing, identifying, fabricating, cleaning, erecting, packaging, handling, shipping, and storing.
 - 2) Requirement that the supplier have an acceptable Quality Assurance Program which implements the appropriate sections and elements of ANSI N45.2-1977 or the ASME code as applicable as established for the item or service to be supplied. This requirement is not applicable to commercial grade items which utilize a supplier's standard or proven design to meet published product descriptions.
 - 3) Requirements for supplier surveillance, audit, and inspection including provisions for Ameren Missouri or agent access to facilities and records and for identification of witness and hold points.
 - 4) Requirements for extending applicable requirements of Ameren Missouri procurement documents to lower-tier suppliers and subcontractors. These requirements shall include right-of-access to subsupplier facilities and records by Ameren Missouri.
 - 5) Requirements for suppliers to obtain Ameren Missouri approval of nonconformances to procurement document requirements dispositioned "use-as-is" and "repair" and conditions of their disposition including identification of those subject to Ameren Missouri approval prior to further processing.
 - 6) Applicability of 10 CFR 21 reporting requirements.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 4
	REVISION: 033a
	DATE: 06/19

- 7) Documentation requirements including records to be prepared, maintained, submitted for approval, or made available for review, such as, drawings, specifications, procedures, procurement documents, inspection and test records, personnel and procedural qualifications, chemical and physical test results, and instructions for the retention, transfer, and disposition of records.
- 8) Requirements that the supplier furnish documentation which identifies the purchased item and provides traceability to the procurement requirements met by the item and documentation identifying any procurement requirements which have not been met.

4.9 Commercial grade calibration and/or testing services may be procured from commercial laboratories based on the laboratory's accreditation to ISO/IEC-17025 by an Accreditation Body (AB) which is a signatory to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA) provided all of the following are met:

- 1) A documented review of the supplier's accreditation is performed and includes a verification of the following:

CN 19-003

- a. The calibration or test laboratory holds accreditation by an accrediting body recognized by the ILAC MRA. The accreditation encompasses ISO/IEC-17025:2005 or ISO/IEC-17025:2017, "General Requirements for the Competence of Testing and Calibration Laboratories."
- b. For procurement of calibration services, the published scope of accreditation for the calibration laboratory covers the needed measurement parameters, ranges, and uncertainties.
- c. For procurement of testing services, the published scope of accreditation for the test laboratory covers the needed testing services including test methodology and tolerances/uncertainty.

- 2) The purchase documents require that:


CN 19-003

- a. The service must be provided in accordance with their accredited ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program and scope of accreditation.
- b. As found calibration data must be reported in the certificate of calibration when calibrated items are found to be out-of-tolerance. *(for calibration services only)*
- c. The equipment/standards used to perform the calibration must be identified in the certificate of calibration. *(for calibration services only)*
- d. The customer must be notified of any condition that adversely impacts the laboratory's ability to maintain the scope of accreditation.
- e. Additional technical and quality requirements, as necessary, based upon a review of the procured scope of services, which may include, but are not necessarily limited to, tolerances, accuracies, ranges, and industry standards.


- 3) It is validated, at receipt inspection, that the laboratory's documentation certifies that

CN 19-003


- a. The contracted calibration or test service has been performed in accordance with their ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program, and has been performed within their scope of accreditation, and
- b. The purchase order's requirements are met.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 4
	REVISION: 033a
	DATE: 06/19

- 4.10 The originating organization shall perform a documented independent review of procurement documents to assure requirements are correctly stated, inspectable, and controllable and that there are adequate acceptance and rejection criteria. This review shall be performed by personnel who have access to pertinent information, and who have an adequate understanding of the requirements and intent of the procurement documents.
- 4.11 Bids or proposals shall be evaluated by individuals or groups to evaluate the following subjects, as applicable to the type of procurement as described in 4.11.1, 4.11.2, 4.11.3, and 4.11.4:
- 1) Technical considerations
 - 2) Quality Assurance requirements
 - 3) Research and development effort
 - 4) Suppliers' personnel qualifications
 - 5) Suppliers' production capability
 - 6) Suppliers' past performance
 - 7) Alternates
 - 8) Exceptions
- 4.11.1 Supply Chain Operations shall initiate and coordinate bid evaluation activities for those proposals received in response to requisitions. Supply Chain Operations shall review bids or proposals, except those associated with ESAs or nuclear fuel cycle related goods or services, for alternates or exceptions to procurement document requirements (areas 7 and 8 above) taken by the Supplier. These reviews shall be documented.
- 4.11.2 The originating organization shall review bids or proposals in all eight areas for ESAs; and for parts, equipment, or services that are not a direct replacement, or from the original approved supplier. They shall also review areas 1 through 3 above for replacement parts or equipment ordered from the original supplier as part of procurement document preparation.
- 4.11.3 The Nuclear Oversight Department and the originating organization review areas 4 through 6 above as part of maintaining a supplier on the Qualified Supplier List as described in the OQAM, Sections 7.0 and 18.0.
- 4.11.4 The Fuel Cycle Management Department shall evaluate bids or proposals for fuel cycle goods or services in the above areas.
- 4.12 Bids or proposals with alternates or exceptions identified in Section 4.11 by Supply Chain Operations shall also be evaluated by the originating organization to provide additional assurance that no unacceptable conditions result from such changes. Unacceptable conditions identified in bid or proposal evaluations shall be resolved prior to purchase award.
- 4.13 Letters of intent may be utilized with suppliers of materials, parts, components, and services for the purpose of reserving schedule space prior to the resolution of the commercial requirements to be included in a purchase order, contract, or ESA. If employed, letters of intent must normally specify that no safety-related activities may begin until an approved purchase order, contract, or ESA is executed. Letters of intent shall be prepared, approved and issued by Supply Chain Operations for those suppliers to be covered by purchase order, by the originating organization for ESA's, or by the Fuel Cycle Management Department for contracts for nuclear fuel cycle-related goods and/or services. However in the event a letter of intent is issued for the purpose of securing an agreement and thereby allow safety-related work to begin prior to the issuance of such documents, it shall include the applicable quality and technical requirements, as specified by the originating organization.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 4
	REVISION: 033a
	DATE: 06/19


- 4.14 Supply Chain Operations is responsible for reviewing purchase orders to verify that the technical and quality requirements have been accurately transferred from the requisition to the purchase order. Approval of the purchase requisition, letter of intent, ESA, or contract shall be by an individual who has approval authority and signifies that the technical and quality review of the document has been completed. Contracts initiated for nuclear fuel cycle-related goods and/or services shall be the responsibility of the Senior Vice President and Chief Nuclear Officer with preparation and negotiation by the Fuel Cycle Management Department. Nuclear fuel cycle-related contracts and ESAs for professional services shall be executed by the Senior Vice President and Chief Nuclear Officer or another company officer in accordance with Nuclear Generation and corporate procedures related to agreements or contracts for services.
- 4.15 Additions, modifications, exceptions, and other changes to procurement document quality and technical requirements shall require a review equivalent to that of the original document and approval by the originator or the originating department approval authority. Commercial consideration changes shall not require review and concurrence by the originator. Conditions specified on the Qualified Suppliers List (QSL) that apply to a vendor may be revised without concurrence from the originating organization since they are imposed without the knowledge of the originator.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 6
	REVISION: 033a
	DATE: 06/19

6. DOCUMENT CONTROL

- 6.1 Documents and their revisions which control all activities affecting safety-related structures, systems, and components shall be prepared, reviewed by knowledgeable individuals, and approved by authorized personnel prior to release or issuance in accordance with written approved procedures.
- 6.2 Divisions, departments, and organizations responsible for OQAP implementing documents shall be required to provide the necessary review and approval for instructions, procedures, specifications, and drawings. Reviews and approvals shall assure that issued documents are adequate, authorized, include proper quality and technical requirements, and are correct for intended use. Individuals or groups responsible for preparing, reviewing, and approving documents and revisions thereto shall be identified in written procedures. Specifically, QC personnel shall review maintenance and modification procedures;¹ and QC personnel are responsible for the preparation of inspection procedures and/or checklists to support maintenance and modification activities. These reviews by QC personnel determine:
- 1) The need for inspection, identification of inspection personnel, and documentation of inspection results; and
 - 2) That the necessary inspection requirements, methods, and acceptance criteria have been identified.
- 6.3 Changes to documents shall be reviewed and approved by the same function, department, group, or organization that performed the original review and approval; however, Ameren Missouri may assume or delegate this responsibility. The reviewing organizations shall have access to pertinent background information upon which to base their approval and shall have adequate understanding of requirements and intent of the original document.
- 6.4 Documents relating to the Ameren Missouri OQAP shall be controlled to an extent which considers the document type, its importance to safety, and the intended use of the document. The preparation, review, approval and revision of procedures, instructions and drawings shall adhere to the OQAP.
- 6.5 The controls governing the issuance of documents shall provide for the availability of documents at the point of use prior to commencing an activity and the prompt transmittal of approved changes for incorporation into subsequent revisions. Measures shall be established to prevent the inadvertent use of superseded documents.
- 6.6 Types of documents which shall be controlled include the FSAR, specifications, Operating Quality Assurance Manual, other manuals, procurement documents, policies, work authorizing documents, design documents (e.g., calculations, drawings, analyses) including documents related to computer codes, nonconformance reports, as-built drawings, the Callaway Plant Operating Procedures, and topical reports.

¹ Work authorizing documents, such as Jobs may contain instructions to workers. However, Jobs are not considered "Maintenance procedures" which require QC review. When required, the assignment of inspection points for work authorizing documents is performed by QC or Work Management Department personnel based on established criteria. Work authorizing documents with assigned inspection points are routed to QC before work starts and after completion for tracking of inspection point assignments.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 6
	REVISION: 033a
	DATE: 06/19

6.7

~~The issuance of controlled documents at the General Office and Callaway Plant is coordinated by the Regulatory Affairs and the Administration organizations. The Administration organization shall be responsible for assuring the issuance of controlled documents at the Plant Site. Regulatory Affairs shall be responsible for assuring the issuance of controlled documents at the General Office, and for transmittal of documents to the Administration organization for entry into the document control system.~~


CN 19-002

6.8

Document control methods shall be defined consistent with the importance of the document to safety. Selected documents shall receive a control number. A serialized distribution list shall identify selected document holders by name and control number. Acknowledgment of receipt of selected documents, incorporation of revisions, and destroying or voiding of superseded documents shall be required by the distributor. In addition the distributing organization for documents controlled by a system of control numbers shall periodically compose a master list of the documents showing the effective revision date of each.

6.9

Procedures shall specify the requirements for the processing and maintenance of records. Procedures shall also be established to control instructions, procedures, and drawings governed by the OQAP. These procedural controls shall provide for the prompt transmittal of document revisions to work locations and the removal, destruction, or voiding of obsolete/superseded documents. The unit staff and other Ameren Missouri organizations shall assure that current documents are distributed to and used at the location where the prescribed activity is performed. It is recognized that, in certain instances, activities are controlled via the communication of documented procedural instructions from a remote location, (i.e., separated from the location where the prescribed activity is being performed). Identified, controlled copies of documents shall be used to perform an activity. Uncontrolled copies shall be identified.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 7
	REVISION: 033a
	DATE: 06/19

7. **CONTROL OF PURCHASED MATERIAL, EQUIPMENT AND SERVICES**


7.1 Materials, equipment, and services shall conform to procurement documents as prescribed in Section 4. Provisions shall be established to control activities affecting quality associated with the procurement of material, equipment and services including:

- 1) The preparation, review, and change control of procurement documents as described in Section 4
- 2) Bid evaluation and award as described in Section 4
- 3) Procurement source selections
- 4) Verification activities (surveillance, inspection, and audit) required by the purchaser
- 5) Control of nonconformances as described in Section 15
- 6) Corrective action as described in Section 16
- 7) Material, equipment, and service acceptance
- 8) Control of quality assurance records
- 9) Audits of the procurement program as described in Section 18


7.2 Ameren Missouri shall assure that suppliers providing safety-related materials, equipment, or services are acceptable procurement sources. Provisions shall be made for supplier evaluations which assess their capabilities prior to award by: 1) source evaluation; or 2) review for objective evidence of quality; or 3) a review of supplier history. When evaluations are performed, the assessment of a supplier's capability shall be specific to the procured item, commodity, or service and the supplier's ability to provide the items or services in accordance with procurement document requirements. Suppliers of hardware and services which are manufactured prior to award, considered a commercial grade item, or implemented under the Ameren Missouri OQAP, do not require pre-award source evaluation or post-award audits which attest to their capability as a procurement source.

7.3 During Callaway's operating life, procurements may be made from: 1) suppliers judged capable (prior to award) of providing items or services in accordance with procurement document requirements and a quality assurance program appropriate for the item or service procured; 2) suppliers and others in possession of hardware manufactured prior to award and whose acceptability can be determined by receiving inspection, an examination of quality verification documentation, or other suitable means; 3) suppliers of commercial grade items able to be ordered solely on the basis of published product descriptions (catalog information); and 4) outside organizations working under the Ameren Missouri OQAP. Regardless of the basis for the acceptability of the procurement source, prior to the issuance of a purchase order or execution of a contract or ESA, a verification of the supplier/outside organization's acceptability shall be documented. Except in unusual circumstances (e.g. replacement parts are needed to preclude the development of some unsafe or undesirable condition), an evaluation of a Supplier's acceptability as a procurement source shall be accomplished prior to award. In the case of purchase orders, the supplier shall be verified as an acceptable procurement source for the item or service being procured. Purchase orders may be issued prior to an assessment of suppliers' capability provided a prohibition on safety-related work is imposed. Such suppliers may be released to begin safety-related work when evaluated to be an acceptable procurement source.


7.4 Code certified material may be obtained from an ASME accredited Material Manufacturer or Material Supplier for repair or replacement applications. However Ameren Missouri may also obtain Code certified materials from non-ASME accredited Material Manufacturers or Material Suppliers if such Manufacturers or Suppliers are otherwise qualified as stipulated in Sections 4 and 7 of the OQAM. These provisions are consistent with ASME Code Interpretation XI-1-83-50R dated May 14, 1985.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 7
	REVISION: 033a
	DATE: 06/19

- 7.5 Procurement source evaluation and selection involves the Nuclear Oversight Department and the originating organization. The evaluation and selection process shall be specified in department procedures and may vary depending on the complexity and relative importance to safety of the item or service. Nuclear Engineering, Fuel Cycle Management, the unit staff or other organizations may be requested to provide input to the qualification evaluations of suppliers.
- 7.6 Procurement source selection and evaluations shall consider one or more of the following:
- 1) Experience of users of identical or similar products of the prospective supplier. NRC Vendor Inspection reports, ASME Certificates of Authorization (C of A), audit reports, Ameren Missouri records accumulated in previous procurement actions, and Ameren Missouri product-operating experience may be used in this evaluation. Supplier history shall reflect recent capability. Previous favorable quality experience with suppliers may be an adequate basis for judgments attesting to their capability. When an NRC Vendor Inspection report, an audit report, or an ASME C of A is used to establish a supplier's acceptability as a procurement source, the document shall be identified.
 - 2) An evaluation of the supplier's current quality records supported by documented qualitative and quantitative information which can be objectively evaluated. This may include review and evaluation of the supplier's QA Program, Manual, and Procedures, as appropriate; and responses to questionnaires.
 - 3) A source evaluation of the supplier's technical and quality capability as determined by a direct evaluation (audit or surveillance) of facilities, personnel and Quality Assurance Program implementation.
 - 4) For commercial grade items, the procurement source selection should consider one or more of the following:
 - a) Survey of documented supplier controls over critical characteristics and that supplier activities adequately control the items supplied, and verify the implementation of manufacturer's measures for control of design, process, and material changes.
 - b) Acceptable supplier/item performance record utilizing monitored performance of the item, industry product tests, national codes, and standards (not specific to the nuclear industry), or other industry databases (UL, INPO NPRDS, EPRI EQDB, ANSI, NEMA, MIL-STDs, NRC Bulletins/Notices, and Licensee Event Reports, etc.) that is directly related to the item's critical characteristics and intended application.
- 7.7 Procurement source evaluations involve a review of technical and quality assurance considerations. Technical considerations include the design or manufacturing capability and technical ability of suppliers to produce or provide the design, service, item, or component. Quality assurance considerations include one of the previously defined methods of supplier evaluation and a consideration of changes in a supplier's Quality Assurance Program or capabilities. The measures employed to evaluate a supplier's continued acceptability as a procurement source (after the initial source evaluation) are described in Section 18.
- 7.8 Organizations participating in the procurement process shall prepare procedures to monitor and evaluate suppliers' performance to procurement document requirements. These procedures shall include provisions for: 1) controlling documents generated or processed during activities fulfilling procurement requirements; 2) identifying and processing change information; 3) establishing a method of control and documentation of information exchange with the supplier; and 4) audit or surveillance of supplier activities.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 7
	REVISION: 033a
	DATE: 06/19

- 7.9 Depending on the complexity or scope of the item or service, Supply Chain Operations and/or the originating organization shall initiate award activities. Meetings or other forms of communication may be held to establish the intent of Ameren Missouri in monitoring and evaluating the supplier's performance, establish an understanding of procurement requirements, and identify supplier activities to be utilized in fulfilling requirements. The depth and necessity of these activities shall be a function of the relative importance, quantity, uniqueness, complexity, frequency of transactions with the same supplier, and the supplier's past performance. Ameren Missouri hold and witness points shall be documented as early as practicable in the procurement process.
- 7.10 The originating organization shall establish measures for monitoring supplier-generated document submittals against procurement document requirements. Similarly, measures shall be established for reviewing and approving supplier generated documents for use. Changes to procurement documents shall be in accordance with the controls described in Section 4.
- 7.11 Supplier monitoring activities may be performed by personnel from Nuclear Oversight, Nuclear Engineering, Protective Services, Fuel Cycle Management, the unit staff, or outside organizations in accordance with plans to perform inspections, examinations or tests. Supplier monitoring activities may include:
- 1) Audits of supplier quality assurance program implementation
 - 2) Monitoring, witnessing, or observing inspections, examinations, and performance tests
 - 3) Surveillance of manufacturing processes
 - 4) Audits of supplier records to verify certification validity and the resolution of nonconformances
- 7.12 To support the control of purchased material, copies of purchase orders and other appropriate procurement documents shall be forwarded to the applicable receiving or acceptance point. Departments receiving or utilizing procured items or services shall establish measures to maintain and control procurement documents until the items or services are received and accepted. These documents shall include purchase orders, drawings and specifications, approved changes, and other related documents.
- 7.13 Receiving inspection instructions shall be documented. These instructions include specifying inspections or tests of commercial grade items procured from suppliers on the basis of product performance. Should it become necessary to upgrade stocked non-safety related items to specific requirements, inspections, tests, or documentation reviews may be employed to establish the items' acceptability. Documentation shall be generated as a result of Ameren Missouri receiving inspection activities.
- 7.14 Acceptance of items and services shall include one or more of the following:
- 1) Written certifications
 - 2) Source verification
 - 3) Receiving inspection
 - 4) Post-installation test (in addition to one of the above).

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 7
	REVISION: 033a
	DATE: 06/19

7.15 Commercial grade items shall rely on proven design and utilize verification methods by the purchaser, to the extent appropriate to item application. Procedures provide for the acceptance of commercial grade items based on one or more of the following:

- 1) Special Tests and Inspections
- 2) Survey of Supplier (Commercial Grade)
- 3) Source Verification
- 4) Acceptable Supplier/Item Performance Record

Method 4 should not be used alone unless:

- a. The established historical record is based on industry wide performance data that is directly applicable to the item's critical characteristics and the intended safety-related application; and
- b. The manufacturer's measures for the control of design, process, and material changes have been adequately implemented as verified by audit (multi-licensee team audits are acceptable).


7.16 Where required by Code, regulation or contract requirement, documentary evidence that items conform to procurement documents shall be available during receiving inspection or prior to use of such items. Where not precluded by other requirements, documentary evidence may take the form of written certificates of conformance. When certificates of conformance are employed as a means of item acceptance, verification of the validity of supplier certificates and the effectiveness of the certification systems shall be conducted at intervals commensurate with the supplier's past quality performance. Certificates of conformance and compliance shall be required to be signed or accompanied by a signed letter of transmittal. Where acceptance is based upon source verification, documented evidence of these surveillances shall be furnished to the Plant Quality Control organization by the responsible Ameren Missouri organization or their designated agent prior to acceptance.

7.16.1 When purchasing commercial grade calibration or testing services from a laboratory holding accreditation by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA), commercial grade surveys need not be performed provided all of the following conditions are met:


- 1) A documented review of the supplier's accreditation is performed and includes a verification of the following:
 - a. The calibration or test laboratory holds accreditation by an accrediting body recognized by the ILAC MRA. The accreditation encompasses ISO/IEC-17025:2005 or ISO/IEC-17025:2017, "General Requirements for the Competence of Testing and Calibration Laboratories."
 - b. For procurement of calibration services, the published scope of accreditation for the calibration laboratory covers the needed measurement parameters, ranges, and uncertainties.
 - c. For procurement of testing services, the published scope of accreditation for the test laboratory covers the needed testing services including test methodology and tolerances/uncertainty.
- 2) It is validated, at receipt inspection, that the laboratory's documentation certifies that:
 - a. The contracted calibration or test service has been performed in accordance with their ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program, and has been performed within their scope of accreditation, and
 - b. The purchase order's requirements are met.

CN 19-003

CN 19-003


 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 7
	REVISION: 033a
	DATE: 06/19

- 7.17 Acceptance by receiving inspection shall be utilized as a prime method of verification and may be utilized as the sole means of item acceptance when items are relatively simple and standard in design and manufacture, such as certain spare parts; when items are adaptable to standard or automated inspections; and when inspections do not require operations which could adversely affect the integrity, function, or cleanliness of the item. When other methods are utilized, receiving inspection shall be employed to verify that items have not sustained damage.
- 7.18 Quality Control personnel performing receiving inspection shall be certified to ANSI N45.2.6 - 1978, (as clarified in OQAM Appendix A Regulatory Guide 1.58). Other unit staff personnel qualified to ANSI 3.1 - 1978 may be utilized to perform receipt inspections requiring specialized skills, such as receipt inspection of radioactive material, bulk chemicals and diesel fuel. During outages, extensive modifications, or other special circumstances, receiving inspection may be assigned to an outside organization(s).
- 7.19 Final acceptance of items shall be by Quality Control personnel or designated inspection personnel. The final acceptance of services shall be the responsibility of the originating organization. Acceptance shall be documented.
- 7.20 Receiving inspection activities shall include:
- 1) Verifying that materials, parts, and components, have been identified by tagging or other means; or that they are segregated and controlled in areas separate from the storage facilities for accepted items.
 - 2) Verifying that items for acceptance have been examined for physical damage, correctness of identification and quality documentation, and completeness of specified quality documentation.
 - 3) Verifying that received items conform to procurement documents by inspecting or, where appropriate, testing using approved procedures and calibrated tools, gages and measuring equipment to verify the acceptability of items, including those from commercial grade suppliers.
 - 4) Providing final acceptance after determining that required verifications are complete and acceptable. Items determined to be acceptable for use shall be tagged with an accept tag or other means of identification or segregation, and released for storage or use. Conditional acceptance of items by receiving inspection shall be procedurally controlled.
 - 5) Verifying that received items which do not conform to procurement documents are segregated (if practicable) and processed in accordance with Section 15.
- 7.21 Acceptance by post-installation test may be utilized following one of the preceding acceptance methods. Post-installation testing shall be used as the prime means of acceptance verification when it is difficult to verify item quality characteristics; the item requires an integrated system checkout or test; or the item cannot demonstrate its ability to perform when not in use. Post-installation test requirements and acceptance documentation shall be established by Ameren Missouri.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 18
	REVISION: 033a
	DATE: 06/19

18. **AUDITS**

- 18.1 A comprehensive audit program shall be established and implemented by Ameren Missouri to verify internal and external quality activities' compliance with the OQAP. The audit program shall assure that all applicable elements of the Program have been developed, documented, and are being effectively implemented and shall provide for the reporting and review of audit results by management. The audit system is described in manuals and procedures. Nonconformances and program deficiencies shall be identified and corrective action shall be initiated and verified. See Section 3.14 for a specific audit topic.
- 18.2 The Ameren Missouri audit system shall include the performance of audits and surveillances by the Nuclear Oversight (NOS) Department. Audits determine, through investigation, the adequacy of and adherence to established procedures, instructions, specifications, codes, and other applicable contractual and licensing requirements and the effectiveness of implementation. Surveillances involve the periodic or continuous monitoring of the operation or performance of a supplier, item, component, or system. Surveillance in this audit sense should not be confused with inspections for the purpose of process control or product acceptance or with requirements relating to test, calibration or inspection to assure that the necessary quality of systems and components is maintained, that facility operations are within the safety limits, and that limiting conditions of operations are being met (surveillance tests). NOS personnel performing surveillances should be familiar with the area to be surveilled and the applicable implementing procedure(s) governing surveillances. Surveillances may also be performed by personnel from other organizations, but these require no unique personnel qualifications or certifications (except when performed for product acceptance). See Sections 10.6, 10.7, 10.8, 11.10, 11.11, 11.12, and 18.4.
- 18.3 The Director, Nuclear Oversight shall establish a program which provides for the qualification and training of NOS Department audit and surveillance personnel. Audits shall be directed by an Audit Team Leader (ATL) who is a certified Lead Auditor. A Lead Auditor is an individual certified as qualified to direct an audit, perform an audit, report audit findings, and to evaluate corrective action. Other personnel may assist Lead Auditors in the conduct of audits; namely, technical specialists, management representatives, auditors and other Lead Auditors. The persons having direct responsibility for performance of the activities being audited shall not be involved in the selection of the audit team. Personnel selected for NOS auditing or surveillance assignments shall have training or experience commensurate with the scope, complexity, or special nature of the activities to be reviewed or investigated and shall have no direct responsibility for the area being evaluated. The NOS personnel training program shall provide general orientation and specific training which develop competence for performing audits or surveillances. Training records shall provide a history of NOS personnel training, evaluations, qualification, certifications, and retraining.
- 18.4 NOS Department personnel who perform audit and surveillance activities shall be qualified in accordance with the requirements prescribed in NOS Department procedures. Lead Auditor qualification requirements shall include education or professional status, previous work experience or training, training received through Ameren Missouri, on-the-job performance and participation in surveillances or audits as an auditor, a qualification examination, and other factors applicable to auditing not defined by procedure. The qualification certification of Lead Auditors shall be based on an evaluation of these factors by the Director, Nuclear Oversight. The maintenance of proficiency by Lead Auditors shall be accomplished by active participation in the audit process; a review of program, codes, standards, procedures and other document revisions related to the OQAP; or participation in training programs. The Director, Nuclear Oversight shall provide for annual assessments of each Lead Auditor to determine proficiency. As long as a Lead Auditor is performing satisfactorily and is maintaining proficiency, there is no limit on the period of certification. However if at any time the Lead Auditor's performance is evaluated as being unacceptable, Lead Auditor certification shall be rescinded. In addition the failure to maintain proficiency for a period of two years or more shall be basis for Lead Auditor certification revocation. If certification is rescinded or revoked, requalification shall be required prior to recertification.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 18
	REVISION: 033a
	DATE: 06/19

- 18.5 The Director, Nuclear Oversight shall be responsible for assuring the implementation of a comprehensive system of planned audits to verify compliance with the OQAP. The Director, Nuclear Oversight has sufficient authority and organizational freedom to schedule and perform both internal and external audits. This individual has the organizational responsibility to measure and assure the overall effectiveness of the OQAP and is independent of the economic pressures of production when opposed to safety or quality. The Director, Nuclear Oversight has direct access to the Senior Vice President and Chief Nuclear Officer.
- 18.6 The audit system shall include internal and external audits. The system shall be planned, documented, and conducted to assure coverage of the applicable elements of the OQAP, and overall coordination and scheduling of audit activities. Audit results shall be periodically reviewed by the NOS Department for quality trends and results reported to the appropriate management. The Director, Nuclear Oversight shall monitor the OQAP audit program to assure audits are being accomplished in accordance with the requirements described herein and for overall Program effectiveness. The Director, Nuclear Oversight shall ensure an independent review of the onsite audit program is conducted periodically, to assure that audits are being performed in accordance with the OQAP. Appropriate levels of management shall be provided copies of internal and external audit reports.
- 18.7 Internal audits shall be conducted by the NOS Department and shall be performed with a frequency commensurate with their safety significance. An audit of safety-related functions shall be completed in accordance with formal audit schedules within a period of two (2) years. A grace period of 90 days may be applied to performance of internal audits provided the two (2) year frequency for the following audit performance is not set forward. Each element of the OQAP, such as design control and document control, and each area of Plant operations shall be audited.
- 18.8 Supplementary to the biennial requirements to audit safety-related functions:
- Audits of Unit activities (listed below) SHALL be conducted on a performance based frequency by the NOS Department, not to exceed 24 months *
 - a) The conformance of Unit operation to provisions contained within the Technical Specifications and applicable license conditions;
 - b) The performance, training and qualifications of the entire Unit staff;
 - c) The results of actions taken to correct deficiencies occurring in Unit equipment, structures, systems or method of operation that affect nuclear safety;
 - d) The performance of activities required by the Operational Quality Assurance Program to meet the criteria of Appendix B, 10CFR Part 50,
 - e) The Radiological Environmental Monitoring Program and the results thereof;
 - f) The OFFSITE DOSE CALCULATION MANUAL and implementing procedures;
 - g) The PROCESS CONTROL PROGRAM and implementing procedures for processing and packaging of radioactive wastes;
 - h) The performance of activities required by the Quality Assurance Program for effluent and environmental monitoring; and
 - i) Any other area of Unit operation considered appropriate by the Senior Vice President and Chief Nuclear Officer.
- * A grace period of 90 days may be applied to the 24 month frequency for internal audits, provided the 24 month frequency for the following audit performance is not set forward.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 18
	REVISION: 033a
	DATE: 06/19

18.8.1 The following areas shall be reviewed or audited per the frequency specified in applicable regulations:

- ⇒ Radiological Protection program
- ⇒ Security program
- ⇒ Access Authorization
- ⇒ Fitness-For-Duty program
- ⇒ Radiological Emergency Response Plan

18.8.2 In addition to the audits conducted under 18.8.a) – i) and 18.8.1, a triennial Fire Protection Program audit shall be conducted with an audit scope that includes the following:

- a) FP Program as defined in FSAR SP, Section 9.5.1;
- b) Fire Protection Quality Assurance Program (FSAR-SP, Section 9.5.1.6.2);
- c) NFPA 805 Fire Protection Monitoring Program (FSAR-SP, Section 9.5.1.4.2);
- d) This triennial audit utilizes a qualified outside independent Fire Protection Consultant (non-Ameren).

18.9 During Plant modifications or other major unique activities, audits shall be scheduled as required to assure that Quality Assurance Program requirements are properly implemented.

18.10 External audits shall be conducted by or for the NOS Department as a method for the evaluation of procurement sources and as a post-award source verification of conformance to procurement documents. Audits conducted by other organizations (with similar orders with the same supplier), including other utilities or A/E's, may be employed as a means of post-award source verification in lieu of Ameren Missouri performed audits and may not necessarily audit specific items furnished to Ameren Missouri. These audits and surveillances shall utilize personnel qualified in accordance with this OQAM and shall be conducted in accordance with this OQAM and NOS Department procedures. Commercial grade items do not require pre-or post-award audits. Similarly, items which are relatively simple and standard in design and manufacture may not require supplier qualification or post-award audits to assure their quality.

18.10.1 When purchasing commercial grade calibration or testing services from a laboratory holding accreditation by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA), commercial grade surveys need not be performed provided all of the following conditions are met:

1. A documented review of the supplier's accreditation is performed and includes a verification of the following:


CN 19-003

- a. The calibration or test laboratory holds accreditation by an accrediting body recognized by the ILAC MRA. The accreditation encompasses ISO/IEC-17025:2005 or ISO/IEC-17025:2017, "General Requirements for the Competence of Testing and Calibration Laboratories."
- b. For procurement of calibration services, the published scope of accreditation for the calibration laboratory covers the needed measurement parameters, ranges, and uncertainties.
- c. For procurement of testing services, the published scope of accreditation for the test laboratory covers the needed testing services including test methodology and tolerances/uncertainty.


2. It is validated, at receipt inspection, that the laboratory's documentation certifies that:

CN 19-003

- a. The contracted calibration or test service has been performed in accordance with their ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program, and has been performed within their scope of accreditation, and
- b. The purchase order's requirements are met.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	SECTION NO. 18
	REVISION: 033a
	DATE: 06/19

- 18.11 Applicable elements of suppliers' quality assurance programs shall be audited (post-award) on a triennial basis. A 90-day grace period may be applied to this activity. Audits generally should be initiated when sufficient work is in progress to determine whether the organization is complying with the established quality assurance provisions. Subsequent contracts or contract modifications which significantly enlarge the scope of activities by the same supplier shall be considered in establishing audit requirements. In addition, the need for a triennial audit may be precluded upon evaluation and documentation by the NOS Department that the results of mini-audits performed during source verification and source surveillance activities confirm the adequacy and implementation of the supplier's QA Program.
- 18.12 Supplementary to audits, annual evaluations of suppliers shall be performed which take into account, as applicable: 1) the review of supplier furnished documents such as certificates of conformance, nonconformance notices, and corrective actions; 2) results of previous source verifications, audits, and receiving inspections; 3) operating experience of identical or similar products furnished by the same supplier; 4) results of audits from other sources, and 5) for providers of commercial-grade calibration and testing services, continued maintenance of laboratory accreditation for the specific services supplied to Callaway Energy Center. A 90-day grace period may be applied to this activity.
- 18.13 Audits shall also be conducted when: 1) significant changes are made in functional areas of the Quality Assurance Program such as significant reorganization or procedure revisions; or 2) when it is suspected that the quality of the items is in jeopardy due to deficiencies in the Quality Assurance Program; or 3) when a systematic, independent assessment of Program effectiveness is considered necessary; or 4) when it is necessary to verify implementation of required corrective action.
- 18.14 Audits shall be conducted using written plans in accordance with NOS Department procedures. The procedures require evaluation of work areas, activities, processes, goods, services, and the review of documents and records for quality-related practices, procedures, and instructions to determine the effectiveness of the implementation of the OQAP and compliance with 10 CFR 50, Appendix B. The audit plan shall identify the audit scope, the requirements, the activities to be audited, organizations to be notified, the applicable documents, the schedule, and the written procedures or checklists as appropriate. The audit plan and any necessary reference documents shall be available to the audit team members.
- 18.15 An audit team consists of one or more auditors. A Lead Auditor shall be appointed Audit Team Leader. The Audit Team Leader shall be responsible for the written plans, checklists, team orientation, audit notification, pre-audit conference, audit performance, post-audit conference, reporting, records, and follow-up activity to assure corrective action.
- The audited organization should be informed of adverse findings. Agreement or disagreement with a finding may be expressed in the response from the audited organization. (refer to Appendix A, Subsection 4.3.2.5 of ANSI N45.2.12)
- Any adverse findings shall be reported in a post-audit conference with team members and the audited organization, unless the post-audit conference is waived by the management of the audited organization. (refer to Appendix A, Section 4.3.3 of ANSI N45.2.12)
- 18.15.1 Formal audit reports shall be prepared and submitted within 30 days after the post-audit conference (or last day of the audit, whichever is later) to:
- the audited organization for internal audits conducted in accordance with the Sections described herein, and
 - specifically, the Senior Vice President and Chief Nuclear Officer for audits conducted in accordance with Section 18.8.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

OQAM CONFORMANCE TO APPLICABLE NRC REGULATORY GUIDES

This Appendix briefly discusses the extent to which Ameren Missouri's Operating Quality Assurance Program (OQAP) conforms to NRC published Regulatory Guides for the Callaway Plant. All statements within the Regulatory Position Section (C) of the Regulatory Guides are considered requirements unless a specific exception or clarification has been proposed by Ameren Missouri and accepted by the NRC. This is true regardless of the qualifier (i.e., "shall" or "should") which prefaces the statement. Unless further qualified by a statement within the corresponding Regulatory Guide, ANSI/ANS Standards "shall" statements denote requirements while "should" statements denote recommendations. Clarifications, alternatives, and exceptions to these Regulatory Guides are identified herein. Ameren Missouri's position on other Regulatory Guides is given in Appendix 3A of the Callaway-SA and Callaway-SP Final Safety Analysis Reports (FSARs).

In each of the ANSI standards referenced by one of the listed Regulatory Guides, other documents (i.e. other standards, codes, regulations or appendices) required to be included as a part of the standard are either identified at the point of reference or are described in a special section of the standard. The specific applicability or acceptability of these listed standards, codes regulations or appendices is either covered in other specific areas in the FSAR or this Operating QA Manual (OQAM), including tables, or such documents are not considered as requirements, although they may be used as guidance. When sections are referenced within a standard, it is understood that Ameren Missouri shall comply with the referenced section as clarified.

REGULATORY GUIDE 1.8

REVISION 2

DATED 4/87

Qualification and Training of personnel for Nuclear Power Plants (Endorses ANSI/ANS 3.1-1981 for Shift Supervisor (Section 4.3.1.1), Senior Operator (Section 4.3.1.2), Licensed Operators (Section 4.5.1.2), Shift Technical Advisor (Section 4.4.8), and Radiation Protection (Section 4.4.4) only, and ANSI/ANS N18.1-1971 for all other positions).

DISCUSSION:


Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications and exceptions:

Revision 1, dated 9/75, applies to the position of Radiation Protection Manager only, in accordance with the Callaway Plant Technical Specifications. For the position of Radiation Protection Manager only, Regulatory Guide 1.8, Revision 1, September, 1975 is clarified by USNRC HPPOS-020, Clarification of Regulatory Guide 1.8 on Qualification of Radiation Protection Manager.

The experience, training, and education requirements for the positions of Shift Manager, Operating Supervisor, and Reactor Operator, and personnel fulfilling the duties of Shift Technical Advisor shall meet or exceed the requirements and recommendations of ANSI/ANS 3.1-1981 as endorsed by the Regulatory Guide 1.8, Revision 2, with the same exceptions as contained in the current revision to the Operating Licensing Examiner Standards, NUREG-1021, ES-202.

For all other positions, qualification and training shall comply with ANSI/ANS 3.1-1978 as clarified below:

Refer to Callaway-SA FSAR Section 13.1 for a discussion of the qualifications of personnel responsible for plant operation and support.

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

Personnel responsible for directing or supervising the conduct of safety-related preoperational and startup tests and for review and approval of safety-related preoperational and startup test procedures or results met the qualifications of the Regulatory Guide, but were not required to be certified.

Ameren Missouri may use additional Ameren employees or contract personnel to augment the unit staff. These groups include, but are not limited to, Ameren personnel from outside Nuclear Generation as well as supplemental Radiation Protection and I&C technicians and QC inspectors. When used to perform safety-related activities, these personnel shall meet the education and experience requirements of ANSI/ANS 3.1-1978 for equivalent positions or specified education and experience requirements for non-equivalent positions. As an alternative, these personnel can be qualified for assigned tasks either by Ameren Missouri through its systematic approach to training or by Vendors with Ameren Missouri approved training and qualification programs. Inspection, examination and testing personnel shall meet the requirements for certification as inspection, examination or testing personnel as set forth in Ameren Missouri's commitment to ANSI N45.2.6-1978 given elsewhere in this Appendix.

With regard to Section 5.6 of ANSI/ANS 3.1 - 1978 titled Documentation: Ameren Missouri shall maintain records in accordance with and to meet the requirements of OQAM Section 17 and ANSI N45.2.9 as specified herein.

REGULATORY GUIDE 1.28

REVISION 2

DATED 2/79

Quality Assurance Program Requirements (Design and Construction) (Endorses ANSI N45.2-1977)

DISCUSSION:

This Regulatory Guide is not applicable to the operating phase. However, ANSI N45.2-1977 will be applied to suppliers of safety-related items, components or services, as appropriate, as described under Regulatory Guide 1.123 (ANSI N45.2.13-1976).

REGULATORY GUIDE 1.30

INITIAL ISSUE

DATED 8/72

Quality Assurance Requirements for the Installation, Inspection, and Testing of Instrumentation and Electronic Equipment (Safety Guide 30) (Endorses ANSI N45.2.4-1972/IEEE 336-1971)


DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

For maintenance and modification activities Ameren Missouri shall comply with the Regulatory Position established in this Regulatory Guide in that QA programmatic/administrative requirements included therein (subject to the clarifications below) shall apply to these maintenance and modification activities even though such requirements may not have been in effect originally. Technical requirements associated with the maintenance and modifications shall be equal to or better than the original requirements (e.g., code requirements, material properties, design margins, manufacturing processes, and inspection requirements), or as required to preclude repetition of defects.

Specific clarifications for ANSI N45.2.4 - 1972 are indicated below by sections.

Section 1.4 - Definitions in this Standard which are not included in ANSI N45.2.10 shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

Section 2.1 - Planning requirements, as determined by engineering, shall be incorporated into modification procedures. Engineering actions performed in accordance with this Section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

Section 2.3 - Procedures and Instructions shall be implemented as set forth in OQAM Sections 2, 3, 5, 10 and 11 and by compliance with the Callaway Plant Technical Specifications and Regulatory Guide 1.33 (ANSI N18.7) as set forth in this Appendix in lieu of the requirements set forth here. When compliance with an NRC accepted program (e.g., Callaway Plant Technical Specifications) is referenced, Ameren Missouri has substituted the NRC accepted program for applicable regulatory requirements in lieu of the general requirements of the Quality Assurance program standards.

Section 2.4 - Results shall be implemented as set forth in OQAM Sections 10, 11 and 17 and by compliance with ANSI N18.7 as set forth in this Appendix in lieu of the requirements set forth here. In every case either identical or equivalent controls are provided in the sections of the referenced Standards or documents.

Section 2.5.2 - Calibration and Control covers three classes of instrumentation used by Ameren Missouri:


- (1) M&TE (portable measuring instruments, test equipment, tools, gages, and non-destructive test equipment used in measuring and inspecting safety-related structures, systems, and components);
- (2) reference standards (primary, secondary, transfer, and working); and
- (3) permanently installed process instrumentation (PI).

With respect to the first sentence, M&TE and reference standards shall be included in a calibration program and shall either be calibrated at prescribed intervals or shall be calibrated prior to use. With respect to the last sentence, personnel shall be trained and procedures shall require that the calibration label or tag shall be reviewed to determine calibration status prior to use: This label or tag shall be considered to clearly identify equipment which is out of calibration. Lack of a label or tag shall require the organization responsible for calibrating the M&TE to review records and affix a new label or tag based on calibration data. M&TE and reference standards shall comply with sentences 2, 3 and 4.

With respect to the 3rd sentence, Ameren Missouri uniquely identifies each safety-related item of permanently installed process instrumentation. This identification provides traceability to calibration data. These actions are Ameren Missouri's alternative to the tagging or labeling of items to indicate the calibration date and the identity of the person who performed the calibration. Permanently installed process instrumentation shall comply with sentences 1, 2, and 5.

Section 3 - Preconstruction Verification shall be implemented as follows:

- (1) shall be required only for modifications;
- (2) shall be implemented with the clarification that "approved instruction manuals" shall be interpreted to mean the manuals provided by the supplier as required by the procurement order - these manuals are not necessarily reviewed and approved, per se, by Ameren Missouri;
- (3) no special checks shall be required to be made by the person withdrawing a replacement part from the warehouse - equivalent controls are assured by compliance with Regulatory Guide 1.38 (ANSI N45.2.2) as set forth in this Appendix; and,

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A	
	REVISION:	033a
	DATE:	06/19

- (4) shall be complied with as determined by engineering or by individual technicians as part of the modification process. Engineering actions performed in accordance with this Section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit.

Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

Section 4 - Installation shall be implemented as stated and as follows: Engineering actions performed in accordance with this Section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

Section 5.1 - Inspections, including subsections 5.1.1, 5.1.2, and the first sentence in 5.1.3, shall be implemented as set forth in OQAM Section 10. The inspection program shall incorporate, as determined by engineering and QC, those items listed in these subsections. The remaining sentence in 5.1.3 is covered in equivalent detail in Ameren Missouri's commitment to Regulatory Guide 1.33 (ANSI N18.7), Section 5.2.6; the requirements as set forth in that commitment shall be implemented in lieu of the requirements stated here. In every case either identical or equivalent controls are provided in the Sections of the referenced Standards or documents.

Section 5.2 - Tests, including subsections 5.2.1 through 5.2.3, shall be implemented as set forth in OQAM Sections 3 and 11. In some cases Surveillance testing may be used to meet the appropriate requirements of this Section.

Section 6 - Post-Construction Verification is not generally considered applicable at operating facilities because of the scope of the work and the relatively short interval between installation and operation. Where considered necessary by engineering or QC, the elements described in this Section shall be used in the development and implementation of inspection and testing programs as described in OQAM Sections 3, 10 and 11.

Section 7 - Data Analysis and Evaluation shall be implemented as stated herein after adding the clarifying phrase "Where used" at the beginning of the paragraph. This clarification accounts for the fact that some testing will not generate "Data" as such.

Section 8 - Records shall be implemented by conformance with OQAM Section 17 and Regulatory Guide 1.88 (ANSI N45.2.9) as set forth in this Appendix.

REGULATORY GUIDE 1.33

REVISION 2

DATED 2/78


Quality Assurance Program Requirements (Operation) (Endorses ANSI N18.7-1976/ANS 3.2)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

Paragraph C.3 of Regulatory Guide 1.33 (and Section 4.3.4 of ANSI N18.7 which it references) shall be implemented as required by OQAM Section 1 which defines "Subjects Requiring Independent Review."

When the term "safety evaluation" is used, it should be replaced by "10CFR50.59 evaluation". In addition, the term "unreviewed safety question" should be replaced with "license amendment". Where 10CFR50.59(a)(2) is cited, the corresponding part of the revised rule is 10CFR50.59(c)(2).

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

Paragraph C.4.a, b & c of Regulatory Guide 1.33 (and Section 4.5 of ANSI N18.7 which it references) shall be implemented as required by OQAM Section 18 which defines the "audit program" to be conducted. The audit program is further defined and shall be implemented as required by the commitment to Regulatory Guide 1.144 (ANSI N45.2.12) as stated in this Appendix.

Paragraph C.5.d of Regulatory Guide 1.33 (and Section 5.2.7.1 of ANSI N18.7 which it references) shall be implemented by adding the clarifying phrase "When determined by engineering" in front of the fourth sentence of the fifth paragraph. It is not always practicable to test parts prior to use. For modifications where these requirements are not considered practicable, a review in accordance with the provisions of 10 CFR 50.59 shall be conducted and documented. Engineering actions performed in accordance with this Section of the Regulatory Guide are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

Paragraph C.5.e of Regulatory Guide 1.33 and Section 5.2.13.4 of ANSI N18.7 which it references shall be implemented subject to the same clarifications made for Regulatory Guide 1.38 (ANSI N45.2.2).

Paragraph C.5.f of Regulatory Guide 1.33 (and Section 5.2.19(2) of ANSI N18.7 which it references) shall be implemented with the substitution of the word "practicable" for the word "possible" in the last sentence. The action referenced in this Section is the responsibility of the Callaway Plant Operating Organization, and includes NOS/QC involvement. NOS is involved through audit and surveillance activities. QC is involved in maintenance inspection activities.

Paragraph C.5.g of Regulatory Guide 1.33 (and Section 5.2.19.1 on ANSI N18.7 which it references) shall be implemented with the addition of the modifier "normally" after each of the verbs (should) which the Regulatory Guide converts to "shall." It is Ameren Missouri's intent to fully comply with the requirements of this paragraph, and any conditions which do not fully comply shall be documented and approved by management personnel. Management personnel includes NOS through cross-disciplinary reviews. NOS has and shall conduct audits or surveillances of preoperational testing. In cases where conditions do not fully comply, the reason for the exception shall also be documented. The documentation shall be retained as lifetime records.


With regard to Section 3.4.2 of ANSI N18.7 - 1976 titled Requirements for the Onsite Operating Organization:

Some of Ameren Missouri's technical support organizations are physically located at the Callaway site. Therefore, the second sentence of this Section shall be implemented as follows:

"Initial incumbents or replacements for members of the onsite or offsite technical support organizations shall have appropriate experience, training and retraining to assure that necessary competence is maintained in accordance with the provisions of ANSI/ANS 3.1 - 1978 as committed to in the OQAM."

In the third sentence, Ameren Missouri interprets "QA" to be "QC", consistent with the intent of Regulatory Guide 1.58 (ANSI N45.2.6-1978) and the OQAM.

Training standards referenced in this Section are implemented as described in this Appendix's commitments to Regulatory Guide 1.8 (ANSI/ANS 3.1) and Regulatory Guide 1.58 (ANSI N45.2.6-1978) or as otherwise included as part of the Callaway operating license. Ameren Missouri's methods of documenting and otherwise meeting the remainder of the requirements of this Section are set forth in OQAM Section 2, in the Callaway Plant Technical Specifications, and in other licensing commitments.

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

With regard to Section 4.1 of ANSI N18.7 - 1976 titled General: The Ameren Missouri audit program shall be implemented in accordance with and to meet the requirements of Regulatory Guide 1.144 (ANSI N45.2.12) as endorsed in this Appendix, and OQAM Section 18.

With regard to Section 4.2 of ANSI N18.7 - 1976 titled Program Description: Two aspects are addressed in this Section: audits and independent reviews. The independent review program shall be implemented as required by the OQAM. The Ameren Missouri audit program shall be described in accordance with and to meet the requirements of Regulatory Guide 1.144 (ANSI N45.2.12) as endorsed in this Appendix, and OQAM Section 18.

With regard to Section 4.3 of ANSI N18.7 - 1976 titled Independent Review Process: The requirements of this Section, including of its subparts, shall be met by compliance with the OQAM.

With regard to audit frequency specified in Section 4.5 of ANSI N18.7 – 1976 titled Audit Program: The Ameren Missouri audit program shall be implemented in accordance with the frequencies specified in OQAM Sections 18.7 and 18.8.

With regard to Section 4.5 of ANSI N18.7 - 1976 titled Audit Program: The Ameren Missouri audit program shall be implemented in accordance with and to meet the requirements of Regulatory Guide 1.144 (ANSI N45.2.12) as endorsed in this Appendix, and OQAM Section 18.

With regard to Section 5.1 of ANSI N18.7 - 1976 titled Program Description: The fourth sentence in this Section requires a "summary document." Ameren Missouri's OQAM is organized in accordance with the 18 criteria of 10 CFR 50, Appendix B. Ameren Missouri interprets this OQAM and applicable Regulatory Guides as endorsed in this Appendix to fulfill the requirements for a "summary document."

With regard to Section 5.2.2 of ANSI N18.7 - 1976 titled Procedure Adherence: The temporary change requirements of this Section are delineated in the OQAM for activities occurring after the Operating License (OL) is issued; the requirements of the OQAM shall be used to control temporary changes.


With respect to Section 5.2.6 of ANSI N18.7 - 1976 titled Equipment Control: Ameren Missouri shall comply with the "independent verification" requirements based on the definition of this phrase as given under our commitment to Regulatory Guide 1.74 in this Appendix.

Since Ameren Missouri sometimes uses descriptive names to designate equipment, the sixth paragraph, second sentence is replaced with:

"Suitable means include identification numbers or other descriptions which are traceable to records of the status of inspections and tests."

The first sentence in the seventh paragraph shall be met after clarifying "operating personnel" to mean trained employees assigned to, or under the control of, Plant management at Callaway.

With regard to Section 5.2.7 of ANSI N18.7 - 1976 titled Maintenance and Modification: Ameren Missouri shall interpret the word "original" in the first sentence of this Section to modify ONLY the words "design bases." This interpretation is to assure that original inspection requirements are not imposed, without appropriate review, on modifications or maintenance activities which are similar in nature to original construction activities. In developing means to assure the quality of maintenance or modification activity, inspection requirements from associated construction activities shall be considered. Operational inspection requirements shall assure quality at least equivalent to the original quality.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

Since some emergency situations could arise which might preclude preplanning of all activities, Ameren Missouri shall comply with an alternate to the first sentence in the second paragraph which reads:

"Except in emergency or abnormal operating conditions where immediate actions are required to protect the health and safety of the public, to protect equipment or personnel, or to prevent the deterioration of Plant conditions to a possibly unsafe or unstable level, maintenance or modification of equipment shall be preplanned and performed in accordance with written procedures. Where written procedures would be required and are not used, the activities that were accomplished shall be documented after-the-fact and receive the same degree of review as if they had been preplanned."

With regard to Section 5.2.7.1 of ANSI N18.7 - 1976 titled Maintenance Programs: Ameren Missouri shall comply with the requirements of the first sentence of the fifth paragraph, where practical. This clarification is needed since it is not always possible to promptly determine the cause of the malfunction. Ameren Missouri shall initiate proceedings to determine the cause, and shall make such determinations promptly, where practical. NOS is involved via both audits and surveillances, and QC is involved in inspection of maintenance inspection activities. Ameren Missouri shall comply with the commitment to Regulatory Guide 1.160 (10 CFR50.65) as described in FSAR Appendix 3A.


With regard to Section 5.2.8 of ANSI N18.7 - 1976 titled Surveillance Testing and Inspection Schedule: In lieu of a "master surveillance schedule," the following requirement shall be met: "Schedules shall be established reflecting the status of in-plant surveillance tests and scheduled inspections."

With regard to Section 5.2.9 of ANSI N18.7 - 1976 titled Plant Security and Visitor Control: The requirements of the Security Plan shall be implemented in lieu of these general requirements. When compliance with an NRC accepted program (e.g., Callaway Security Plan) is referenced, Ameren Missouri has substituted the NRC accepted program for applicable regulatory requirements in lieu of the general requirements of the Quality Assurance program standards.

With regard to Section 5.2.10 of ANSI N18.7 - 1976 titled Housekeeping and Cleanliness Control: The requirements of this Section, beginning with the last sentence of the first paragraph and continuing through the end of the Section, shall be implemented as described in Ameren Missouri's commitments to Regulatory Guide 1.39 (ANSI N45.2.3) and Regulatory Guide 1.37 (ANSI N45.2.1) as set forth in this Appendix. In every case either identical or equivalent controls are provided in the Sections of the reference standards or documents.

With regard to Section 5.2.13.1 of ANSI N18.7 - 1976 titled Procurement Document Control: Ameren Missouri shall comply with the following sentences in lieu of the last sentence of the referenced Section.

"When procuring commercial-grade items (products or services), the procurement documents are not required to impose a quality assurance program consistent with ANSI N45.2. Alternative requirements described in Ameren Missouri's commitment to Regulatory Guide 1.123 as set forth in this Appendix may be implemented in lieu of imposing a quality assurance program consistent with ANSI N45.2. Where changes are made to the technical or quality requirements on procurement documents, they shall be subject to an equivalent level of review and approval as the original document by the originating organization."

 <p>CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL</p>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

With regard to Section 5.2.15 of ANSI N18.7-1976 titled Review, Approval and Control of Procedures; in lieu of the wording starting with the second sentence in the third paragraph of this section beginning with "The frequency of ...," through the end of the fourth paragraph, which ends "... a procedure review.", Ameren Missouri provides the following alternative guidance:

"Procedures shall be revised as necessary. These revisions will generally be initiated through reviews conducted by knowledgeable personnel during routine performance of activities. Examples of such reviews include evaluations of problems encountered during performance of a procedure, evaluation of corrective actions for self-identified deficiencies or events, evaluation of events occurring at other plants, evaluation of procedure changes necessary to implement modifications, evaluation of procedure changes necessary to implement License, Technical Specification, FSAR or OQAM revisions as well as evaluations of changes necessary to resolve Regulatory Issues. Such changes shall be implemented as necessary. In some situations such implementation will be completed prior to completion of the in-process activity. Guidance on the need to revise procedures shall be provided in plant administrative controls."

With regard to Section 5.2.17 of ANSI N18.7 - 1976 titled Inspection: The third paragraph is replaced with the following:

Inspections for modifications and nonroutine maintenance shall be conducted as indicated in our reference to Section 5.2.7 of this standard.

The following is a clarification to the sixth paragraph:

Inspections may not require generation of a separate inspection report. Inspection requirements may be integrated into appropriate procedures or other documents with the procedure or document serving as the record. However, records of inspections shall be identifiable and retrievable.


With regard to Section 5.2.18 of ANSI N18.7 - 1976 titled Control of Special Processes: Ameren Missouri shall comply with the following sentence in lieu of the last sentence of the referenced Section:

For special processes not covered by existing codes or standards, or where item quality requirements exceed the requirements of established codes or standards, personnel, equipment and procedure qualification shall be defined by engineering.

With regard to Section 5.3.5(4) of ANSI N18.7 - 1976 titled Supporting Maintenance Documents: Ameren Missouri may choose to include material from vendor manuals in any of three ways.

- (1) The applicable section of a manual may be duplicated, referenced in, and attached to the procedure.
- (2) The procedure may reference the technical manual or a specific section; the manual may then be used in conjunction with the procedure for performing the activity.
- (3) The material, either as originally written or as modified by the procedure's author, may be reproduced within the body of the procedure.

In options (1) and (2) above, the material shall be considered as having received "the same level of review and approval as operating procedures" by virtue of the review and approval of the maintenance procedure. In option (2), the manual shall be available when the procedure is being considered for approval. In option (3), this material receives the same review and approval as the procedure since it is part of the procedure. In any of the options, Ameren Missouri is NOT reviewing and

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

accepting the entire manual. Ameren Missouri reviews and accepts that portion of each vendor manual that is used by Ameren Missouri.

With regard to Section 5.3.9 of ANSI N18.7 - 1976 titled Emergency Procedures: Ameren Missouri's Emergency Procedures are in the format specified by the NRC in the Callaway Safety Evaluation Report, as required for issuance of the Operating License, in lieu of the requirements given here.

With regard to Section 5.3.9.2 of ANSI N18.7 - 1976 titled Events of Potential Emergency: The licensing FSAR identified natural occurrences which affect the Callaway Plant. Therefore, Ameren Missouri shall interpret item (11) to mean the natural occurrences which were evaluated in the licensing FSAR.

With regard to Section 5.3.9.3 of ANSI N18.7 - 1976 titled Procedures for Implementing Emergency Plan: Ameren Missouri's NRC accepted Emergency Plan shall be implemented in lieu of the requirements in this Section. When compliance with an NRC accepted program (e.g., Callaway Plant Radiological Emergency Response Plan) is referenced, Ameren Missouri has substituted the NRC accepted program for applicable regulatory requirements in lieu of the general requirements of the Quality Assurance Program standards.

REGULATORY GUIDE 1.37

INITIAL ISSUE

DATED 3/73

Quality Assurance Requirements for Cleaning of Fluid Systems and Associated Components of Water-Cooled Nuclear Power Plants (Endorses ANSI N45.2.1-1973)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:


For maintenance and modification activities Ameren Missouri shall comply with the Regulatory Position established in this Regulatory Guide in that QA programmatic/administrative requirements included therein (subject to the clarifications below) shall apply to these maintenance and modification activities even though such requirements may not have been in effect originally. Technical requirements associated with maintenance and modifications shall be equal to or better than the original requirements (e.g., code requirements, material properties, design margins, manufacturing processes, and inspection requirements), or as required to preclude repetition of defects.

The Regulatory Position established in the Regulatory Guide does not apply to establishment of specifications or controls on the quality of the operating system water, or on additives to operating system water.

Specific clarifications for this Regulatory Guide and ANSI N45.2.1 - 1973 are indicated below by Sections.

With regard to Paragraph C.3 of Regulatory Guide 1.37: The water quality for final flushing of fluid systems and associated components shall be at least equivalent to the quality of the operating system water except for the oxygen and nitrogen content; but this does not infer that chromates or other additives, normally in the system water, are added to the flush water.

With regard to Paragraph C.4 of Regulatory Guide 1.37: Expendable materials, such as inks and related products; temperature indicating sticks; tapes; gummed labels; wrapping materials (other than polyethylene); water soluble dam materials; lubricants; NDT penetrant materials and couplants, desiccants, which contact stainless steel or nickel alloy surfaces shall not contain lead, zinc, copper, mercury, cadmium and other low melting points metals, their alloys or

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

compounds as basic and essential chemical constituents. No more than 0.1 percent (1,000 ppm) halogens shall be allowed where such elements are leachable or where they could be released by breakdown of the compounds under expected environmental conditions, except as provided for in approved design documents. No more than 1000 ppm sulfur shall be allowed where such elements are leachable or where they could be released by breakdown of the compounds under expected environmental conditions, except as provided for in approved design documents.

With regard to Section 5 of ANSI N45.2.1 - 1973 titled Installation Cleaning: The recommendation that local rusting on corrosion resistant alloys be removed by mechanical methods is interpreted to mean that local rusting may be removed mechanically, but the use of other removal means is not precluded, as determined by engineering or Chemistry. Engineering actions performed in accordance with this Section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

REGULATORY GUIDE 1.38

REVISION 2

DATED 5/77

Quality Assurance Requirements for Packaging, Shipping, Receiving, Storage, and Handling of Items for Water-Cooled Nuclear Power Plants (Endorses ANSI N45.2.2-1972)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:


With regard to Section 1.4 of ANSI N45.2.2 - 1972 titled Definitions: Definitions in this Standard which are not included in ANSI N45.2.10 shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74.

With regard to Section 2.1 of ANSI N45.2.2 - 1972 titled Planning: (First sentence) The specific items to be governed by the Standard shall be identified in Callaway-SP FSAR Table 3.2-1, which lists those structures, systems and components to which the Ameren Missouri QA Program is applied.

With regard to Section 2.3 of ANSI N45.2.2 - 1972 titled Results: The specific methods for performing and documenting tests and inspections are given in OQAM Sections 10 and 11. The requirements in these Sections shall be implemented in lieu of the general requirements here. In every case either identical or equivalent controls are provided in the sections of the referenced Standards or documents.

With regard to Section 2.4 of ANSI N45.2.2 - 1972 titled Personnel Qualifications: Specific requirements for personnel qualifications are set forth in the OQAM description and in the commitments in this Appendix. These requirements shall be implemented in lieu of the general requirements stated in this Section. In every case either identical or equivalent controls are provided in the sections of the referenced Standards or document.

With regard to Section 2.7 of ANSI N45.2.2 - 1972 titled Classification of Items: Ameren Missouri may choose not to explicitly use the four level classification system. However, the specific requirements of the Standard that are appropriate to each class are generally applied to the items suggested in each classification and to similar items, as determined by engineering. Engineering actions performed in accordance with this section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

With regard to Section 3.2.1 of ANSI N45.2.2 - 1972 titled Level A Items: As an alternate to the requirements for packaging and containerizing items in storage to control contaminants (Items (4) and (5)), Ameren Missouri may choose a storage atmosphere which is free of harmful contaminants in concentrations that could produce damage to stored items, as determined by engineering. Similarly (for Item (7)) Ameren Missouri may obviate the need for caps and plugs, as determined by engineering, with an appropriate storage atmosphere, and may choose to protect weld-end preparations and threads by controlling the manner in which the items are stored. These clarifications apply whenever items (4), (5) or (7) are subsequently referenced and to Section 3.5.1 titled Caps and Plugs and Section 3.4 titled Methods of Prevention. Engineering actions performed in accordance with this section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

With regard to Section 3.3 of ANSI N45.2.2 - 1972 titled Cleaning: (Third sentence) Ameren Missouri interprets "documented cleaning methods" to allow generic cleaning procedures to be written which shall be implemented, as necessary, by trained personnel. Each particular cleaning operation shall be either governed by an individual cleaning procedure or by a generic procedure either of which shall specify method(s) of cleaning or type(s) of solvent(s) that may be used in a particular application.

With regard to Section 3.4 of ANSI N45.2.2 - 1972 titled Methods of Preservation: (First sentence) Ameren Missouri shall comply with these requirements subject to the clarifications of Section 3.2.1 (4) and (5) above, and the definition of the phrase "deleterious corrosion" to mean that corrosion which cannot be subsequently removed and which adversely affects form, fit, or function.


With regard to Section 3.6 of ANSI N45.2.2 - 1972 titled Barrier and Wrap Material and Desiccants: This Section requires the use of nonhalogenated materials in contact with austenitic stainless steel. Refer to Regulatory Guide 1.37 for the Ameren Missouri position.

With regard to Section 3.7.1 of ANSI N45.2.2 - 1972 titled Containers: Cleated, sheathed boxes may be used up to 1000 lbs. rather than 500 lbs. as specified in 3.7.1(1). This type of box is safe for, and has been tested for, loads up to 1000 lbs. Other national standards allow this (see Federal Specification PPP-B-601). Special qualification testing shall be required for loads above 1000 lbs.

With regard to Section 3.7.2 of ANSI 45.2.2 - 1972 titled Crates and Skids: Crates shall be used for equipment in excess of 1000 lb. in weight. Skids or runners shall be used on boxes with a gross weight of approximately 100 lb. or more, allowing sufficient floor clearance for forklift tines (as nominally provided by 4 inch lumber).

With regard to Section 4.2.2 of ANSI N45.2.2 - 1972 titled Closed Carriers: The use of fully enclosed furniture vans, as recommended in (2) of this Section, is not considered a requirement. Stated for information only, Ameren Missouri shall assure adequate protection from weather or other environmental conditions by a combination of vehicle enclosure and item packaging.

With regard to Section 5.2.1 of ANSI N45.2.2 - 1972 titled Shipping Damage Inspection: Stores personnel shall normally visually scrutinize incoming shipments for damage of the types listed in this Section; this activity is not necessarily

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

performed prior to unloading. Since required items receive the Item Inspection of Section 5.2.2, separate documentation of the Shipping Damage Inspection is not necessary. Release of the transport agent after unloading and the signing for receipt of the shipment may be all of the only action taken to document completion of the Shipping Damage Inspection. Any nonconformance noted shall be documented and dispositioned as required by OQAM Section 15. The person performing the visual scrutiny during unloading is not considered to be performing an inspection function as defined under Regulatory Guide 1.74; therefore, while this person shall be trained to perform this function, this person may not necessarily be certified to Regulatory Guide 1.58 (ANSI N45.2.6) as an Inspector.

With regard to Section 5.2.2 of ANSI N45.2.2 - 1972 titled Item Inspection: The second division of this subsection requires six additional inspection activities if an item was not inspected or examined at the source. Engineering shall determine and document the extent of receipt inspection based on consideration of items in Section 5.2.2. Engineering actions performed in accordance with this section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

With regard to Section 6.1.2 of ANSI N45.2.2 - 1972 titled Levels of Storage: Subpart (2) is replaced with the following:


- (2) Level B items shall be stored within a fire resistant, weathertight, and well ventilated building or equivalent enclosure in which measures have been taken against vandalism. This building shall be situated and constructed so that it is not normally be subject to flooding; the floor shall be paved or equal, and well drained. If any outside waters should come in contact with stored equipment, such equipment shall be labeled or tagged nonconforming, and then the nonconformance document shall be processed and evaluated in accordance with OQAM Section 15. Items shall be placed on pallets or shoring or shelves to permit air circulation. The building shall be provided with heating and temperature control or its equivalent to reduce condensation and corrosion. Minimum temperature shall be 40° F and maximum temperature shall be 140° F or less if so stipulated by a manufacturer.

With regard to Section 6.2.1 of ANSI N45.2.2 - 1972 titled Access to Storage Areas: Items which fall within the Level D classification of the standard shall be stored in an area which may be posted to limit access, but other positive controls such as fencing or guards shall not normally be provided, with engineering's concurrence. Engineering actions performed in accordance with this section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

With regard to Section 6.2.4 of ANSI N45.2.2 - 1972 titled Storage of Food and Associated Items: The sentence is replaced with the following:

"The use or storage of food, drinks, and salt tablet dispensers in any storage area shall be controlled and shall be limited to designated areas where such use or storage is not deleterious to stored items, with engineering's concurrence."

Engineering actions performed in accordance with this section of the Standard are conducted with NOS/QC involvement and are subject to NOS audit. Procedures for these activities receive a cross-disciplinary review as well as review by the Onsite Review Committee. For other activities, NOS audits and surveillances, and QC inspection activities assure NOS/QC involvement.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

With regard to Section 6.2.5 of ANSI N45.2.2 - 1972 titled Measures to Prevent Entrance of Animals: The sentence is replaced with the following:

"Exterminators or other appropriate measures shall be used to control animals to minimize possible contamination and mechanical damage to stored material."

With regard to Section 6.3.3 of ANSI N45.2.2 - 1972 titled Storage of Hazardous Materials: The sentence is replaced with the following:

"Hazardous chemicals, paints, solvents, and other materials of a like nature shall be stored in approved cabinets or containers which are not in close proximity to installed safety-related systems."

The placement of hazardous material storage lockers in the Plant is based upon installed safety-related systems, not particular components.


With regard to Section 6.4.2 of ANSI N45.2.2 - 1972 titled Care of Items: The following alternates are provided for the indicated subparts:

- (5) "Space heaters in electrical equipment shall be energized unless a documented engineering evaluation determines that such space heaters are not required."
- (6) "Large (greater than or equal to 50 HP) rotating electrical equipment shall be given insulation resistance tests on a scheduled basis unless a documented engineering evaluation determines that such tests are not required."
- (7) "Prior to being placed in storage, large (greater than or equal to 50 HP or when designed to be used with a prime mover of greater than or equal to 50 HP) horizontal rotating equipment shall be evaluated by engineering to determine if shaft rotation in storage is required: the results of the evaluation shall be documented. If rotation is required, it shall be performed at specified intervals, be documented, and be conducted so that parts receive a coating of lubrication where applicable and so that the shaft does not come to rest in the same position occupied prior to rotation. For long shafts or heavy equipment subject to undesirable bowing, shaft orientation after rotation shall be specified and obtained."
- (8) Maintenance requirements specified by the manufacturer's instructions are addressed in this OQAM, Section 13.3.

With regard to Section 6.5 of ANSI N45.2.2 - 1972 titled Removal of Items from Storage: Ameren Missouri does not consider the last sentence of this Section to be applicable to the Operating Phase due to the relatively short period of time between installation and use. The first sentence of the Section is replaced with:

"Ameren Missouri shall develop, issue, and implement a procedure(s) which cover(s) the removal of items from storage. The procedure(s) shall assure that the status of material issued is known, controlled, and appropriately dispositioned."

With regard to Section 7.4.2, a subsection to Section 7.4 of ANSI N45.2.2-1972 titled Inspection of Equipment and Rigging: Stated for information only, it is Ameren Missouri's position that this relates to the operability of the hoisting equipment and does not preclude re-rating as allowed by Section 7.3.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

REGULATORY GUIDE 1.39

REVISION 2

DATED 9/77

Housekeeping Requirements for Water-Cooled Nuclear Power Plants (Endorses ANSI N45.2.3-1973)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

For maintenance and modification activities Ameren Missouri shall comply with the Regulatory Position established in this Regulatory Guide in that QA programmatic/administrative requirements included therein (subject to the clarifications below) shall apply to these maintenance and modification activities even though such requirements may not have been in effect originally. Technical requirements associated with the maintenance or modification shall be equal to or better than the original requirements (e.g., code requirements, material properties, design margins, manufacturing processes, and inspection requirements), or as required to preclude repetition of defects.

Specific clarifications for ANSI N45.2.3 - 1973 are indicated below by Sections.

Section 1.4 - Definitions: Definitions in this Standard which are not included in Regulatory Guide 1.74 (ANSI N45.2.10) shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74.

Section 2.1 - Planning: Ameren Missouri may choose not to utilize the five-level zone designation system, but shall utilize standard janitorial and work practices to maintain a level of cleanliness commensurate with Program requirements in the areas of housekeeping, Plant and personnel safety, and fire protection.

Cleanliness shall be maintained, consistent with the work being performed, so as to prevent the entry of foreign material into safety-related systems. This shall include, as a minimum, documented cleanliness inspections which shall be performed prior to system closure. As necessary, (e.g. the opening is larger than the tools being used) control of personnel, tools, equipment, and supplies shall be established when the reactor system is opened for inspection, maintenance, refueling, modification or repair.


Additional housekeeping requirements shall be implemented as required for control of radioactive contamination.

Section 3.2 - Control of Facilities: Ameren Missouri may choose not to utilize the five-level zone designation system, but shall utilize standard janitorial and work practices to maintain a level of cleanliness commensurate with Program requirements in the areas of housekeeping, Plant and personnel safety, and fire protection.

Cleanliness shall be maintained, consistent with the work being performed, so as to prevent the entry of foreign material into safety-related systems. This shall include, as a minimum, documented cleanliness inspections which shall be performed prior to system closure. As necessary, (e.g. the opening is larger than the tools being used) control of personnel, tools, equipment, and supplies shall be established when the reactor system is opened for inspection, maintenance, modification, refueling or repair.

Additional housekeeping requirements shall be implemented as required for control of radioactive contamination.

Section 4 - Records: The requirements of OQAM Section 17 and Regulatory Guide 1.88 (ANSI N45.2.9) as set forth in this Appendix shall be implemented in lieu of the requirements of the Section. In every case either identical or equivalent controls are provided in the sections of the referenced Standards or documents.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

REGULATORY GUIDE 1.58

REVISION 1

DATED 9/80

Qualification of Nuclear Power Plant Inspection, Examination, and Testing Personnel (Endorses ANSI N45.2.6-1978)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:


The qualification of Ameren Missouri QC or contracted QC personnel performing work at the Plant shall be in accordance with Regulatory Guide 1.58 (ANSI N45.2.6-1978). Other personnel performing inspection, examination, and testing activities shall have appropriate experience, training, and retraining to assure competence in accordance with Regulatory Guide 1.8 (ANSI/ANS 3.1-1978). This position is consistent with Regulatory Guide 1.33 (ANSI N18.7-1976/ANS-3.2, Section 3.4.2).

In instances where the education and experience recommendations of ANSI N45.2.6-1978 are not met by QC personnel, Ameren Missouri shall demonstrate by documented results of written examinations and evaluations of actual work proficiency that these individuals possess comparable or equivalent competence. Persons performing Nondestructive Examinations (NDE) as may be required by Section III or XI of the ASME B&PV Code shall be qualified and certified as required by the Edition and Addenda of the Code to which Ameren Missouri is committed at the time the NDE is performed. However, when qualifying personnel to perform visual examinations in accordance with IWA-2300 of Section XI, Division 1, ANSI/ASME N45.2.6-1978 may be used instead of ANSI N45.2.6-1973 (Code Case N-424). Persons certified to perform NDE for Code work shall also be considered as qualified to perform non-Code NDE (e.g. crane hook inspection) unless more rigorous qualification or certification requirements are imposed by Ameren Missouri's commitments or government regulations.

With regard to Section 1.2 of ANSI N45.2.6 -1978 titled Applicability: The third paragraph requires that the Standard be used in conjunction with ANSI N45.2; Ameren Missouri no longer specifically commits to ANSI N45.2 in the Operating QA Manual. The fourth paragraph requires that the Standard be imposed on personnel other than Ameren employees; the applicability of the Standard to suppliers shall be documented and applied, as appropriate, in the procurement documents for such suppliers.

With regard to Section 1.4 of ANSI N45.2.6 - 1978 titled Definitions: Definitions in this Standard which are not included in Regulatory Guide 1.74 (ANSI N45.2.10) shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74.

With regard to Section 2.5 of ANSI N45.2.6 - 1978 titled Physical: Ameren Missouri shall implement the requirements of this Section with the stipulation that, where no special physical characteristics are required, none shall be specified. The converse is also true: if no special physical requirements are stipulated by Ameren Missouri, none shall be considered necessary.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

REGULATORY GUIDE 1.64 REVISION 2 DATED 6/76

Quality Assurance Requirements for the Design of Nuclear Power Plants (Endorses ANSI N45.2.11-1974)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

When uniqueness or special design considerations warrant or are judged to be appropriate, an independent third-level review may be employed.

With regard to Paragraph C.2(1) of Regulatory Guide 1.64: If the designer's immediate Supervisor is the only technically qualified individual available, this review may be conducted by the Supervisor, provided that:

- (a) the other provisions of the Regulatory Guide are satisfied, and
- (b) the justification is individually documented and approved in advance by the Supervisor's management, and
- (c) nuclear oversight audits cover frequency and effectiveness of use of the Supervisors as design verifiers to guard against abuse.

With regard to Section 1.4 of ANSI N45.2.11 - 1974 titled Definitions: Definitions in this Standard which are not included in Regulatory Guide 1.74 (ANSI N45.2.10) shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in this Appendix.

With regard to the 4th paragraph of subsection 2.1 and subsection 2.2.12, under Program Requirements, and Section 11 (including subsections 11.1 through 11.7) of ANSI N45.2.11 - 1974, titled Audits: Ameren Missouri's audit program shall be implemented in accordance with and to meet the requirements of Regulatory Guide 1.144 (ANSI N45.2.12) as endorsed in this Appendix, and OQAM Sections 16 and 18. In every case either identical or equivalent controls are provided in the sections of the referenced Standards or documents.

With regard to Section 6 of ANSI N45.2.11-1974 titled Design Verification, the formal design verification process applies to design changes.

REGULATORY GUIDE 1.74

INITIAL ISSUE

DATED 2/74


Quality Assurance Terms and Definitions (Endorses ANSI N45.2.10-1973)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications.

Ameren Missouri reserves the right to define additional words or phrases which are not included in this Standard. Such additional definitions shall be documented in appropriate procedures or in Sections of the Operating QA Manual.

In addition to the Standard's definition of "Inspection," Ameren Missouri shall use the following: "Inspection (when used to refer to activities that are NOT performed by NOS or QC personnel) - Examining, viewing closely, scrutinizing, looking over or otherwise checking activities. Personnel performing these functions are not necessarily certified to Regulatory Guide 1.58 (ANSI N45.2.6)." These activities are controlled by the Callaway Plant Operating Procedures.

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

When Ameren Missouri intends for Inspection to be performed in accordance with the Operating QA Program by personnel certified as required by that Program and for activities defined by "Inspection" in ANSI N45.2.10, appropriate references to QC group or the procedures to be used for performing the activity shall be made. If such references are NOT made, inspections are to be considered under the additional definition given above.

In addition to the Standard's definition of "procurement documents," Ameren Missouri shall utilize the definition given in ANSI N45.2.13. The compound definition is given as follows: Procurement documents - Contractually binding documents that identify and define the requirements which items or services must meet in order to be considered acceptable by the purchaser. They may include documents which authorize the seller to perform services or supply equipment, material or facilities on behalf of the purchaser (e.g. Engineering Service Agreement agreements for engineering, construction, or consulting services), contracts, letters of intent, purchase requisitions, purchase orders, or proposals and their acceptance, drawings, specifications, or instruction which define requirements for purchase.

"Bids" - Supplier quotation submitted in response to specified technical and quality requirements for which price and delivery are primary considerations.


"Proposals" - Supplier offerings that define the scope of supply as well as specific technical and quality requirements for a product or service. Such offerings usually require negotiation prior to acceptance as either a purchase order, contract, or Engineering Service Agreement.

"Program Deficiencies" (Not defined in ANSI N45.2.10, but used and defined differently in Regulatory Guide 1.144 (ANSI N45.2.12)) - Failure to develop, document or implement effectively any applicable element of the Operating QA Program.

"Quality Assurance Program Requirements" (Not defined in ANSI N45.2.10 but used and defined differently in ANSI N45.2.13) - Those individual requirements of the Operating QA Program which, when invoked in total or in part, establish the requirements of the quality assurance program for the activity being controlled. Although not specifically used in the Operating QA Program, ANSI N45.2 may be imposed upon Ameren Missouri's suppliers.

"Independent Verification" - Verification by an individual other than the person who performed the operation or activity being verified that required actions have been completed. Such verification need not require confirmation of the identical action when other indications provide assurance or indication that the prescribed activity is in fact complete. Examples include, but are not limited to: verification of a breaker opening by observed remote breaker indication lights; verification of a set point (made with a voltmeter or ammeter for example) by observing the actuation of status or indicating lights at the required Panel-meter indicated value; verification that a valve has been positioned by observing the starting or stopping of flow on meter indications or by remote valve positions indicating lights.

"Audit" (This is a modification of the word's definition - to allow the use of subjective evidence if no evidence is available - as defined in Section 1.4 of ANSI N45.2.12 - 1977 (Regulatory Guide 1.144) and Section 1.4.3 of ANSI N45.2.23 - 1978 (Regulatory Guide 1.146) as opposed to the definition given in ANSI N45.2.10 - 1973) - A documented activity performed in accordance with written procedures or checklists to verify, by examination and evaluation of objective evidence where available, (subjective evidence may be used when objective evidence is not available), that applicable elements of the Quality Assurance Program have been developed, documented and effectively implemented in accordance with specified requirements. An audit should not be confused with surveillance or inspection for the sole purpose of process control or product acceptance.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

"Must" - (Not defined in any ANSI Standard) - An internally auditable requirement imposed by Ameren Missouri management upon its employees, contractors, and agents - above and in excess of the legally binding requirements of the appropriate regulatory body. Such items are internally required but not externally enforceable. (See additional discussion under Section 2.14 of the OQAM.)

"Unit staff" - (Not defined in any ANSI standard) - Means those personnel who report to the Senior Director, Nuclear Operations. This term shall also be synonymous with the "onsite operating organization" described (but not defined) in ANSI N18.7-1976, Section 3.4.2; the "unit staff" as used in the OQAM and in Callaway Plant Technical Specifications Section 5.2 and its subparts; including "operating staff" and "unit organization" as described in the Callaway Plant Technical Specifications Section 5.2.1 and 5.2.2, respectively; and personnel having "line responsibility for operation of the unit" as used in the OQAM.

"Like kind replacements" - (Not defined in any ANSI standard) - Like kind replacements include both exact item replacements and other item replacements which are not "exact" but meet the original design requirements.

REGULATORY GUIDE 1.88

REVISION 2

DATED 10/76

Collection, Storage, and Maintenance of Nuclear Power Plant Quality Assurance Records (Endorses ANSI N45.2.9-1974)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

With regard to Section 3.2.1 of ANSI N45.2.9 - 1974 titled Generation of Quality Assurance Records: The phrase "completely filled out" is clarified to mean that sufficient information is recorded to fulfill the intended purpose of the record. It is the information, not the form, that is the record. Thus the information, not the form, needs to be complete to furnish documented "evidence of activities affecting quality".


With regard to Section 3.2.2 of ANSI N45.2.9 - 1974 titled Index: The phrase "an index" is clarified to mean a collection of documents or indices which, when taken together, supply the information attributed to "an index" in the Standard.

The specific location of a record "within a storage area" may not be delineated. (e.g. The specific location within a computer record file may not be constant. Further, Ameren Missouri may utilize a computer assisted random access filing system where such location could not be readily "documented," or would such a location be "relevant.") The storage location shall be delineated, but where file locations change with time, the specific location of a record within that file may not always be documented.

With regard to Section 4.2 of ANSI N45.2.9 - 1974 titled Timeliness: Ameren Missouri's contractual agreement with its contractors and suppliers shall constitute fulfillment of the requirements of this Section.

With regard to Section 5.3.3 of ANSI N45.2.9-1974: The phrase "A method for verifying that the records received are in agreement with the transmittal document . . .", is clarified to mean that internal Callaway Plant generated records received are in agreement with procedural guidelines contained in Callaway Plant Administrative procedures. If a transmittal does exist (e.g. on supplier-generated documents, etc.), the records received will be verified against the transmittal document.

The following clarification is substituted for the current subsection 5.4.3: "Provisions shall be made for special processed records (such as radiographs, photographs, negatives, microfilm and magnetic media) to prevent damage from excessive

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

light, stacking, electromagnetic fields, temperature and humidity as appropriate to the records type." Consideration shall be given to manufacturer's recommendation.

With regard to Section 5.5 of ANSI N45.2.9 - 1974 titled Safekeeping: Routine General Offices and Plant site security systems and access controls shall be provided: no special security systems are required to be established for record storage areas.

With regard to Section 5.6 of ANSI N45.2.9 - 1974 titled Facility: This Section provides no distinction between temporary and permanent facilities. To cover temporary storage, the following clarification is added: "Active records (those completed but not yet duplicated or placed on microfilm) may be temporarily stored in one-hour fire rated file cabinets. In general, records shall not be maintained in such temporary storage for more than three months after completion without being duplicated (for dual storage),-being placed on microfilm or optical disk. Open-ended documents --those revised or updated on a more-or-less continuing basis over an extended period of time (e.g. personnel qualification and training documents, equipment history cards, master audit or master surveillance schedules) and those which are cumulative in nature (e.g. nonconforming item logs and control room log books)-- are not considered as QA records since they are not "complete." These types of documents shall become QA records when they are issued as a specific revision (e.g., the master audit schedule); when they are filled-up or discontinued (e.g. log books or equipment history cards); on a predefined periodic basis when the completed portion of the on-going document shall be transferred to document control as a "record" (e.g. training and qualification records).

Paragraph 4, subsection 3 is clarified to require a two-hour minimum fire rating to be consistent with the 1979 version of the Standard and NRC Criteria for Records Storage Facilities (Guidance-ANSI N45.2.9, Section 5.6) issued 7/1/80.

Paragraph 4, subsection 9 is clarified to read:


"No pipes or penetrations except those providing fire protection, lighting, temperature/ humidity control, or communications are to be located within the facility and they shall comply with a minimum two-hour fire protection rating."

Where duplicate storage is employed, no special precautions or provisions (including vault storage, special humidity and temperature recorders and similar items) are required.

Paragraph 5 is clarified to read the same as our commitment to subsection 5.4.3. Both paragraphs address the same requirement and therefore the commitment must be the same.

With regard to Section 5.7 of ANSI N45.2.9-1974 titled Audits: These specific activities in sub-sections 1, 2 and 3 are accomplished through the establishment of administrative controls by the responsible management.

Audits of these administrative controls are performed in accordance with this OQAM, Section 18 and commitments to Reg. Guide 1.144 in this Appendix.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

REGULATORY GUIDE 1.94

REVISION 1

DATED 4/76

Quality Assurance Requirements for Installation, Inspection and Testing of Structural Concrete and Structural Steel during the Construction Phase of Nuclear Power Plants. (Endorses ANSI N45.2.5-1974)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

For modification activities Ameren Missouri shall comply with the Regulatory Position established in this Regulatory Guide in that QA programmatic/administrative requirements included therein (subject to the clarifications below) shall apply to these modification activities even though such requirements may not have been in effect originally. Technical requirements associated with modifications shall be equal to or better than the original requirements (e.g., code requirements, material properties, design margins, manufacturing processes, and inspection requirements), or as required to preclude repetition of defects. The recommendations for structural concrete, structural steel, and other Plant components shall be met as indicated by the applicable design documents with the following exceptions:

With regard to Section 2.4 of ANSI N45.2.5-1974 titled Personnel Qualification: Ameren Missouri will comply with Regulatory Guide 1.58 as endorsed in this OQAM in lieu of the requirements of this standard.

In regard to Section 2.5.2 of ANSI N45.2.5-1974 titled Calibration and Control: The last sentence is clarified as follows: "Ameren Missouri's inspection or test results conducted with M&TE found to be discrepant are to be evaluated as described in the OQAM, Section 12.8."

With regard to Section 5.4 of ANSI N45.2.5-1974 titled High Strength Bolting: In lieu of the first two sentences in the first paragraph, Ameren Missouri will comply with the following:

"Bolts for friction type connections may be tightened using direct tension indicators in accordance with the AISC Specification for Structural Joints Using ASTM A325 or A490 Bolts, approved May 8, 1974."

In lieu of (1) in the second paragraph, Ameren Missouri will comply with the following:

"The requirement for the acceptance of tightened bolt assemblies is, the length of the bolts shall be such that the point of the bolt shall be flush with or outside of the face of the nut when completely installed."

REGULATORY GUIDE 1.116

REVISION 0-R


DATED 5/77

Quality Assurance Requirements for Installation, Inspection, and Testing of Mechanical Equipment and Systems (Endorses ANSI N45.2.8-1975)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

For maintenance and modification activities Ameren Missouri shall comply with the Regulatory Position established in this Regulatory Guide in that QA programmatic/administrative requirements included therein shall apply to these maintenance and modification activities even though such requirements may not have been in effect originally. Technical requirements associated with maintenance and modifications shall be equal to or better than the original requirements (e.g., code

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

requirements, material properties, design margins, manufacturing processes, and inspection requirements), or as required to preclude repetition of defects.

With regard to Section 2.7 of ANSI N45.2.8 - 1975 titled Personnel Qualifications: Personnel performing inspection and testing activities, shall be qualified consistent with the qualification requirements of OQAM Section 10 and, as endorsed in this Appendix, Regulatory Guide 1.58 [ANSI N45.2.6-1978] and Regulatory Guide 1.8 [ANSI/ANS 3.1-1978].

REGULATORY GUIDE 1.123

REVISION 1

DATED 7/77

Quality Assurance Requirements for Control of Procurement of Items and Services for Nuclear Power Plants (Endorses ANSI N45.2.13-1976)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

With regard to Section 1.3 of ANSI N45.2.13 - 1976 titled Definitions: With two exceptions (Procurement Document and Quality Assurance Program Requirements) definitions in this Standard which are not included in Regulatory Guide 1.74 (ANSI N45.2.10) shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74. The two exceptions are defined in this Appendix under Regulatory Guide 1.74.

With regard to Section 1.2.2 of ANSI N45.2.13 - 1976 titled Purchaser's Responsibilities: Item C is one of the options which may be used by Ameren Missouri to assure quality; however, any of the options given in 10 CFR 50, Appendix B, Criterion VII as implemented by OQAM Sections 4 and 7 may also be used.


With regard to Section 3.1 of ANSI N45.2.13 - 1976 titled Procurement Document Preparation, Review and Change Control: The phrase "the same degree of control" is stipulated to mean "equivalent level of review and approval." The changed document may not always be re-reviewed by the originator; however, at least an equivalent level of supervision shall review and approve any changes.

With regard to Section 3.2.3 of ANSI N45.2.13 - 1976 titled Quality Assurance Program Requirements, the requirements of the Section are accepted with the following exceptions:

"As defined in 10CFR21.3, basic components include: safety related structures, systems, components or parts thereof; and also include safety-related design, analysis, inspection, testing, fabrication, replacement of parts, or consulting services that are associated with the component hardware whether these services are performed by the component supplier or others.

Procurement documents for basic components are not required to impose a quality assurance program consistent with ANSI N45.2, provided that all the following are met:

1. The basic components meet the definition of commercial grade item in 10CFR21.3.
2. The basic components are dedicated by the Purchaser in accordance with the Purchaser's 10CFR50 Appendix B quality assurance program as described in 10CFR21.3 and 10CFR21.21(c).

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

3. The Purchaser adopts appropriate procedures for notifications to satisfy 10CFR21.21.

When purchasing commercial grade calibration or testing services from a laboratory holding accreditation by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA), commercial grade surveys need not be performed provided each of the following conditions are met:

- 1) A documented review of the supplier's accreditation is performed and includes a verification of the following:

a) The calibration or test laboratory holds accreditation by an accrediting body recognized by the ILAC MRA. The accreditation encompasses ISO/IEC-17025:2005 or ISO/IEC-17025:2017, "General Requirements for the Competence of Testing and Calibration Laboratories."

CN 19-003

b) For procurement of calibration services, the published scope of accreditation for the calibration laboratory covers the needed measurement parameters, ranges, and uncertainties.

c) For procurement of testing services, the published scope of accreditation for the test laboratory covers the needed testing services including test methodology and tolerances/uncertainty.

- 2) The purchase documents require that:

a) The service must be provided in accordance with their accredited ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program and scope of accreditation.

CN 19-003

b) As found calibration data must be reported in the certificate of calibration when calibrated items are found to be out of tolerance. (for calibration services only)

c) The equipment/standards used to perform the calibration must be identified in the certificate of calibration. (for calibration services only)

d) The customer must be notified of any condition that adversely impacts the laboratory's ability to maintain the scope of accreditation.

e) Additional technical and quality requirements, as necessary, based upon a review of the procured scope of services, which may include, but are not necessarily limited to, tolerances, accuracies, ranges, and industry standards.

- 3) It is validated, at receipt inspection, that the laboratory's documentation certifies that:

a) The contracted calibration or test service has been performed in accordance with their ISO/IEC-17025:2005 or ISO/IEC-17025:2017 program, and has been performed within their scope of accreditation, and

CN 19-003


b) The purchase order's requirements are met.

With regard to Section 3.4 of ANSI N45.2.13 - 1976 titled Procurement Document Control: Ameren Missouri shall meet the requirements of OQAM Sections 4 and 7 in lieu of the requirements specified in this Section. In every case either identical or equivalent controls are provided in the sections of the referenced documents.

With regard to Section 5.3 of ANSI N45.2.13 - 1976 titled Preaward Evaluation: Ameren Missouri shall comply with an alternate paragraph which reads:

"Except in unusual circumstances (e.g. replacement parts are needed to preclude the development of some unsafe or undesirable condition at Callaway), an evaluation of the supplier's acceptability as a procurement source shall be performed as required by the Operating QA Manual."

While it is not the intent to make "unusual circumstances" determinations without Engineering or NOS involvement, Callaway Operations Support is ultimately responsible for the decision. NOS audit and surveillance activities assure against abuse.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

With regard to Section 6.4 of ANSI N45.2.13 - 1976 titled Control of Changes in Items of Services: The phrase "the Operating QA Program" is inserted in lieu of "ANSI N45.2, Section 7."

With regard to Section 7.3.1 of ANSI N45.2.13-1976 titled Source Verification Activities and Section 12 of ANSI N45.2.13 - 1976 titled Audit of Procurement Program: The Ameren Missouri audit program shall be implemented in accordance with and to meet the requirements of Regulatory Guide 1.144 (ANSI N45.2.12) as endorsed in this Appendix, and OQAM Sections 16 and 18.

With regard to Section 7.5 of ANSI N45.2.13 - 1976 titled Personnel Qualifications: The phrase: "Personnel responsible for performing verification activities shall be qualified in accordance with ANSI N45.2.6 as applicable", is subject to the following clarification: Qualification of personnel performing verification activities for the Callaway Plant shall be in accordance with Ameren Missouri's position on Regulatory Guide 1.58.

With regard to Section 8.2 of ANSI N45.2.13 - 1976 titled Disposition: The third sentence of item b is revised to read:

Nonconformances to the contractual procurement requirements or Purchaser approved documents and which consist of one or more of the following shall be submitted to the Purchaser for approval of the recommended disposition prior to shipment when the nonconformance could adversely affect the end use of a module¹ or shippable component relative to safety, interchangeability, operability, reliability, integrity, or maintainability:

- 1) Technical or material requirement is violated;
- 2) Requirement in Supplier documents, which have been approved by the Purchaser, is violated;
- 3) Nonconformance cannot be corrected by continuation of the original manufacturing process or by rework; and/or
- 4) The item does not conform to the original requirement even though the item can be restored to a condition such that the capability of the item to function is unimpaired.

REGULATORY GUIDE 1.144

REVISION 1

DATED 9/80


Auditing of Quality Assurance Programs for Nuclear Power Plants (Endorses ANSI N45.2.12-1977)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

With regard to Section C.3.b(2) of Regulatory Guide 1.144, the requirements of the section are accepted with the following interpretation:

¹ A module is an assembled device, instrument, or piece of equipment identified by serial number or other identification code, having been evaluated by inspection and/or test for conformance to procurement requirements regarding end use. A shippable component is a part of sub-assembly of a device, instrument, or piece of equipment which is shipped as an individual item and which has been evaluated by inspection and/or test for conformance to procurement requirements regarding end use.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

Supplier Audits – Section C.3.b.(2) of Reg. Guide 1.144, Revision 1 states that audits be performed on a "triennial basis". The 90-day grace period may be applied to this activity.

Supplier Evaluation – Section C.3.b.(2) of Reg. Guide 1.144, Revision 1 states that documented evaluations be performed "annually". The 90-day grace period may be applied to this activity.

"When procuring commercial grade calibration or testing services from a laboratory holding accreditation by an accrediting body recognized by the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA), the accreditation process and accrediting body may be credited with carrying out a portion of the Purchaser's duties of verifying acceptability and effective implementation of the calibration or testing service laboratory's quality assurance program.

In lieu of performing commercial grade survey or accepting a commercial grade survey performed by another licensee, a documented review of the laboratory's accreditation is performed which includes a verification of the following:

CN 19-003

1. The calibration or test laboratory holds accreditation by an accrediting body recognized by the ILAC MRA. The accreditation encompasses ISO/IEC-17025:2005 or ISO/IEC-17025:2017, "General Requirements for the Competence of Testing and Calibration Laboratories."
2. For procurement of calibration services, the published scope of accreditation for the calibration laboratory covers the needed measurement parameters, ranges, and uncertainties.
3. For procurement of testing services, the published scope of accreditation for the test laboratory covers the needed testing services including test methodology and tolerances/uncertainty.

Also, annual evaluations of commercial-grade calibration service suppliers shall verify continued maintenance of laboratory accreditation."


With regard to Section 1.4 of ANSI N45.2.12 - 1977 titled Definitions: With one exception (Program Deficiencies) the definitions in this Standard which are not included in Regulatory Guide 1.74 (ANSI N45.2.10) shall be used; definitions which are included in ANSI N45.2.10 shall be used as clarified in Ameren Missouri's commitment to Regulatory Guide 1.74. The one excepted definition and a clarified definition (of audit) relevant to this Standard are defined in this Appendix under Regulatory Guide 1.74.

With regard to Section 2.1 of ANSI N45.2.12-1977 titled General: Identical or equivalent controls are provided in this OQAM, Section 18.3 regarding the second paragraph discussing audit team selection.

With regard to Section 2.2 of ANSI N45.2.12 - 1977 titled Personnel Qualification: The qualification of Ameren Missouri audit personnel shall be accomplished as described to meet the requirements of Regulatory Guide 1.146 (ANSI N45.2.23 - 1978) as endorsed in this Appendix and OQAM Section 18.

With regard to Section 2.3 (and subsections 2.3.1 through 2.3.3) of ANSI N45.2.12 - 1977 titled Training: The training of Ameren Missouri audit personnel shall be accomplished as described to meet the requirements of Regulatory Guide 1.146 (ANSI N45.2.23 - 1978) as endorsed in this Appendix and OQAM Section 18.

With regard to Section 2.4 of ANSI N45.2.12 - 1977 titled Maintenance of Proficiency: The maintenance of proficiency of Ameren Missouri audit personnel shall be accomplished as described to meet the requirements of Regulatory Guide 1.146 (ANSI N45.2.23 - 1978) as endorsed in this Appendix and OQAM Section 18.

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

With regard to Section 3.3 of ANSI N45.2.12 - 1977 titled Essential Elements of the Audit System: Ameren Missouri shall comply with subsection 3.3.5 as it was originally written (subsection 3.2.5) in ANSI N45.2.12, Draft 3, Revision 4: "Provisions for reporting on the effectiveness of the Quality Assurance Program to the responsible management." For the auditing organization (Ameren Missouri), effectiveness shall be reported as required by OQAM Section 18. Other than audit reports, Ameren Missouri may not directly report on the effectiveness of the quality assurance programs to the audited organization when such organizations are outside of Ameren Missouri.

Subsection 3.3.6 requirements are considered to be fulfilled by compliance with the organization and reporting measures outlined in this OQAM. In every case either identical or equivalent controls are provided in the sections of the referenced documents.

Subsection 3.3.7 requires verification of effective corrective action on a timely basis.

Verification of the implementation of corrective action is performed as indicated in Section 16 of this OQAM. Corrective action program effectiveness is determined through audit or surveillance as described in Section 18 of this OQAM, using previously issued corrective action documents as input to the scope of audits and surveillances. Additionally, trending of corrective action documents will be used to reveal potentially ineffective corrective actions and the effectiveness of the corrective action program.


With regard to Section 3.4 of ANSI N45.2.12-1977 titled Audit Planning: Identical or equivalent controls are provided in this OQAM, Section 18.

With regard to Section 3.5 of ANSI N45.2.12 - 1977 titled Scheduling: Identical or equivalent controls are provided in this OQAM, Section 18 for the requirements of Subsections 3.5.1 and 3.5.2. Subsection 3.5.3.1 is interpreted to mean that Ameren Missouri may procedurally control qualification of a contractor's or supplier's quality assurance program prior to awarding a contract or purchase order by means other than audit. The measures outlined in Sections 4 and 7 of this OQAM address the requirements of Subsection 3.5.3.1.

With regard to Section 4.3.1 of ANSI N45.2.12 - 1977 titled Pre-Audit Conference: Ameren Missouri shall comply with requirements of this Section by inserting the word "Normally" at the beginning of the first sentence. This clarification is required because, in the case of certain unannounced audits or audits of a particular operation or work activity, a pre-audit conference might interfere with the spontaneity of the operation or activity being audited. In other cases, persons who should be present at a pre-audit conference may not always be available: such lack of availability should not be an impediment to beginning an audit. Even in the above examples, which are not intended to be all inclusive, the material set forth in Section 4.3.1 shall normally be covered during the course of the audit.

With regard to Section 4.3.2 of ANSI N45.2.12 - 1977 titled Audit Process:

- (a) Subsection 4.3.2.2 could be interpreted to limit auditors to the review of only objective evidence; sometimes and for some Program elements, no objective evidence may be available. Ameren Missouri shall comply with an alternate sentence which reads: "When available, objective evidence shall be examined for compliance with Quality Assurance Program requirements. If subjective evidence is used (e.g. personal interviews, direct observations by the auditor), then the audit report must indicate how the evidence was obtained."
- (b) Subsection 4.3.2.4 is modified as follows to take into account the fact that some nonconformances are virtually "obvious" with respect to the needed corrective action: "When a nonconformance or Quality Assurance Program deficiency is identified as a result of an audit, unless the apparent cause, extent, and corrective action are readily

 <p>AMEREN MISSOURI CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL</p>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

evident, further investigation shall be conducted by the audited organization in an effort to identify the cause and effect and to determine the extent of the corrective action required."

- (c) Subsection 4.3.2.5 contains a recommendation which is clarified with the definition of "acknowledged by a member of the audited organization" to mean that "a member of the audited organization has been informed of the findings." Agreement or disagreement with a finding may be expressed in the response from the audited organization.
- (d) Subsection 4.3.2.6 is modified as follows to account for the fact that immediate notification is not always possible: "Conditions requiring immediate corrective action (i.e. those which are so severe that any delay would be undesirable) shall be reported immediately to the audited organization and as soon as practical to the management thereof."

With regard to Section 4.3.3 of ANSI N45.2.12 - 1977 titled Post-Audit Conference: Ameren Missouri shall substitute and comply with the following paragraph:

"For external audits, a post-audit conference shall be held with management of the audited organization to present audit findings and clarify misunderstandings; where no adverse findings exist, this conference may be waived by management of the audited organization: such waiver shall be documented in the audit report. Unless unusual operating or maintenance conditions preclude attendance by appropriate managers/supervisors, a post-audit conference shall be held with managers/supervisors for internal audits for the same reasons as above. Again, if there are no adverse findings, management of the internal audited organization may waive the post-audit conference: such waiver shall be documented in the audit report."

With regard to Section 4.4 of ANSI N45.2.12 - 1977 titled Reporting:


- (a) This Section requires that the audit report shall be signed by the Audit Team Leader (ATL); this is not always the most expeditious route to take to assure that the audit report is issued as soon as practical. Ameren Missouri shall comply with Section 4.4 as clarified in the following opening:

"An audit report, which shall be signed by the Audit Team Leader (ATL), or the ATL's supervisor in the ATL's absence, shall provide: . . ."

In cases where the audit report is not signed by the ATL due to absence, one record copy of the report must be signed by the ATL upon return. The report shall not require the ATL's review/concurrence/signature if the ATL is no longer employed by Ameren Missouri at the time the audit report is issued.

- (b) Ameren Missouri shall comply with subsection 4.4.3 clarified to read: "Supervisory level personnel with whom significant discussions were held during the course of pre-audit (where conducted) audit, and post-audit (where conducted) activities."
- (c) Audit reports may not necessarily contain an evaluation statement regarding the effectiveness of the Quality Assurance Program elements which were audited, as required by subsection 4.4.4, but they shall provide a summary of the audited areas and the results which identify the importance of any adverse findings.

With regard to Section 4.5.1 of ANSI N45.2.12 - 1977 titled By Audited Organization: Ameren Missouri shall comply with the following clarification of the Section: Management of the audited organization or activity shall review and investigate adverse audit findings, as necessary, (e.g., where the cause is not already known, another organization has not already investigated and found the cause, etc.) to determine and schedule appropriate remedial action. The audited organization shall assure documentation of remedial action taken is provided. Adverse audit findings shall be evaluated to

 CALLAWAY ENERGY CENTER OPERATING QUALITY ASSURANCE MANUAL	APPENDIX A
	REVISION: 033a
	DATE: 06/19

determine the need for action to prevent recurrence. If such action is deemed necessary, the results of the investigation (root cause analysis), the corrective action taken or planned to prevent recurrence, and a schedule for implementation shall be provided by the audited organization. Such evaluations and implementation of actions shall be scheduled and performed consistent with the safety significance of the item. The audited organization shall take appropriate action to assure corrective action is accomplished as scheduled. In the event the action or schedule of implementation must be changed, the audited organization shall provide a revised response on or before the originally scheduled completion date which states the corrective action and states its completion date. Evaluation progress and corrective action implementation will be performed and tracked in accordance with provisions of Section 16 of the Ameren Missouri Operating Quality Assurance Manual.

With regard to Section 4.5.2 of ANSI N45.2.12-1977 titled By Auditing Organization: Ameren Missouri shall comply with the following clarification of the section: For internal audits, performed by or for the Nuclear Oversight Department, follow-up actions will be taken by the audited organization as described in Section 16 of this OQAM. The internal audit program implemented in Section 18 of this OQAM provides assurance that the corrective action program requirements are properly implemented. By sampling responses to conditions adverse to quality, the adequacy of root cause analysis, implementation of remedial action, and action to prevent recurrence are verified to assure effective corrective action program implementation. Therefore, the auditing organization will not necessarily evaluate the adequacy and assure action is identified and accomplished for each adverse finding. External audits shall comply with section 4.5.2 of ANSI N45.2.12-1977.

REGULATORY GUIDE 1.146

INITIAL ISSUE

DATED 8/80

Qualification of Quality Assurance Program Audit Personnel for Nuclear Power Plants (Endorses ANSI N45.2.23-1978)

DISCUSSION:

Ameren Missouri complies with the recommendations of this Regulatory Guide with the following clarifications:

With respect to Section 1.4 of ANSI N45.2.23-1978 titled Definitions: Definitions in this Standard which are not included in ANSI N45.2.10 shall be used: "Audit" which is included in this Standard and ANSI N45.2.10 shall be used as clarified in this Appendix under Regulatory Guide 1.74.


With respect to Section 2.2 of ANSI N45.2.23 - 1978 titled Qualification of Auditors: Subsection 2.2.1 references an ANSI B45.2 (presumed to be standard N45.2); therefore, Ameren Missouri shall comply with an alternate subsection 2.2.1 which reads:

Orientation to provide a working knowledge and understanding of the Operating QA Manual, including the ANSI standards and Regulatory Guides included in this Appendix and Ameren Missouri's procedures for implementing audits and reporting results.

With respect to Section 2.3.4 of ANSI N45.2.23-1978, titled Audit Participation: Ameren Missouri shall substitute the following for this section:

The prospective Lead Auditor shall demonstrate the ability to effectively implement the audit process and lead an audit team. This process is described in written procedures which provide for evaluation and documentation. A prospective Lead Auditor shall have participated in at least one nuclear oversight audit within the year preceding the individual's effective date of qualification.

With respect to Section 3.2 of ANSI N45.2.23 - 1978 titled Maintenance of Proficiency: Ameren Missouri shall comply with the requirements of this Section by defining "annual assessment" as one which takes places every 12 + or - 3 months

 CALLAWAY ENERGY CENTER <i>OPERATING QUALITY ASSURANCE MANUAL</i>	APPENDIX A
	REVISION: 033a
	DATE: 06/19

and which uses the initial date of certification (not the calendar year) as the starting date for determining when such annual assessment is due. The combined time interval for any three consecutive assessment intervals shall not exceed 3.25 years.

With respect to Section 4.1 of ANSI N45.2.23 - 1978 titled Organizational Responsibility: Ameren Missouri shall comply with this Section with the substitution of the following sentence in place of the last sentence in the Section:

The Director, Nuclear Oversight; Supervisor, NOS; or Lead Auditor shall, prior to commencing the audit, assign personnel who collectively have experience or training commensurate with the scope, complexity, or special nature of the activities to be audited.

With respect to Section 5.3 of ANSI N45.2.23 - 1978 titled Updating of Lead Auditor's Records: Ameren Missouri shall substitute the following sentence for this Section:

Records for each Lead Auditor shall be maintained and updated during the period of the annual management assessment as defined in Section 3.2 (as clarified).

With respect to Section 5.4 of ANSI N45.2.23 - 1978 titled Records Retention: Ameren Missouri shall substitute the following sentence for this Section:

Qualification records shall be generated and maintained as required by OQAM Section 17 and by commitment to Regulatory Guide 1.88 (ANSI N45.2.9) as clarified in this Appendix.

In every case either identical or equivalent controls are provided in the sections of the referenced Standards and documents.