



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

REGION IV  
1600 EAST LAMAR BOULEVARD  
ARLINGTON, TEXAS 76011-4511

October 30, 2019

Mr. John Dent, Jr.  
Vice President-Nuclear and CNO  
Nebraska Public Power District  
Cooper Nuclear Station  
72676 648A Avenue  
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION – INTEGRATED INSPECTION  
REPORT 05000298/2019003

Dear Mr. Dent:

On September 30, 2019, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at Cooper Nuclear Station. On October 17, 2019, the NRC inspectors discussed the results of this inspection with Mr. J. Sullivan, General Manager Plant Operations, and other members of your staff. The results of this inspection are documented in the enclosed report.

Two findings of very low safety significance (Green) are documented in this report. These findings involved violations of NRC requirements. We are treating these violations as non-cited violations (NCVs) consistent with Section 2.3.2 of the Enforcement Policy.

If you contest the violations or significance of the violations documented in this inspection report, you should provide a response within 30 days of the date of this inspection report, with the basis for your denial, to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555-0001; with copies to the Regional Administrator, Region IV; the Director, Office of Enforcement; and the NRC Resident Inspector at Cooper Nuclear Station.

If you disagree with a cross-cutting aspect assignment in this report, you should provide a response within 30 days of the date of this inspection report, with the basis for your disagreement, to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555-0001; with copies to the Regional Administrator, Region IV; and the NRC Resident Inspector at Cooper Nuclear Station.

J. Dent, Jr.

2

This letter, its enclosure, and your response (if any) will be made available for public inspection and copying at <http://www.nrc.gov/reading-rm/adams.html> and at the NRC Public Document Room in accordance with 10 CFR 2.390, "Public Inspections, Exemptions, Requests for Withholding."

Sincerely,

*/RA/*

Christopher W. Newport, Acting Chief  
Reactor Projects Branch C  
Division of Reactor Projects

Docket No. 05000298  
License No. DPR-46

Enclosure:  
As stated

cc w/ encl: Distribution via LISTSERV®

SUBJECT: COOPER NUCLEAR STATION – INTEGRATED INSPECTION  
 REPORT 05000298/2019003 – October 30, 2019

DISTRIBUTION

SMorris, RA  
 MShaffer, DRA  
 AVegel, DRP  
 TInverso, DRP  
 RLantz, DRS  
 GMiller, DRS  
 DCylkowski, RC  
 JQuichocho, RIV/OEDO  
 VDricks, ORA  
 JWeil, OCA  
 TWengert, NRR  
 AMoreno, RIV/OCA  
 BMaier, RSLO  
 RAZua, IPAT  
 CNewport, DRP  
 CYoung, DRP  
 DProulx, DRP  
 PVossmar, DRP  
 MStafford, DRP  
 LFlores, DRP  
 AElam, DRP  
 PJayroe, IPAT  
 MHerrera, DRMA  
 R4Enforcement  
 ROP Reports

DOCUMENT NAME: R:\\_REACTORS\CNS\2019\CNS2019003-IR-PV.docx

ADAMS ACCESSION NUMBER: ML19303A660

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	SRI:DRP/C	RI:DRP/C	ARI:DRP/C	C:DRS/EB1	C:DRS/EB2
NAME	PVossmar	MStafford MHS	LFlores LRF	VGaddy	NTaylor NHT
DATE	10/28 PJV	10/28/19	10/28/19	10/23/19	10/25/2019
OFFICE	C:DRS/OB	ATL:DRS/IPAT	C:DRS/RCB	C:DNMS/RxIB	SPE:DRP/C
NAME	GWerner <i>GEW</i>	RAzua <i>RVA</i>	MHaire <i>MSH</i>	GWarnick <i>GAW</i>	DProulx; <i>DLP</i>
DATE	10/23/2019	10/24/2019	10/222/2019	10/23/19	10/22/19
OFFICE	ABC:DRP/C				
NAME	CNewport				
DATE	10/30/2019				

**U.S. NUCLEAR REGULATORY COMMISSION  
Inspection Report**

Docket Number: 05000298

License Number: DPR-46

Report Number: 05000298/2019003

Enterprise Identifier: I-2019-003-0003

Licensee: Nebraska Public Power District

Facility: Cooper Nuclear Station

Location: Brownville, NE

Inspection Dates: July 1, 2019 to September 30, 2019

Inspectors: B. Baca, Health Physicist  
L. Carson, Senior Health Physicist  
L. Flores, Project Engineer  
N. Greene, Senior Health Physicist  
J. O'Donnell, Health Physicist  
N. Okonkwo, Reactor Inspector  
D. Proulx, Senior Project Engineer  
W. Sifre, Senior Reactor Inspector  
M. Stafford, Senior Resident Inspector  
C. Stott, Reactor Inspector  
P. Vossmar, Senior Resident Inspector

Approved By: Christopher W. Newport, Acting Chief  
Reactor Projects Branch C  
Division of Reactor Projects

## SUMMARY

The U.S. Nuclear Regulatory Commission (NRC) continued monitoring the licensee’s performance by conducting an integrated inspection at Cooper Nuclear Station in accordance with the Reactor Oversight Process. The Reactor Oversight Process is the NRC’s program for overseeing the safe operation of commercial nuclear power reactors. Refer to <https://www.nrc.gov/reactors/operating/oversight.html> for more information.

### List of Findings and Violations

Failure to Implement Fire Protection Program Surveillance Requirements for a Fire Barrier Seal			
Cornerstone	Significance	Cross-Cutting Aspect	Report Section
Mitigating Systems	Green NCV 05000298/2019003-01 Open/Closed	[P.1] - Identification	71111.05Q
<p>The inspectors identified a Green, non-cited violation of License Condition 2.C(4), “Fire Protection,” for the failure to implement all provisions of the approved fire protection program. Specifically, prior to July 2, 2019, the licensee failed to implement Surveillance Procedure 6.FP.606, “Fire Barrier/Penetration Seal Visual Examination,” Revision 25, for visual inspection of the cable expansion room west wall fire barrier and its associated MN 46 penetration to ensure that an unsealed penetration opening was identified. As a result, the licensee failed to identify that the conduit seal was degraded until it was discovered by the inspectors on July 2, 2019, and subsequently declared nonfunctional by operations personnel.</p>			

Failure to Take Required Actions of Technical Specification 3.5.2 for Reactor Pressure Vessel Water Inventory Control During Secondary Containment Work			
Cornerstone	Significance	Cross-Cutting Aspect	Report Section
Barrier Integrity	Green NCV 05000298/2019003-02 Open/Closed	[H.5] - Work Management	71153
<p>The inspectors documented a self-revealed, Green, non-cited violation of Technical Specification 3.5.2, “Reactor Pressure Vessel Water Inventory Control,” for the licensee’s failure to take technical specification required actions during a reactor pressure vessel water inventory control activity. Specifically, on October 10, 2018, during a planned water inventory control activity, the licensee failed to meet Technical Specification 3.5.2, Condition C, when an unplanned and unrecognized breach of secondary containment occurred, and the licensee did not verify secondary containment could be closed as required until the breach was discovered several hours later. In particular, during residual heat removal service water piping work, the penetration of the same residual heat removal service water piping on both the control building and reactor building sides of the secondary containment boundary was not recognized, and as a result, a containment closure plan was not in place.</p>			

### Additional Tracking Items

Type	Issue Number	Title	Report Section	Status
LER	05000298/2018-002-00	Lack of Procedural Guidance Results in Work Scheduling Error Causing Breach of Secondary Containment and Condition Prohibited by Technical Specifications	71153	Closed

## PLANT STATUS

Cooper Nuclear Station began the inspection period at rated thermal power. On August 23, 2019, the unit was down powered to 70 percent for a control rod sequence exchange. The plant was returned to rated thermal power on August 24, 2019, and remained at or near rated thermal power for the remainder of the inspection period

## INSPECTION SCOPES

Inspections were conducted using the appropriate portions of the inspection procedures (IPs) in effect at the beginning of the inspection unless otherwise noted. Currently approved IPs with their attached revision histories are located on the public website at <http://www.nrc.gov/reading-rm/doc-collections/insp-manual/inspection-procedure/index.html>. Samples were declared complete when the IP requirements most appropriate to the inspection activity were met consistent with Inspection Manual Chapter (IMC) 2515, "Light-Water Reactor Inspection Program - Operations Phase." The inspectors performed plant status activities described in IMC 2515, Appendix D, "Plant Status," and conducted routine reviews using IP 71152, "Problem Identification and Resolution." The inspectors reviewed selected procedures and records, observed activities, and interviewed personnel to assess licensee performance and compliance with Commission rules and regulations, license conditions, site procedures, and standards.

## REACTOR SAFETY

### 71111.04Q - Equipment Alignment

#### Partial Walkdown Sample (IP Section 03.01) (4 Samples)

The inspectors evaluated system configurations during partial walkdowns of the following systems/trains:

- (1) Standby liquid control B on July 8, 2019
- (2) Service water booster pump A subsystem on July 16, 2019
- (3) Reactor core isolation cooling on September 13, 2019
- (4) Core spray B on September 26, 2019

### 71111.04S - Equipment Alignment

#### Complete Walkdown Sample (IP Section 03.02) (1 Sample)

- (1) The inspectors evaluated system configurations during a complete walkdown of the hardened containment vent system installed in accordance with NRC Order EA-13-109 on August 27, 2019. [Completion of this sample was in accordance with the guidance in Temporary Instruction 2515/193, with credit taken in IP 71111.04 - further details are documented in Inspection Report 05000298/2019012, ADAMS Accession No. ML19266A571.]

### 71111.05Q - Fire Protection

#### Quarterly Inspection (IP Section 03.01) (5 Samples)

The inspectors evaluated fire protection program implementation in the following selected areas:

- (1) Cable expansion room on July 3, 2019
- (2) Reactor building suppression pool 859 feet elevation on July 22, 2019
- (3) Southeast quad 859 feet and 881 feet elevations on August 21, 2019
- (4) Control cable spreading room on September 17, 2019
- (5) Critical switchgear rooms 1F and 1G on September 18, 2019

#### 71111.06 - Flood Protection Measures

##### Inspection Activities - Internal Flooding (IP Section 02.02a.) (1 Sample)

The inspectors evaluated internal flooding mitigation protections in the:

- (1) Reactor building 931 feet elevation on September 30, 2019

##### Inspection Activities - Underground Cables (IP Section 02.02c.) (1 Sample)

The inspectors evaluated cable submergence protection in:

- (1) Sump W during sump pump failure and elevated river levels on September 27, 2019

#### 71111.11Q - Licensed Operator Requalification Program and Licensed Operator Performance

##### Licensed Operator Performance in the Actual Plant/Main Control Room (IP Section 03.01) (1 Sample)

- (1) The inspectors observed and evaluated licensed operator performance in the control room during a planned quarterly downpower on August 24, 2019.

##### Licensed Operator Requalification Training/Examinations (IP Section 03.02) (1 Sample)

- (1) The inspectors observed and evaluated a licensed operator training drill performed as a corrective action for a declining emergency response performance trend on July 30, 2019.

#### 71111.12 - Maintenance Effectiveness

##### Routine Maintenance Effectiveness Inspection (IP Section 02.01) (1 Sample)

The inspectors evaluated the effectiveness of routine maintenance activities associated with the following equipment and/or safety significant functions:

- (1) Reactor building essential ventilation units on September 30, 2019

##### Quality Control (IP Section 02.02) (1 Sample)

The inspectors evaluated maintenance and quality control activities associated with the following equipment performance activities:

- (1) Reactor core isolation cooling commercially dedicated signal conditioner failure on September 24, 2019

### 71111.13 - Maintenance Risk Assessments and Emergent Work Control

#### Risk Assessment and Management Sample (IP Section 03.01) (5 Samples)

The inspectors evaluated the risk assessments for the following planned and emergent work activities:

- (1) Standby liquid control A pump planned maintenance on July 8, 2019
- (2) Unplanned reactor core isolation cooling unavailability on July 24, 2019
- (3) Core spray B planned work window on August 13, 2019
- (4) Emergency station service transformer planned work window on August 21, 2019
- (5) Emergent RF-MO-29 valve packing injection on August 27, 2019

### 71111.15 - Operability Determinations and Functionality Assessments

#### Operability Determination or Functionality Assessment (IP Section 02.02) (5 Samples)

The inspectors evaluated the following operability determinations and functionality assessments:

- (1) Part 21 for reactor core isolation cooling positioner defect on July 3, 2019
- (2) Residual heat removal to radwaste primary containment isolation valve classification/operability on August 15, 2019
- (3) Service water check valve 37 past operability on August 19, 2019
- (4) Southeast quad fan coil unit failed to meet surveillance acceptance criteria on August 16, 2019
- (5) Questionable results during containment isolation valve local leak-rate test on September 19, 2019

### 71111.17T - Evaluations of Changes, Tests, and Experiments

#### Sample Selection (IP Section 02.01) (33 Samples)

The inspectors reviewed the following evaluations, screenings, and/or applicability determinations for 10 CFR 50.59 from September 20, 2013, to September 20, 2019:

- (1) Evaluation 2013-3, Revision 2, Remove heater bay steam leak detection temperature switches
- (2) Evaluation 2015-2, Revision 0, Startup transformer replacement
- (3) Evaluation 2015-4, Revision 1, Time critical operator action for suppression pool cooling
- (4) Evaluation 2015-5, Revision 1, Reactor containment isolation cooling turbine governor control system replacement
- (5) Evaluation 2018-1, Revision 0, Engineering Change (EC) 6038060, Open phase protection system
- (6) Evaluation 2018-2, Revision 0, Engineering Evaluation (EE) 18-012, Extending inspection duration of underwater torus region
- (7) Evaluation 2019-2, Revision 0, Technical Requirements Manual 3.7.1, flooding forecast removed
- (8) Screen 71719, 161 kV low voltage limit
- (9) Screen 71720, CR-CNS-2016-02270, Standing Order 2016-005
- (10) Screen 81728, R3402, sudden pressure relay replacement

- (11) Screen 81739, Service water surveillance operation, Division 2
- (12) Screen 81731, Use of NSF fuel channels
- (13) Screen 81734, Control room air conditioning temporary compressor breaker
- (14) Screen 91748, Procedure 6.1EE.306, 4160 V, bus 1F, undervoltage relay channel functional test
- (15) Screen 91758, 4160 V, bus 1G, undervoltage relay channel functional test (Division 2)
- (16) Screen 91770, Reactor equipment cooling sequential load time delay relay relocation
- (17) Screen 91778, Code Case N-513-3 compensatory actions
- (18) Screen 91795, Operability Evaluation CR-CNS-2016-05558
- (19) Screen 91793, Reclassify MCC-L and MCC-T as nonessential motor control centers
- (20) Screen 101794, CR-CNS-2016-05628, CA-001
- (21) Screen 111827, High pressure core injection turbine overspeed functional test
- (22) Screen 121884, Asea Brown Bovari breaker 145PMB40 BLK limit switch upgrade (1602)
- (23) Screen 121895, Service water booster pump oil sight glasses and reservoir
- (24) Screen 121898, T2 transformer sudden pressure and seal-in relay replacement
- (25) Screen 121948, Replace high pressure core injection flow controller (analog to digital)
- (26) Screen 121953, Main generator underfrequency relay replacement
- (27) Screen 122011, Residual heat removal service water booster pump system
- (28) Screen 122025, Emergency diesel generator indicating light isolation
- (29) Screen 122038, Reclassify relays HV-REL-1CFX and HV-REL-1DFX to nonessential
- (30) Screen 122067, Various motor operated valve packing load adjustment calculation revisions
- (31) Screen 122093, High pressure core injection loss of coolant heat exchanger thermal performance and tube plugging margin
- (32) Screen 122143, Residual heat removal and high pressure core injection net positive suction head margins for an anticipated transient without SCRAM event
- (33) Screen 142229, Reactor equipment cooling heat exchanger allowable tube plugging increase

#### 71111.18 - Plant Modifications

##### Temporary Modifications and/or Permanent Modifications (IP Section 03.01 and/or 03.02) (1 Sample)

The inspectors evaluated the following temporary or permanent modifications:

- (1) Hardened containment vent system installed in accordance with NRC Order EA-13-109 on August 29, 2019. [Completion of this permanent modification sample was in accordance with the guidance in Temporary Instruction 2515/193, with credit taken in Inspection Procedure 71111.18 - further details are documented in Inspection Report 05000298/2019012, ADAMS Accession No. ML19266A571.]

#### 71111.19 - Post-Maintenance Testing

##### Post Maintenance Test Sample (IP Section 03.01) (5 Samples)

The inspectors evaluated the following post maintenance tests:

- (1) Service water check valve 37 leakage post maintenance testing on July 23, 2019

- (2) Reactor building outer railroad airlock door seal post maintenance testing on July 25, 2019
- (3) Scram discharge volume check valve replacement on August 6, 2019
- (4) Core spray B planned work window on August 16, 2019
- (5) Southeast quad fan coil unit flow test following coil cleaning on September 5, 2019

#### 71111.22 - Surveillance Testing

The inspectors evaluated the following surveillance tests:

#### Surveillance Tests (other) (IP Section 03.01) (2 Samples)

- (1) Emergency diesel generator 2 monthly operability test on July 15, 2019
- (2) Control room emergency filtration system flow test on July 19, 2019

#### Inservice Testing (IP Section 03.01) (1 Sample)

- (1) Reactor equipment cooling motor operated valve operability inservice test on July 31, 2019

#### FLEX Testing (IP Section 03.02) (1 Sample)

- (1) Spent fuel pool secondary level instrument functional testing on August 7, 2019

### **RADIATION SAFETY**

#### 71124.05 - Radiation Monitoring Instrumentation

#### Walk Downs and Observations (IP Section 02.01) (1 Sample)

The inspectors evaluated radiation monitoring instrumentation during plant walkdowns.

- (1) The inspectors reviewed the following:

#### Portable Survey Instruments

- RO-20            RP-11376
- AMS-4           RP-10762
- Model 3         RP-11438
- TelePole        RP-11451
- REM 500        RP-11177
- Model 177      RP-11275
- H-809V         RP-11469

#### Source Check Demonstration

- RO-20            RP-11419
- Model 3         RP-11438
- TelePole        RP-11451

Area Radiation Monitors and Continuous Air Monitors

- CNS-0-RMA-RA-2
- CNS-0-RMA-RA-6
- CNS-0-RMA-RA-7
- CNS-0-RMA-RA-11
- CNS-0-RMA-RA-16
- CNS-0-RMA-RA-23
- CNS-0-RMA-RA-24

Personnel Contamination Monitors, Portal Monitors and Small Article Monitors

- PCM-2        RP-10571
- PM-12        RP-11178
- SAM-12        RP-11152

Calibration and Testing Program (IP Section 02.02) (1 Sample)

The inspectors evaluated the calibration and testing program implementation.

- (1) The inspectors reviewed the following:

Alarm Setpoint and Calibration Method Check of Personnel Contamination Monitors, Portal Monitors and Small Article Monitors

- PM-12        RP-11178
- SAM-12        RP-11152

Failure to Meet Calibration or Source Check Acceptance Criteria

- None Available

71124.06 - Radioactive Gaseous and Liquid Effluent Treatment

Walk Downs and Observations (IP Section 02.01) (1 Sample)

The inspectors walked down the following gaseous and liquid radioactive effluent monitoring and filtered ventilation systems to assess the material condition and verify proper alignment according to plant design:

- (1)
- Liquid waste effluent system
  - Elevated release point (ERP) system
  - Radwaste ventilation
  - Reactor building ventilation

Calibration and Testing Program (Process & Effluent Monitors) (IP Section 02.02) (1 Sample)

The inspectors reviewed the following gaseous and liquid effluent monitor instrument calibrations and tests:

- (1)
- ERP

- Liquid radwaste
- Reactor building

#### Sampling and Analysis (IP Section 02.03) (1 Sample)

The inspectors reviewed the following:

(1) Radioactive Effluent Sampling and Analysis Activities

- ERP
- Reactor building
- Radwaste
- Turbine building

#### Effluent Discharges

The licensee did not perform a continuous or batch liquid effluent discharge during the inspection for observation. The inspectors reviewed selected discharge permits and the licensee's procedures for performing liquid and gaseous effluent discharges.

#### Instrumentation and Equipment (IP Section 02.04) (1 Sample)

The inspectors reviewed the following radioactive effluent discharge system surveillance test results:

(1) Air Cleaning System Surveillances

- Standby gas treatment
- Control room envelope filtration system [CREFS]

#### High-Range Effluent Monitoring Instrumentation Calibrations

- Reactor building
- Radwaste
- ERP

## Dose Calculations (IP Section 02.05) (1 Sample)

The inspectors reviewed the following to assess public dose:

### (1) Liquid and Gaseous Discharge Permits

The inspectors walked through the EFFECTS computer program, which documented the weekly continuous gaseous effluent discharge sample inputs, with a chemistry technician and the associated procedure for selected time periods during the inspection period. In addition, the inspectors reviewed the following liquid batch discharge releases:

- 18-15
- 18-33
- 18-42
- 19-10
- 19-13
- 19-43

### Annual Radiological Effluent Release Reports

- 2017 Annual Radioactive Effluent Release Report
- 2018 Annual Radioactive Effluent Release Report

### Abnormal Gaseous or Liquid Tank Discharges

The licensee did not have an abnormal gaseous or liquid tank release during the inspection period. The inspectors reviewed release logs and discharge permits for abnormal discharges. The inspectors verified an infrequent tank discharge was performed according to licensee procedures.

## 71124.07 - Radiological Environmental Monitoring Program

### Site Inspection (IP Section 02.01) (1 Sample)

The inspectors evaluated the radiological environmental monitoring program implementation.

- Air sampling station No. 1
- Air sampling station No. 2
- Air sampling station No. 6 (aka solar station No. 1)
- Air sampling station No. 7
- Thermo-luminescent dosimeter (TLD) monitoring station No. 2
- TLD monitoring station No. 7
- TLD monitoring station No. 10

### Environmental Sample Collections and Preparation Observation

1. Environmental samples: None were available for review and observation during this inspection. The inspectors visited a milk cow collection point and observed the licensee's delivery of a milk sampling container in preparation for the next milk

sampling. The inspectors observed the collection and replacement of air sample cartridges at the following stations:

- Air sampling station No. 1
- Air sampling station No. 2
- Air sampling station No. 6 (aka solar station No. 1)
- Air sampling station No. 7

Licensee Actions in Response to Missed Sample, Inoperable Sampler, Lost TLD or Anomalous Measurement

1. CR-CNS-2019-03895: Sampling at positions Nos. 28 and 35 were not available due to flooding July 19, 2019
2. CR-CNS-2019-03596: Suitable broadleaf vegetation unavailable due to flooding July 1, 2019
3. CR-CNS-2018-06283: Air samplers Stations 03, 05, and 08 were inaccessible due to excessive flooding October 10, 2018
4. CR-CNS-2018-08143: 100-meter A channel wind speed excessively high; repair/replace November 30, 2018
5. CR-CNS-2018-02820: 100-meter B channel temperature sensor erroneous/incorrect May 9, 2018

Groundwater Protection Initiative (GPI) Implementation (IP Section 02.02) (1 Sample)

Sampling Program for the Potential of Licensed Material Entering Groundwater

Groundwater Monitoring Well (GMW)

- CR-CNS-2019-01891, GMW-15 out of service due to excessive flooding, 03/26/19
- CR-CNS-2019-03553, GMW-12 out of service due to excessive flooding, 06/27/19
- CR-CNS-2019-00355, GMW-10 out of service due to excessive flooding, 06/27/19
- CR-CNS-2018-01877, GMW-06 & GMW out of service due to broken submersible pump, 03/29/19

For the 19 GMWs available for the inspection period, all wells measured less than 3,000 pCi/l H-3. The reporting level for H-3 in groundwater is 20,000 pCi/l.

- GMWs: 1D, 1S, 2, 3, 4D, 4S, 5, 6, 7D, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17

71124.08 - Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transportation

Radioactive Material Storage (IP Section 02.01) (1 Sample)

The inspectors evaluated radioactive material storage.

(1) The inspectors toured the following areas:

- Low Level Radioactive Waste (LLRW) Storage Pad
- Radioactive Materials Storage Building - Blue Building
- East Warehouse Radioactive Material Storage

- Dry Fuel Storage Pad - ISFSI Horizontal Storage Module (HSM) Pad
- Multipurpose Facility (MPF)
- Spent Fuel Pool Area

The inspectors performed a container check (e.g., swelling, leakage and deformation) on the following various containers:

- LSA Boxes in Blue Building
- 55 Gallon Drums
- Sealands with Dry Active Waste
- Used Oil Drums
- Wooden Boxes
- Radioactive Trash Bags

#### Radioactive Waste System Walkdown (IP Section 02.02) (1 Sample)

The inspectors evaluated the following radioactive waste processing systems and processes during plant walkdowns:

##### (1) Liquid or Solid Radioactive Waste Processing Systems

- Floor Drain Filter System
- Reactor Water Cleanup System
- Condensate Waste Storage System
- Low Level Radioactive Waste Processing

##### Radioactive Waste Resin and/or Sludge Discharges Processes

- NUPAC Resin Dewatering System

#### Waste Characterization and Classification (IP Section 02.03) (1 Sample)

The inspectors evaluated the radioactive waste characterization and classification for the following waste streams:

- (1)
- RWCU - RWCU Resins, February 28, 2019
  - CONDWST - WST RESIN/COND RESIN, March 4, 2019
  - DAW - DRY ACTIVE WASTE, March 4, 2019
  - SPENT - SPENT BEAD RESIN, March 4, 2019
  - SCO - Surface Contaminated Equipment, March 4, 2019
  - LAUNDRY - Contaminated Laundry, March 4, 2019
  - DAW - Dry Active Waste, April 11, 2019

#### Shipment Preparation (IP Section 02.04) (1 Sample)

The inspectors evaluated and observed the following radioactive material shipment preparation processes:

- (1)
  - The inspectors were not able to evaluate and observe actual radioactive material shipment preparation processes as no shipments were in process. The inspectors observed loads of sampled soil being removed from the site which was appropriately surveyed and analyzed. The inspectors also reviewed several shipment packages that included surveys and assessments in preparation for shipment.

#### Shipping Records (IP Section 02.05) (1 Sample)

The inspectors evaluated the following nonexcepted package shipment records:

- (1)
  - 17-24, Type A, October 17, 2017
  - 17-25, Type A, December 6, 2017
  - 17-26, Type A, December 15, 2017
  - 18-05, Type A, August 9, 2018
  - 18-10, Type A, September 11, 2018
  - 18-11, Type A, October 11, 2018
  - 18-14, Type A, December 11, 2018
  - 19-01, Type B, March 4, 2019
  - 19-03, Type B, April 2, 2019

### **OTHER ACTIVITIES – BASELINE**

#### 71151 - Performance Indicator Verification

The inspectors verified licensee performance indicators submittals listed below:

#### IE04: Unplanned Scrams with Complications (USwC) Sample (IP Section 02.03) (1 Sample)

- (1) July 1, 2018 - June 30, 2019

#### PR01: Radiological Effluent Technical Specifications/Offsite Dose Calculation Manual Radiological Effluent Occurrences (RETS/ODCM) Radiological Effluent Occurrences Sample. (IP Section 02.16) (1 Sample)

- (1) October 1, 2018 - June 30, 2019

#### 71152 - Problem Identification and Resolution

#### Semiannual Trend Review (IP Section 02.02) (1 Sample)

- (1) The inspectors reviewed the licensee's corrective action program for potential adverse trends in emergency preparedness drill classification that might be indicative of a more significant safety issue on August 2, 2019.

## 71153 - Followup of Events and Notices of Enforcement Discretion

### Event Report (IP Section 03.02) (1 Sample)

The inspectors evaluated the following licensee event reports (LERs):

- (1) LER 05000298/2018-002-00, Lack of Procedural Guidance Results in Work Scheduling Error Causing Breach of Secondary Containment and Condition Prohibited by Technical Specifications (ADAMS Accession No. ML18353A278). The circumstances surrounding this LER and an associated non-cited violation are documented in the Inspection Results section of this report.

### **INSPECTION RESULTS**

Failure to Implement Fire Protection Program Surveillance Requirements for a Fire Barrier Seal			
Cornerstone	Significance	Cross-Cutting Aspect	Report Section
Mitigating Systems	Green NCV 05000298/2019003-01 Open/Closed	[P.1] - Identification	71111.05Q
<p>The inspectors identified a Green, non-cited violation of License Condition 2.C(4), "Fire Protection," for the failure to implement all provisions of the approved fire protection program. Specifically, prior to July 2, 2019, the licensee failed to implement Surveillance Procedure 6.FP.606, "Fire Barrier/Penetration Seal Visual Examination," Revision 25, for visual inspection of the cable expansion room west wall fire barrier and its associated MN 46 penetration to ensure that an unsealed penetration opening was identified. As a result, the licensee failed to identify that the conduit seal was degraded until it was discovered by the inspectors on July 2, 2019, and subsequently declared nonfunctional by operations personnel.</p> <p><u>Description:</u> On July 2, 2019, the inspectors toured the cable expansion room, a risk-significant area where safety-related cables from both divisions are routed. The inspectors observed that a 3-inch cable conduit ran about 8 feet from the west wall of the room and opened near one of the cable trays. The west wall of the cable expansion room was an FP1 Technical Requirements Manual (TRM)-required fire barrier. The open end of the conduit had four cables in it, and the inspectors noted that the conduit seal material was missing from about half of the conduit opening. The inspectors reported the degraded seal, labeled MN 46, to the control room. In response, operations and fire protection personnel walked down the seal. After review of applicable procedures and plant drawings, the licensee determined that the required intact smoke and hot gas seal could not be proven to exist. Because the deficiency represented an unsealed fire barrier penetration, operations personnel declared the FP1 fire barrier that the conduit penetrated nonfunctional under TRM 3.11.7 and implemented the required hourly fire watch.</p> <p>The inspectors noted that the seal appeared to have been degrading for some period of time prior to discovery and the inspectors noted that the degraded seal should have been identified during inspections required by TRM 3.11.7, "Fire Barrier and Fire Wall Penetration Fire Seals," Technical Surveillance Requirement (TSR) 3.11.7.1. TSR 3.11.7.1 states, "visually inspect each side of each fire barrier and penetration fire seal (where possible)" on a 24-month frequency. The inspectors reviewed the results of the licensee's most recently performed TSR inspection, documented in Procedure 6.FP.606, "Fire Barrier/Penetration Seal Visual Examination," Revision 25, and performed on August 27, 2018. The inspectors noted</p>			

that Procedure 6.FP.606 directed plant personnel to inspect the adequacy of the fire barriers and penetration seals via plant drawings and a checklist of the walls in each room. Step 5.1 contained inspection for "all fire barriers" and required verification that there were "no unsealed openings" and "no unsealed penetrations." The inspectors also noted that Fire Protection Program Procedure 3.6.1, "Fire Barrier Control," Revision 21, stated that the internal sealing requirement for a conduit with a diameter of 2-4 inches is a "smoke and hot gas seal within 5 feet of barrier or nearest opening." In addition, Engineering Evaluation (EE) 10-055, "Conduit Internal Seals," Revision 0, which was credited in the licensee's NFPA 805 licensing basis contained industry testing data and stated, in part, that larger sized conduits, 3 inches diameter and over, allowed quantities of smoke to pass through the barrier and escape the conduits such that an exposure to sensitive equipment on the non-fire side of the barrier could be postulated. The smoke, if released on the non-fire side, could be expected to affect exposed equipment. The inspectors concluded that the seal contained in conduit MN 46 was a required penetration seal, and the lack of an intact seal should have been identified during performance of Procedure 6.FP.606.

After discussion with fire protection personnel, the inspectors noted that although Surveillance Procedure 6.FP.606 required identification of any unsealed openings and penetrations in fire barriers, the licensee failed to implement the procedure in a manner that ensured unsealed conduit penetrations like MN 46 would be identified. Specifically, although conduit MN 46 penetrated the wall and partially extended out into a room where it opened, plant personnel stated that they only inspected the external seal surrounding the outside of the conduit located at the wall and had not inspected the seal at the opening of the conduit. Fire protection personnel stated that they had determined that this seal was inaccessible and inspection at this location was not possible. After review of Procedure 6.FP.606, the inspectors concluded that the seal in question was accessible. Specifically, Procedure 6.FP.606 defines inaccessible as penetration seals or sections of fire barriers/fire walls that cannot be visually examined due to field configurations, and directs consideration of factors like hazardous material exposures, potential for plant trip or damage to safety equipment, and the need to remove permanent plant equipment to access the seal. The inspectors determined that MN 46 met none of the criteria listed in that it was located in an open area approximately 7 feet from the floor and was easily accessed via normal traversing paths. As a result, the inspectors determined that the licensee had failed to inspect the cable expansion room west wall fire barrier and its associated MN 46 penetration in accordance with TSR 3.11.7.1 and Procedure 6.FP.606.

**Corrective Actions:** Corrective actions included declaring the fire barrier nonfunctional, implementing TRM requirements for an hourly fire watch, and resealing the degraded penetration seal.

**Corrective Action References:** Condition Report CR-CNS-2019-03631

**Performance Assessment:**

**Performance Deficiency:** The licensee's failure to implement fire protection program inspection requirements for an FP1 fire barrier was a performance deficiency.

**Screening:** The inspectors determined the performance deficiency was more than minor because it was associated with the Protection Against External Factors attribute of the Mitigating Systems Cornerstone and adversely affected the cornerstone objective to ensure the availability, reliability, and capability of systems that respond to initiating events to prevent undesirable consequences. Specifically, the performance deficiency resulted in a

nonfunctional fire barrier in the cable expansion room, which houses both Division 1 and Division 2 safety-related cabling.

**Significance:** The inspectors assessed the significance of the finding using Appendix A, “The Significance Determination Process (SDP) for Findings At-Power.” Because the finding involved the ability to confine a fire, the inspectors applied Inspection Manual Chapter 0609, Appendix F, “Fire Protection SDP,” to determine the finding’s significance. The inspectors determined that there was an adequate automatic suppression system on either side of the fire confinement element, and therefore, they concluded that the performance deficiency was of very low safety significance (Green).

**Cross-Cutting Aspect:** P.1 - Identification: The organization implements a corrective action program with a low threshold for identifying issues. Individuals identify issues completely, accurately, and in a timely manner in accordance with the program. Specifically, fire protection personnel failed to identify the need to inspect the conduit seal at the opening of fire barrier penetration MN 46 during fire barrier surveillance inspections and failed to identify that the seal was degraded during walkdowns.

**Enforcement:**

**Violation:** License Condition 2.C(4) requires, in part, that, “NPPD shall implement and maintain in effect all provisions of the approved fire protection program.” TRM 3.11.7, “Fire Barrier and Fire Wall Penetration Fire Seals,” TSR 3.11.7.1 states, visually inspect each side of each fire barrier and penetration fire seal (where possible) on a 24-month frequency. Surveillance Procedure 6.FP.606, “Fire Barrier/Penetration Seal Visual Examination,” Revision 25, implements this TSR and Step 5.1 states, in part, for all fire barriers, verify no unsealed openings and no unsealed penetrations.

Contrary to the above, prior to July 2, 2019, the licensee failed to verify there were no unsealed openings and no unsealed penetrations for all fire barriers. Specifically, the licensee failed to implement Surveillance Procedure 6.FP.606 for visual inspection of the cable expansion room west wall fire barrier and its associated MN 46 penetration to ensure that an unsealed penetration opening was identified. As a result, the licensee failed to identify that the conduit seal was degraded and nonfunctional until it was discovered by the inspectors on July 2, 2019.

**Enforcement Action:** This violation is being treated as a non-cited violation, consistent with Section 2.3.2 of the Enforcement Policy.

**Failure to Take Required Actions of Technical Specification 3.5.2 for Reactor Pressure Vessel Water Inventory Control During Secondary Containment Work**

Cornerstone	Significance	Cross-Cutting Aspect	Report Section
Barrier Integrity	Green NCV 05000298/2019003-02 Open/Closed	[H.5] - Work Management	71153

The inspectors documented a self-revealed, Green, non-cited violation of Technical Specification 3.5.2, “Reactor Pressure Vessel Water Inventory Control,” for the licensee’s failure to take technical specification required actions during a reactor pressure vessel water inventory control activity. Specifically, on October 10, 2018, during a planned water inventory control activity, the licensee failed to meet Technical Specification 3.5.2, Condition C, when

an unplanned and unrecognized breach of secondary containment occurred, and the licensee did not verify secondary containment could be closed as required until the breach was discovered several hours later. In particular, during residual heat removal service water piping work, the penetration of the same residual heat removal service water piping on both the control building and reactor building sides of the secondary containment boundary was not recognized, and as a result, a containment closure plan was not in place.

Description: During the licensee's refueling outage, on September 30, 2018, work orders for residual heat removal service water (RHRSW) piping, located in the control building, were added to an originally approved scope on the same line of RHRSW piping located in the reactor building. When the work was added to the original scope, the licensee did not plan for the repairs to be ongoing simultaneously and, therefore, did not identify the need for a contingency plan to be established for a breach of a secondary containment boundary. On October 10, 2018, Day 11 of the refueling outage, control rod drive mechanism (CRDM) maintenance was ongoing during the RHRSW piping repairs. The CRDM maintenance involved some leakage of reactor pressure vessel (RPV) water during the maintenance activity and was considered a planned water inventory control activity (WICA). Technical Specification (TS) 3.5.2, "Reactor Pressure Vessel Water Inventory Control," requires that the drain time of the RPV water inventory to the top of active fuel must be  $\geq 36$  hours. The licensee calculated the drain time to be 21.62 hours for the CRDM maintenance. As such, entry into TS Limiting Condition for Operation (LCO) 3.5.2, Condition C, was required. One of the requirements of TS 3.5.2, Condition C, is that the licensee must verify that each secondary containment penetration flow path will be capable of being isolated in less than the drain time within 4 hours of LCO entry. Upon entry into the LCO for the CRDM work, at 12:10 a.m. on October 10, 2018, the licensee took action to verify containment closure plans were in place for all secondary containment breaches that plant personnel were aware of.

Containment closure contingency planning is contained in the licensee's procedures. Administrative Procedure 0-CNS-OU-108, "Cooper Shutdown Safety Management Program," Revision 6, Section 6.17, contains containment defense in depth considerations that include, in part, maintaining containment closure capability during reduced water inventory operations. Within that section, Step 6.17.4 references Administrative Procedure 0.50.5, "Outage Shutdown Safety," Revision 40, for containment control requirements. Administrative Procedure 0.50.5 states, in part, that during Modes 4 and 5 when containment closure is required, simultaneously breaching both sides of a secondary containment piping penetration requires preplanned means to block off the breach.

On October 10, 2018, at 11:15 a.m., the licensee discovered that both the control building side and the reactor building side of the RHRSW piping were open simultaneously without a preplanned containment closure document (contingency plan) in place and failed to meet the technical specification LCO requirement that was entered for CRDM maintenance. This configuration existed for approximately 8 hours before the breach was secured. The licensee was able to re-establish the boundary in less than 1 hour from discovery and established a containment closure plan for the RHRSW piping work. Had the licensee recognized that the RHRSW piping work was ongoing in both the control building and the reactor building simultaneously during the RPV water inventory control activity, the containment closure plan would have contained these secondary containment penetrations and included them for the verification of flow path isolation capability within the 4-hour time requirement, and the TS violation would not have occurred. However, during the approximately 8 hours that the condition existed, the licensee was unaware of the breach until discovery at 11:15 a.m., and if containment closure was required during that time, sealing of this breach would not have occurred. This issue was identified through an event reported to the NRC as a condition

prohibited by TS in LER 05000298/2018-002-00, "Lack of Procedural Guidance Results in Work Scheduling Error Causing Breach of Secondary Containment and Condition Prohibited by Technical Specifications." It was self-revealed in that workers in the vicinity were unable to weld due to the sustained high volume of air flow through the secondary containment breach.

Corrective Actions: The licensee immediately stopped work, re-established the secondary containment boundary within an hour, and established a contingency closure plan for the RHRSW piping repairs.

Corrective Action References: Condition Report CR-CNS-2018-06295

Performance Assessment:

Performance Deficiency: The licensee's failure to take actions required by Technical Specification 3.5.2 for reactor pressure vessel water inventory control is a performance deficiency.

Screening: The inspectors determined the performance deficiency was more than minor because it was associated with the Configuration Control attribute of the Barrier Integrity Cornerstone and adversely affected the cornerstone objective to provide reasonable assurance that physical design barriers protect the public from radionuclide releases caused by accidents or events. Specifically, the licensee was unaware that there was ongoing work on RHRSW piping in both the control building and reactor building that breached secondary containment. These piping penetrations were not contained in a contingency closure plan and thus not verified to be capable of being isolated within the 4 hours required by TS LCO 3.5.2, Condition C, when performing a reactor pressure vessel water inventory control activity.

Significance: The inspectors assessed the significance of the finding using Appendix G, "Shutdown Safety SDP." The inspectors determined that the performance deficiency degraded the ability to close or isolate the containment, and as a result, Appendix G, Attachment 1, Exhibit 4, directed entry into Inspection Manual Chapter 0609, Appendix H, "Containment Integrity Significance Determination Process." The inspectors applied Appendix H, Section 07.02, "Approach for Assessing Type B Findings at Shutdown," Step 2.1, to the finding. At the time of the event, the plant operating status (POS) was "POS 3," which represents the Mode 5 shutdown condition when the RPV water level is  $\geq$  the minimum level required for movement of irradiated fuel assemblies within the RPV. The inspectors determined that the finding was of very low safety significance (Green) because it: (1) did not occur in POS 1 or POS 2; (2) did not occur in TW-E (Early Time Window); and (3) it did not occur within 8 days of the start of the outage.

Cross-Cutting Aspect: H.5 - Work Management: The organization implements a process of planning, controlling, and executing work activities such that nuclear safety is the overriding priority. The work process includes the identification and management of risk commensurate to the work and the need for coordination with different groups or job activities. Specifically, the licensee failed to implement a process of planning, controlling, and executing work, resulting in a breach of secondary containment that was not recognized as a secondary containment penetration that needed to be verified to be capable of isolation by TS 3.5.2, Condition C, for the RPV water inventory control activity.

Enforcement:

Violation: Technical Specification (TS) 3.5.2, "RPV Water Inventory Control," requires, in part, that in Modes 4 and 5, drain time of RPV water inventory to the top of active fuel (TAF) shall be  $\geq 36$  hours. The TS action statement requires that, "with Drain time  $< 36$  hours and  $\geq 8$  hours, verify each secondary containment penetration flow path is capable of being isolated in less than the drain time within 4 hours or initiate action to restore drain time to  $\geq 36$  hours immediately.

Contrary to the above, on October 10, 2018, for approximately 8 hours, while in Mode 5, the licensee failed to ensure the drain time of RPV water inventory to the TAF was  $\geq 36$  hours or take the required actions. Specifically, with the drain time of  $< 36$  hours and  $\geq 8$  hours, the licensee failed to verify each secondary containment penetration flow path was capable of being isolated in less than the drain time within 4 hours or initiate action to restore drain time to  $\geq 36$  hours immediately. In particular, improperly sequenced RHRSW work created an unplanned and unrecognized breach of secondary containment, which resulted in the licensee failing to identify the need to take the TS required actions.

Enforcement Action: This violation is being treated as a non-cited violation, consistent with Section 2.3.2 of the Enforcement Policy.

## **EXIT MEETINGS AND DEBRIEFS**

The inspectors verified no proprietary information was retained or documented in this report.

- On August 22, 2019, the inspectors presented the Public Radiation Safety Cornerstone inspection results to Mr. J. Sullivan, General Manager Plant Operations, and other members of the licensee staff.
- On September 19, 2019, the inspectors presented the Evaluations of Changes, Tests, and Experiments inspection results to Mr. J. Sullivan, General Manager of Plant Operations, and other members of the licensee staff.
- On October 17, 2019, the inspectors presented the integrated inspection results to Mr. J. Sullivan, General Manager Plant Operations, and other members of the licensee staff.

## DOCUMENTS REVIEWED

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.04Q	Drawings	2006, Sheet 4	Flow Diagram Control Building Service Water System	61
71111.04Q	Drawings	2036, Sheet 1	Flow Diagram Reactor Building Service Water System	A6
71111.04Q	Drawings	2043	Flow Diagram Reactor Core Isolation Coolant and Reactor Feed Systems	57
71111.04Q	Drawings	2045, Sheet 1	Flow Diagram Core Spray System	N58
71111.04Q	Procedures	2.2.67	Reactor Core Isolation Cooling System	80
71111.04Q	Procedures	2.2.67.1	Reactor Core Isolation Cooling System Operations	45
71111.04Q	Procedures	2.2.67A	Reactor Core Isolation Cooling System Component Checklist	23
71111.04Q	Procedures	2.2.67B	Reactor Core Isolation Cooling System Instrument Valve Checklist	3
71111.04Q	Procedures	2.2.74A	Standby Liquid Control System Component Checklist	11
71111.04Q	Procedures	2.2.74B	Standby Liquid Control System Instrument Valve Checklist	1
71111.04Q	Procedures	2.2.9	Core Spray System	85
71111.04Q	Procedures	2.2A.CS.DIV2	Core Spray Component Checklist (DIV 2)	3
71111.04Q	Procedures	2.2A.RHRSW.DIV1	RHR Service Water Booster Pump System Component Checklist	10
71111.04Q	Procedures	2.2B.CS.DIV2	Core Spray System Instrument Valve Checklist (DIV 2)	0
71111.04Q	Procedures	2.2B.RHRSW.DIV1	RHR Service Water Booster Pump System Instrument Valve Checklist	0
71111.04Q	Work Orders	WO	5211509	
71111.05Q	Corrective Action Documents	CR-CNS-	2019-03631	
71111.05Q	Engineering Evaluations	EE 10-055	Conduit Internal Seals	0
71111.05Q	Fire Plans	CNS-FP-136	Fire Area Boundary Drawing	6
71111.05Q	Fire Plans	CNS-FP-212	Reactor SE Quad, Elevations 881 and 859	0
71111.05Q	Fire Plans	CNS-FP-285	Fire Barrier Penetration Seal Details	7
71111.05Q	Miscellaneous	CNS-FP-234	Office Building Cable Expansion Room Elevation 918' 6"	4
71111.05Q	Miscellaneous	CNS-FP-39	Reactor Building Suppression Pool Elevation 859'-9"	0
71111.05Q	Miscellaneous	NEDC 10-080	Fundamental Fire Protection Program and Design Elements Review	4

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.05Q	Procedures	0-BARRIER-MAPS	Barrier Maps	9
71111.05Q	Procedures	0-BARRIER-MAPS	Barrier Maps	10
71111.05Q	Procedures	0-BARRIER-REACTOR		14
71111.05Q	Procedures	0.7.1	Control of Combustibles	40
71111.05Q	Procedures	3.6.1	Fire Barrier Control	21
71111.05Q	Procedures	6.FP.606	Fire Barrier/Penetration Seal Visual Examination	25
71111.06	Corrective Action Documents	CR-CNS-	2017-00229, 2019-02931, 2019-04268, 2019-05066, 2019-05271, 2019-05283	
71111.06	Procedures	0-BARRIER	Barrier Control Process	29
71111.06	Procedures	0-BARRIER-REACTOR		14
71111.11Q	Miscellaneous	RMP 31-013	Quarterly Downpower, 10-EN-RE-215/6CO, Att 2	0
71111.11Q	Procedures	10.13	Control Rod Sequence and Movement Control	75
71111.11Q	Procedures	10.9	Control Rod Scram Time Evaluation	71
71111.11Q	Procedures	2.0.3	Conduct of Operations	102
71111.12	Corrective Action Documents	CR-CNS-	2018-07835, 2019-02127, 2019-02581, 2019-03265, 2019-03488, 2019-03501, 2019-03934, 2019-03936, 2019-04317, 2019-04336, 2017-04701	
71111.12	Engineering Evaluations	EE-PF02F	Maintenance Rule Function EE-PF02F Performance Criteria Basis	4
71111.12	Miscellaneous		Maintenance Rule (a)(1) Evaluation RCIC-PF01 – RCIC System	0, 1
71111.12	Miscellaneous	8001553-1	Turbine Control Schematic	1
71111.12	Miscellaneous	RCIC-PF01	Maintenance Rule Function RCIC-PF01 Performance Criteria Basis	6
71111.12	Procedures	3-EN-DC-206	Maintenance Rule (a)(1) Process	3C3
71111.12	Procedures	6.2HV.601	Air Flow Test of Fan Coil Unit FC-R-1E (DIV 2)	7
71111.12	Work Orders	WO	5312924	
71111.13	Corrective Action Documents	CR-CNS-	2019-03936, 2019-03947, 2019-03964, 2019-04218, 2019-04347	
71111.13	Drawings		18'-900# Gate Valve – R.S.-Press Seal Cast STL WCB – Stellite Trim – B.W. Ends SMB-2 (60#) Motor Operator	760-3

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.13	Miscellaneous		Critical Evolutions Meeting Presentation – RF-MOV-29MV Reactor Feed Pump 'A' Discharge Valve, Packing Gland Leak Injection	
71111.13	Miscellaneous		Risk Management Plan - RF-MOV-29MV Reactor Feed Pump A Discharge Valve, Packing Gland Leak Injection	
71111.13	Miscellaneous		Protected Equipment Tracking Form – ESST Planned Work Window	08/21/2019
71111.13	Miscellaneous		Protected Equipment Tracking Form – SLC A LCO	07/08/2019
71111.13	Miscellaneous		Protected Equipment Tracking Form – Core Spray B 1933 Maintenance Window	08/13/2019
71111.13	Miscellaneous		Protected Equipment Tracking Form – RCIC inoperable	07/24/2019
71111.13	Miscellaneous	5284609-03	Work Plan, RF-MOV-29MV	
71111.13	Miscellaneous	5284609-05	Work Plan, RF-MOV-29MV	
71111.13	Procedures	0-CNS-WM-104	Online Schedule Risk Assessment	9
71111.13	Procedures	0-CNS-WM-104	Attachment 1, Risk Characterization, for WO 5284609-5	
71111.13	Procedures	0-PROTECT-EQP	Protected Equipment Program	46
71111.13	Work Orders	WO	5201509, 5209480, 5211242, 5211244, 5211377, 5211509, 5284609-Rev. 3, 5284609-Rev. 5, 5309711	
71111.15	Corrective Action Documents	CR-CNS-	2017-04701, 2019-02127, 2019-03189, 2019-03478, 2019-03860, 2019-03889, 2019-03934, 2019-03936, 2019-04317, 2019-04336	
71111.15	Drawings	2040, Sheet 2	Flow Diagram – Residual Heat Removal Sys Loop “B”	20
71111.15	Engineering Evaluations	EE 10-073	Deletion of Type C Testing of One Barrier due to Closed Loop Analysis for 9 Pens	0
71111.15	Miscellaneous		CNS Original Custom Technical Specifications	
71111.15	Miscellaneous	LO 2019-0045	Part 21 Issue	06/07/2019
71111.15	Miscellaneous	USQE-1999	Combine Table V-2-7 and Table VII-3-1	0
71111.15	Procedures	6.2HV.601	Air Flow Test of Fan Coil Unit FC-R-1E (DIV 2)	7
71111.15	Procedures	6.2SW.401	Diesel Generator Service Water Check Valve and Sump Test (IST) (DIV 2)	3
71111.15	Work Orders	WO	5166780, 5196337, 5312924	
71111.17T	Calculations	NEDC 92-064	Transient Temperature Rise in SWBP Room After Loss of Cooling	3
71111.17T	Calculations	NEDC 94-034B	CNS Containment System Response for NPSH Analysis	2

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.17T	Calculations	NEDC 97-044A	NPSH Margins for the RHR and CS Pumps	4
71111.17T	Calculations	NEDC 97-044D	RHR and HPCI NPSH Margins for ATWS Event	2
71111.17T	Corrective Action Documents	CR-CNS-	2019-02345, 2019-02364, 2019-03587, 2019-03790, 2019-03880, 2019-04668	
71111.17T	Corrective Action Documents Resulting from Inspection	CR-CNS-	2019-04959	
71111.17T	Drawings	CNS-EE-319	SSST OPP Cabinets #1 and #2 Connection Diagram	01
71111.17T	Drawings	3001	Main One Line Diagram	30
71111.17T	Drawings	3006, Sh. 5	Auxiliary One Line Diagram MCC Z, SWGR Bus 1A, 1B, 1E, & Critical SWGR Bus 1F 1G	37
71111.17T	Drawings	3006, Sh. 5	Auxiliary One Line Diagram Starter Racks LZ and TZ MCC's K, L, LX, RA, RX, S, T, TX, X	90
71111.17T	Drawings	3017, Sh. 1	4160V Switchgear Elementary Diagrams	26
71111.17T	Drawings	3020, Sh. 4	4160V Switchgear Elementary Diagrams	27
71111.17T	Drawings	3031, Sh. 3	Control Elementary Diagrams Switch Developments	31
71111.17T	Drawings	3040, Sh. 9	Control Elementary Diagram	40
71111.17T	Drawings	3253, Sh. DT4	460V Motor Control Centers Wiring Details, Connection Wiring Diagram	21
71111.17T	Drawings	3700, Sh. 19	Annunciator Elementary Ladder Diagram	N09
71111.17T	Drawings	791E271, Sh. 6	HPCI System Elementary Diagram	21
71111.17T	Drawings	CNS-EE-320	ESST OPP Cabinets #1 and #2 Connection Diagram	01
71111.17T	Drawings	IL-E-70-3, Sh. 107B	Area Temp. Monitoring System for Nuclear Boiler Systems Leak Detection	7
71111.17T	Drawings	IL-E-70-3, Sh. 107BB	Area Temperature Monitoring System for Nuclear Boiler Systems Leak Detection	1
71111.17T	Drawings	NC 02161	One-line Switching Diagram 345KV/161KV/4160V	34
71111.17T	Drawings	NC 43456	Cooper 161kV Substation One-line Switching Diagram	13
71111.17T	Drawings	NC 66688	Cooper 345kV Substation One-line Switching Diagram	24
71111.17T	Drawings	OPP-ELE-B101, Pg. 1 of 18	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Pg. 2 of 18	Open Phase Detection and Protection System	01

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.17T	Drawings	OPP-ELE-B101, Sh. 3 of 18	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Sh. 4 of 18	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Sh. 5	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Sh. 6	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Sh. 7	Open Phase Detection and Protection System	01
71111.17T	Drawings	OPP-ELE-B101, Sh. 8 of 18	Open Phase Detection and Protection System	01
71111.17T	Drawings	SKE-EC-6016502-3	HPCI Flow Control Wiring Diagram	5
71111.17T	Engineering Changes	DEC 5243039	Emergency Diesel Generator Indicating Light Isolation	0
71111.17T	Engineering Changes	EC 6016502	HPCI Flow Control	0
71111.17T	Engineering Changes	EC 60387820	Main Generator Under Frequency Relay Replacement	0
71111.17T	Engineering Changes	EC 6040480	SWBP Oil Sight Glasses and Reservoir	0
71111.17T	Engineering Evaluations	EE 16-021	Engineering Evaluation for 161KV Low Voltage Limit	0
71111.17T	Engineering Evaluations	EE 16-048	Engineering Evaluation MCC-L and MCC-T to Non-Essential	0
71111.17T	Engineering Evaluations	EE 18-012	Re-Evaluation of Torus Inspection Frequency During Period of Extended Operation	0
71111.17T	Engineering Evaluations	EE 18-028	Various MOV Packing Load Adjustment Calculation Revisions	0
71111.17T	Engineering Evaluations	EE 18-045	HPCI LOC HX Thermal Performance and Tube Plugging Margin	0
71111.17T	Engineering Evaluations	EE 18-046	RHR and HPCI NPSH Margins for ATWS Event	0

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.17T	Engineering Evaluations	EE 19-018	REC HX Allowable Tube Plugging Increase	0
71111.17T	Engineering Evaluations	EE-18-021	Engineering Evaluation for Reclassifying Relays HV-REL-1CFX and HV-REL-1DFX to Non-Essential	15C11
71111.17T	Engineering Evaluations	MDE-270-1285	Evaluation of ATWS Performance at Cooper Nuclear Station	December 1985
71111.17T	Miscellaneous	CDA-EE-001-C1	Control Group Assessment - Open Phase Protection System Controller (CRIO-9068)	1
71111.17T	Miscellaneous	CDA-EE-001-ES	Control Group Assessment - Open Phase Protection System Injection Source	0
71111.17T	Miscellaneous	CDA-EE-001-ES1	Control Group Assessment - Open Phase Protection System DC Power Supply	0
71111.17T	Miscellaneous	CDA-EE-001-KP	Control Group Assessment - Open Phase Protection System Keypad	0
71111.17T	Miscellaneous	CDA-EE-001-R	Control Group Assessment - Open Phase Protection System Recorder	0
71111.17T	Miscellaneous	CDA-EE-001-REL	Control Group Assessment - Open Phase Protection System Current Switch	0
71111.17T	Miscellaneous	CDA-EE-001-UPS	Control Group Assessment - Open Phase Protection System UPS	0
71111.17T	Miscellaneous	CDA-EE-0013	Functional Description and Consequence Analysis	3
71111.17T	Miscellaneous	IEGR-MN-699	Vendor Manual Open Phase Protection (OPP) System Operating and Maintenance Manual	1.03
71111.17T	Miscellaneous	NLS2018053	10 CFR 50.59(dX2) and 10 CFR 72.48(dX2) Summary Report Cooper Nuclear Station, Docket No. 50-298, License No. DPR-46	10/08/2018
71111.17T	Miscellaneous	RCE 2017-07513	Both EDGs Declared Inoperable Due to Test Failure of Spare Indicating Light	1
71111.17T	Procedures	0-CNS-LI-100	Process Applicability Determination	26
71111.17T	Procedures	0-CNS-LI-101	10 CFR 50.59 Evaluations	19
71111.17T	Procedures	0-CNS-LI-112	10 CFR 72.48 Evaluations	13
71111.17T	Procedures	0-EN-HU-106	Procedure and Work Instruction Use and Adherence	3C2
71111.17T	Procedures	2.0.1.3	Time Critical Operator Action Control and Maintenance	7
71111.17T	Procedures	2.1.11.1	Turbine Building Data	178

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.17T	Procedures	2.2.70	RHR Service Water Booster Pump System	90
71111.17T	Procedures	2.3_R-1	Alarm Procedure for Panel R – Annunciator R-1	19
71111.17T	Procedures	2.4HVAC	Computer Room Ventilation Failure/Temperature High	24
71111.17T	Procedures	3-ED-DC-167	Classification of Structure, Systems, and Component	4C2
71111.17T	Procedures	3-EN-DC-115	Engineering Change Process	15C14
71111.17T	Procedures	6.1EE.302	4160V Bus 1F Undervoltage Relay and Relay Timer Functional Test (DIV 1)	45
71111.17T	Procedures	6.1EE.306	4160V Bus 1F Undervoltage Relay Channel Functional Test (DIV 1)	04
71111.17T	Procedures	7.2.14	RHR SWBP Overhaul and Replacement	45
71111.17T	Procedures	7.3.41	Examination, Repair, High Pot Testing of Non-Segregated Buses and Associated Equipment	16
71111.17T	Procedures	IP-ENG-001	Standard Design Process	0C0
71111.17T	Self-Assessments	2019-0098	50.59 Pre-Inspection Focused Self-Assessment	1
71111.17T	Self-Assessments	QAD 2018-008	QA Audit 18-02, "Engineering"	03/27/2018
71111.19	Corrective Action Documents	CR-CNS-	2017-04701, 2019-03889, 2019-04141, 2019-04142, 2019-04209, 2019-04222, 2019-04317, 2019-04336	
71111.19	Miscellaneous		SW-CV-37 Leakage Troubleshooting Plan	0
71111.19	Miscellaneous	11628207	Notification	
71111.19	Procedures	2.2.8	Control Rod Drive System	106
71111.19	Procedures	6.2CS.101	Core Spray Test Mode Surveillance Operation (IST) (DIV 2)	32
71111.19	Procedures	6.2CS.201	CS Motor Operated Valve Operability Test (IST) (DIV 2)	22
71111.19	Procedures	6.2HV.601	Air Flow Test of Fan Coil Unit FC-R-1E (DIV 2)	7
71111.19	Procedures	6.2SW.401	Diesel Generator Service Water Check Valve and Sump Test (IST) (DIV 2)	3
71111.19	Procedures	6.CRD.201	North and South SDV Vent and Drain Valve Cycling, Open Verification, and Timing Test	27
71111.19	Procedures	6.SC.501	Secondary Containment Leak Test	28
71111.19	Procedures	6.SC.502	Secondary Containment Penetration Examination	19
71111.19	Procedures	7.0.10	Railroad Airlock Door Operations	26
71111.19	Procedures	7.0.5	Post-Maintenance Testing	59
71111.19	Work Orders	WO	5201509, 5209480, 5210423, 5211242, 5211244, 5211377, 5265105, 5309143, 5312924	

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71111.22	Corrective Action Documents	CR-CNS-	2019-23824	
71111.22	Miscellaneous	2174	Vendor Manual – Mohr SFP-1 Level Prove Assembly Technical Manual	02/13/2015
71111.22	Procedures	14.41.1.2	FPC-LIT-2 Testing	4
71111.22	Procedures	2.2.32	Fuel Pool Cooling and Demineralizer System	105
71111.22	Procedures	2.2.84	HVAC Main Control Room and Cable Spreading Room	59
71111.22	Procedures	6.2DG.101	Diesel Generator 31 Day Operability Test (IST) (DIV 2)	86
71111.22	Procedures	6.HV.105	Control Room Envelope Pressurization and CREFS Flow Test	20
71111.22	Procedures	6.REC.201	REC Motor Operated Valve Operability Test (IST)	31
71111.22	Work Orders	WO	5195163, 5234083	
71114.06	Miscellaneous		Drill Scenario Guide	07/30/2019
71124.05	Calibration Records	5149599	Area Radiation Monitors Calibration and Functional Test	09/20/2018
71124.05	Calibration Records	5156820	SW Radiation Monitor - B Calibration Check and Instrument Channel Test – RMP-RM-332B	05/16/2018
71124.05	Calibration Records	5166729	High Range Containment Monitor Victoreen Model 875 Source Calibration Check	10/03/2018
71124.05	Calibration Records	5166732	Containment High Range Monitors A/R/H Determination	10/03/2018
71124.05	Calibration Records	5166734	Main Steam Line Process Radiation Monitor Channel Calibration, Source Test, and Setpoint Determination RMP-RM-251A/B/C/D Data Sheets	10/04/2018
71124.05	Calibration Records	5167782	Containment High Range Area Monitor Channel Calibration RMA-RM-40 A/B	08/29/2018
71124.05	Calibration Records	5167787	Main Steam Line Process Radiation Monitor Channel Calibration, Source Test, and Setpoint Determination RMP-RM-251A/B/C/D Data Sheets	09/11/2018
71124.05	Calibration Records	5186806	REC Radiation Monitor Calibration Check and Instrument Channel Test	05/01/2019
71124.05	Calibration Records	Detector 1	2 Inch Particulate Filter at 5 cm	05/03/2017
71124.05	Calibration	Detector 1	2000 ml Marinelli with 1.5 Density	05/17/2017

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
	Records			
71124.05	Calibration Records	Detector 1	500 cc Charcoal Marinelli	10/05/2018
71124.05	Calibration Records	Detector 1	Charcoal Cartridge at 5 cm	05/05/2017
71124.05	Calibration Records	DG11095729	Tri-Carb 2910TR Efficiency Calibration	02/28/2019
71124.05	Calibration Records	RP-10571	Instrument Calibration Sheet (PCM-2) S/N 401	07/03/2019
71124.05	Calibration Records	RP-10588	RMV-CAM-20 Particulate & Iodine Calibration Sheets	03/27/2019
71124.05	Calibration Records	RP-10765/11497	Instrument Calibration Data Sheet – AMS-4	01/19/2019
71124.05	Calibration Records	RP-10848	XLB Calibration Data Sheet – Unit 1	01/23/2019
71124.05	Calibration Records	RP-11152	Instrument Calibration Sheet Thermo Eberline SAM Contamination Monitor	05/22/2019
71124.05	Calibration Records	RP-11178	PM-12 Calibration Data Sheet S/N 0902PM1207	06/11/2018
71124.05	Calibration Records	RP-11241	Instrument Calibration Data Sheet – DRM-1 or DRM-2	06/25/2019
71124.05	Calibration Records	RP-11376	Instrument Calibration Data Sheet – RO-20	02/14/2019
71124.05	Calibration Records	RP-11724	Instrument Calibration Data Sheet – H-809V1	06/10/2019
71124.05	Corrective Action Documents	CR-CNS-	2017-06407, 2017-06689, 2018-03723, 2018-05687, 2018-06543, 2018-08139, 2019-00818, 2019-00866, 2019-00880, 2019-01310, 2019-01442, 2019-02130, 2019-02362, 2019-02669	
71124.05	Miscellaneous		PCM-2 Weekly Source Checks	08/18/2019
71124.05	Miscellaneous		PM-7/PM-12 Daily/Weekly Source Checks	08/20/2019
71124.05	Miscellaneous		SAM-11 / SAM-12 Weekly Functional Checks	08/18/2019
71124.05	Miscellaneous		CNS System Health Report - RM	06/2019
71124.05	Miscellaneous		Results of Radiochemistry Cross Check Program (Quarterly)	12/13/2017

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
			Results)	through 06/05/2019
71124.05	Miscellaneous	878-10	Source Calibration Certificate (S/N 135)	06/26/2003
71124.05	Miscellaneous	878-10A	Source Calibration Certificate (S/N 126)	09/24/2003
71124.05	Miscellaneous	878-10B	Source Calibration Certificate (S/N 121)	09/18/2003
71124.05	Procedures	15.ARM.302	Area Radiation Monitors Calibration and Functional Test	19
71124.05	Procedures	6.PRM.322	Containment High Range Area Monitor Channel Calibration	21
71124.05	Procedures	6.PRM.323	High Range Containment Monitor Victoreen Model 875 Source Calibration Check	9
71124.05	Procedures	6.PRM.324	Main Steam Line Process Radiation Monitor Channel Calibration, Source Test and Setpoint Determination	29
71124.05	Procedures	6.PRM.326	Drywell Air Sampling System Known Source Calibration and Functional Test	17
71124.05	Procedures	6.PRM.329	Containment High Range Monitors A/R/H Determination	5
71124.05	Procedures	6.PRM.331	SW Radiation Monitor A Calibration Check and Instrument Channel Test	15
71124.05	Procedures	8-CNS-CY-102	Laboratory Analytical Quality Control	2
71124.05	Procedures	8-CNS-CY-110	Canberra APEX Gamma Spectroscopy System Operation	2
71124.05	Procedures	8.5.2.4	Tri-Carb 2910TR Liquid Scintillation System	2
71124.05	Procedures	9.INST.15	Rem 500 Neutron Survey Meter	1
71124.05	Procedures	9.INST.53	Ion Chamber Survey Instrument Eberline Model RO-20	7
71124.05	Procedures	9.INST.57	Friskers	6
71124.05	Procedures	9.INST.64	Thermo Electron Corporation Small Articles Monitor (SAM)	4
71124.05	Procedures	9.INST.68	WR Telepole GM Survey Instrument	4
71124.05	Self-Assessments	LO 2018-0186-04	Radiological Monitoring Instrumentation and Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transport	05/17/2019
71124.05	Self-Assessments	QAD 2018-019	QA Audit 18-05, "Radiological Controls"	08/23/2018
71124.06	Corrective Action Documents	CR-CNS-	2017-04647, 2017-05654, 2017-05888, 2017-06574, 2018-00199, 2018-02613, 2018-03046, 2018-03588, 2018-04125, 2018-04354, 2018-04569, 2018-04936, 2018-05167, 2018-07906, 2018-07922, 2019-01916, 2019-02850, 2019-02904, 2019-03082, 2019-03460, 2019-03497, 2019-03946	
71124.06	Miscellaneous		Teledyne Brown Engineering Environmental Services	07/20/2019

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
			Laboratory Quality Control Program: 2nd Quarter 2019 Quality Assurance Report	
71124.06	Miscellaneous		Teledyne Brown Engineering Environmental Services Laboratory Quality Control Program: 4th Quarter 2018 Quality Assurance Report	02/04/2019
71124.06	Miscellaneous	20-AUG-19-210006	Gama Spectrum Analysis: ERP Particulate	08/20/2019
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	08/17/2018
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	11/17/2018
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	12/31/2018
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	03/27/2019
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	04/02/2019
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	05/25/2019
71124.06	Miscellaneous	Liquid Radioactive Waste Discharge Form	Liquid Radioactive Waste Discharge Form: Floor Drain Sample Tank (FDST)	07/03/2019
71124.06	Miscellaneous	LO-2018-0186-008	Liquid and Gaseous Effluents Focused Self-Assessment Report	06/05/2019
71124.06	Miscellaneous	NUPIC Audit 24791	NUPIC Audit/Survey: Teledyne Brown Engineering-Environmental Services	05/09/2019
71124.06	Miscellaneous	NUPIC Audit: 24391	NUPIC Audit/Survey: NCS Corporation	03/30/2017

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71124.06	Miscellaneous	ODAM	Cooper Nuclear Station Offsite Dose Assessment Manual for Gaseous and Liquid Effluents	10/03/2018
71124.06	Miscellaneous	ODAM	2018 Annual Land Use Census	07/16/2018
71124.06	Miscellaneous	QAD 2017-0031	Quality Assurance (QA) Audit 17-07: "Chemistry and Radiological Effluent and Environmental Monitoring Program"	10/11/2017
71124.06	Procedures	6.1SGT.501	SGT A Carbon Sample, Carbon Absorber and HEPA Filter In-Place Leak Test, and Components Leak Test (DIV 1)	18
71124.06	Procedures	6.2SGT.501	SGT B Carbon Sample, Carbon Absorber and HEPA Filter In-Place Leak Test, and Components Leak Test (DIV 2)	20
71124.06	Procedures	6.HV.104	Control Room Emergency Filter System Flow Test, Charcoal and HEPA Filter Leak Test, Filter DP Test, and Charcoal Sample Analysis	19
71124.06	Procedures	6.PRM.306	Liquid Radwaste Effluent Flow Monitor Channel Calibration	8
71124.06	Procedures	6.PRM.308	Liquid Radwaste Effluent System Channel Calibration	15
71124.06	Procedures	6.PRM.310	ERP Kaman Monitor Channel Calibration	28
71124.06	Procedures	6.PRM.313	Reactor Building Kaman Monitor Channel Calibration	18
71124.06	Procedures	6.PRM.320	Radwaste Building Kaman Monitor Channel Calibration	28
71124.06	Procedures	6.PRM.328	Kaman Sample Flow System Channel Calibration	13
71124.06	Procedures	8-CNS-CY-102	Laboratory Analytical Quality Control	2
71124.06	Procedures	8.11.1	EFFECTS Program	21
71124.06	Procedures	8.8.1.19	Effluent Composite Sample Preparation and Analysis	0
71124.06	Procedures	8.8.11	Liquid Radioactive Waste Discharge Authorization	34
71124.06	Procedures	8.8.ERP	Particulate and Iodine Sample Collection for ERP Effluent	18
71124.06	Procedures	8.8.RW	Particulate and Iodine Sample Collection for Radwaste Building Effluent	13
71124.06	Procedures	8.8.RX	Particulate and Iodine Sample Collection for Reactor Building Effluent	16
71124.06	Procedures	8.8.TB	Particulate and Iodine Sample Collection for Turbine Building Effluent	13
71124.06	Work Orders	WO	5028538, 5034888, 5043642, 5078036, 5078037, 5080852, 5094262, 5114291, 5119827, 5123375, 5132845, 5147008, 5149663, 5166229, 5166230, 5180017, 5183064, 5189063, 5191559, 5202504, 5226340, 5285586	
71124.07	Calibration	7318	Sample Station No. 7 Pump	04/10/19

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
	Records			
71124.07	Calibration Records	7319	Sample Station No. 2 Pump	04/23/19
71124.07	Calibration Records	7321	Sample Station No. 111	04/10/19
71124.07	Calibration Records	7453	Sample Station No. 8	
71124.07	Calibration Records	7454	Sample Station No. 10	04/10/19
71124.07	Calibration Records	7455	Sample Station No. 1 Pump	04/10/19
71124.07	Calibration Records	7539	Sample Station No. 9	04/10/19
71124.07	Corrective Action Documents	CR-CNS-	2017-06303, 2017-06091, 2017-06726, 2018-00145, 2018-00508, 2018-00643, 2018-01230, 2018-01646, 2018-02826, 2018-03600, 2018-04300, 2018-07515, 2019-01684, 2019-02054, 2019-02653, 2019-02693, 2019-02772, 2019-02966, 2019-03245	
71124.07	Miscellaneous		2018 Land Use Census	07/11/18
71124.07	Miscellaneous		2018 Cooper Nuclear Station Radioactive Effluent Release Report	2018
71124.07	Miscellaneous		2017 Cooper Nuclear Station Radioactive Effluent Release Report	2017
71124.07	Miscellaneous		Cooper Radiological Environmental Monitoring Program 2017 Annual Report	12/31/17
71124.07	Miscellaneous		Cooper Radiological Environmental Monitoring Program 2017 Annual Report	12/31/18
71124.07	Miscellaneous		2019 Land Use Census	07/15/19
71124.07	Procedures	8.ENV.1	CNS Radiological Environmental Monitoring Program Administration	4
71124.07	Procedures	8.ENV.4	CNS Environmental Air Pump Calibration and Maintenance	0
71124.07	Procedures	8.ENV.5	Annual Review of Broadleaf Vegetation Sample Locations Procedure	0
71124.07	Procedures	8.ENV.8	Administering the CNS Meteorological Program (CNS MET)	3

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71124.07	Procedures	8.ENV.9	Ground Water Monitoring Program Sampling, Monitoring, and Administrative Requirements	11
71124.07	Procedures	14.MET.304	Meteorological Maintenance Procedure for New 100-Meter Tower - System A	
71124.07	Procedures	14.MET.305	Meteorological Maintenance Procedure for New 100-Meter Tower - System B	
71124.07	Procedures	8.ENV.2	REMP Sampling	4
71124.07	Procedures	8.ENV.3	Action Levels for Environmental Samples	3
71124.07	Self-Assessments		CNS Environmental Program Self-Assessment Support in Advance of NRC Inspection	07/24/19
71124.07	Self-Assessments		Cooper Nuclear Station 2018 Environmental Assessment	07/26/18
71124.07	Self-Assessments	LO Number: 2018-0186-008 - Assessment Report	Radiological Environmental Monitoring Program Focused Self-Assessment Report	06/06/19
71124.07	Self-Assessments	NUPIC Audit/Survey Number: 24229	Duke Energy / NUPIC QA Audit of GEL Laboratories - October 2016	11/01/16
71124.07	Self-Assessments	NUPIC Audit/Survey Number: 24791	Radioanalytical Laboratory Audit Report: Teledyne Brown Engineering-Environmental Services	04/19/19
71124.07	Self-Assessments	SS17-009	4500187675 "2016-2018 Environmental TLD Service"	11/06/17
71124.08	Corrective Action Documents	CR-CNS-	2017-02377; 2017-06224; 2017-06352; 2018-00572; 2019-01039; 2019-02631	
71124.08	Corrective Action Documents Resulting from Inspection	CR-CNS-	2019-04451; 2019-04462	
71124.08	Miscellaneous		Gamma Spectrum Analysis of ERP Tower Silt	07/31/2019
71124.08	Miscellaneous		2017 Cooper Nuclear Station Radioactive Effluent Release Report	2017
71124.08	Miscellaneous		2018 Cooper Nuclear Station Radioactive Effluent Release Report	2018
71124.08	Miscellaneous		Onsite Radioactive Material Storage Areas	08/05/2019

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71124.08	Miscellaneous		Offsite Radioactive Material Storage Inventory	05/20/2019
71124.08	Miscellaneous		Radioactive Material Storage Building Inventory	08/06/2019
71124.08	Miscellaneous		Top Ten Equipment Reliability Action Plan - Radwaste System Reliability	08/05/2019
71124.08	Miscellaneous	469062001	Waste Stream Analysis for Dry Active Waste	11/14/2018
71124.08	Miscellaneous	CNS-RP-602	CNS Radioactive Material Shipment Log - 2017	2017
71124.08	Miscellaneous	CNS-RP-602	CNS Radioactive Material Shipment Log - 2018	2018
71124.08	Miscellaneous	CNS-RP-602	CNS Radioactive Material Shipment Log - 2019	2019
71124.08	Procedures	0.PCP.1	Process Control Program	0
71124.08	Procedures	2.5.4.4	NUPAC Dewatering System	16
71124.08	Procedures	59.RW.10	Physical Protection of Category I Quantities of Radioactive Material in Transit	9
71124.08	Procedures	9.ENN-RP-106-1	Radiation and Contamination Surveys	22
71124.08	Procedures	9.RADOP.10	Radioactive Source Control and Accountability	23
71124.08	Procedures	9.RADOP.14	Off-Site Radioactive Material Storage	5
71124.08	Procedures	9.RW.1	Radioactive Shipments	39
71124.08	Procedures	9.RW.3	Dry Radioactive Waste Classification/Listing and Radioactive Material Shipments	4
71124.08	Procedures	9.RW.5	Control of On-Site Storage of RWCU and Condensate Resins and Wastes (Transfer Out of Storage)	4
71124.08	Procedures	9.RW.6	Control of On-Site Dry Active Waste Storage	4
71124.08	Procedures	9.RW.7	Waste Stream Sampling	19
71124.08	Procedures	9.RW.9	Filling Containers with Waste/Radioactive Material	18
71124.08	Radiation Surveys	CNS-1904-0013	Underwater Survey of Spent Fuel Pool	04/11/2019
71124.08	Radiation Surveys	CNS-1906-0000	OCA 903' - Rad Material Storage Building	06/04/2019
71124.08	Radiation Surveys	CNS-1906-0013	Multipurpose Facility (MPF) 903'	06/25/2019
71124.08	Radiation Surveys	CNS-1907-0006	Horizontal Storage Module (HSM) ISFSI Pad	07/08/2019
71124.08	Radiation Surveys	CNS-1907-0007	Horizontal Storage Module (HSM) ISFSI Pad Top View	07/08/2019

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
71124.08	Radiation Surveys	CNS-RP-138	Alpha/Beta Smear Count Quarterly Survey of Offsite RAM Storage	05/08/2019
71124.08	Radiation Surveys	CNS-RP-508	Low Level Radwaste Storage Building	03/20/2019
71124.08	Self-Assessments		Annual Review of 10 CFR Part 37 Transportation Security Plan, Hittman Transport, 2018	07/23/2018
71124.08	Self-Assessments	LO-2018-0186-04	Self-Assessment: Radiological Monitoring Instrumentation and Radioactive Solid Waste Processing and Radioactive Material Handling, Storage, and Transport	04/17/2019
71124.08	Self-Assessments	QA 18-05	Radiological Controls Quality Assurance Audit	08/23/2018
71124.08	Shipping Records	17-24	UN3321 RAM - LSA II, Fissile-Excepted, 7, RQ, Spent Resin	10/17/2017
71124.08	Shipping Records	17-25	UN3321 RAM - LSA II, Fissile-Excepted, 7, Dry Active Waste	12/06/2017
71124.08	Shipping Records	17-26	UN2912 RAM - LSA I, Fissile-Excepted, 7, RQ, Dry Active Waste	12/15/2017
71124.08	Shipping Records	18-05	UN2912 RAM - LSA I, Fissile-Excepted, 7, RQ, Dry Active Waste	08/09/2018
71124.08	Shipping Records	18-10	UN3321 RAM - LSA II, Fissile-Excepted, 7, Spent Resin	09/11/2018
71124.08	Shipping Records	18-11	UN3321 RAM - LSA II, Fissile-Excepted, 7, Dry Active Waste	10/11/2018
71124.08	Shipping Records	18-14	UN3321 RAM - LSA II, Fissile-Excepted, 7, Dry Active Waste	12/11/2018
71124.08	Shipping Records	19-01	UN2916 RAM - Type B(U), Fissile-Excepted, 7, RQ, Spent Resin	03/04/2019
71124.08	Shipping Records	19-03	UN2916 RAM - Type B(U), Fissile-Excepted, 7, RQ, Spent Resin	04/02/2019
71151	Miscellaneous		3Q18 thru 4Q19 PI Verification Package – Complicated SCRAMS	
71152	Corrective Action Documents	CR-CNS-	2018-08615, 2019-00171, 2019-01287, 2019-02281, 2019-02371, 2019-02739, 2019-02791, 2019-02798, 2019-02842, 2019-02875, 2019-04219	
71153	Corrective Action Documents	CR-CNS-	2018-06295	
71153	Miscellaneous		CNS Operations Log	10/09/2018
71153	Miscellaneous		CNS Operations Log	10/10/2018
71153	Miscellaneous	LER 2018-002-00	Lack of Procedural Guidance Results in Work Scheduling Error Causing Breach of Secondary Containment and	

Inspection Procedure	Type	Designation	Description or Title	Revision or Date
			Condition Prohibited by Technical Specifications	
71153	Procedures	0-CNS-OU-108	Cooper Shutdown Safety Management Program	6
71153	Procedures	0-CNS-WM-102	Work Implementation and Closeout	10, 11
71153	Procedures	0.50.5	Outage Shutdown Safety	40
71153	Procedures	0.Barrier	Barrier Control Process	29
71153	Work Orders	WO	5267091, 5267093	