


# NEI 17-06 Review

Modernization Plan #3-  
Commercial Grade  
Dedication

November 6, 2019



©2019 Nuclear Energy Institute





# The EPRI Report- Section 3 of NEI 17-06

- SIL Certification Aligns Well With EPRI TR-106439

EPRI TR-106439	SIL Certification- Safety Case
Development Personnel Qualifications/ Experience	
HW/SW Design, Development, Verification & Validation Processes	
Availability/Reliability Requirements	
Failure Modes Analysis/ Testing/ Management	
Design Documentation	
Configuration Management	
Quality Assurance	
SW Requirements Definition & Requirements Traceability	
Vendor Testing (Performance, Environmental, SW V&V, Fault Insertion)	
Product Operating History	
Error Tracking/ Problem Reporting	

# The EPRI Report- Section 3 of NEI 17-06

- Certification Bodies (CBs) have a standardized, rigorous, and reliable evaluation process



- Accreditation Bodies (ABs) ensure CBs are consistent and trustworthy




# The EPRI Report- Section 3 of NEI 17-06

- Failure Data Indicates Reliable Operation of SIL Certified Equipment.
- SIL Certifications is an Accurate Indicator of Reliability



# COTS Justification Process Overview






# Justification Process- Section 4 of NEI 17-06

Since SIL Certification Aligns Well With EPRI TR-106439, It Can Be Used By Dedicating Entities In Place Of:


- Commercial Grade Surveys- CGD Method 2
- Operating History- CGD Method 4
- Dependability Reviews- Suitability of Design

# Justification Process- Section 4 of NEI 17-06





# Justification Process- Section 4 of NEI 17-06







# Justification Process- Section 4 of NEI 17-06

- No Specific SIL Prescribed, Any SIL Potentially Valid to Meet EPRI TR-106439 Dependability Critical Characteristics
- Graded Approach (NRC Safety Evaluation Report of EPRI TR-1064339)
  - Safety Significance
  - Complexity
- Documented Engineering Judgement for Achieving Reasonable Assurance



# NEI 17-06 Document Clarifications

- Previously Dedicated Items are Not Impacted by the Expiration of a SIL Certificate, Just Like the Impact of the Expiration of a Previously Utilized Commercial Grade Survey
- The word “supplier” will be updated to be “dedicating entity” in several places throughout Section 5.





# NRC Comments on NEI 17-06 Rev B

## *Comment #1:*

[content omitted] I don't think that the "are adequately controlled" is accurate because CBs certify the equipment for more applications than nuclear power plants, and nuclear power plants have requirements such as radiation resistance which may not be examined by CBs. [content omitted]

*Response- Will be reworded for clarity, as follows:*

to provide reasonable assurance that ~~critical characteristics, and in particular~~ dependability critical characteristics described in EPRI Technical Report 106439, "[content omitted]" are adequately controlled.

# NRC Comments

## *Comment #2:*

The last sentence of Section 1.2 states “[content omitted]” Again, the staff believes that [content omitted] one cannot declare adequately controlled.

## *Response- Will be reworded for clarity, as follows:*

This supplemental guidance document describes a method for using the accredited SIL certification process in lieu of a commercial grade survey as a dedication acceptance method to provide reasonable assurance that ~~critical characteristics of digital devices, and in particular~~ dependability characteristics, are adequately controlled.



# NRC Comments

## *Comment #3:*

The error in the last paragraph of Section 2 on page 12 should be fixed.

*Response- More information is needed to identify the error.*



# NRC Comments

## *Comment #4:*

In the first sentence of the second paragraph, “EPRI explained that the motivation of this work comes from the desire of the nuclear industry to utilize the existing ecosystem of SIL certified electrical, electronic, and programmable electronic (E/E/PE) equipment.” The highlighted “this” should be “its” as “this work” means NEI 17-06.

*Response- Comment Incorporated*





# NRC Comments

## *Comment #5:*

The last sentence of the second bullet on Page 19 claims “in no cases did they result from software faults (i.e., no instances of software CCF).” NRC/RES staff indicated to the NEI staff that this claim is not firmly supported from EPRI’s report (again a searchable e-document may be helpful).

*Response- This content is not on page 19. It is believed that this comment concerns the 2<sup>nd</sup> bullet on Page 20. A searchable version of the EPRI report is available from EPRI. Chapter 6 and Appendix F of the EPRI report address the failure data.*

# NRC Comments

## *Comment #6:*

Figure 4.2 may be misleading. The two blocks “Review of SIL Certification” may not be equivalent to the corresponding blocks on the left because CBs certification may not consider nuclear specific requirements such as radiation resistance.

*Response- The remaining blocks on the left labeled as “Qualification Testing...” and “Implement the Method 1...” are where the nuclear specific requirements such as radiation resistance are addresses.*



# NRC Comments

## *Comment #7:*

Section 4.2, which documents the technical evaluation and acceptance method, includes statements such as the following regarding "reliability" under the "SIL Certification Process Method of Verification": "See p3-7 through p3-13 of Reference 8 for details", where reference 8 is the EPRI research report. If such information is needed to complete the technical evaluation then, it should be included in NEI 17-06 in order to make it a standalone document.

*Response - These pointers are only added for convenience.*



# NRC Comments

## *Comment #8:*

[content omitted] Section 3 should be scrubbed to ensure that it focuses on providing the necessary information from the EPRI report to complete the technical evaluation in Section 4 of NEI 17-06.

*Response- Section 3 will be scrubbed accordingly*



# MP3 Schedule

---

# NEI 17-06 Schedule for Completion

Task	Due Date
12. NEI submits NEI 17-06 for NRC Review	
12.a NEI submits NEI 17-06 Rev B for NRC Review (Rev B will include draft of Sections 3 and 4)	9/30/2019 - complete
12.b MP3 Public Meeting to discuss Sections 3 and 4 of NEI 17-06 Rev B	11/06/2019
12.c NEI submits NEI 17-06 Rev 0 for NRC Review (*assuming all comments received by 11/15)	12/13/2019*
12.d NEI submits NUPIC Observation Procedure Rev 0 for NRC Review (*assuming all comments received by 11/15)	12/13/2019*
13. NRC makes decision on technical adequacy of NEI 17-06	TBD
14. NUPIC Observation of SIL Accrediting Body with NRC staff participation	10/29-30/2019 - complete
15. NRC formally enters NEI 17-06 into the Regulatory Guide development process (if decision is made to endorse)	TBD