



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
WASHINGTON, D.C. 20555-0001

November 13, 2019

LICENSEE: Vistra Operations Company LLC

FACILITY: Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2

SUBJECT: SUMMARY OF NOVEMBER 5, 2019, TELECONFERENCE WITH VISTRA OPERATIONS COMPANY LLC TO DISCUSS A PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES – OPERATING" (EPID L-2019-LRM-0072)

On November 5, 2019, a public teleconference was held between the U.S. Nuclear Regulatory Commission (NRC) staff and representatives of Vistra Operations Company LLC (the licensee). The purpose of the teleconference was to discuss the proposed license amendment request (LAR) to change Technical Specification (TS) 3.8.1, "AC [Alternating Current] Sources - Operating," for Comanche Peak Nuclear Power Plant, Unit Nos. 1 and 2. The meeting notice and agenda, dated October 24, 2019, are available in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML19301E008. A list of attendees is enclosed.

The licensee presented informational slides at the meeting (ADAMS Accession No. ML19296D559). During the meeting, the licensee described (1) its AC sources, (2) the reason for TS change, (3) the proposed change, and (4) some precedents.

The NRC staff and the licensee discussed the above topics. The NRC staff recommended that the proposed LAR should address the impact of the changes to the steady-state frequency limit and voltage limit in the proposed TSs for the emergency diesel generator on accident analyses in Chapter 15 of the Final Safety Analysis Report. In addition, the NRC staff recommended that the proposed LAR include a complete description of each of the proposed surveillance testing changes, and how each fits into the licensee's overall scheme to demonstrate the continued operability of the diesel generators.

No members of the public called into the teleconference. No regulatory decisions or commitments were made at the meeting. No public meeting feedback forms were received.

Please direct any inquiries to me at 301-415-6256 or Dennis.Galvin@nrc.gov.

/RA/

Dennis J. Galvin, Project Manager
Plant Licensing Branch 4
Division of Operator Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure:
List of Attendees

cc: Listserv

LIST OF ATTENDEES

NOVEMBER 5, 2019, PRE-SUBMITTAL TELECONFERENCE WITH

VISTRA OPERATIONS COMPANY LLC

REGARDING PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE

TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES - OPERATING" FOR

COMANCHE PEAK NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2

U.S. Nuclear Regulatory Commission

J. Cintron-Rivera

J. Dixon-Herrity

D. Galvin

V. Goel

P. Snyder

S. Sun

Vistra Operations Company, LLC*

S. Copeland

C. Corbin

J. Hicks

C. McBeth

G. Struble

K. Vehstedt

* participated by phone

SUBJECT: SUMMARY OF NOVEMBER 5, 2019, TELECONFERENCE WITH VISTRA OPERATIONS COMPANY LLC TO DISCUSS A PROPOSED LICENSE AMENDMENT REQUEST TO CHANGE TECHNICAL SPECIFICATION 3.8.1, "AC SOURCES – OPERATING" (EPID L-2019-LRM-0072) DATED NOVEMBER 13, 2019

DISTRIBUTION:

PUBLIC
PM File Copy
RidsACRS_MailCTR Resource
RidsNrrDexEeob Resource
RidsNrrDexEmib Resource
RidsNrrDorlLpl4 Resource
RidsNrrDssSnsb Resource
RidsNrrDssStsb Resource
RidsNrrLAPBlechman Resource
RidsNrrPMComanchePeak Resource

RidsRgn4MailCenter Resource
JCintron-Rivera, NRR
VGoel, NRR
PSnyder, NRR
SSun, NRR
LBetancourt, NRR
RAnzalone, NRR
MMcCoppin, OEDO, NRR
JQuichocho, OEDO, RIV

ADAMS Accession No.: ML19311C212

***by e-mail**

OFFICE	NRR/DORL/LPL4/PM	NRR/DORL/LPL4/LA	NRR/DEX/EEOB/BC*	NRR/DSS/STSB/BC*
NAME	DGalvin	PBlechman	BTitus	VCusumano (MHamm for)
DATE	11/12/19	11/12/19	11/06/19	11/06/19
OFFICE	NRR/DSS/SNSB/BC(A)*	NRR/DORL/LPL4/BC	NRR/DORL/LPL4/PM	
NAME	JBorromeo	JDixon-Herrity	DGalvin	
DATE	11/06/19	11/13/19	11/13/19	

OFFICIAL RECORD COPY