

Appendix A**Power Distribution Monitoring Factors**

Table	Description	Page
TABLE A-1	F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) NORMAL OPERATION	2
TABLE A-2	M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION	218
TABLE A-3	F-DEL-H & M-DEL-H VALUES NORMAL OPERATION	242
TABLE A-4	F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) POWER ESCALATION	251
TABLE A-5	M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION	299
TABLE A-6	F-DEL-H & M-DEL-H VALUES POWER ESCALATION	305

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 2 of 306

TABLE A-1

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6939	* 0.6444	* 0.6138	* 0.6709	* 0.6177	* 0.5375	* 0.4551	* 0.2858
	* 2.8315	* 3.0420	* 3.1671	* 2.9089	* 3.1584	* 3.5951	* 3.8571	* 5.9812
9	* 0.6444	* 0.6295	* 0.6708	* 0.6172	* 0.6506	* 0.5652	* 0.4692	* 0.2829
	* 3.0420	* 3.0505	* 2.8662	* 3.1479	* 2.9972	* 3.4309	* 3.9604	* 6.3491
10	* 0.6138	* 0.6711	* 0.6080	* 0.6402	* 0.5977	* 0.5597	* 0.4310	*
	* 3.1671	* 2.8650	* 3.1047	* 2.9794	* 3.2509	* 3.4815	* 4.4620	*
11	* 0.6709	* 0.6169	* 0.6395	* 0.5702	* 0.5812	* 0.5053	* 0.3218	*
	* 2.9089	* 3.1492	* 2.9800	* 3.3318	* 3.3619	* 3.8758	* 6.0611	*
12	* 0.6177	* 0.6480	* 0.5965	* 0.5808	* 0.5101	* 0.3827	*	*
	* 3.1584	* 3.0095	* 3.2573	* 3.3643	* 3.8432	* 5.1061	*	*
13	* 0.5375	* 0.5625	* 0.5583	* 0.5043	* 0.3812	*	*	*
	* 3.5951	* 3.4474	* 3.4906	* 3.8833	* 5.1272	*	*	*
14	* 0.4551	* 0.4680	* 0.4294	* 0.3205	*	*	*	*
	* 3.8571	* 3.9701	* 4.4782	* 6.0863	*	*	*	*
15	* 0.2858	* 0.2814	* F-SUB-Q					
	* 5.9812	* 6.3825	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4171	* 1.2456	* 1.1504	* 1.3174	* 1.2145	* 1.0465	* 1.0652	* 0.6141
	* 1.3979	* 1.5887	* 1.7096	* 1.4957	* 1.6210	* 1.8632	* 1.7683	* 3.0249
9	* 1.2456	* 1.2530	* 1.3110	* 1.1904	* 1.3442	* 1.1091	* 1.0568	* 0.5731
	* 1.5887	* 1.5599	* 1.4934	* 1.6506	* 1.4641	* 1.7644	* 1.8077	* 3.2675
10	* 1.1504	* 1.3121	* 1.1525	* 1.2708	* 1.1560	* 1.1982	* 0.8464	*
	* 1.7096	* 1.4927	* 1.6810	* 1.5297	* 1.7015	* 1.6407	* 2.2994	*
11	* 1.3174	* 1.1895	* 1.2706	* 1.0924	* 1.1609	* 1.0938	* 0.6295	*
	* 1.4957	* 1.6519	* 1.5300	* 1.7769	* 1.6993	* 1.8057	* 3.1266	*
12	* 1.2145	* 1.3376	* 1.1540	* 1.1600	* 1.0961	* 0.7153	*	*
	* 1.6210	* 1.4715	* 1.7045	* 1.7007	* 1.8045	* 2.7677	*	*
13	* 1.0465	* 1.1046	* 1.1952	* 1.0919	* 0.7133	*	*	*
	* 1.8632	* 1.7736	* 1.6449	* 1.8091	* 2.7760	*	*	*
14	* 1.0652	* 1.0542	* 0.8432	* 0.6267	*	*	*	*
	* 1.7683	* 1.8120	* 2.3081	* 3.1402	*	*	*	*
15	* 0.6141	* 0.5653	* F-SUB-Q					
	* 3.0249	* 3.3122	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 3 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4779	* 1.4130	* 1.3071	* 1.4113	* 1.3768	* 1.2343	* 1.2438	* 0.7440 *
	* 1.3573	* 1.4182	* 1.5290	* 1.4140	* 1.4489	* 1.6036	* 1.5634	* 2.5798 *
9	* 1.4130	* 1.4097	* 1.3536	* 1.3423	* 1.4237	* 1.2799	* 1.2384	* 0.6936 *
	* 1.4182	* 1.4129	* 1.4710	* 1.4861	* 1.4017	* 1.5483	* 1.5777	* 2.7781 *
10	* 1.3071	* 1.3553	* 1.3077	* 1.3672	* 1.3220	* 1.3268	* 1.0147	*
	* 1.5290	* 1.4691	* 1.5153	* 1.4529	* 1.5076	* 1.5008	* 1.9466	*
11	* 1.4113	* 1.3414	* 1.3659	* 1.2560	* 1.2387	* 1.2664	* 0.7428	*
	* 1.4140	* 1.4871	* 1.4542	* 1.5783	* 1.6130	* 1.5780	* 2.6824	*
12	* 1.3768	* 1.4134	* 1.3189	* 1.2373	* 1.2420	* 0.8171	*	
	* 1.4489	* 1.4122	* 1.5113	* 1.6149	* 1.6119	* 2.4371	*	
13	* 1.2343	* 1.2724	* 1.3221	* 1.2638	* 0.8154	*		
	* 1.6036	* 1.5576	* 1.5062	* 1.5814	* 2.4426	*		
14	* 1.2438	* 1.2349	* 1.0105	* 0.7394	*			
	* 1.5634	* 1.5822	* 1.9548	* 2.6945	*			
15	* 0.7440	* 0.6859	* F-SUB-Q					
	* 2.5798	* 2.8088	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6373	* 1.5414	* 1.4224	* 1.5669	* 1.5155	* 1.3729	* 1.4347	* 0.8301 *
	* 1.2456	* 1.3200	* 1.4303	* 1.2956	* 1.3339	* 1.4682	* 1.3852	* 2.3711 *
9	* 1.5414	* 1.5450	* 1.5056	* 1.4607	* 1.5887	* 1.4214	* 1.4282	* 0.7595 *
	* 1.3200	* 1.3175	* 1.3511	* 1.3897	* 1.2779	* 1.4191	* 1.3967	* 2.5992 *
10	* 1.4224	* 1.5081	* 1.3907	* 1.5174	* 1.4465	* 1.5018	* 1.1176	*
	* 1.4303	* 1.3488	* 1.4544	* 1.3341	* 1.4023	* 1.3485	* 1.8002	*
11	* 1.5669	* 1.4560	* 1.5156	* 1.3506	* 1.3842	* 1.4270	* 0.7947	*
	* 1.2956	* 1.3943	* 1.3358	* 1.4975	* 1.4678	* 1.4234	* 2.5485	*
12	* 1.5155	* 1.5765	* 1.4424	* 1.3823	* 1.3842	* 0.8642	*	
	* 1.3339	* 1.2880	* 1.4064	* 1.4698	* 1.4698	* 2.3110	*	
13	* 1.3729	* 1.4112	* 1.4955	* 1.4234	* 0.8628	*		
	* 1.4682	* 1.4294	* 1.3542	* 1.4270	* 2.3151	*		
14	* 1.4347	* 1.4238	* 1.1121	* 0.7905	*			
	* 1.3852	* 1.4011	* 1.8092	* 2.5619	*			
15	* 0.8301	* 0.7485	* F-SUB-Q					
	* 2.3711	* 2.6370	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 4 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6850	* 1.5708	* 1.4500	* 1.6232	* 1.5683	* 1.4182	* 1.5097	* 0.8706 *
	* 1.2320	* 1.3197	* 1.4302	* 1.2734	* 1.3126	* 1.4493	* 1.3488	* 2.3240 *
9	* 1.5708	* 1.5741	* 1.5448	* 1.4962	* 1.6444	* 1.4696	* 1.5004	* 0.7966 *
	* 1.3197	* 1.3140	* 1.3425	* 1.3818	* 1.2569	* 1.3987	* 1.3606	* 2.5454 *
10	* 1.4500	* 1.5477	* 1.4327	* 1.5714	* 1.4897	* 1.5651	* 1.1705	*
	* 1.4302	* 1.3399	* 1.4428	* 1.3135	* 1.3843	* 1.3140	* 1.7515	*
11	* 1.6232	* 1.4907	* 1.5691	* 1.3980	* 1.4383	* 1.4895	* 0.8273	*
	* 1.2734	* 1.3870	* 1.3155	* 1.4762	* 1.4292	* 1.3695	* 2.4592	*
12	* 1.5683	* 1.6305	* 1.4847	* 1.4359	* 1.4389	* 0.8968	*	
	* 1.3126	* 1.2678	* 1.3892	* 1.4317	* 1.4186	* 2.2317	*	
13	* 1.4182	* 1.4578	* 1.5575	* 1.4853	* 0.8953	*		
	* 1.4493	* 1.4102	* 1.3206	* 1.3738	* 2.2356	*		
14	* 1.5097	* 1.4950	* 1.1642	* 0.8229	*			
	* 1.3488	* 1.3655	* 1.7611	* 2.4727	*			
15	* 0.8706	* 0.7867	* F-SUB-Q					
	* 2.3240	* 2.5775	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7075	* 1.5853	* 1.4643	* 1.6574	* 1.6027	* 1.4464	* 1.5558	* 0.8953 *
	* 1.2227	* 1.3186	* 1.4295	* 1.2543	* 1.2936	* 1.4356	* 1.3286	* 2.3018 *
9	* 1.5853	* 1.5948	* 1.5641	* 1.5182	* 1.6786	* 1.5012	* 1.5448	* 0.8204 *
	* 1.3186	* 1.3121	* 1.3398	* 1.3714	* 1.2384	* 1.3773	* 1.3392	* 2.5129 *
10	* 1.4643	* 1.5674	* 1.4566	* 1.6045	* 1.5188	* 1.6055	* 1.2044	*
	* 1.4295	* 1.3370	* 1.4381	* 1.2995	* 1.3644	* 1.2860	* 1.7165	*
11	* 1.6574	* 1.5119	* 1.6017	* 1.4290	* 1.4736	* 1.5300	* 0.8491	*
	* 1.2543	* 1.3773	* 1.3018	* 1.4601	* 1.3969	* 1.3326	* 2.3924	*
12	* 1.6027	* 1.6634	* 1.5127	* 1.4708	* 1.4751	* 0.9201	*	
	* 1.2936	* 1.2499	* 1.3699	* 1.4003	* 1.3821	* 2.1830	*	
13	* 1.4464	* 1.4901	* 1.5968	* 1.5251	* 0.9185	*		
	* 1.4356	* 1.3879	* 1.2921	* 1.3371	* 2.1869	*		
14	* 1.5558	* 1.5387	* 1.1973	* 0.8443	*			
	* 1.3286	* 1.3446	* 1.7270	* 2.4063	*			
15	* 0.8953	* 0.8106	* F-SUB-Q					
	* 2.3018	* 2.5429	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 5 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7464	* 1.6140	* 1.4908	* 1.7064	* 1.6490	* 1.4847	* 1.6148	* 0.9155 *
	* 1.2004	* 1.3023	* 1.4126	* 1.2238	* 1.2641	* 1.4055	* 1.2912	* 2.2732 *
9	* 1.6140	* 1.6284	* 1.6033	* 1.5518	* 1.7318	* 1.5460	* 1.6037	* 0.8354 *
	* 1.3023	* 1.2931	* 1.3141	* 1.3484	* 1.2057	* 1.3437	* 1.2995	* 2.4894 *
10	* 1.4908	* 1.6067	* 1.4731	* 1.6520	* 1.5581	* 1.6643	* 1.2298	*
	* 1.4126	* 1.3113	* 1.4329	* 1.2680	* 1.3343	* 1.2433	* 1.6871	*
11	* 1.7064	* 1.5449	* 1.6487	* 1.4528	* 1.5228	* 1.5851	* 0.8601	*
	* 1.2238	* 1.3547	* 1.2706	* 1.4440	* 1.3536	* 1.2918	* 2.3693	*
12	* 1.6490	* 1.7156	* 1.5513	* 1.5196	* 1.5258	* 0.9354	*	
	* 1.2641	* 1.2173	* 1.3404	* 1.3569	* 1.3412	* 2.1639	*	
13	* 1.4847	* 1.5333	* 1.6544	* 1.5795	* 0.9339	*		
	* 1.4055	* 1.3550	* 1.2498	* 1.2965	* 2.1673	*		
14	* 1.6148	* 1.5969	* 1.2220	* 0.8546	*			
	* 1.2912	* 1.3051	* 1.6980	* 2.3845	*			
15	* 0.9155	* 0.8237	* F-SUB-Q					
	* 2.2732	* 2.5244	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7565	* 1.6225	* 1.4987	* 1.7264	* 1.6721	* 1.5028	* 1.6434	* 0.9269 *
	* 1.2062	* 1.3064	* 1.4155	* 1.2200	* 1.2553	* 1.3985	* 1.2816	* 2.2632 *
9	* 1.6225	* 1.6406	* 1.6140	* 1.5650	* 1.7535	* 1.5686	* 1.6317	* 0.8459 *
	* 1.3064	* 1.2940	* 1.3148	* 1.3472	* 1.2007	* 1.3326	* 1.2888	* 2.4795 *
10	* 1.4987	* 1.6176	* 1.4819	* 1.6715	* 1.5768	* 1.6913	* 1.2470	*
	* 1.4155	* 1.3119	* 1.4373	* 1.2615	* 1.3288	* 1.2327	* 1.6727	*
11	* 1.7264	* 1.5574	* 1.6678	* 1.4682	* 1.5449	* 1.6110	* 0.8696	*
	* 1.2200	* 1.3539	* 1.2644	* 1.4392	* 1.3474	* 1.2857	* 2.3677	*
12	* 1.6721	* 1.7364	* 1.5692	* 1.5413	* 1.5486	* 0.9470	*	
	* 1.2553	* 1.2127	* 1.3353	* 1.3505	* 1.3366	* 2.1669	*	
13	* 1.5028	* 1.5546	* 1.6803	* 1.6048	* 0.9456	*		
	* 1.3985	* 1.3444	* 1.2396	* 1.2906	* 2.1702	*		
14	* 1.6434	* 1.6243	* 1.2384	* 0.8636	*			
	* 1.2816	* 1.2948	* 1.6841	* 2.3838	*			
15	* 0.9269	* 0.8342	* F-SUB-Q					
	* 2.2632	* 2.5139	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 6 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7938	* 1.6504	* 1.5230	* 1.7718	* 1.7139	* 1.5359	* 1.6955	* 0.9400 *
	* 1.2041	* 1.3085	* 1.4183	* 1.2106	* 1.2461	* 1.3896	* 1.2535	* 2.2474 *
9	* 1.6504	* 1.6722	* 1.6521	* 1.5943	* 1.8030	* 1.6078	* 1.6838	* 0.8540 *
	* 1.3085	* 1.2906	* 1.3073	* 1.3464	* 1.1888	* 1.3216	* 1.2622	* 2.4725 *
10	* 1.5230	* 1.6557	* 1.4896	* 1.7155	* 1.6119	* 1.7449	* 1.2629	*
	* 1.4183	* 1.3044	* 1.4427	* 1.2491	* 1.3235	* 1.2172	* 1.6762	*
11	* 1.7718	* 1.5860	* 1.7113	* 1.4840	* 1.5891	* 1.6597	* 0.8727	*
	* 1.2106	* 1.3535	* 1.2521	* 1.4461	* 1.3340	* 1.2722	* 2.4027	*
12	* 1.7139	* 1.7849	* 1.6034	* 1.5851	* 1.5937	* 0.9557	*	
	* 1.2461	* 1.2010	* 1.3305	* 1.3379	* 1.3244	* 2.1916	*	
13	* 1.5359	* 1.5927	* 1.7328	* 1.6528	* 0.9543	*		
	* 1.3896	* 1.3340	* 1.2244	* 1.2773	* 2.1946	*		
14	* 1.6955	* 1.6757	* 1.2534	* 0.8672	*			
	* 1.2535	* 1.2682	* 1.6886	* 2.4174	*			
15	* 0.9400	* 0.8389	* F-SUB-Q					
	* 2.2474	* 2.5166	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7458	* 1.6162	* 1.4963	* 1.7312	* 1.6883	* 1.5121	* 1.6598	* 0.9366 *
	* 1.2712	* 1.3727	* 1.4807	* 1.2721	* 1.2980	* 1.4472	* 1.3087	* 2.2995 *
9	* 1.6162	* 1.6389	* 1.6031	* 1.5762	* 1.7580	* 1.5831	* 1.6466	* 0.8624 *
	* 1.3727	* 1.3517	* 1.3833	* 1.3988	* 1.2515	* 1.3767	* 1.3199	* 2.4969 *
10	* 1.4963	* 1.6072	* 1.4902	* 1.6759	* 1.5915	* 1.7058	* 1.2682	*
	* 1.4807	* 1.3798	* 1.4885	* 1.3116	* 1.3805	* 1.2730	* 1.7097	*
11	* 1.7312	* 1.5611	* 1.6716	* 1.4859	* 1.5545	* 1.6233	* 0.8855	*
	* 1.2721	* 1.4122	* 1.3150	* 1.4818	* 1.4006	* 1.3351	* 2.4287	*
12	* 1.6883	* 1.7391	* 1.5827	* 1.5504	* 1.5574	* 0.9673	*	
	* 1.2980	* 1.2652	* 1.3881	* 1.4041	* 1.3915	* 2.2235	*	
13	* 1.5121	* 1.5674	* 1.6948	* 1.6161	* 0.9655	*		
	* 1.4472	* 1.3901	* 1.2809	* 1.3408	* 2.2274	*		
14	* 1.6598	* 1.6380	* 1.2584	* 0.8790	*			
	* 1.3087	* 1.3267	* 1.7225	* 2.4459	*			
15	* 0.9366	* 0.8497	* F-SUB-Q					
	* 2.2995	* 2.5335	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 7 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7994	* 1.6547	* 1.5251	* 1.7916	* 1.7406	* 1.5538	* 1.7280	* 0.9484
	* 1.2755	* 1.3869	* 1.5044	* 1.2705	* 1.3011	* 1.4545	* 1.2958	* 2.3367
9	* 1.6547	* 1.6814	* 1.6591	* 1.6040	* 1.8261	* 1.6334	* 1.7159	* 0.8630
	* 1.3869	* 1.3624	* 1.3818	* 1.4203	* 1.2450	* 1.3778	* 1.3060	* 2.5676
10	* 1.5251	* 1.6631	* 1.4960	* 1.7344	* 1.6307	* 1.7764	* 1.2787	*
	* 1.5044	* 1.3785	* 1.5226	* 1.3083	* 1.3879	* 1.2644	* 1.7495	*
11	* 1.7916	* 1.5947	* 1.7295	* 1.4968	* 1.6128	* 1.6879	* 0.8799	*
	* 1.2705	* 1.4285	* 1.3124	* 1.5203	* 1.3931	* 1.3260	* 2.5218	*
12	* 1.7406	* 1.8064	* 1.6209	* 1.6082	* 1.6173	* 0.9664	*	*
	* 1.3011	* 1.2586	* 1.3961	* 1.3979	* 1.3840	* 2.2978	*	*
13	* 1.5538	* 1.6162	* 1.7624	* 1.6799	* 0.9650	*	*	*
	* 1.4545	* 1.3920	* 1.2727	* 1.3319	* 2.3008	*	*	*
14	* 1.7280	* 1.7067	* 1.2680	* 0.8737	*	*	*	*
	* 1.2958	* 1.3129	* 1.7634	* 2.5383	*	*	*	*
15	* 0.9484	* 0.8475	* F-SUB-Q					
	* 2.3367	* 2.6139	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7976	* 1.6527	* 1.5229	* 1.7983	* 1.7497	* 1.5588	* 1.7405	* 0.9512
	* 1.2702	* 1.3814	* 1.4975	* 1.2692	* 1.3066	* 1.4657	* 1.3163	* 2.3957
9	* 1.6527	* 1.6826	* 1.6581	* 1.6054	* 1.8327	* 1.6422	* 1.7274	* 0.8668
	* 1.3814	* 1.3576	* 1.3761	* 1.4211	* 1.2455	* 1.3907	* 1.3247	* 2.6269
10	* 1.5229	* 1.6622	* 1.4965	* 1.7407	* 1.6366	* 1.7870	* 1.2853	*
	* 1.4975	* 1.3727	* 1.5259	* 1.3107	* 1.3936	* 1.2772	* 1.7723	*
11	* 1.7983	* 1.5956	* 1.7354	* 1.5026	* 1.6215	* 1.6981	* 0.8839	*
	* 1.2692	* 1.4296	* 1.3146	* 1.5169	* 1.4036	* 1.3401	* 2.5634	*
12	* 1.7497	* 1.8121	* 1.6261	* 1.6161	* 1.6257	* 0.9714	*	*
	* 1.3066	* 1.2594	* 1.4025	* 1.4082	* 1.3973	* 2.3298	*	*
13	* 1.5588	* 1.6240	* 1.7730	* 1.6895	* 0.9699	*	*	*
	* 1.4657	* 1.4060	* 1.2870	* 1.3467	* 2.3334	*	*	*
14	* 1.7405	* 1.7176	* 1.2743	* 0.8772	*	*	*	*
	* 1.3163	* 1.3321	* 1.7873	* 2.5828	*	*	*	*
15	* 0.9512	* 0.8529	* F-SUB-Q					
	* 2.3957	* 2.6687	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 8 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7544	* 1.6197	* 1.4944	* 1.7614	* 1.7249	* 1.5357	* 1.7098	* 0.9443
	* 1.2856	* 1.3922	* 1.5065	* 1.2797	* 1.3084	* 1.4685	* 1.3216	* 2.3803
9	* 1.6197	* 1.6506	* 1.6154	* 1.5845	* 1.7932	* 1.6187	* 1.6958	* 0.8694
	* 1.3922	* 1.3667	* 1.3952	* 1.4218	* 1.2572	* 1.3929	* 1.3313	* 2.5834
10	* 1.4944	* 1.6198	* 1.4846	* 1.7050	* 1.6115	* 1.7567	* 1.2831	*
	* 1.5065	* 1.3915	* 1.5182	* 1.3210	* 1.3978	* 1.2828	* 1.7528	*
11	* 1.7614	* 1.5677	* 1.6996	* 1.4951	* 1.5905	* 1.6665	* 0.8878	*
	* 1.2797	* 1.4369	* 1.3256	* 1.5057	* 1.4136	* 1.3488	* 2.5212	*
12	* 1.7249	* 1.7719	* 1.6005	* 1.5854	* 1.5940	* 0.9749	*	*
	* 1.3084	* 1.2721	* 1.4073	* 1.4181	* 1.4081	* 2.2942	*	*
13	* 1.5357	* 1.5998	* 1.7431	* 1.6576	* 0.9731	*	*	*
	* 1.4685	* 1.4091	* 1.2926	* 1.3560	* 2.2984	*	*	*
14	* 1.7098	* 1.6854	* 1.2715	* 0.8800	*	*	*	*
	* 1.3216	* 1.3393	* 1.7685	* 2.5432	*	*	*	*
15	* 0.9443	* 0.8560	* F-SUB-Q					
	* 2.3803	* 2.6233	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7891	* 1.6389	* 1.5091	* 1.7998	* 1.7582	* 1.5610	* 1.7601	* 0.9464
	* 1.2514	* 1.3657	* 1.4807	* 1.2428	* 1.2734	* 1.4328	* 1.2717	* 2.3472
9	* 1.6389	* 1.6734	* 1.6516	* 1.5972	* 1.8402	* 1.6522	* 1.7476	* 0.8616
	* 1.3657	* 1.3377	* 1.3537	* 1.3995	* 1.2156	* 1.3537	* 1.2803	* 2.5764
10	* 1.5091	* 1.6558	* 1.4866	* 1.7439	* 1.6374	* 1.8056	* 1.2800	*
	* 1.4807	* 1.3503	* 1.5018	* 1.2807	* 1.3648	* 1.2383	* 1.7402	*
11	* 1.7998	* 1.5863	* 1.7371	* 1.4885	* 1.6323	* 1.7130	* 0.8724	*
	* 1.2428	* 1.4089	* 1.2856	* 1.4984	* 1.3653	* 1.3004	* 2.5362	*
12	* 1.7582	* 1.8181	* 1.6255	* 1.6252	* 1.6359	* 0.9652	*	*
	* 1.2734	* 1.2301	* 1.3745	* 1.3710	* 1.3587	* 2.2904	*	*
13	* 1.5610	* 1.6316	* 1.7906	* 1.7033	* 0.9637	*	*	*
	* 1.4328	* 1.3705	* 1.2483	* 1.3075	* 2.2938	*	*	*
14	* 1.7601	* 1.7366	* 1.2676	* 0.8654	*	*	*	*
	* 1.2717	* 1.2882	* 1.7567	* 2.5559	*	*	*	*
15	* 0.9464	* 0.8450	* F-SUB-Q					
	* 2.3472	* 2.6259	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 9 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7863	* 1.6309	* 1.5013	* 1.8013	* 1.7610	* 1.5605	* 1.7710	* 0.9420 *
	* 1.2314	* 1.3484	* 1.4623	* 1.2199	* 1.2495	* 1.4075	* 1.2404	* 2.3133 *
9	* 1.6309	* 1.6683	* 1.6493	* 1.5922	* 1.8447	* 1.6564	* 1.7588	* 0.8560 *
	* 1.3484	* 1.3180	* 1.3319	* 1.3792	* 1.1912	* 1.3263	* 1.2487	* 2.5445 *
10	* 1.5013	* 1.6535	* 1.4810	* 1.7471	* 1.6366	* 1.8160	* 1.2739	*
	* 1.4623	* 1.3285	* 1.4799	* 1.2558	* 1.3413	* 1.2093	* 1.7171	*
11	* 1.8013	* 1.5807	* 1.7398	* 1.4842	* 1.6387	* 1.7217	* 0.8634	*
	* 1.2199	* 1.3889	* 1.2609	* 1.4755	* 1.3362	* 1.2712	* 2.5181	*
12	* 1.7610	* 1.8218	* 1.6239	* 1.6312	* 1.6421	* 0.9584	*	
	* 1.2495	* 1.2058	* 1.3514	* 1.3421	* 1.3303	* 2.2674	*	
13	* 1.5605	* 1.6347	* 1.7997	* 1.7115	* 0.9565	*		
	* 1.4075	* 1.3434	* 1.2197	* 1.2786	* 2.2717	*		
14	* 1.7710	* 1.7472	* 1.2609	* 0.8564	*			
	* 1.2404	* 1.2567	* 1.7342	* 2.5382	*			
15	* 0.9420	* 0.8384	* F-SUB-Q					
	* 2.3133	* 2.5968	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7629	* 1.6107	* 1.4817	* 1.7837	* 1.7475	* 1.5455	* 1.7577	* 0.9336 *
	* 1.2312	* 1.3469	* 1.4618	* 1.2151	* 1.2414	* 1.4010	* 1.2313	* 2.2997 *
9	* 1.6107	* 1.6495	* 1.6282	* 1.5736	* 1.8266	* 1.6430	* 1.7451	* 0.8509 *
	* 1.3469	* 1.3148	* 1.3304	* 1.3764	* 1.1865	* 1.3182	* 1.2400	* 2.5224 *
10	* 1.4817	* 1.6325	* 1.4625	* 1.7311	* 1.6216	* 1.8033	* 1.2657	*
	* 1.4618	* 1.3276	* 1.4780	* 1.2500	* 1.3350	* 1.2005	* 1.7036	*
11	* 1.7837	* 1.5619	* 1.7235	* 1.4684	* 1.6246	* 1.7075	* 0.8588	*
	* 1.2151	* 1.3866	* 1.2553	* 1.4710	* 1.3294	* 1.2642	* 2.4971	*
12	* 1.7475	* 1.8033	* 1.6085	* 1.6169	* 1.6275	* 0.9538	*	
	* 1.2414	* 1.2016	* 1.3456	* 1.3356	* 1.3241	* 2.2479	*	
13	* 1.5455	* 1.6206	* 1.7869	* 1.6969	* 0.9522	*		
	* 1.4010	* 1.3359	* 1.2111	* 1.2718	* 2.2514	*		
14	* 1.7577	* 1.7331	* 1.2524	* 0.8514	*			
	* 1.2313	* 1.2484	* 1.7212	* 2.5182	*			
15	* 0.9336	* 0.8339	* F-SUB-Q					
	* 2.2997	* 2.5725	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 10 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7031	* 1.5676	* 1.4424	* 1.7325	* 1.7065	* 1.5082	* 1.7076	* 0.9197 *
	* 1.2618	* 1.3701	* 1.4867	* 1.2380	* 1.2575	* 1.4201	* 1.2529	* 2.3077 *
9	* 1.5676	* 1.6067	* 1.5736	* 1.5385	* 1.7698	* 1.6030	* 1.6933	* 0.8476 *
	* 1.3701	* 1.3361	* 1.3619	* 1.3929	* 1.2119	* 1.3362	* 1.2634	* 2.5032 *
10	* 1.4424	* 1.5776	* 1.4366	* 1.6821	* 1.5830	* 1.7547	* 1.2555	*
	* 1.4867	* 1.3601	* 1.4886	* 1.2729	* 1.3532	* 1.2201	* 1.6985	*
11	* 1.7325	* 1.5221	* 1.6744	* 1.4534	* 1.5778	* 1.6582	* 0.8603	*
	* 1.2380	* 1.4082	* 1.2786	* 1.4714	* 1.3543	* 1.2878	* 2.4660	*
12	* 1.7065	* 1.7461	* 1.5697	* 1.5700	* 1.5799	* 0.9513	*	
	* 1.2575	* 1.2281	* 1.3643	* 1.3609	* 1.3496	* 2.2301	*	
13	* 1.5082	* 1.5805	* 1.7381	* 1.6474	* 0.9494	*		
	* 1.4201	* 1.3547	* 1.2314	* 1.2959	* 2.2343	*		
14	* 1.7076	* 1.6810	* 1.2421	* 0.8516	*			
	* 1.2529	* 1.2724	* 1.7163	* 2.4906	*			
15	* 0.9197	* 0.8338	* F-SUB-Q					
	* 2.3077	* 2.5436	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7442	* 1.5844	* 1.4557	* 1.7686	* 1.7321	* 1.5244	* 1.7504	* 0.9132 *
	* 1.2107	* 1.3320	* 1.4479	* 1.1930	* 1.2191	* 1.3831	* 1.2043	* 2.2948 *
9	* 1.5844	* 1.6277	* 1.6106	* 1.5489	* 1.8144	* 1.6279	* 1.7380	* 0.8308 *
	* 1.3320	* 1.2963	* 1.3088	* 1.3614	* 1.1632	* 1.2958	* 1.2127	* 2.5218 *
10	* 1.4557	* 1.6148	* 1.4376	* 1.7175	* 1.6017	* 1.7965	* 1.2401	*
	* 1.4479	* 1.3063	* 1.4642	* 1.2271	* 1.3163	* 1.1740	* 1.6949	*
11	* 1.7686	* 1.5364	* 1.7094	* 1.4475	* 1.6150	* 1.6990	* 0.8352 *	
	* 1.1930	* 1.3723	* 1.2329	* 1.4539	* 1.3038	* 1.2388	* 2.5077	*
12	* 1.7321	* 1.7900	* 1.5877	* 1.6067	* 1.6169	* 0.9323 *		
	* 1.2191	* 1.1788	* 1.3278	* 1.3104	* 1.3002	* 2.2464 *		
13	* 1.5244	* 1.6040	* 1.7788	* 1.6875	* 0.9302 *			
	* 1.3831	* 1.3148	* 1.1854	* 1.2470	* 2.2512 *			
14	* 1.7504	* 1.7251	* 1.2260	* 0.8276 *				
	* 1.2043	* 1.2216	* 1.7140	* 2.5303 *				
15	* 0.9132	* 0.8128	* F-SUB-Q					
	* 2.2948	* 2.5765	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 11 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7202	* 1.5618	* 1.4333	* 1.7412	* 1.7084	* 1.5002	* 1.7230	* 0.8939 *
	* 1.2005	* 1.3212	* 1.4381	* 1.1849	* 1.2083	* 1.3741	* 1.1961	* 2.2932 *
9	* 1.5618	* 1.6051	* 1.5869	* 1.5246	* 1.7880	* 1.6041	* 1.7114	* 0.8141 *
	* 1.3212	* 1.2854	* 1.3000	* 1.3526	* 1.1544	* 1.2857	* 1.2040	* 2.5176 *
10	* 1.4333	* 1.5913	* 1.4135	* 1.6903	* 1.5775	* 1.7704	* 1.2170	*
	* 1.4381	* 1.2965	* 1.4567	* 1.2195	* 1.3071	* 1.1648	* 1.6890	*
11	* 1.7412	* 1.5119	* 1.6820	* 1.4237	* 1.5894	* 1.6726	* 0.8178	*
	* 1.1849	* 1.3638	* 1.2254	* 1.4458	* 1.2958	* 1.2307	* 2.5059	*
12	* 1.7084	* 1.7634	* 1.5633	* 1.5810	* 1.5905	* 0.9151	*	
	* 1.2083	* 1.1702	* 1.3188	* 1.3025	* 1.2930	* 2.2397	*	
13	* 1.5002	* 1.5798	* 1.7524	* 1.6610	* 0.9131	*		
	* 1.3741	* 1.3051	* 1.1765	* 1.2391	* 2.2445	*		
14	* 1.7230	* 1.6983	* 1.2028	* 0.8102	*			
	* 1.1960	* 1.2132	* 1.7088	* 2.5291	*			
15	* 0.8939	* 0.7958	* F-SUB-Q					
	* 2.2932	* 2.5744	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6938	* 1.5336	* 1.4050	* 1.6978	* 1.6696	* 1.4641	* 1.6707	* 0.8659 *
	* 1.1972	* 1.3211	* 1.4408	* 1.1932	* 1.2135	* 1.3824	* 1.2110	* 2.3250 *
9	* 1.5336	* 1.5733	* 1.5610	* 1.4924	* 1.7537	* 1.5640	* 1.6686	* 0.8080 *
	* 1.3211	* 1.2875	* 1.2978	* 1.3569	* 1.1556	* 1.2944	* 1.2122	* 2.4913 *
10	* 1.4050	* 1.5654	* 1.3815	* 1.6457	* 1.5420	* 1.7305	* 1.1860	*
	* 1.4408	* 1.2942	* 1.4637	* 1.2299	* 1.3128	* 1.1702	* 1.7020	*
11	* 1.6978	* 1.4799	* 1.6376	* 1.3893	* 1.5459	* 1.6324	* 0.7965	*
	* 1.1932	* 1.3682	* 1.2358	* 1.4550	* 1.3081	* 1.2381	* 2.5276	*
12	* 1.6696	* 1.7293	* 1.5281	* 1.5393	* 1.5519	* 0.9108	*	
	* 1.2135	* 1.1718	* 1.3246	* 1.3140	* 1.3014	* 2.2104	*	
13	* 1.4641	* 1.5401	* 1.7106	* 1.6210	* 0.9087	*		
	* 1.3824	* 1.3142	* 1.1836	* 1.2467	* 2.2155	*		
14	* 1.6707	* 1.6559	* 1.1720	* 0.7889	*			
	* 1.2110	* 1.2214	* 1.7220	* 2.5516	*			
15	* 0.8659	* 0.7735	* F-SUB-Q					
	* 2.3250	* 2.6018	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 12 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6488	* 1.4885	* 1.3624	* 1.6257	* 1.6048	* 1.4062	* 1.5945	* 0.8221 *
	* 1.2122	* 1.3415	* 1.4648	* 1.2282	* 1.2440	* 1.4184	* 1.2500	* 2.4143 *
9	* 1.4885	* 1.5228	* 1.5192	* 1.4457	* 1.6985	* 1.4980	* 1.5939	* 0.7660 *
	* 1.3415	* 1.3110	* 1.3145	* 1.3805	* 1.1759	* 1.3315	* 1.2504	* 2.5904 *
10	* 1.3624	* 1.5234	* 1.3361	* 1.5697	* 1.4880	* 1.6653	* 1.1378	*
	* 1.4648	* 1.3109	* 1.4921	* 1.2708	* 1.3407	* 1.1981	* 1.7485	*
11	* 1.6257	* 1.4339	* 1.5621	* 1.3432	* 1.4918	* 1.5664	* 0.7666	*
	* 1.2282	* 1.3918	* 1.2769	* 1.4833	* 1.3363	* 1.2715	* 2.5891	*
12	* 1.6048	* 1.6752	* 1.4748	* 1.4863	* 1.4906	* 0.8758	*	
	* 1.2440	* 1.1921	* 1.3525	* 1.3413	* 1.3353	* 2.2662	*	
13	* 1.4062	* 1.4755	* 1.6464	* 1.5554	* 0.8736	*		
	* 1.4184	* 1.3516	* 1.2117	* 1.2803	* 2.2716	*		
14	* 1.5945	* 1.5815	* 1.1243	* 0.7591	*			
	* 1.2500	* 1.2601	* 1.7692	* 2.6143	*			
15	* 0.8221	* 0.7390	* F-SUB-Q					
	* 2.4143	* 2.6845	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5490	* 1.4138	* 1.2967	* 1.5359	* 1.5128	* 1.3138	* 1.4533	* 0.7538 *
	* 1.2761	* 1.3967	* 1.5221	* 1.2851	* 1.3044	* 1.5010	* 1.3558	* 2.6044 *
9	* 1.4138	* 1.4577	* 1.4314	* 1.3840	* 1.6013	* 1.4046	* 1.4527	* 0.7063 *
	* 1.3967	* 1.3541	* 1.3790	* 1.4258	* 1.2331	* 1.4038	* 1.3562	* 2.7793 *
10	* 1.2967	* 1.4354	* 1.2763	* 1.4834	* 1.4157	* 1.5479	* 1.0543	*
	* 1.5221	* 1.3759	* 1.5446	* 1.3298	* 1.3929	* 1.2742	* 1.8660	*
11	* 1.5359	* 1.3732	* 1.4772	* 1.2782	* 1.3969	* 1.4550	* 0.7205	*
	* 1.2851	* 1.4370	* 1.3353	* 1.5416	* 1.4111	* 1.3531	* 2.7247	*
12	* 1.5128	* 1.5799	* 1.4038	* 1.3918	* 1.3964	* 0.8308	*	
	* 1.3044	* 1.2497	* 1.4047	* 1.4161	* 1.4093	* 2.3627	*	
13	* 1.3138	* 1.3842	* 1.5308	* 1.4451	* 0.8286	*		
	* 1.5010	* 1.4243	* 1.2882	* 1.3623	* 2.3686	*		
14	* 1.4533	* 1.4417	* 1.0422	* 0.7134	*			
	* 1.3558	* 1.3664	* 1.8874	* 2.7518	*			
15	* 0.7538	* 0.6837	* F-SUB-Q					
	* 2.6044	* 2.8701	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 13 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3954	* 1.1918	* 1.1105	* 1.3728	* 1.2721	* 1.0750	* 1.1877	* 0.6129 *
	* 1.4041	* 1.6434	* 1.7617	* 1.4254	* 1.5379	* 1.8195	* 1.6439	* 3.1784 *
9	* 1.1918	* 1.2582	* 1.2986	* 1.1907	* 1.4259	* 1.1811	* 1.1679	* 0.5773 *
	* 1.6434	* 1.5557	* 1.5071	* 1.6430	* 1.3723	* 1.6552	* 1.6716	* 3.3743 *
10	* 1.1105	* 1.2993	* 1.1117	* 1.3348	* 1.2087	* 1.3163	* 0.8607	*
	* 1.7617	* 1.5062	* 1.7598	* 1.4651	* 1.6176	* 1.4844	* 2.2669	*
11	* 1.3728	* 1.1808	* 1.3280	* 1.0951	* 1.2257	* 1.1933	* 0.6087	*
	* 1.4254	* 1.6572	* 1.4725	* 1.7846	* 1.5934	* 1.6357	* 3.2006	*
12	* 1.2721	* 1.4058	* 1.1992	* 1.2213	* 1.1706	* 0.7092	*	
	* 1.5379	* 1.3919	* 1.6303	* 1.5991	* 1.6667	* 2.7460	*	
13	* 1.0750	* 1.1650	* 1.3035	* 1.1855	* 0.7072	*		
	* 1.8195	* 1.6779	* 1.4988	* 1.6464	* 2.7538	*		
14	* 1.1877	* 1.1586	* 0.8514	* 0.6026	*			
	* 1.6439	* 1.6848	* 2.2914	* 3.2326	*			
15	* 0.6129	* 0.5660	* F-SUB-Q					
	* 3.1784	* 3.4407	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6006	* 0.5374	* 0.5267	* 0.6108	* 0.5681	* 0.4946	* 0.4709	* 0.2784 *
	* 3.2441	* 3.6251	* 3.6956	* 3.1861	* 3.4251	* 3.9316	* 4.1248	* 6.9649 *
9	* 0.5374	* 0.5585	* 0.5912	* 0.5474	* 0.6042	* 0.5228	* 0.4607	* 0.2595 *
	* 3.6251	* 3.4855	* 3.2924	* 3.5548	* 3.2197	* 3.7183	* 4.2157	* 7.4737 *
10	* 0.5267	* 0.5913	* 0.5262	* 0.5913	* 0.5404	* 0.5355	* 0.3903	*
	* 3.6956	* 3.2916	* 3.6976	* 3.2886	* 3.5983	* 3.6288	* 4.9734	*
11	* 0.6108	* 0.5436	* 0.5895	* 0.5086	* 0.5369	* 0.4671	* 0.2774	*
	* 3.1861	* 3.5792	* 3.2990	* 3.8220	* 3.6181	* 4.1553	* 6.9915	*
12	* 0.5681	* 0.5976	* 0.5362	* 0.5350	* 0.4668	* 0.3349	*	
	* 3.4251	* 3.2551	* 3.6258	* 3.6309	* 4.1566	* 5.7874	*	
13	* 0.4946	* 0.5166	* 0.5305	* 0.4643	* 0.3338	*		
	* 3.9316	* 3.7628	* 3.6627	* 4.1796	* 5.8067	*		
14	* 0.4709	* 0.4572	* 0.3864	* 0.2748	*			
	* 4.1248	* 4.2472	* 5.0231	* 7.0580	*			
15	* 0.2784	* 0.2584	* F-SUB-Q					
	* 6.9649	* 7.5026	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 14 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6267 *	* 0.5813 *	* 0.5598 *	* 0.6199 *	* 0.5720 *	* 0.5010 *	* 0.4306 *	* 0.2757 *
	* 3.0684 *	* 3.3008 *	* 3.4035 *	* 3.0798 *	* 3.3357 *	* 3.7598 *	* 3.9513 *	* 6.0593 *
9	* 0.5813 *	* 0.5752 *	* 0.6151 *	* 0.5662 *	* 0.6070 *	* 0.5230 *	* 0.4468 *	* 0.2729 *
	* 3.3008 *	* 3.2664 *	* 3.0492 *	* 3.3572 *	* 3.1416 *	* 3.6258 *	* 4.0601 *	* 6.4309 *
10	* 0.5598 *	* 0.6154 *	* 0.5445 *	* 0.5997 *	* 0.5497 *	* 0.5319 *	* 0.4055 *	
	* 3.4035 *	* 3.0478 *	* 3.3652 *	* 3.1220 *	* 3.4589 *	* 3.5823 *	* 4.6359 *	
11	* 0.6199 *	* 0.5654 *	* 0.5990 *	* 0.5249 *	* 0.5526 *	* 0.4820 *	* 0.3090 *	
	* 3.0798 *	* 3.3597 *	* 3.1226 *	* 3.5524 *	* 3.4599 *	* 3.9751 *	* 6.1762 *	
12	* 0.5720 *	* 0.6047 *		* 0.5487 *	* 0.5523 *	* 0.4885 *	* 0.3661 *	
	* 3.3357 *	* 3.1534 *	* 3.4652 *	* 3.4621 *	* 3.9289 *	* 5.2353 *		
13	* 0.5010 *	* 0.5209 *	* 0.5306 *	* 0.4811 *	* 0.3647 *			
	* 3.7598 *	* 3.6418 *	* 3.5909 *	* 3.9819 *	* 5.2561 *			
14	* 0.4306 *	* 0.4458 *	* 0.4041 *	* 0.3078 *				
	* 3.9513 *	* 4.0691 *	* 4.6509 *	* 6.1996 *				
15	* 0.2757 *	* 0.2713 *	F-SUB-Q					
	* 6.0593 *	* 6.4679 *	M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2706 *	* 1.1152 *	* 1.0449 *	* 1.2086 *	* 1.1170 *	* 0.9683 *	* 1.0080 *	* 0.5893 *
	* 1.5274 *	* 1.7391 *	* 1.8456 *	* 1.5953 *	* 1.7250 *	* 1.9699 *	* 1.8250 *	* 3.0813 *
9	* 1.1152 *	* 1.1359 *	* 1.1926 *	* 1.0905 *	* 1.2399 *	* 1.0315 *	* 1.0035 *	* 0.5511 *
	* 1.7391 *	* 1.6857 *	* 1.6007 *	* 1.7617 *	* 1.5531 *	* 1.8589 *	* 1.8596 *	* 3.3213 *
10	* 1.0449 *	* 1.1935 *	* 1.0315 *	* 1.1782 *	* 1.0757 *	* 1.1239 *	* 0.7928 *	
	* 1.8456 *	* 1.5999 *	* 1.8280 *	* 1.6195 *	* 1.7905 *	* 1.7110 *	* 2.4006 *	
11	* 1.2086 *	* 1.0882 *	* 1.1771 *	* 0.9953 *	* 1.0935 *	* 1.0356 *	* 0.6021 *	
	* 1.5953 *	* 1.7626 *	* 1.6198 *	* 1.9118 *	* 1.7660 *	* 1.8665 *	* 3.1997 *	
12	* 1.1170 *	* 1.2346 *	* 1.0739 *	* 1.0928 *	* 1.0384 *	* 0.6835 *		
	* 1.7250 *	* 1.5600 *	* 1.7936 *	* 1.7672 *	* 1.8651 *	* 2.8375 *		
13	* 0.9683 *	* 1.0276 *	* 1.1214 *	* 1.0340 *	* 0.6816 *			
	* 1.9699 *	* 1.8662 *	* 1.7148 *	* 1.8695 *	* 2.8452 *			
14	* 1.0080 *	* 1.0013 *	* 0.7902 *	* 0.5996 *				
	* 1.8250 *	* 1.8635 *	* 2.4086 *	* 3.2126 *				
15	* 0.5893 *	* 0.5438 *	F-SUB-Q					
	* 3.0813 *	* 3.3659 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 15 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3584	* 1.2694	* 1.1885	* 1.3266	* 1.2784	* 1.1472	* 1.1948	* 0.7245 *
	* 1.4478	* 1.5455	* 1.6471	* 1.4736	* 1.5277	* 1.6895	* 1.5901	* 2.5907 *
9	* 1.2694	* 1.2898	* 1.2663	* 1.2468	* 1.3373	* 1.2000	* 1.1871	* 0.6766 *
	* 1.5455	* 1.5119	* 1.5408	* 1.5680	* 1.4616	* 1.6202	* 1.6087	* 2.7847 *
10	* 1.1885	* 1.2677	* 1.1862	* 1.2931	* 1.2395	* 1.2652	* 0.9594 *	
	* 1.6471	* 1.5391	* 1.6375	* 1.5050	* 1.5762	* 1.5410	* 2.0147 *	
11	* 1.3266	* 1.2435	* 1.2920	* 1.1581	* 1.2002	* 1.2231	* 0.7207 *	
	* 1.4736	* 1.5701	* 1.5063	* 1.6780	* 1.6312	* 1.5999	* 2.7078 *	
12	* 1.2784	* 1.3294	* 1.2368	* 1.1989	* 1.1988	* 0.7960 *		
	* 1.5277	* 1.4706	* 1.5797	* 1.6330	* 1.6362	* 2.4525 *		
13	* 1.1472	* 1.1945	* 1.2611	* 1.2208	* 0.7944 *			
	* 1.6895	* 1.6279	* 1.5461	* 1.6029	* 2.4578 *			
14	* 1.1948	* 1.1843	* 0.9559	* 0.7177 *				
	* 1.5901	* 1.6126	* 2.0221	* 2.7190 *				
15	* 0.7245	* 0.6696	* F-SUB-Q					
	* 2.5907	* 2.8134	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5199	* 1.3936	* 1.3007	* 1.4942	* 1.4215	* 1.2847	* 1.3979	* 0.8186 *
	* 1.3169	* 1.4339	* 1.5340	* 1.3320	* 1.3946	* 1.5378	* 1.3898	* 2.3522 *
9	* 1.3936	* 1.4199	* 1.4143	* 1.3711	* 1.5109	* 1.3445	* 1.3862	* 0.7519 *
	* 1.4339	* 1.4012	* 1.4077	* 1.4528	* 1.3175	* 1.4727	* 1.4074	* 2.5689 *
10	* 1.3007	* 1.4159	* 1.2926	* 1.4572	* 1.3742	* 1.4487	* 1.0666 *	
	* 1.5340	* 1.4061	* 1.5305	* 1.3623	* 1.4478	* 1.3699	* 1.8474 *	
11	* 1.4942	* 1.3668	* 1.4555	* 1.2656	* 1.3624	* 1.4001	* 0.7814 *	
	* 1.3320	* 1.4574	* 1.3639	* 1.5707	* 1.4626	* 1.4216	* 2.5413 *	
12	* 1.4215	* 1.5013	* 1.3705	* 1.3606	* 1.3577	* 0.8572 *		
	* 1.3946	* 1.3261	* 1.4519	* 1.4646	* 1.4694	* 2.2847 *		
13	* 1.2847	* 1.3370	* 1.4432	* 1.3971	* 0.8559 *			
	* 1.5378	* 1.4811	* 1.3746	* 1.4248	* 2.2885 *			
14	* 1.3979	* 1.3824	* 1.0619	* 0.7780 *				
	* 1.3898	* 1.4114	* 1.8556	* 2.5526 *				
15	* 0.8186	* 0.7415	* F-SUB-Q					
	* 2.3522	* 2.6048	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 16 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5711	* 1.4262	* 1.3371	* 1.5602	* 1.4810	* 1.3363	* 1.4854	* 0.8685 *
	* 1.2997	* 1.4307	* 1.5238	* 1.3009	* 1.3654	* 1.5101	* 1.3422	* 2.2819 *
9	* 1.4262	* 1.4623	* 1.4663	* 1.4147	* 1.5782	* 1.4045	* 1.4779	* 0.7979 *
	* 1.4307	* 1.3913	* 1.3886	* 1.4362	* 1.2829	* 1.4371	* 1.3514	* 2.4896 *
10	* 1.3371	* 1.4680	* 1.3315	* 1.5222	* 1.4273	* 1.5291	* 1.1280	*
	* 1.5238	* 1.3869	* 1.5199	* 1.3315	* 1.4194	* 1.3161	* 1.7828	*
11	* 1.5602	* 1.4097	* 1.5202	* 1.3115	* 1.4317	* 1.4789	* 0.8234	*
	* 1.3009	* 1.4414	* 1.3333	* 1.5462	* 1.4097	* 1.3527	* 2.4279	*
12	* 1.4810	* 1.5667	* 1.4227	* 1.4295	* 1.4285	* 0.9014	*	
	* 1.3654	* 1.2959	* 1.4242	* 1.4119	* 1.3998	* 2.1788	*	
13	* 1.3363	* 1.3958	* 1.5236	* 1.4753	* 0.9001	*		
	* 1.5101	* 1.4462	* 1.3212	* 1.3564	* 2.1822	*		
14	* 1.4854	* 1.4729	* 1.1228	* 0.8191	*			
	* 1.3422	* 1.3561	* 1.7912	* 2.4412	*			
15	* 0.8685	* 0.7887	* F-SUB-Q					
	* 2.2819	* 2.5185	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5972	* 1.4440	* 1.3596	* 1.6028	* 1.5218	* 1.3708	* 1.5435	* 0.9018 *
	* 1.2897	* 1.4289	* 1.5156	* 1.2765	* 1.3415	* 1.4905	* 1.3153	* 2.2464 *
9	* 1.4440	* 1.4881	* 1.4962	* 1.4442	* 1.6271	* 1.4465	* 1.5406	* 0.8303 *
	* 1.4289	* 1.3864	* 1.3796	* 1.4192	* 1.2544	* 1.4061	* 1.3168	* 2.4412 *
10	* 1.3596	* 1.4980	* 1.3582	* 1.5650	* 1.4647	* 1.5858	* 1.1702	*
	* 1.5156	* 1.3779	* 1.5124	* 1.3102	* 1.3911	* 1.2749	* 1.7379	*
11	* 1.6029	* 1.4386	* 1.5626	* 1.3494	* 1.4797	* 1.5338	* 0.8536	*
	* 1.2765	* 1.4250	* 1.3127	* 1.5218	* 1.3673	* 1.3053	* 2.3413	*
12	* 1.5218	* 1.6093	* 1.4594	* 1.4771	* 1.4786	* 0.9348	*	
	* 1.3415	* 1.2692	* 1.3965	* 1.3699	* 1.3530	* 2.1117	*	
13	* 1.3708	* 1.4368	* 1.5793	* 1.5296	* 0.9334	*		
	* 1.4905	* 1.4158	* 1.2804	* 1.3092	* 2.1151	*		
14	* 1.5435	* 1.5349	* 1.1643	* 0.8488	*			
	* 1.3153	* 1.3219	* 1.7469	* 2.3549	*			
15	* 0.9018	* 0.8201	* F-SUB-Q					
	* 2.2464	* 2.4714	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 17 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6387	* 1.4734	* 1.3907	* 1.6602	* 1.5725	* 1.4130	* 1.6149	* 0.9301 *
	* 1.2633	* 1.4095	* 1.4919	* 1.2393	* 1.3069	* 1.4557	* 1.2714	* 2.2067 *
9	* 1.4734	* 1.5241	* 1.5400	* 1.4830	* 1.6904	* 1.4985	* 1.6168	* 0.8520 *
	* 1.4095	* 1.3640	* 1.3504	* 1.3901	* 1.2144	* 1.3649	* 1.2667	* 2.4075 *
10	* 1.3907	* 1.5419	* 1.3935	* 1.6221	* 1.5111	* 1.6562	* 1.2027	*
	* 1.4919	* 1.3486	* 1.4864	* 1.2699	* 1.3545	* 1.2247	* 1.7001	*
11	* 1.6602	* 1.4767	* 1.6193	* 1.3837	* 1.5408	* 1.6012	* 0.8714	*
	* 1.2393	* 1.3966	* 1.2728	* 1.4888	* 1.3161	* 1.2580	* 2.3043	*
12	* 1.5725	* 1.6703	* 1.5049	* 1.5379	* 1.5411	* 0.9586	*	
	* 1.3069	* 1.2294	* 1.3603	* 1.3187	* 1.3060	* 2.0795	*	
13	* 1.4130	* 1.4876	* 1.6487	* 1.5964	* 0.9573	*		
	* 1.4557	* 1.3752	* 1.2305	* 1.2620	* 2.0823	*		
14	* 1.6149	* 1.6102	* 1.1961	* 0.8662	*			
	* 1.2714	* 1.2720	* 1.7095	* 2.3182	*			
15	* 0.9301	* 0.8408	* F-SUB-Q					
	* 2.2067	* 2.4392	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6512	* 1.4831	* 1.4038	* 1.6869	* 1.6004	* 1.4357	* 1.6548	* 0.9489 *
	* 1.2673	* 1.4124	* 1.4897	* 1.2319	* 1.2949	* 1.4451	* 1.2562	* 2.1847 *
9	* 1.4831	* 1.5392	* 1.5561	* 1.5021	* 1.7223	* 1.5284	* 1.6599	* 0.8695 *
	* 1.4124	* 1.3626	* 1.3463	* 1.3848	* 1.2029	* 1.3490	* 1.2474	* 2.3842 *
10	* 1.4038	* 1.5582	* 1.4100	* 1.6499	* 1.5363	* 1.6953	* 1.2271	*
	* 1.4897	* 1.3461	* 1.4824	* 1.2553	* 1.3453	* 1.2094	* 1.6781	*
11	* 1.6869	* 1.4951	* 1.6462	* 1.4048	* 1.5730	* 1.6393	* 0.8877	*
	* 1.2319	* 1.3920	* 1.2584	* 1.4759	* 1.3048	* 1.2460	* 2.2909	*
12	* 1.6004	* 1.7007	* 1.5295	* 1.5697	* 1.5751	* 0.9784	*	
	* 1.2949	* 1.2185	* 1.3515	* 1.3075	* 1.2961	* 2.0714	*	
13	* 1.4357	* 1.5164	* 1.6870	* 1.6339	* 0.9770	*		
	* 1.4451	* 1.3598	* 1.2155	* 1.2502	* 2.0741	*		
14	* 1.6548	* 1.6526	* 1.2200	* 0.8822	*			
	* 1.2562	* 1.2531	* 1.6880	* 2.3052	*			
15	* 0.9489	* 0.8589	* F-SUB-Q					
	* 2.1847	* 2.4133	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 18 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6892	* 1.5093	* 1.4300	* 1.7381	* 1.6444	* 1.4711	* 1.7175	* 0.9681 *
	* 1.2639	* 1.4152	* 1.4909	* 1.2200	* 1.2848	* 1.4352	* 1.2238	* 2.1628 *
9	* 1.5093	* 1.5709	* 1.5964	* 1.5350	* 1.7785	* 1.5730	* 1.7263	* 0.8831 *
	* 1.4152	* 1.3587	* 1.3333	* 1.3825	* 1.1881	* 1.3361	* 1.2144	* 2.3704 *
10	* 1.4300	* 1.5974	* 1.4393	* 1.7027	* 1.5757	* 1.7571	* 1.2483	*
	* 1.4909	* 1.3348	* 1.4761	* 1.2401	* 1.3389	* 1.1910	* 1.6782	*
11	* 1.7381	* 1.5270	* 1.6985	* 1.4381	* 1.6267	* 1.6971	* 0.8957	*
	* 1.2200	* 1.3890	* 1.2434	* 1.4695	* 1.2894	* 1.2306	* 2.3192	*
12	* 1.6444	* 1.7554	* 1.5681	* 1.6230	* 1.6290	* 0.9931	*	
	* 1.2848	* 1.2039	* 1.3455	* 1.2922	* 1.2820	* 2.0896	*	
13	* 1.4711	* 1.5598	* 1.7478	* 1.6911	* 0.9918	*		
	* 1.4352	* 1.3475	* 1.1973	* 1.2350	* 2.0921	*		
14	* 1.7175	* 1.7181	* 1.2403	* 0.8907	*			
	* 1.2238	* 1.2202	* 1.6890	* 2.3319	*			
15	* 0.9681	* 0.8684	* F-SUB-Q					
	* 2.1628	* 2.4099	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6431	* 1.4794	* 1.4102	* 1.7006	* 1.6245	* 1.4537	* 1.6884	* 0.9709 *
	* 1.3364	* 1.4851	* 1.5566	* 1.2835	* 1.3382	* 1.4934	* 1.2755	* 2.2058 *
9	* 1.4794	* 1.5418	* 1.5595	* 1.5124	* 1.7453	* 1.5548	* 1.6975	* 0.8976 *
	* 1.4851	* 1.4233	* 1.4036	* 1.4442	* 1.2457	* 1.3907	* 1.2667	* 2.3860 *
10	* 1.4102	* 1.5583	* 1.4184	* 1.6687	* 1.5569	* 1.7294	* 1.2612	*
	* 1.5566	* 1.4047	* 1.5402	* 1.3027	* 1.3954	* 1.2454	* 1.7070	*
11	* 1.7006	* 1.5043	* 1.6640	* 1.4275	* 1.5977	* 1.6708	* 0.9152	*
	* 1.2835	* 1.4507	* 1.3062	* 1.5294	* 1.3524	* 1.2878	* 2.3366	*
12	* 1.6245	* 1.7214	* 1.5489	* 1.5939	* 1.6017	* 1.0121	*	
	* 1.3382	* 1.2631	* 1.4025	* 1.3555	* 1.3436	* 2.1137	*	
13	* 1.4537	* 1.5412	* 1.7196	* 1.6644	* 1.0103	*		
	* 1.4934	* 1.4029	* 1.2524	* 1.2925	* 2.1171	*		
14	* 1.6884	* 1.6890	* 1.2529	* 0.9089	*			
	* 1.2755	* 1.2730	* 1.7180	* 2.3522	*			
15	* 0.9709	* 0.8851	* F-SUB-Q					
	* 2.2058	* 2.4192	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 19 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6964	* 1.5138	* 1.4378	* 1.7668	* 1.6776	* 1.4956	* 1.7684	* 0.9880 *
	* 1.3405	* 1.5036	* 1.5811	* 1.2808	* 1.3434	* 1.5043	* 1.2602	* 2.2395 *
9	* 1.5138	* 1.5825	* 1.6167	* 1.5527	* 1.8168	* 1.6088	* 1.7820	* 0.9030 *
	* 1.5036	* 1.4365	* 1.4025	* 1.4584	* 1.2403	* 1.3932	* 1.2489	* 2.4509 *
10	* 1.4378	* 1.6138	* 1.4524	* 1.7362	* 1.6036	* 1.8070	* 1.2758	*
	* 1.5811	* 1.4049	* 1.5597	* 1.2982	* 1.4050	* 1.2356	* 1.7480	*
11	* 1.7668	* 1.5441	* 1.7310	* 1.4588	* 1.6653	* 1.7440	* 0.9131	*
	* 1.2808	* 1.4652	* 1.3019	* 1.5467	* 1.3457	* 1.2795	* 2.4266	*
12	* 1.6776	* 1.7912	* 1.5948	* 1.6610	* 1.6694	* 1.0159	*	*
	* 1.3434	* 1.2580	* 1.4126	* 1.3489	* 1.3370	* 2.1836	*	*
13	* 1.4956	* 1.5937	* 1.7961	* 1.7369	* 1.0145	*	*	*
	* 1.5043	* 1.4061	* 1.2428	* 1.2844	* 2.1860	*	*	*
14	* 1.7684	* 1.7726	* 1.2667	* 0.9074	*	*	*	*
	* 1.2602	* 1.2554	* 1.7600	* 2.4408	*	*	*	*
15	* 0.9880	* 0.8881	* F-SUB-Q					
	* 2.2395	* 2.4910	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6948	* 1.5122	* 1.4386	* 1.7767	* 1.6898	* 1.5040	* 1.7896	* 0.9963 *
	* 1.3461	* 1.5084	* 1.5840	* 1.2850	* 1.3535	* 1.5201	* 1.2833	* 2.2938 *
9	* 1.5122	* 1.5845	* 1.6225	* 1.5577	* 1.8302	* 1.6224	* 1.8046	* 0.9120 *
	* 1.5084	* 1.4408	* 1.4066	* 1.4649	* 1.2488	* 1.4089	* 1.2704	* 2.5034 *
10	* 1.4386	* 1.6194	* 1.4557	* 1.7486	* 1.6136	* 1.8265	* 1.2881	*
	* 1.5840	* 1.4093	* 1.5686	* 1.3046	* 1.4141	* 1.2510	* 1.7715	*
11	* 1.7767	* 1.5491	* 1.7431	* 1.4660	* 1.6799	* 1.7625	* 0.9221	*
	* 1.2850	* 1.4727	* 1.3086	* 1.5540	* 1.3559	* 1.2929	* 2.4611	*
12	* 1.6898	* 1.8035	* 1.6041	* 1.6753	* 1.6853	* 1.0263	*	*
	* 1.3535	* 1.2670	* 1.4223	* 1.3595	* 1.3493	* 2.2082	*	*
13	* 1.5040	* 1.6063	* 1.8148	* 1.7549	* 1.0249	*	*	*
	* 1.5201	* 1.4227	* 1.2588	* 1.2984	* 2.2111	*	*	*
14	* 1.7896	* 1.7944	* 1.2787	* 0.9159	*	*	*	*
	* 1.2833	* 1.2774	* 1.7842	* 2.4775	*	*	*	*
15	* 0.9963	* 0.8987	* F-SUB-Q					
	* 2.2938	* 2.5401	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 20 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6530	* 1.4827	* 1.4162	* 1.7425	* 1.6696	* 1.4864	* 1.7660	* 0.9948 *
	* 1.3631	* 1.5193	* 1.5891	* 1.2936	* 1.3520	* 1.5179	* 1.2819	* 2.2647 *
9	* 1.4827	* 1.5555	* 1.5885	* 1.5344	* 1.7999	* 1.6044	* 1.7801	* 0.9204 *
	* 1.5193	* 1.4491	* 1.4184	* 1.4684	* 1.2534	* 1.4061	* 1.2698	* 2.4459 *
10	* 1.4162	* 1.5853	* 1.4342	* 1.7177	* 1.5940	* 1.8023	* 1.2925	*
	* 1.5891	* 1.4213	* 1.5699	* 1.3113	* 1.4133	* 1.2513	* 1.7422	*
11	* 1.7425	* 1.5259	* 1.7119	* 1.4475	* 1.6539	* 1.7391	* 0.9313	*
	* 1.2936	* 1.4762	* 1.3157	* 1.5540	* 1.3602	* 1.2939	* 2.4063	*
12	* 1.6696	* 1.7725	* 1.5842	* 1.6491	* 1.6608	* 1.0363	*	
	* 1.3520	* 1.2725	* 1.4220	* 1.3640	* 1.3524	* 2.1605	*	
13	* 1.4864	* 1.5878	* 1.7900	* 1.7311	* 1.0344	*		
	* 1.5179	* 1.4205	* 1.2597	* 1.2997	* 2.1644	*		
14	* 1.7660	* 1.7696	* 1.2826	* 0.9240	*			
	* 1.2819	* 1.2772	* 1.7555	* 2.4251	*			
15	* 0.9948	* 0.9066	* F-SUB-Q					
	* 2.2647	* 2.4828	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6849	* 1.4994	* 1.4298	* 1.7872	* 1.7045	* 1.5126	* 1.8293	* 1.0022 *
	* 1.3265	* 1.4903	* 1.5609	* 1.2515	* 1.3137	* 1.4792	* 1.2253	* 2.2257 *
9	* 1.4994	* 1.5778	* 1.6266	* 1.5569	* 1.8503	* 1.6421	* 1.8477	* 0.9166 *
	* 1.4903	* 1.4172	* 1.3733	* 1.4358	* 1.2096	* 1.3627	* 1.2122	* 2.4320 *
10	* 1.4298	* 1.6230	* 1.4516	* 1.7646	* 1.6225	* 1.8617	* 1.2939	*
	* 1.5609	* 1.3764	* 1.5382	* 1.2665	* 1.3779	* 1.2017	* 1.7260	*
11	* 1.7872	* 1.5480	* 1.7582	* 1.4702	* 1.7027	* 1.7948	* 0.9191	*
	* 1.2515	* 1.4438	* 1.2710	* 1.5176	* 1.3110	* 1.2441	* 2.4152	*
12	* 1.7045	* 1.8211	* 1.6117	* 1.6975	* 1.7105	* 1.0302	*	
	* 1.3137	* 1.2288	* 1.3869	* 1.3149	* 1.3023	* 2.1531	*	
13	* 1.5126	* 1.6239	* 1.8482	* 1.7861	* 1.0288	*		
	* 1.4792	* 1.3777	* 1.2103	* 1.2501	* 2.1558	*		
14	* 1.8293	* 1.8362	* 1.2832	* 0.9126	*			
	* 1.2253	* 1.2197	* 1.7401	* 2.4319	*			
15	* 1.0022	* 0.9003	* F-SUB-Q					
	* 2.2257	* 2.4754	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 21 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6797	* 1.4913	* 1.4239	* 1.7922	* 1.7097	* 1.5143	* 1.8492	* 1.0022
	* 1.3115	* 1.4766	* 1.5446	* 1.2300	* 1.2914	* 1.4560	* 1.1944	* 2.1892
9	* 1.4913	* 1.5734	* 1.6286	* 1.5546	* 1.8592	* 1.6501	* 1.8697	* 0.9150
	* 1.4766	* 1.4002	* 1.3512	* 1.4167	* 1.1869	* 1.3369	* 1.1807	* 2.3969
10	* 1.4239	* 1.6247	* 1.4480	* 1.7721	* 1.6245	* 1.8785	* 1.2924	*
	* 1.5446	* 1.3544	* 1.5186	* 1.2427	* 1.3563	* 1.1742	* 1.7018	*
11	* 1.7922	* 1.5452	* 1.7654	* 1.4704	* 1.7132	* 1.8107	* 0.9137	*
	* 1.2300	* 1.4251	* 1.2473	* 1.4949	* 1.2838	* 1.2153	* 2.3942	*
12	* 1.7097	* 1.8286	* 1.6131	* 1.7077	* 1.7228	* 1.0270	*	*
	* 1.2914	* 1.2063	* 1.3656	* 1.2880	* 1.2743	* 2.1291	*	*
13	* 1.5143	* 1.6309	* 1.8642	* 1.8014	* 1.0252	*	*	*
	* 1.4560	* 1.3523	* 1.1830	* 1.2213	* 2.1327	*	*	*
14	* 1.8492	* 1.8573	* 1.2812	* 0.9070	*	*	*	*
	* 1.1944	* 1.1884	* 1.7163	* 2.4112	*	*	*	*
15	* 1.0022	* 0.8977	* F-SUB-Q					
	* 2.1892	* 2.4425	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6567	* 1.4718	* 1.4054	* 1.7747	* 1.6974	* 1.5011	* 1.8391	* 0.9958
	* 1.3159	* 1.4808	* 1.5488	* 1.2289	* 1.2865	* 1.4525	* 1.1865	* 2.1771
9	* 1.4718	* 1.5547	* 1.6101	* 1.5379	* 1.8445	* 1.6386	* 1.8593	* 0.9117
	* 1.4808	* 1.4022	* 1.3523	* 1.4170	* 1.1833	* 1.3314	* 1.1732	* 2.3772
10	* 1.4054	* 1.6060	* 1.4304	* 1.7567	* 1.6110	* 1.8682	* 1.2871	*
	* 1.5488	* 1.3557	* 1.5209	* 1.2401	* 1.3531	* 1.1676	* 1.6896	*
11	* 1.7747	* 1.5282	* 1.7497	* 1.4558	* 1.7006	* 1.7997	* 0.9107	*
	* 1.2289	* 1.4257	* 1.2450	* 1.4940	* 1.2794	* 1.2095	* 2.3763	*
12	* 1.6974	* 1.8133	* 1.5992	* 1.6949	* 1.7106	* 1.0244	*	*
	* 1.2865	* 1.2033	* 1.3628	* 1.2839	* 1.2700	* 2.1122	*	*
13	* 1.5011	* 1.6189	* 1.8532	* 1.7900	* 1.0229	*	*	*
	* 1.4525	* 1.3473	* 1.1767	* 1.2158	* 2.1151	*	*	*
14	* 1.8391	* 1.8465	* 1.2755	* 0.9037	*	*	*	*
	* 1.1865	* 1.1811	* 1.7046	* 2.3941	*	*	*	*
15	* 0.9958	* 0.8953	* F-SUB-Q					
	* 2.1771	* 2.4201	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 22 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6005 *	* 1.4307 *	* 1.3692 *	* 1.7202 *	* 1.6572 *	* 1.4659 *	* 1.7870 *	* 0.9825 *
	* 1.3524 *	* 1.5125 *	* 1.5783 *	* 1.2585 *	* 1.3076 *	* 1.4760 *	* 1.2107 *	* 2.1876 *
9	* 1.4307 *	* 1.5122 *	* 1.5582 *	* 1.4992 *	* 1.7902 *	* 1.5994 *	* 1.8043 *	* 0.9106 *
	* 1.5125 *	* 1.4312 *	* 1.3874 *	* 1.4430 *	* 1.2099 *	* 1.3533 *	* 1.1986 *	* 2.3595 *
10	* 1.3692 *	* 1.5541 *	* 1.3968 *	* 1.7043 *	* 1.5733 *	* 1.8166 *	* 1.2790 *	
	* 1.5783 *	* 1.3909 *	* 1.5461 *	* 1.2688 *	* 1.3752 *	* 1.1912 *	* 1.6866 *	
11	* 1.7202 *	* 1.4894 *	* 1.6972 *	* 1.4223 *	* 1.6517 *	* 1.7502 *	* 0.9136 *	
	* 1.2585 *	* 1.4523 *	* 1.2740 *	* 1.5179 *	* 1.3073 *	* 1.2340 *	* 2.3504 *	
12	* 1.6572 *	* 1.7589 *	* 1.5614 *	* 1.6456 *	* 1.6624 *	* 1.0237 *		
	* 1.3076 *	* 1.2310 *	* 1.3855 *	* 1.3123 *	* 1.2970 *	* 2.0977 *		
13	* 1.4659 *	* 1.5796 *	* 1.8015 *	* 1.7403 *	* 1.0216 *			
	* 1.4760 *	* 1.3699 *	* 1.2009 *	* 1.2407 *	* 2.1017 *			
14	* 1.7870 *	* 1.7913 *	* 1.2673 *	* 0.9053 *				
	* 1.2107 *	* 1.2070 *	* 1.7018 *	* 2.3713 *				
15	* 0.9825 *	* 0.8957 *	F-SUB-Q					
	* 2.1876 *	* 2.3985 *	M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6283 *	* 1.4408 *	* 1.3756 *	* 1.7551 *	* 1.6781 *	* 1.4775 *	* 1.8332 *	* 0.9751 *
	* 1.3099 *	* 1.4797 *	* 1.5480 *	* 1.2151 *	* 1.2722 *	* 1.4430 *	* 1.1633 *	* 2.1762 *
9	* 1.4408 *	* 1.5272 *	* 1.5886 *	* 1.5097 *	* 1.8279 *	* 1.6212 *	* 1.8544 *	* 0.8911 *
	* 1.4797 *	* 1.3961 *	* 1.3410 *	* 1.4117 *	* 1.1676 *	* 1.3159 *	* 1.1496 *	* 2.3806 *
10	* 1.3756 *	* 1.5841 *	* 1.4019 *	* 1.7396 *	* 1.5875 *	* 1.8602 *	* 1.2614 *	
	* 1.5480 *	* 1.3447 *	* 1.5182 *	* 1.2249 *	* 1.3430 *	* 1.1467 *	* 1.6863 *	
11	* 1.7551 *	* 1.4994 *	* 1.7321 *	* 1.4313 *	* 1.6885 *	* 1.7903 *	* 0.8860 *	
	* 1.2151 *	* 1.4213 *	* 1.2301 *	* 1.4869 *	* 1.2608 *	* 1.1894 *	* 2.3927 *	
12	* 1.6781 *	* 1.7950 *	* 1.5749 *	* 1.6816 *	* 1.6979 *	* 1.0009 *		
	* 1.2722 *	* 1.1887 *	* 1.3535 *	* 1.2659 *	* 1.2525 *	* 2.1179 *		
13	* 1.4775 *	* 1.6001 *	* 1.8440 *	* 1.7799 *	* 0.9990 *			
	* 1.4430 *	* 1.3330 *	* 1.1566 *	* 1.1963 *	* 2.1218 *			
14	* 1.8332 *	* 1.8403 *	* 1.2491 *	* 0.8789 *				
	* 1.1633 *	* 1.1583 *	* 1.7027 *	* 2.4120 *				
15	* 0.9751 *	* 0.8735 *	F-SUB-Q					
	* 2.1762 *	* 2.4283 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 23 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5972	* 1.4138	* 1.3478	* 1.7215	* 1.6490	* 1.4488	* 1.8000	* 0.9524 *
	* 1.3094	* 1.4787	* 1.5494	* 1.2144	* 1.2690	* 1.4424	* 1.1608	* 2.1842 *
9	* 1.4138	* 1.4994	* 1.5571	* 1.4801	* 1.7937	* 1.5921	* 1.8203	* 0.8711 *
	* 1.4787	* 1.3943	* 1.3415	* 1.4119	* 1.1663	* 1.3132	* 1.1474	* 2.3873 *
10	* 1.3478	* 1.5527	* 1.3729	* 1.7058	* 1.5577	* 1.8275	* 1.2351	*
	* 1.5494	* 1.3454	* 1.5203	* 1.2247	* 1.3418	* 1.1439	* 1.6882	*
11	* 1.7215	* 1.4697	* 1.6982	* 1.4025	* 1.6557	* 1.7581	* 0.8653	*
	* 1.2144	* 1.4218	* 1.2301	* 1.4880	* 1.2606	* 1.1873	* 2.4027	*
12	* 1.6490	* 1.7605	* 1.5450	* 1.6487	* 1.6650	* 0.9797	*	
	* 1.2690	* 1.1880	* 1.3527	* 1.2658	* 1.2524	* 2.1222	*	
13	* 1.4488	* 1.5709	* 1.8111	* 1.7475	* 0.9778	*		
	* 1.4424	* 1.3308	* 1.1541	* 1.1943	* 2.1262	*		
14	* 1.8000	* 1.8057	* 1.2226	* 0.8581	*			
	* 1.1608	* 1.1565	* 1.7052	* 2.4226	*			
15	* 0.9524	* 0.8532	* F-SUB-Q					
	* 2.1842	* 2.4372	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5538	* 1.3796	* 1.3109	* 1.6669	* 1.6013	* 1.4060	* 1.7302	* 0.9163 *
	* 1.3246	* 1.4913	* 1.5680	* 1.2342	* 1.2856	* 1.4626	* 1.1877	* 2.2336 *
9	* 1.3796	* 1.4596	* 1.5169	* 1.4386	* 1.7367	* 1.5425	* 1.7447	* 0.8572 *
	* 1.4913	* 1.4095	* 1.3554	* 1.4298	* 1.1851	* 1.3334	* 1.1772	* 2.3873 *
10	* 1.3109	* 1.5126	* 1.3332	* 1.6491	* 1.5124	* 1.7610	* 1.1963	*
	* 1.5680	* 1.3593	* 1.5410	* 1.2466	* 1.3599	* 1.1675	* 1.7149	*
11	* 1.6669	* 1.4283	* 1.6417	* 1.3600	* 1.5967	* 1.7036	* 0.8367	*
	* 1.2342	* 1.4398	* 1.2521	* 1.5103	* 1.2866	* 1.2054	* 2.4456	*
12	* 1.6013	* 1.7084	* 1.5000	* 1.5891	* 1.6126	* 0.9652	*	
	* 1.2856	* 1.2041	* 1.3710	* 1.2925	* 1.2725	* 2.1199	*	
13	* 1.4060	* 1.5216	* 1.7450	* 1.6931	* 0.9633	*		
	* 1.4626	* 1.3515	* 1.1781	* 1.2127	* 2.1240	*		
14	* 1.7302	* 1.7301	* 1.1841	* 0.8296	*			
	* 1.1877	* 1.1870	* 1.7324	* 2.4663	*			
15	* 0.9163	* 0.8231	* F-SUB-Q					
	* 2.2336	* 2.4859	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 24 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4889	* 1.3290	* 1.2581	* 1.5774	* 1.5242	* 1.3397	* 1.6151	* 0.8597 *
	* 1.3652	* 1.5287	* 1.6137	* 1.2877	* 1.3332	* 1.5155	* 1.2558	* 2.3504 *
9	* 1.3290	* 1.3988	* 1.4566	* 1.3786	* 1.6452	* 1.4631	* 1.6196	* 0.8031 *
	* 1.5287	* 1.4523	* 1.3939	* 1.4733	* 1.2347	* 1.3874	* 1.2524	* 2.5152 *
10	* 1.2581	* 1.4527	* 1.2771	* 1.5563	* 1.4444	* 1.6579	* 1.1369	*
	* 1.6137	* 1.3977	* 1.5888	* 1.3042	* 1.4057	* 1.2247	* 1.7813	*
11	* 1.5774	* 1.3689	* 1.5494	* 1.2975	* 1.5025	* 1.6146	* 0.7959	*
	* 1.2877	* 1.4834	* 1.3099	* 1.5633	* 1.3497	* 1.2553	* 2.5386	*
12	* 1.5242	* 1.6276	* 1.4329	* 1.4954	* 1.5307	* 0.9162	*	
	* 1.3332	* 1.2476	* 1.4169	* 1.3560	* 1.3235	* 2.2049	*	
13	* 1.3397	* 1.4437	* 1.6412	* 1.6047	* 0.9143	*		
	* 1.5155	* 1.4058	* 1.2371	* 1.2629	* 2.2095	*		
14	* 1.6151	* 1.6085	* 1.1252	* 0.7888	*			
	* 1.2558	* 1.2609	* 1.7996	* 2.5611	*			
15	* 0.8597	* 0.7772	* F-SUB-Q					
	* 2.3504	* 2.5993	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3846	* 1.2533	* 1.1879	* 1.4680	* 1.4189	* 1.2395	* 1.4493	* 0.7755 *
	* 1.4537	* 1.6053	* 1.6925	* 1.3699	* 1.4175	* 1.6218	* 1.3852	* 2.5799 *
9	* 1.2533	* 1.3217	* 1.3577	* 1.3004	* 1.5261	* 1.3542	* 1.4528	* 0.7277 *
	* 1.6053	* 1.5218	* 1.4809	* 1.5464	* 1.3182	* 1.4839	* 1.3818	* 2.7488 *
10	* 1.1879	* 1.3544	* 1.2025	* 1.4435	* 1.3550	* 1.5177	* 1.0391	*
	* 1.6925	* 1.4845	* 1.6711	* 1.3920	* 1.4834	* 1.3243	* 1.9294	*
11	* 1.4680	* 1.2918	* 1.4374	* 1.2153	* 1.3805	* 1.4716	* 0.7354	*
	* 1.3699	* 1.5564	* 1.3978	* 1.6527	* 1.4542	* 1.3632	* 2.7205	*
12	* 1.4189	* 1.5084	* 1.3447	* 1.3749	* 1.4084	* 0.8517	*	
	* 1.4175	* 1.3335	* 1.4947	* 1.4607	* 1.4240	* 2.3485	*	
13	* 1.2395	* 1.3368	* 1.5029	* 1.4628	* 0.8499	*		
	* 1.6218	* 1.5030	* 1.3372	* 1.3712	* 2.3537	*		
14	* 1.4493	* 1.4432	* 1.0288	* 0.7289	*			
	* 1.3852	* 1.3909	* 1.9485	* 2.7445	*			
15	* 0.7755	* 0.7063	* F-SUB-Q					
	* 2.5799	* 2.8319	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 25 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 75 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2363	* 1.0525	* 1.0069	* 1.2805	* 1.1842	* 1.0108	* 1.1775	* 0.6205 *
	* 1.6153	* 1.8975	* 1.9824	* 1.5587	* 1.6854	* 1.9739	* 1.6911	* 3.2018 *
9	* 1.0525	* 1.1306	* 1.2019	* 1.1040	* 1.3447	* 1.1249	* 1.1652	* 0.5850 *
	* 1.8975	* 1.7658	* 1.6603	* 1.8078	* 1.4842	* 1.7730	* 1.7087	* 3.3956 *
10	* 1.0069	* 1.2007	* 1.0159	* 1.2642	* 1.1376	* 1.2773	* 0.8392 *	
	* 1.9824	* 1.6619	* 1.9638	* 1.5779	* 1.7536	* 1.5602	* 2.3715 *	
11	* 1.2806	* 1.0970	* 1.2583	* 1.0194	* 1.1972	* 1.1794	* 0.6114 *	
	* 1.5587	* 1.8192	* 1.5851	* 1.9560	* 1.6640	* 1.6879	* 3.2493 *	
12	* 1.1842	* 1.3276	* 1.1296	* 1.1935	* 1.1573	* 0.7141 *		
	* 1.6854	* 1.5033	* 1.7659	* 1.6691	* 1.7197	* 2.7814 *		
13	* 1.0108	* 1.1114	* 1.2666	* 1.1728	* 0.7123 *			
	* 1.9739	* 1.7944	* 1.5733	* 1.6974	* 2.7881 *			
14	* 1.1775	* 1.1570	* 0.8314	* 0.6060 *				
	* 1.6911	* 1.7206	* 2.3934	* 3.2782 *				
15	* 0.6205	* 0.5742	* F-SUB-Q					
	* 3.2018	* 3.4593	* M-SUB-Q					

AT 100% POWER, 75 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5371	* 0.4781	* 0.4846	* 0.5725	* 0.5334	* 0.4713	* 0.4688	* 0.2813 *
	* 3.7000	* 4.1562	* 4.0983	* 3.4691	* 3.7234	* 4.2105	* 4.2271	* 7.0339 *
9	* 0.4781	* 0.5085	* 0.5486	* 0.5131	* 0.5775	* 0.5017	* 0.4586	* 0.2626 *
	* 4.1562	* 3.9061	* 3.6201	* 3.8700	* 3.4380	* 3.9539	* 4.3207	* 7.5350 *
10	* 0.4846	* 0.5486	* 0.4889	* 0.5637	* 0.5164	* 0.5260	* 0.3828 *	
	* 4.0983	* 3.6203	* 4.0609	* 3.5211	* 3.8428	* 3.7704	* 5.1742 *	
11	* 0.5725	* 0.5098	* 0.5621	* 0.4861	* 0.5288	* 0.4700	* 0.2788 *	
	* 3.4691	* 3.8955	* 3.5308	* 4.0810	* 3.7494	* 4.2136	* 7.0967 *	
12	* 0.5334	* 0.5717	* 0.5129	* 0.5271	* 0.4701	* 0.3371 *		
	* 3.7234	* 3.4723	* 3.8688	* 3.7608	* 4.2121	* 5.8679 *		
13	* 0.4713	* 0.4965	* 0.5217	* 0.4676	* 0.3361 *			
	* 4.2105	* 3.9951	* 3.8010	* 4.2348	* 5.8847 *			
14	* 0.4688	* 0.4557	* 0.3795	* 0.2764 *				
	* 4.2271	* 4.3485	* 5.2186	* 7.1569 *				
15	* 0.2813	* 0.2614	* F-SUB-Q					
	* 7.0339	* 7.5688	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 26 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5674	* 0.5284	* 0.5141	* 0.5719	* 0.5298	* 0.4694	* 0.4101	* 0.2661 *
	* 3.2687	* 3.5036	* 3.5751	* 3.2188	* 3.4723	* 3.8638	* 3.9822	* 6.0459 *
9	* 0.5284	* 0.5268	* 0.5644	* 0.5233	* 0.5620	* 0.4886	* 0.4273	* 0.2630 *
	* 3.5036	* 3.4392	* 3.2089	* 3.5079	* 3.2709	* 3.7348	* 4.0850	* 6.4176 *
10	* 0.5141	* 0.5644	* 0.4911	* 0.5569	* 0.5111	* 0.5025	* 0.3817	*
	* 3.5751	* 3.2075	* 3.5200	* 3.2497	* 3.5939	* 3.6545	* 4.7428	*
11	* 0.5719	* 0.5223	* 0.5564	* 0.4898	* 0.5202	* 0.4574	* 0.2953	*
	* 3.2188	* 3.5093	* 3.2501	* 3.6965	* 3.5444	* 4.0382	* 6.2291	*
12	* 0.5298	* 0.5601	* 0.5103	* 0.5199	* 0.4655	* 0.3473	*	*
	* 3.4723	* 3.2819	* 3.5996	* 3.5463	* 3.9793	* 5.3395	*	*
13	* 0.4694	* 0.4870	* 0.5014	* 0.4567	* 0.3460	*	*	*
	* 3.8638	* 3.7502	* 3.6624	* 4.0444	* 5.3595	*	*	*
14	* 0.4101	* 0.4263	* 0.3806	* 0.2943	*	*	*	*
	* 3.9822	* 4.0935	* 4.7565	* 6.2506	*	*	*	*
15	* 0.2661	* 0.2613	* F-SUB-Q					
	* 6.0459	* 6.4578	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1417	* 1.0022	* 0.9510	* 1.1044	* 1.0268	* 0.8971	* 0.9514	* 0.5638 *
	* 1.6424	* 1.8705	* 1.9591	* 1.6856	* 1.8122	* 2.0514	* 1.8617	* 3.1016 *
9	* 1.0022	* 1.0306	* 1.0847	* 0.9981	* 1.1367	* 0.9595	* 0.9517	* 0.5284 *
	* 1.8705	* 1.7947	* 1.6980	* 1.8576	* 1.6351	* 1.9287	* 1.8888	* 3.3357 *
10	* 0.9510	* 1.0846	* 0.9411	* 1.0823	* 0.9925	* 1.0473	* 0.7423	*
	* 1.9591	* 1.6973	* 1.9326	* 1.7062	* 1.8743	* 1.7718	* 2.4728	*
11	* 1.1044	* 0.9961	* 1.0814	* 0.9190	* 1.0181	* 0.9762	* 0.5719	*
	* 1.6856	* 1.8586	* 1.7064	* 2.0114	* 1.8315	* 1.9111	* 3.2506	*
12	* 1.0268	* 1.1325	* 0.9910	* 1.0175	* 0.9714	* 0.6468	*	*
	* 1.8122	* 1.6415	* 1.8773	* 1.8326	* 1.9249	* 2.8950	*	*
13	* 0.8971	* 0.9559	* 1.0453	* 0.9749	* 0.6451	*	*	*
	* 2.0514	* 1.9359	* 1.7754	* 1.9137	* 2.9027	*	*	*
14	* 0.9514	* 0.9498	* 0.7401	* 0.5698	*	*	*	*
	* 1.8617	* 1.8925	* 2.4802	* 3.2627	*	*	*	*
15	* 0.5638	* 0.5211	* F-SUB-Q					
	* 3.1016	* 3.3824	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 27 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2515 *	* 1.1500 *	* 1.0952 *	* 1.2368 *	* 1.1860 *	* 1.0663 *	* 1.1389 *	* 0.7008 *
	* 1.5210 *	* 1.6513 *	* 1.7296 *	* 1.5286 *	* 1.5924 *	* 1.7559 *	* 1.6069 *	* 2.5809 *
9	* 1.1500 *	* 1.1839 *	* 1.1835 *	* 1.1555 *	* 1.2547 *	* 1.1234 *	* 1.1550 *	* 0.6556 *
	* 1.6513 *	* 1.5940 *	* 1.5911 *	* 1.6363 *	* 1.5042 *	* 1.6726 *	* 1.5924 *	* 2.7695 *
10	* 1.0952 *	* 1.1841 *	* 1.0934 *	* 1.2120 *	* 1.1582 *	* 1.1972 *	* 0.9036 *	
	* 1.7296 *	* 1.5903 *	* 1.7121 *	* 1.5537 *	* 1.6318 *	* 1.5741 *	* 2.0651 *	
11	* 1.2368 *	* 1.1527 *	* 1.2104 *	* 1.0700 *	* 1.1449 *	* 1.1606 *	* 0.6927 *	
	* 1.5286 *	* 1.6377 *	* 1.5549 *	* 1.7617 *	* 1.6530 *	* 1.6297 *	* 2.7221 *	
12	* 1.1860 *	* 1.2472 *	* 1.1558 *	* 1.1438 *	* 1.1397 *	* 0.7665 *		
	* 1.5924 *	* 1.5136 *	* 1.6352 *	* 1.6546 *	* 1.6642 *	* 2.4707 *		
13	* 1.0663 *	* 1.1185 *	* 1.1945 *	* 1.1587 *	* 0.7651 *			
	* 1.7559 *	* 1.6800 *	* 1.5777 *	* 1.6324 *	* 2.4755 *			
14	* 1.1389 *	* 1.1523 *	* 0.9007 *	* 0.6901 *				
	* 1.6069 *	* 1.5961 *	* 2.0718 *	* 2.7326 *				
15	* 0.7008 *	* 0.6486 *	F-SUB-Q					
	* 2.5809 *	* 2.7992 *	M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4170 *	* 1.2710 *	* 1.2118 *	* 1.4138 *	* 1.3304 *	* 1.1995 *	* 1.3513 *	* 0.7989 *
	* 1.3700 *	* 1.5250 *	* 1.5960 *	* 1.3637 *	* 1.4447 *	* 1.5936 *	* 1.3842 *	* 2.3247 *
9	* 1.2710 *	* 1.3173 *	* 1.3445 *	* 1.2834 *	* 1.4401 *	* 1.2693 *	* 1.3695 *	* 0.7353 *
	* 1.5250 *	* 1.4643 *	* 1.4327 *	* 1.5039 *	* 1.3352 *	* 1.5099 *	* 1.3732 *	* 2.5345 *
10	* 1.2118 *	* 1.3452 *	* 1.2140 *	* 1.3891 *	* 1.2967 *	* 1.3892 *	* 1.0111 *	
	* 1.5960 *	* 1.4319 *	* 1.5790 *	* 1.3858 *	* 1.4866 *	* 1.3822 *	* 1.8842 *	
11	* 1.4138 *	* 1.2796 *	* 1.3869 *	* 1.1940 *	* 1.3196 *	* 1.3473 *	* 0.7580 *	
	* 1.3637 *	* 1.5084 *	* 1.3881 *	* 1.6133 *	* 1.4622 *	* 1.4279 *	* 2.5356 *	
12	* 1.3304 *	* 1.4302 *	* 1.2934 *	* 1.3180 *	* 1.3076 *	* 0.8371 *		
	* 1.4447 *	* 1.3462 *	* 1.4905 *	* 1.4640 *	* 1.4778 *	* 2.2701 *		
13	* 1.1995 *	* 1.2628 *	* 1.3856 *	* 1.3450 *	* 0.8360 *			
	* 1.5936 *	* 1.5178 *	* 1.3859 *	* 1.4305 *	* 2.2735 *			
14	* 1.3513 *	* 1.3659 *	* 1.0072 *	* 0.7550 *				
	* 1.3842 *	* 1.3768 *	* 1.8915 *	* 2.5457 *				
15	* 0.7989 *	* 0.7249 *	F-SUB-Q					
	* 2.3247 *	* 2.5707 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 28 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4746	* 1.3101	* 1.2566	* 1.4897	* 1.3925	* 1.2531	* 1.4507	* 0.8523 *
	* 1.3465	* 1.5146	* 1.5758	* 1.3231	* 1.4097	* 1.5619	* 1.3258	* 2.2469 *
9	* 1.3101	* 1.3683	* 1.4110	* 1.3367	* 1.5227	* 1.3338	* 1.4642	* 0.7845 *
	* 1.5146	* 1.4453	* 1.3983	* 1.4763	* 1.2909	* 1.4681	* 1.3192	* 2.4475 *
10	* 1.2566	* 1.4107	* 1.2620	* 1.4655	* 1.3566	* 1.4758	* 1.0743	*
	* 1.5758	* 1.3987	* 1.5584	* 1.3430	* 1.4506	* 1.3241	* 1.8143	*
11	* 1.4897	* 1.3319	* 1.4627	* 1.2476	* 1.3989	* 1.4381	* 0.8045	*
	* 1.3231	* 1.4811	* 1.3458	* 1.5788	* 1.4003	* 1.3406	* 2.4162	*
12	* 1.3925	* 1.5111	* 1.3525	* 1.3970	* 1.3886	* 0.8889	*	
	* 1.4097	* 1.3022	* 1.4551	* 1.4023	* 1.3976	* 2.1457	*	
13	* 1.2531	* 1.3262	* 1.4714	* 1.4353	* 0.8878	*		
	* 1.5619	* 1.4767	* 1.3283	* 1.3435	* 2.1485	*		
14	* 1.4507	* 1.4601	* 1.0700	* 0.8007	*			
	* 1.3258	* 1.3230	* 1.8217	* 2.4279	*			
15	* 0.8523	* 0.7756	* F-SUB-Q					
	* 2.2469	* 2.4756	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5078	* 1.3345	* 1.2866	* 1.5413	* 1.4370	* 1.2898	* 1.5184	* 0.8885 *
	* 1.3320	* 1.5079	* 1.5608	* 1.2928	* 1.3839	* 1.5415	* 1.2970	* 2.2151 *
9	* 1.3345	* 1.4019	* 1.4569	* 1.3739	* 1.5796	* 1.3795	* 1.5283	* 0.8206 *
	* 1.5079	* 1.4345	* 1.3772	* 1.4527	* 1.2589	* 1.4356	* 1.2893	* 2.4001 *
10	* 1.2866	* 1.4563	* 1.2957	* 1.5193	* 1.4000	* 1.5367	* 1.1183	*
	* 1.5608	* 1.3778	* 1.5444	* 1.3103	* 1.4170	* 1.2798	* 1.7686	*
11	* 1.5413	* 1.3690	* 1.5158	* 1.2863	* 1.4555	* 1.5026	* 0.8383	*
	* 1.2928	* 1.4589	* 1.3135	* 1.5508	* 1.3505	* 1.2872	* 2.3210	*
12	* 1.4370	* 1.5666	* 1.3952	* 1.4533	* 1.4473	* 0.9290	*	
	* 1.3839	* 1.2697	* 1.4220	* 1.3527	* 1.3437	* 2.0666	*	
13	* 1.2898	* 1.3709	* 1.5315	* 1.4995	* 0.9279	*		
	* 1.5415	* 1.4446	* 1.2843	* 1.2901	* 2.0691	*		
14	* 1.5184	* 1.5236	* 1.1135	* 0.8341	*			
	* 1.2970	* 1.2934	* 1.7764	* 2.3329	*			
15	* 0.8885	* 0.8096	* F-SUB-Q					
	* 2.2151	* 2.4323	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 29 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5567 *	* 1.3679 *	* 1.3236 *	* 1.6072 *	* 1.4902 *	* 1.3327 *	* 1.6003 *	* 0.9194 *
	* 1.2989 *	* 1.4831 *	* 1.5301 *	* 1.2487 *	* 1.3459 *	* 1.5061 *	* 1.2493 *	* 2.1770 *
9	* 1.3679 *	* 1.4444 *	* 1.5162 *	* 1.4189 *	* 1.6512 *	* 1.4332 *	* 1.6061 *	* 0.8436 *
	* 1.4831 *	* 1.4061 *	* 1.3364 *	* 1.4172 *	* 1.2129 *	* 1.3921 *	* 1.2426 *	* 2.3716 *
10	* 1.3236 *	* 1.5155 *	* 1.3369 *	* 1.5872 *	* 1.4509 *	* 1.6126 *	* 1.1523 *	
	* 1.5301 *	* 1.3371 *	* 1.5125 *	* 1.2638 *	* 1.3754 *	* 1.2243 *	* 1.7305 *	
11	* 1.6072 *	* 1.4137 *	* 1.5832 *	* 1.3316 *	* 1.5254 *	* 1.5817 *	* 0.8593 *	
	* 1.2487 *	* 1.4237 *	* 1.2672 *	* 1.5058 *	* 1.2946 *	* 1.2338 *	* 2.2786 *	
12	* 1.4902 *	* 1.6367 *	* 1.4455 *	* 1.5229 *	* 1.5171 *	* 0.9569 *		
	* 1.3459 *	* 1.2240 *	* 1.3807 *	* 1.2968 *	* 1.2926 *	* 2.0305 *		
13	* 1.3327 *	* 1.4238 *	* 1.6068 *	* 1.5781 *	* 0.9558 *			
	* 1.5061 *	* 1.4017 *	* 1.2290 *	* 1.2368 *	* 2.0327 *			
14	* 1.6003 *	* 1.6008 *	* 1.1471 *	* 0.8549 *				
	* 1.2493 *	* 1.2469 *	* 1.7386 *	* 2.2904 *				
15	* 0.9194 *	* 0.8340 *	F-SUB-Q					
	* 2.1770 *	* 2.3987 *	M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5767 *	* 1.3829 *	* 1.3434 *	* 1.6430 *	* 1.5215 *	* 1.3574 *	* 1.6493 *	* 0.9414 *
	* 1.2987 *	* 1.4826 *	* 1.5230 *	* 1.2366 *	* 1.3316 *	* 1.4943 *	* 1.2300 *	* 2.1521 *
9	* 1.3829 *	* 1.4665 *	* 1.5466 *	* 1.4448 *	* 1.6913 *	* 1.4660 *	* 1.6521 *	* 0.8642 *
	* 1.4826 *	* 1.3993 *	* 1.3239 *	* 1.4072 *	* 1.1983 *	* 1.3744 *	* 1.2241 *	* 2.3448 *
10	* 1.3434 *	* 1.5457 *	* 1.3601 *	* 1.6253 *	* 1.4819 *	* 1.6578 *	* 1.1791 *	
	* 1.5230 *	* 1.3247 *	* 1.5026 *	* 1.2462 *	* 1.3632 *	* 1.2075 *	* 1.7068 *	
11	* 1.6430 *	* 1.4394 *	* 1.6208 *	* 1.3586 *	* 1.5661 *	* 1.6298 *	* 0.8792 *	
	* 1.2366 *	* 1.4126 *	* 1.2497 *	* 1.4914 *	* 1.2798 *	* 1.2180 *	* 2.2607 *	
12	* 1.5215 *	* 1.6755 *	* 1.4759 *	* 1.5633 *	* 1.5595 *	* 0.9820 *		
	* 1.3316 *	* 1.2099 *	* 1.3688 *	* 1.2821 *	* 1.2791 *	* 2.0169 *		
13	* 1.3574 *	* 1.4556 *	* 1.6513 *	* 1.6258 *	* 0.9810 *			
	* 1.4943 *	* 1.3843 *	* 1.2124 *	* 1.2211 *	* 2.0190 *			
14	* 1.6493 *	* 1.6463 *	* 1.1734 *	* 0.8745 *				
	* 1.2300 *	* 1.2286 *	* 1.7152 *	* 2.2728 *				
15	* 0.9414 *	* 0.8542 *	F-SUB-Q					
	* 2.1521 *	* 2.3720 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 30 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6209 *	* 1.4116 *	* 1.3741 *	* 1.7011 *	* 1.5670 *	* 1.3930 *	* 1.7210 *	* 0.9630 *
	* 1.2922 *	* 1.4848 *	* 1.5225 *	* 1.2222 *	* 1.3215 *	* 1.4852 *	* 1.1940 *	* 2.1303 *
9	* 1.4116 *	* 1.5028 *	* 1.5985 *	* 1.4826 *	* 1.7546 *	* 1.5113 *	* 1.7191 *	* 0.8796 *
	* 1.4848 *	* 1.3935 *	* 1.3070 *	* 1.4025 *	* 1.1812 *	* 1.3625 *	* 1.1935 *	* 2.3319 *
10	* 1.3741 *	* 1.5975 *	* 1.3939 *	* 1.6853 *	* 1.5248 *	* 1.7254 *	* 1.2015 *	
	* 1.5225 *	* 1.3079 *	* 1.4953 *	* 1.2294 *	* 1.3564 *	* 1.1879 *	* 1.7082 *	
11	* 1.7011 *	* 1.4769 *	* 1.6803 *	* 1.3960 *	* 1.6275 *	* 1.6991 *	* 0.8901 *	
	* 1.2222 *	* 1.4079 *	* 1.2331 *	* 1.4846 *	* 1.2627 *	* 1.1987 *	* 2.2875 *	
12	* 1.5670 *	* 1.7374 *	* 1.5182 *	* 1.6244 *	* 1.6194 *	* 1.0004 *		
	* 1.3215 *	* 1.1935 *	* 1.3624 *	* 1.2651 *	* 1.2643 *	* 2.0340 *		
13	* 1.3930 *	* 1.4999 *	* 1.7182 *	* 1.6947 *	* 0.9996 *			
	* 1.4852 *	* 1.3729 *	* 1.1930 *	* 1.2019 *	* 2.0356 *			
14	* 1.7210 *	* 1.7129 *	* 1.1951 *	* 0.8859 *				
	* 1.1940 *	* 1.1979 *	* 1.7172 *	* 2.2981 *				
15	* 0.9630 *	* 0.8657 *	F-SUB-Q					
	* 2.1303 *	* 2.3689 *	M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5815 *	* 1.3903 *	* 1.3569 *	* 1.6723 *	* 1.5533 *	* 1.3809 *	* 1.6967 *	* 0.9696 *
	* 1.3666 *	* 1.5558 *	* 1.5919 *	* 1.2843 *	* 1.3763 *	* 1.5454 *	* 1.2451 *	* 2.1709 *
9	* 1.3903 *	* 1.4819 *	* 1.5673 *	* 1.4682 *	* 1.7272 *	* 1.4994 *	* 1.6962 *	* 0.8981 *
	* 1.5558 *	* 1.4579 *	* 1.3756 *	* 1.4628 *	* 1.2391 *	* 1.4176 *	* 1.2445 *	* 2.3442 *
10	* 1.3569 *	* 1.5661 *	* 1.3788 *	* 1.6589 *	* 1.5137 *	* 1.7017 *	* 1.2186 *	
	* 1.5919 *	* 1.3766 *	* 1.5608 *	* 1.2904 *	* 1.4123 *	* 1.2445 *	* 1.7365 *	
11	* 1.6723 *	* 1.4621 *	* 1.6536 *	* 1.3843 *	* 1.6046 *	* 1.6772 *	* 0.9137 *	
	* 1.2843 *	* 1.4692 *	* 1.2945 *	* 1.5474 *	* 1.3246 *	* 1.2560 *	* 2.3028 *	
12	* 1.5533 *	* 1.7096 *	* 1.5067 *	* 1.6014 *	* 1.6018 *	* 1.0285 *		
	* 1.3763 *	* 1.2524 *	* 1.4188 *	* 1.3272 *	* 1.3226 *	* 2.0479 *		
13	* 1.3809 *	* 1.4878 *	* 1.6941 *	* 1.6726 *	* 1.0270 *			
	* 1.5454 *	* 1.4287 *	* 1.2501 *	* 1.2594 *	* 2.0507 *			
14	* 1.6967 *	* 1.6897 *	* 1.2121 *	* 0.9084 *				
	* 1.2451 *	* 1.2492 *	* 1.7456 *	* 2.3158 *				
15	* 0.9696 *	* 0.8860 *	F-SUB-Q					
	* 2.1709 *	* 2.3756 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 31 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6418	* 1.4262	* 1.3939	* 1.7469	* 1.6079	* 1.4229	* 1.7889	* 0.9899 *
	* 1.3684	* 1.5774	* 1.6128	* 1.2801	* 1.3840	* 1.5607	* 1.2270	* 2.2059 *
9	* 1.4262	* 1.5272	* 1.6344	* 1.5134	* 1.8080	* 1.5541	* 1.7818	* 0.9059 *
	* 1.5774	* 1.4717	* 1.3727	* 1.4779	* 1.2319	* 1.4236	* 1.2311	* 2.4109 *
10	* 1.3939	* 1.6331	* 1.4191	* 1.7352	* 1.5643	* 1.7879	* 1.2350	*
	* 1.6128	* 1.3737	* 1.5792	* 1.2850	* 1.4235	* 1.2335	* 1.7821	*
11	* 1.7469	* 1.5068	* 1.7293	* 1.4280	* 1.6821	* 1.7647	* 0.9149	*
	* 1.2801	* 1.4844	* 1.2893	* 1.5628	* 1.3151	* 1.2437	* 2.3936	*
12	* 1.6079	* 1.7886	* 1.5567	* 1.6786	* 1.6762	* 1.0338	*	
	* 1.3840	* 1.2446	* 1.4304	* 1.3187	* 1.3171	* 2.1228	*	
13	* 1.4229	* 1.5412	* 1.7794	* 1.7596	* 1.0330	*		
	* 1.5607	* 1.4354	* 1.2392	* 1.2471	* 2.1244	*		
14	* 1.7889	* 1.7747	* 1.2278	* 0.9102	*			
	* 1.2270	* 1.2359	* 1.7922	* 2.4052	*			
15	* 0.9899	* 0.8932	* F-SUB-Q					
	* 2.2059	* 2.4449	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6471	* 1.4300	* 1.4009	* 1.7648	* 1.6248	* 1.4351	* 1.8185	* 1.0023 *
	* 1.3829	* 1.5922	* 1.6250	* 1.2935	* 1.4074	* 1.5932	* 1.2620	* 2.2753 *
9	* 1.4300	* 1.5356	* 1.6473	* 1.5253	* 1.8290	* 1.5720	* 1.8091	* 0.9187 *
	* 1.5922	* 1.4847	* 1.3844	* 1.4953	* 1.2496	* 1.4545	* 1.2679	* 2.4828 *
10	* 1.4009	* 1.6458	* 1.4288	* 1.7553	* 1.5806	* 1.8146	* 1.2512	*
	* 1.6250	* 1.3856	* 1.5971	* 1.2999	* 1.4432	* 1.2592	* 1.8258	*
11	* 1.7648	* 1.5183	* 1.7490	* 1.4413	* 1.7052	* 1.7932	* 0.9283	*
	* 1.2935	* 1.5020	* 1.3045	* 1.5799	* 1.3360	* 1.2717	* 2.4470	*
12	* 1.6248	* 1.8085	* 1.5724	* 1.7014	* 1.7009	* 1.0500	*	
	* 1.4074	* 1.2633	* 1.4505	* 1.3389	* 1.3376	* 2.1603	*	
13	* 1.4351	* 1.5583	* 1.8055	* 1.7878	* 1.0491	*		
	* 1.5932	* 1.4670	* 1.2654	* 1.2754	* 2.1621	*		
14	* 1.8185	* 1.8015	* 1.2439	* 0.9226	*			
	* 1.2620	* 1.2730	* 1.8362	* 2.4619	*			
15	* 1.0023	* 0.9066	* F-SUB-Q					
	* 2.2753	* 2.5155	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 32 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6121	* 1.4090	* 1.3835	* 1.7399	* 1.6123	* 1.4240	* 1.8019	* 1.0061 *
	* 1.3954	* 1.5958	* 1.6248	* 1.2950	* 1.3995	* 1.5839	* 1.2584	* 2.2433 *
9	* 1.4090	* 1.5150	* 1.6194	* 1.5111	* 1.8059	* 1.5619	* 1.7937	* 0.9325 *
	* 1.5958	* 1.4858	* 1.3902	* 1.4901	* 1.2491	* 1.4444	* 1.2622	* 2.4185 *
10	* 1.3835	* 1.6178	* 1.4136	* 1.7331	* 1.5695	* 1.7971	* 1.2617	*
	* 1.6248	* 1.3916	* 1.5932	* 1.2996	* 1.4348	* 1.2548	* 1.7861	*
11	* 1.7399	* 1.5033	* 1.7264	* 1.4298	* 1.6871	* 1.7783	* 0.9425	*
	* 1.2950	* 1.4975	* 1.3045	* 1.5725	* 1.3333	* 1.2658	* 2.3794	*
12	* 1.6123	* 1.7858	* 1.5609	* 1.6831	* 1.6872	* 1.0696	*	*
	* 1.3995	* 1.2624	* 1.4425	* 1.3364	* 1.3317	* 2.0945	*	*
13	* 1.4240	* 1.5478	* 1.7875	* 1.7726	* 1.0683	*	*	*
	* 1.5839	* 1.4573	* 1.2614	* 1.2698	* 2.0971	*	*	*
14	* 1.8019	* 1.7858	* 1.2540	* 0.9365	*	*	*	*
	* 1.2584	* 1.2677	* 1.7968	* 2.3946	*	*	*	*
15	* 1.0061	* 0.9192	* F-SUB-Q					
	* 2.2433	* 2.4531	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6532	* 1.4289	* 1.4063	* 1.7968	* 1.6521	* 1.4542	* 1.8821	* 1.0192 *
	* 1.3508	* 1.5621	* 1.5868	* 1.2446	* 1.3549	* 1.5392	* 1.1925	* 2.1930 *
9	* 1.4289	* 1.5439	* 1.6680	* 1.5412	* 1.8696	* 1.6038	* 1.8682	* 0.9331 *
	* 1.5621	* 1.4470	* 1.3393	* 1.4499	* 1.1974	* 1.3953	* 1.2007	* 2.3941 *
10	* 1.4063	* 1.6663	* 1.4397	* 1.7924	* 1.6057	* 1.8694	* 1.2679	*
	* 1.5868	* 1.3407	* 1.5507	* 1.2470	* 1.3918	* 1.1968	* 1.7628	*
11	* 1.7968	* 1.5330	* 1.7850	* 1.4603	* 1.7531	* 1.8531	* 0.9356	*
	* 1.2446	* 1.4574	* 1.2521	* 1.5280	* 1.2738	* 1.2054	* 2.3785	*
12	* 1.6521	* 1.8503	* 1.5963	* 1.7472	* 1.7482	* 1.0674	*	*
	* 1.3549	* 1.2095	* 1.3998	* 1.2780	* 1.2759	* 2.0836	*	*
13	* 1.4543	* 1.5882	* 1.8588	* 1.8469	* 1.0665	*	*	*
	* 1.5392	* 1.4088	* 1.2035	* 1.2094	* 2.0851	*	*	*
14	* 1.8821	* 1.8595	* 1.2595	* 0.9304	*	*	*	*
	* 1.1925	* 1.2062	* 1.7743	* 2.3916	*	*	*	*
15	* 1.0192	* 0.9188	* F-SUB-Q					
	* 2.1930	* 2.4311	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 33 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6560	* 1.4264	* 1.4074	* 1.8125	* 1.6640	* 1.4659	* 1.9159	* 1.0255 *
	* 1.3364	* 1.5507	* 1.5712	* 1.2233	* 1.3338	* 1.5137	* 1.1608	* 2.1568 *
9	* 1.4264	* 1.5467	* 1.6778	* 1.5470	* 1.8901	* 1.6185	* 1.8996	* 0.9370 *
	* 1.5507	* 1.4312	* 1.3194	* 1.4319	* 1.1745	* 1.3709	* 1.1703	* 2.3595 *
10	* 1.4074	* 1.6759	* 1.4435	* 1.8105	* 1.6161	* 1.8977	* 1.2725	*
	* 1.5712	* 1.3209	* 1.5322	* 1.2240	* 1.3712	* 1.1692	* 1.7404	*
11	* 1.8125	* 1.5383	* 1.8027	* 1.4687	* 1.7789	* 1.8849	* 0.9358	*
	* 1.2233	* 1.4397	* 1.2292	* 1.5054	* 1.2448	* 1.1753	* 2.3560	*
12	* 1.6640	* 1.8725	* 1.6061	* 1.7726	* 1.7721	* 1.0709	*	
	* 1.3338	* 1.1852	* 1.3795	* 1.2491	* 1.2479	* 2.0582	*	
13	* 1.4659	* 1.6021	* 1.8863	* 1.8782	* 1.0697	*		
	* 1.5137	* 1.3846	* 1.1760	* 1.1793	* 2.0603	*		
14	* 1.9159	* 1.8904	* 1.2638	* 0.9304	*			
	* 1.1608	* 1.1758	* 1.7522	* 2.3692	*			
15	* 1.0255	* 0.9204	* F-SUB-Q					
	* 2.1568	* 2.4017	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6377	* 1.4122	* 1.3937	* 1.8015	* 1.6580	* 1.4608	* 1.9150	* 1.0245 *
	* 1.3449	* 1.5589	* 1.5792	* 1.2246	* 1.3315	* 1.5099	* 1.1536	* 2.1448 *
9	* 1.4122	* 1.5329	* 1.6631	* 1.5363	* 1.8828	* 1.6136	* 1.8991	* 0.9388 *
	* 1.5589	* 1.4370	* 1.3245	* 1.4348	* 1.1727	* 1.3676	* 1.1631	* 2.3399 *
10	* 1.3937	* 1.6611	* 1.4313	* 1.8015	* 1.6090	* 1.8944	* 1.2735	*
	* 1.5792	* 1.3261	* 1.5377	* 1.2239	* 1.3703	* 1.1649	* 1.7292	*
11	* 1.8015	* 1.5270	* 1.7933	* 1.4607	* 1.7747	* 1.8830	* 0.9375 *	
	* 1.2246	* 1.4432	* 1.2294	* 1.5063	* 1.2413	* 1.1702	* 2.3392 *	
12	* 1.6580	* 1.8660	* 1.5986	* 1.7681	* 1.7679	* 1.0741	*	
	* 1.3315	* 1.1829	* 1.3790	* 1.2458	* 1.2446	* 2.0419	*	
13	* 1.4608	* 1.5967	* 1.8825	* 1.8760	* 1.0730	*		
	* 1.5099	* 1.3817	* 1.1720	* 1.1744	* 2.0438	*		
14	* 1.9150	* 1.8895	* 1.2644	* 0.9319	*			
	* 1.1536	* 1.1688	* 1.7413	* 2.3530	*			
15	* 1.0245	* 0.9243	* F-SUB-Q					
	* 2.1448	* 2.3761	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 34 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5836	* 1.3772	* 1.3604	* 1.7504	* 1.6246	* 1.4345	* 1.8671	* 1.0166 *
	* 1.3886	* 1.5963	* 1.6157	* 1.2583	* 1.3562	* 1.5339	* 1.1797	* 2.1550 *
9	* 1.3772	* 1.4947	* 1.6112	* 1.5030	* 1.8329	* 1.5822	* 1.8551	* 0.9435 *
	* 1.5963	* 1.4716	* 1.3651	* 1.4644	* 1.2021	* 1.3917	* 1.1872	* 2.3211 *
10	* 1.3604	* 1.6090	* 1.3987	* 1.7519	* 1.5769	* 1.8474	* 1.2725	*
	* 1.6157	* 1.3668	* 1.5713	* 1.2565	* 1.3959	* 1.1921	* 1.7264	*
11	* 1.7504	* 1.4933	* 1.7436	* 1.4311	* 1.7294	* 1.8375	* 0.9452	*
	* 1.2583	* 1.4736	* 1.2623	* 1.5352	* 1.2713	* 1.1965	* 2.3152	*
12	* 1.6246	* 1.8160	* 1.5665	* 1.7227	* 1.7264	* 1.0812	*	
	* 1.3562	* 1.2130	* 1.4049	* 1.2761	* 1.2722	* 2.0245	*	
13	* 1.4345	* 1.5652	* 1.8348	* 1.8304	* 1.0795	*		
	* 1.5339	* 1.4065	* 1.1998	* 1.2009	* 2.0275	*		
14	* 1.8671	* 1.8454	* 1.2633	* 0.9382	*			
	* 1.1797	* 1.1933	* 1.7385	* 2.3320	*			
15	* 1.0166	* 0.9290	* F-SUB-Q					
	* 2.1550	* 2.3571	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6149	* 1.3857	* 1.3692	* 1.7912	* 1.6476	* 1.4521	* 1.9295	* 1.0137 *
	* 1.3485	* 1.5709	* 1.5888	* 1.2166	* 1.3233	* 1.5000	* 1.1300	* 2.1415 *
9	* 1.3857	* 1.5103	* 1.6447	* 1.5157	* 1.8815	* 1.6063	* 1.9133	* 0.9272 *
	* 1.5709	* 1.4416	* 1.3234	* 1.4367	* 1.1589	* 1.3567	* 1.1395	* 2.3409 *
10	* 1.3692	* 1.6424	* 1.4090	* 1.7939	* 1.5944	* 1.9012	* 1.2585	*
	* 1.5888	* 1.3252	* 1.5435	* 1.2141	* 1.3660	* 1.1464	* 1.7282	*
11	* 1.7911	* 1.5058	* 1.7850	* 1.4453	* 1.7775	* 1.8941	* 0.9206	*
	* 1.2166	* 1.4459	* 1.2201	* 1.5044	* 1.2244	* 1.1492	* 2.3556	*
12	* 1.6476	* 1.8632	* 1.5833	* 1.7703	* 1.7679	* 1.0583	*	
	* 1.3233	* 1.1701	* 1.3754	* 1.2293	* 1.2298	* 2.0489	*	
13	* 1.4521	* 1.5882	* 1.8882	* 1.8864	* 1.0570	*		
	* 1.5000	* 1.3720	* 1.1541	* 1.1538	* 2.0513	*		
14	* 1.9295	* 1.9027	* 1.2487	* 0.9148	*			
	* 1.1300	* 1.1457	* 1.7415	* 2.3704	*			
15	* 1.0137	* 0.9100	* F-SUB-Q					
	* 2.1415	* 2.3849	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 35 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5824	* 1.3578	* 1.3407	* 1.7575	* 1.6203	* 1.4279	* 1.9013	* 0.9944 *
	* 1.3559	* 1.5797	* 1.5990	* 1.2214	* 1.3254	* 1.5019	* 1.1286	* 2.1495 *
9	* 1.3578	* 1.4813	* 1.6094	* 1.4863	* 1.8487	* 1.5803	* 1.8882	* 0.9104 *
	* 1.5797	* 1.4483	* 1.3326	* 1.4436	* 1.1617	* 1.3582	* 1.1366	* 2.3475 *
10	* 1.3407	* 1.6071	* 1.3798	* 1.7603	* 1.5659	* 1.8724	* 1.2362	*
	* 1.5990	* 1.3345	* 1.5532	* 1.2189	* 1.3703	* 1.1464	* 1.7326	*
11	* 1.7575	* 1.4762	* 1.7513	* 1.4172	* 1.7471	* 1.8665	* 0.9018	*
	* 1.2214	* 1.4532	* 1.2251	* 1.5117	* 1.2270	* 1.1484	* 2.3688	*
12	* 1.6203	* 1.8301	* 1.5546	* 1.7397	* 1.7371	* 1.0385	*	
	* 1.3254	* 1.1733	* 1.3801	* 1.2321	* 1.2331	* 2.0571	*	
13	* 1.4279	* 1.5620	* 1.8585	* 1.8586	* 1.0373	*		
	* 1.5020	* 1.3739	* 1.1548	* 1.1532	* 2.0595	*		
14	* 1.9013	* 1.8771	* 1.2263	* 0.8959	*			
	* 1.1286	* 1.1431	* 1.7464	* 2.3842	*			
15	* 0.9944	* 0.8927	* F-SUB-Q					
	* 2.1495	* 2.3937	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5321	* 1.3199	* 1.2980	* 1.6933	* 1.5706	* 1.3822	* 1.8235	* 0.9579 *
	* 1.3838	* 1.6059	* 1.6325	* 1.2526	* 1.3508	* 1.5327	* 1.1617	* 2.2036 *
9	* 1.3199	* 1.4353	* 1.5475	* 1.4392	* 1.7800	* 1.5305	* 1.8176	* 0.8953 *
	* 1.6059	* 1.4771	* 1.3696	* 1.4732	* 1.1921	* 1.3853	* 1.1656	* 2.3573 *
10	* 1.2980	* 1.5453	* 1.3346	* 1.6943	* 1.5154	* 1.8022	* 1.1988	*
	* 1.6325	* 1.3715	* 1.5872	* 1.2513	* 1.3991	* 1.1762	* 1.7647	*
11	* 1.6933	* 1.4293	* 1.6855	* 1.3693	* 1.6774	* 1.7928	* 0.8720	*
	* 1.2526	* 1.4832	* 1.2577	* 1.5464	* 1.2625	* 1.1807	* 2.4205	*
12	* 1.5706	* 1.7602	* 1.5044	* 1.6701	* 1.6786	* 1.0190	*	
	* 1.3508	* 1.2050	* 1.4091	* 1.2678	* 1.2607	* 2.0714	*	
13	* 1.3822	* 1.5123	* 1.7891	* 1.7848	* 1.0177	*		
	* 1.5327	* 1.4017	* 1.1846	* 1.1858	* 2.0739	*		
14	* 1.8235	* 1.8063	* 1.1890	* 0.8659	*			
	* 1.1617	* 1.1727	* 1.7790	* 2.4371	*			
15	* 0.9579	* 0.8623	* F-SUB-Q					
	* 2.2036	* 2.4475	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 36 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4498	* 1.2633	* 1.2353	* 1.5853	* 1.4878	* 1.3047	* 1.6767	* 0.8957 *
	* 1.4485	* 1.6622	* 1.6996	* 1.3252	* 1.4122	* 1.6079	* 1.2504	* 2.3330 *
9	* 1.2633	* 1.3643	* 1.4635	* 1.3681	* 1.6689	* 1.4466	* 1.6832	* 0.8367 *
	* 1.6622	* 1.5395	* 1.4348	* 1.5354	* 1.2590	* 1.4512	* 1.2456	* 2.4969 *
10	* 1.2353	* 1.4598	* 1.2677	* 1.5832	* 1.4361	* 1.6786	* 1.1364	*
	* 1.6996	* 1.4384	* 1.6556	* 1.3262	* 1.4623	* 1.2500	* 1.8431	*
11	* 1.5853	* 1.3590	* 1.5752	* 1.2957	* 1.5565	* 1.6592	* 0.8251	*
	* 1.3252	* 1.5455	* 1.3329	* 1.6189	* 1.3471	* 1.2627	* 2.5328	*
12	* 1.4878	* 1.6471	* 1.4260	* 1.5498	* 1.5821	* 0.9603	*	
	* 1.4122	* 1.2750	* 1.4725	* 1.3527	* 1.3243	* 2.1763	*	
13	* 1.3047	* 1.4298	* 1.6664	* 1.6516	* 0.9589	*		
	* 1.6079	* 1.4679	* 1.2590	* 1.2683	* 2.1793	*		
14	* 1.6767	* 1.6726	* 1.1269	* 0.8191	*			
	* 1.2504	* 1.2534	* 1.8584	* 2.5510	*			
15	* 0.8957	* 0.8111	* F-SUB-Q					
	* 2.3330	* 2.5759	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3372	* 1.1805	* 1.1496	* 1.4491	* 1.3703	* 1.1957	* 1.4747	* 0.7996 *
	* 1.5585	* 1.7656	* 1.8129	* 1.4385	* 1.5213	* 1.7423	* 1.4098	* 2.5923 *
9	* 1.1805	* 1.2708	* 1.3411	* 1.2713	* 1.5209	* 1.3264	* 1.4929	* 0.7504 *
	* 1.7656	* 1.6401	* 1.5540	* 1.6397	* 1.3705	* 1.5699	* 1.3925	* 2.7617 *
10	* 1.1496	* 1.3382	* 1.1765	* 1.4433	* 1.3291	* 1.5117	* 1.0313	*
	* 1.8129	* 1.5573	* 1.7707	* 1.4436	* 1.5678	* 1.3768	* 2.0146	*
11	* 1.4491	* 1.2634	* 1.4365	* 1.1952	* 1.4027	* 1.4873	* 0.7546 *	
	* 1.4385	* 1.6497	* 1.4503	* 1.7422	* 1.4830	* 1.3981	* 2.7476 *	
12	* 1.3703	* 1.4997	* 1.3203	* 1.3985	* 1.4330	* 0.8801	*	
	* 1.5213	* 1.3892	* 1.5780	* 1.4878	* 1.4505	* 2.3562	*	
13	* 1.1957	* 1.3117	* 1.5018	* 1.4804	* 0.8786	*		
	* 1.7423	* 1.5873	* 1.3856	* 1.4044	* 2.3598	*		
14	* 1.4747	* 1.4835	* 1.0230	* 0.7490	*			
	* 1.4098	* 1.4012	* 2.0308	* 2.7677	*			
15	* 0.7996	* 0.7302	* F-SUB-Q					
	* 2.5923	* 2.8383	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 37 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1619	* 0.9878	* 0.9626	* 1.2322	* 1.1334	* 0.9730	* 1.1747	* 0.6314 *
	* 1.7826	* 2.0976	* 2.1524	* 1.6815	* 1.8277	* 2.1279	* 1.7583	* 3.2630 *
9	* 0.9878	* 1.0728	* 1.1645	* 1.0642	* 1.3013	* 1.0908	* 1.1652	* 0.5962 *
	* 2.0976	* 1.9311	* 1.7787	* 1.9469	* 1.5919	* 1.8974	* 1.7725	* 3.4553 *
10	* 0.9626	* 1.1636	* 0.9815	* 1.2276	* 1.1025	* 1.2529	* 0.8269	*
	* 2.1524	* 1.7801	* 2.1102	* 1.6869	* 1.8783	* 1.6507	* 2.4968	*
11	* 1.2322	* 1.0581	* 1.2228	* 0.9914	* 1.1845	* 1.1817	* 0.6193	*
	* 1.6815	* 1.9579	* 1.6934	* 2.0881	* 1.7458	* 1.7471	* 3.3281	*
12	* 1.1334	* 1.2869	* 1.0959	* 1.1816	* 1.1551	* 0.7256	*	
	* 1.8277	* 1.6091	* 1.8894	* 1.7500	* 1.7883	* 2.8407	*	
13	* 0.9730	* 1.0794	* 1.2442	* 1.1768	* 0.7242	*		
	* 2.1279	* 1.9170	* 1.6619	* 1.7541	* 2.8458	*		
14	* 1.1747	* 1.1585	* 0.8206	* 0.6147	*			
	* 1.7583	* 1.7826	* 2.5155	* 3.3526	*			
15	* 0.6314	* 0.5855	* F-SUB-Q					
	* 3.2630	* 3.5186	* M-SUB-Q					

AT 100% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5101	* 0.4550	* 0.4679	* 0.5562	* 0.5173	* 0.4610	* 0.4719	* 0.2868 *
	* 4.0436	* 4.5333	* 4.4088	* 3.7093	* 3.9872	* 4.4701	* 4.3590	* 7.1579 *
9	* 0.4550	* 0.4889	* 0.5330	* 0.4993	* 0.5653	* 0.4931	* 0.4619	* 0.2681 *
	* 4.5333	* 4.2187	* 3.8700	* 4.1307	* 3.6481	* 4.1773	* 4.4524	* 7.6563 *
10	* 0.4679	* 0.5326	* 0.4766	* 0.5533	* 0.5065	* 0.5236	* 0.3804	*
	* 4.4088	* 3.8730	* 4.3264	* 3.7268	* 4.0696	* 3.9324	* 5.4048	*
11	* 0.5562	* 0.4967	* 0.5513	* 0.4780	* 0.5289	* 0.4780	* 0.2832	*
	* 3.7093	* 4.1520	* 3.7396	* 4.3112	* 3.8932	* 4.3017	* 7.2506	*
12	* 0.5173	* 0.5603	* 0.5036	* 0.5276	* 0.4790	* 0.3427	*	
	* 3.9872	* 3.6796	* 4.0929	* 3.9025	* 4.2921	* 5.9932	*	
13	* 0.4610	* 0.4887	* 0.5201	* 0.4761	* 0.3419	*		
	* 4.4701	* 4.2146	* 3.9586	* 4.3185	* 6.0066	*		
14	* 0.4719	* 0.4594	* 0.3777	* 0.2812	*			
	* 4.3590	* 4.4765	* 5.4425	* 7.3013	*			
15	* 0.2868	* 0.2668	* F-SUB-Q					
	* 7.1579	* 7.6920	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 38 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5476	* 0.5149	* 0.5056	* 0.5600	* 0.5239	* 0.4700	* 0.4207	* 0.2749 *
	* 3.4180	* 3.6320	* 3.6746	* 3.3246	* 3.5544	* 3.8993	* 3.8924	* 5.9138 *
9	* 0.5149	* 0.5164	* 0.5503	* 0.5167	* 0.5533	* 0.4889	* 0.4407	* 0.2710 *
	* 3.6320	* 3.5438	* 3.3287	* 3.5931	* 3.3622	* 3.7828	* 4.0056	* 6.2880 *
10	* 0.5056	* 0.5502	* 0.4727	* 0.5489	* 0.5088	* 0.5070	* 0.3833	*
	* 3.6746	* 3.3277	* 3.6015	* 3.3406	* 3.6558	* 3.6697	* 4.7821	*
11	* 0.5600	* 0.5157	* 0.5484	* 0.4882	* 0.5199	* 0.4661	* 0.3011	*
	* 3.3246	* 3.5945	* 3.3410	* 3.7547	* 3.5921	* 4.0196	* 6.1908	*
12	* 0.5239	* 0.5516	* 0.5081	* 0.5196	* 0.4716	* 0.3517	*	*
	* 3.5544	* 3.3725	* 3.6612	* 3.5938	* 3.9792	* 5.3452	*	*
13	* 0.4700	* 0.4873	* 0.5059	* 0.4654	* 0.3503	*	*	*
	* 3.8993	* 3.7967	* 3.6773	* 4.0254	* 5.3655	*	*	*
14	* 0.4207	* 0.4397	* 0.3823	* 0.3000	*	*	*	*
	* 3.8924	* 4.0139	* 4.7945	* 6.2128	*	*	*	*
15	* 0.2749	* 0.2691	* F-SUB-Q					
	* 5.9138	* 6.3301	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0782	* 0.9520	* 0.9176	* 1.0643	* 0.9932	* 0.8744	* 0.9611	* 0.5703 *
	* 1.7538	* 1.9812	* 2.0509	* 1.7680	* 1.8954	* 2.1294	* 1.8631	* 3.0933 *
9	* 0.9520	* 0.9892	* 1.0428	* 0.9646	* 1.0970	* 0.9384	* 0.9543	* 0.5342 *
	* 1.9812	* 1.8879	* 1.7857	* 1.9415	* 1.7139	* 1.9968	* 1.9055	* 3.3307 *
10	* 0.9176	* 1.0427	* 0.9123	* 1.0484	* 0.9660	* 1.0297	* 0.7298	*
	* 2.0509	* 1.7852	* 2.0151	* 1.7826	* 1.9491	* 1.8252	* 2.5457	*
11	* 1.0643	* 0.9627	* 1.0475	* 0.8969	* 0.9986	* 0.9726	* 0.5724	*
	* 1.7680	* 1.9425	* 1.7829	* 2.0856	* 1.8897	* 1.9431	* 3.2892	*
12	* 0.9932	* 1.0935	* 0.9644	* 0.9980	* 0.9579	* 0.6472	*	*
	* 1.8954	* 1.7196	* 1.9522	* 1.8908	* 1.9766	* 2.9304	*	*
13	* 0.8744	* 0.9350	* 1.0277	* 0.9713	* 0.6456	*	*	*
	* 2.1294	* 2.0038	* 1.8288	* 1.9457	* 2.9377	*	*	*
14	* 0.9611	* 0.9524	* 0.7277	* 0.5705	*	*	*	*
	* 1.8631	* 1.9091	* 2.5527	* 3.3003	*	*	*	*
15	* 0.5703	* 0.5265	* F-SUB-Q					
	* 3.0933	* 3.3791	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 39 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2240	* 1.1040	* 1.0775	* 1.2354	* 1.1603	* 1.0347	* 1.1740	* 0.7070 *
	* 1.5670	* 1.7348	* 1.7740	* 1.5452	* 1.6454	* 1.8291	* 1.5717	* 2.5799 *
9	* 1.1040	* 1.1576	* 1.2015	* 1.1349	* 1.2587	* 1.1019	* 1.1588	* 0.6603 *
	* 1.7348	* 1.6443	* 1.5796	* 1.6774	* 1.5154	* 1.7251	* 1.6044	* 2.7736 *
10	* 1.0775	* 1.2015	* 1.0839	* 1.2183	* 1.1408	* 1.1984	* 0.8861	*
	* 1.7740	* 1.5795	* 1.7450	* 1.5631	* 1.6750	* 1.5916	* 2.1296	*
11	* 1.2354	* 1.1339	* 1.2169	* 1.0613	* 1.1607	* 1.1681	* 0.6951	*
	* 1.5452	* 1.6788	* 1.5650	* 1.7959	* 1.6482	* 1.6381	* 2.7445	*
12	* 1.1603	* 1.2539	* 1.1386	* 1.1597	* 1.1458	* 0.7811	*	
	* 1.6454	* 1.5214	* 1.6783	* 1.6497	* 1.6737	* 2.4572	*	
13	* 1.0347	* 1.0974	* 1.1960	* 1.1665	* 0.7798	*		
	* 1.8291	* 1.7321	* 1.5947	* 1.6403	* 2.4617	*		
14	* 1.1740	* 1.1563	* 0.8835	* 0.6927	*			
	* 1.5717	* 1.6078	* 2.1357	* 2.7539	*			
15	* 0.7070	* 0.6528	* F-SUB-Q					
	* 2.5799	* 2.8051	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4133	* 1.2307	* 1.2107	* 1.4477	* 1.3085	* 1.1543	* 1.3693	* 0.7956 *
	* 1.3817	* 1.5860	* 1.6094	* 1.3424	* 1.4856	* 1.6717	* 1.3780	* 2.3504 *
9	* 1.2307	* 1.3106	* 1.4141	* 1.2798	* 1.4716	* 1.2410	* 1.3442	* 0.7298 *
	* 1.5860	* 1.4818	* 1.3697	* 1.5175	* 1.3191	* 1.5598	* 1.4125	* 2.5717 *
10	* 1.2107	* 1.4140	* 1.2232	* 1.4312	* 1.2870	* 1.3993	* 0.9829	*
	* 1.6094	* 1.3698	* 1.5808	* 1.3560	* 1.5118	* 1.3849	* 1.9571	*
11	* 1.4477	* 1.2786	* 1.4292	* 1.1986	* 1.3607	* 1.3641	* 0.7584	*
	* 1.3424	* 1.5190	* 1.3579	* 1.6216	* 1.4308	* 1.4255	* 2.5594	*
12	* 1.3085	* 1.4642	* 1.2841	* 1.3594	* 1.3312	* 0.8590	*	
	* 1.4856	* 1.3259	* 1.5152	* 1.4322	* 1.4650	* 2.2377	*	
13	* 1.1543	* 1.2352	* 1.3955	* 1.3621	* 0.8580	*		
	* 1.6717	* 1.5672	* 1.3886	* 1.4276	* 2.2404	*		
14	* 1.3693	* 1.3412	* 0.9796	* 0.7555	*			
	* 1.3780	* 1.4156	* 1.9635	* 2.5692	*			
15	* 0.7956	* 0.7208	* F-SUB-Q					
	* 2.3504	* 2.6035	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 40 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4864	* 1.2798	* 1.2693	* 1.5398	* 1.3704	* 1.1963	* 1.4342	* 0.8319 *
	* 1.3397	* 1.5568	* 1.5671	* 1.2870	* 1.4465	* 1.6500	* 1.3505	* 2.3135 *
9	* 1.2798	* 1.3780	* 1.5105	* 1.3456	* 1.5655	* 1.2960	* 1.4069	* 0.7660 *
	* 1.5568	* 1.4406	* 1.3106	* 1.4738	* 1.2644	* 1.5237	* 1.3836	* 2.5195 *
10	* 1.2693	* 1.5103	* 1.2860	* 1.5266	* 1.3518	* 1.4847	* 1.0326	*
	* 1.5671	* 1.3108	* 1.5383	* 1.2964	* 1.4659	* 1.3293	* 1.9040	*
11	* 1.5398	* 1.3442	* 1.5242	* 1.2628	* 1.4555	* 1.4479	* 0.8002	*
	* 1.2870	* 1.4756	* 1.2984	* 1.5696	* 1.3543	* 1.3447	* 2.4552	*
12	* 1.3704	* 1.5568	* 1.3483	* 1.4540	* 1.4222	* 0.9143	*	
	* 1.4465	* 1.2716	* 1.4697	* 1.3557	* 1.3742	* 2.1047	*	
13	* 1.1963	* 1.2895	* 1.4802	* 1.4459	* 0.9135	*		
	* 1.6500	* 1.5316	* 1.3332	* 1.3467	* 2.1068	*		
14	* 1.4342	* 1.4037	* 1.0293	* 0.7975	*			
	* 1.3505	* 1.3867	* 1.9101	* 2.4636	*			
15	* 0.8319	* 0.7570	* F-SUB-Q					
	* 2.3135	* 2.5494	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5309	* 1.3107	* 1.3071	* 1.6003	* 1.4091	* 1.2188	* 1.4640	* 0.8481 *
	* 1.3092	* 1.5344	* 1.5368	* 1.2478	* 1.4182	* 1.6427	* 1.3576	* 2.3357 *
9	* 1.3107	* 1.4214	* 1.5738	* 1.3888	* 1.6261	* 1.3284	* 1.4363	* 0.7840 *
	* 1.5344	* 1.4148	* 1.2747	* 1.4456	* 1.2269	* 1.5027	* 1.3846	* 2.5301 *
10	* 1.3071	* 1.5735	* 1.3272	* 1.5902	* 1.3944	* 1.5375	* 1.0604	*
	* 1.5368	* 1.2749	* 1.5128	* 1.2565	* 1.4285	* 1.2899	* 1.8792	*
11	* 1.6003	* 1.3872	* 1.5874	* 1.3062	* 1.5196	* 1.5003	* 0.8268	*
	* 1.2478	* 1.4475	* 1.2588	* 1.5312	* 1.2970	* 1.2979	* 2.3700	*
12	* 1.4091	* 1.6165	* 1.3907	* 1.5180	* 1.4846	* 0.9569	*	
	* 1.4182	* 1.2338	* 1.4325	* 1.2985	* 1.3155	* 2.0182	*	
13	* 1.2188	* 1.3213	* 1.5327	* 1.4982	* 0.9559	*		
	* 1.6427	* 1.5109	* 1.2940	* 1.2998	* 2.0203	*		
14	* 1.4640	* 1.4330	* 1.0569	* 0.8241	*			
	* 1.3576	* 1.3879	* 1.8854	* 2.3781	*			
15	* 0.8481	* 0.7742	* F-SUB-Q					
	* 2.3357	* 2.5622	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 41 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5899	* 1.3457	* 1.3474	* 1.6716	* 1.4516	* 1.2437	* 1.5027	* 0.8576 *
	* 1.2658	* 1.5028	* 1.4993	* 1.1993	* 1.3818	* 1.6200	* 1.3403	* 2.3467 *
9	* 1.3457	* 1.4687	* 1.6499	* 1.4338	* 1.7003	* 1.3649	* 1.4747	* 0.7885 *
	* 1.5028	* 1.3776	* 1.2235	* 1.4077	* 1.1775	* 1.4681	* 1.3630	* 2.5532 *
10	* 1.3474	* 1.6496	* 1.3705	* 1.6659	* 1.4402	* 1.6020	* 1.0759	*
	* 1.4993	* 1.2238	* 1.4753	* 1.2052	* 1.3868	* 1.2395	* 1.8619	*
11	* 1.6716	* 1.4321	* 1.6629	* 1.3515	* 1.5956	* 1.5627	* 0.8386	*
	* 1.1993	* 1.4097	* 1.2076	* 1.4870	* 1.2373	* 1.2527	* 2.3419	*
12	* 1.4516	* 1.6908	* 1.4361	* 1.5937	* 1.5535	* 0.9778	*	
	* 1.3818	* 1.1830	* 1.3909	* 1.2387	* 1.2635	* 1.9919	*	
13	* 1.2437	* 1.3572	* 1.5968	* 1.5605	* 0.9772	*		
	* 1.6200	* 1.4766	* 1.2437	* 1.2545	* 1.9930	*		
14	* 1.5027	* 1.4712	* 1.0723	* 0.8359	*			
	* 1.3403	* 1.3663	* 1.8682	* 2.3495	*			
15	* 0.8576	* 0.7798	* F-SUB-Q					
	* 2.3467	* 2.5815	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6166	* 1.3617	* 1.3685	* 1.7069	* 1.4724	* 1.2523	* 1.5120	* 0.8595 *
	* 1.2577	* 1.4969	* 1.4870	* 1.1849	* 1.3736	* 1.6184	* 1.3433	* 2.3567 *
9	* 1.3617	* 1.4941	* 1.6902	* 1.4580	* 1.7381	* 1.3809	* 1.4852	* 0.7914 *
	* 1.4969	* 1.3645	* 1.2032	* 1.3934	* 1.1606	* 1.4585	* 1.3651	* 2.5595 *
10	* 1.3685	* 1.6899	* 1.3940	* 1.7049	* 1.4644	* 1.6330	* 1.0854	*
	* 1.4870	* 1.2035	* 1.4621	* 1.1842	* 1.3755	* 1.2260	* 1.8536	*
11	* 1.7069	* 1.4562	* 1.7019	* 1.3767	* 1.6381	* 1.5945	* 0.8494	*
	* 1.1849	* 1.3955	* 1.1864	* 1.4666	* 1.2191	* 1.2437	* 2.3365	*
12	* 1.4724	* 1.7297	* 1.4601	* 1.6362	* 1.5938	* 0.9998	*	
	* 1.3736	* 1.1656	* 1.3797	* 1.2206	* 1.2484	* 1.9784	*	
13	* 1.2523	* 1.3728	* 1.6275	* 1.5923	* 0.9995	*		
	* 1.6184	* 1.4672	* 1.2302	* 1.2454	* 1.9791	*		
14	* 1.5119	* 1.4816	* 1.0817	* 0.8466	*			
	* 1.3433	* 1.3685	* 1.8599	* 2.3441	*			
15	* 0.8595	* 0.7825	* F-SUB-Q					
	* 2.3567	* 2.5883	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 42 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6667	* 1.3881	* 1.3971	* 1.7630	* 1.5031	* 1.2685	* 1.5401	* 0.8617 *
	* 1.2452	* 1.4977	* 1.4855	* 1.1701	* 1.3715	* 1.6217	* 1.3283	* 2.3658 *
9	* 1.3881	* 1.5294	* 1.7510	* 1.4896	* 1.7978	* 1.4066	* 1.5145	* 0.7873 *
	* 1.4977	* 1.3575	* 1.1823	* 1.3893	* 1.1430	* 1.4563	* 1.3488	* 2.5886 *
10	* 1.3971	* 1.7506	* 1.4245	* 1.7637	* 1.4966	* 1.6851	* 1.0895	*
	* 1.4855	* 1.1826	* 1.4552	* 1.1669	* 1.3729	* 1.2103	* 1.8725	*
11	* 1.7630	* 1.4876	* 1.7604	* 1.4084	* 1.6992	* 1.6435	* 0.8514	*
	* 1.1701	* 1.3915	* 1.1691	* 1.4617	* 1.2009	* 1.2328	* 2.3770	*
12	* 1.5031	* 1.7902	* 1.4920	* 1.6974	* 1.6465	* 1.0106	*	
	* 1.3715	* 1.1480	* 1.3772	* 1.2022	* 1.2330	* 2.0033	*	
13	* 1.2685	* 1.3980	* 1.6793	* 1.6414	* 1.0104	*		
	* 1.6217	* 1.4653	* 1.2145	* 1.2344	* 2.0035	*		
14	* 1.5401	* 1.5108	* 1.0854	* 0.8481	*			
	* 1.3283	* 1.3521	* 1.8793	* 2.3860	*			
15	* 0.8617	* 0.7783	* F-SUB-Q					
	* 2.3657	* 2.6181	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6275	* 1.3853	* 1.3820	* 1.7274	* 1.4830	* 1.2622	* 1.4977	* 0.8538 *
	* 1.3140	* 1.5490	* 1.5488	* 1.2303	* 1.4310	* 1.6766	* 1.3949	* 2.4321 *
9	* 1.3853	* 1.5267	* 1.7152	* 1.4741	* 1.7618	* 1.3846	* 1.4735	* 0.7942 *
	* 1.5490	* 1.4026	* 1.2433	* 1.4465	* 1.2009	* 1.5205	* 1.4170	* 2.6149 *
10	* 1.3820	* 1.7149	* 1.4086	* 1.7300	* 1.4804	* 1.6481	* 1.0949	*
	* 1.5488	* 1.2436	* 1.5160	* 1.2257	* 1.4301	* 1.2727	* 1.9108	*
11	* 1.7274	* 1.4721	* 1.7268	* 1.3944	* 1.6675	* 1.6133	* 0.8672 *	
	* 1.2303	* 1.4488	* 1.2280	* 1.5220	* 1.2618	* 1.2939	* 2.4009	*
12	* 1.4830	* 1.7540	* 1.4757	* 1.6657	* 1.6265	* 1.0358	*	
	* 1.4310	* 1.2064	* 1.4346	* 1.2631	* 1.2907	* 2.0161	*	
13	* 1.2622	* 1.3761	* 1.6423	* 1.6112	* 1.0352	*		
	* 1.6766	* 1.5299	* 1.2772	* 1.2955	* 2.0172	*		
14	* 1.4977	* 1.4698	* 1.0910	* 0.8643	*			
	* 1.3949	* 1.4205	* 1.9174	* 2.4087	*			
15	* 0.8538	* 0.7846	* F-SUB-Q					
	* 2.4321	* 2.6463	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 43 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6968	* 1.4022	* 1.4154	* 1.8021	* 1.5220	* 1.2705	* 1.5425	* 0.8562 *
	* 1.3098	* 1.5880	* 1.5713	* 1.2256	* 1.4477	* 1.7227	* 1.3983	* 2.4989 *
9	* 1.4022	* 1.5560	* 1.7941	* 1.5120	* 1.8423	* 1.4189	* 1.5192	* 0.7853 *
	* 1.5880	* 1.4295	* 1.2360	* 1.4662	* 1.1928	* 1.5381	* 1.4196	* 2.7258 *
10	* 1.4154	* 1.7937	* 1.4450	* 1.8069	* 1.5195	* 1.7192	* 1.0948	*
	* 1.5713	* 1.2363	* 1.5367	* 1.2199	* 1.4476	* 1.2654	* 1.9776	*
11	* 1.8021	* 1.5099	* 1.8035	* 1.4316	* 1.7454	* 1.6792	* 0.8605	*
	* 1.2256	* 1.4684	* 1.2222	* 1.5415	* 1.2530	* 1.2907	* 2.5080	*
12	* 1.5220	* 1.8344	* 1.5145	* 1.7437	* 1.6968	* 1.0347	*	
	* 1.4477	* 1.1980	* 1.4522	* 1.2543	* 1.2804	* 2.0970	*	
13	* 1.2705	* 1.4098	* 1.7132	* 1.6772	* 1.0347	*		
	* 1.7227	* 1.5479	* 1.2697	* 1.2921	* 2.0968	*		
14	* 1.5425	* 1.5154	* 1.0909	* 0.8579	*			
	* 1.3983	* 1.4231	* 1.9843	* 2.5154	*			
15	* 0.8562	* 0.7767	* F-SUB-Q					
	* 2.4989	* 2.7554	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7076	* 1.4076	* 1.4232	* 1.8187	* 1.5295	* 1.2711	* 1.5427	* 0.8543 *
	* 1.3037	* 1.5805	* 1.5636	* 1.2257	* 1.4569	* 1.7527	* 1.4522	* 2.6006 *
9	* 1.4076	* 1.5717	* 1.8124	* 1.5216	* 1.8601	* 1.4234	* 1.5202	* 0.7869 *
	* 1.5805	* 1.4189	* 1.2309	* 1.4646	* 1.1991	* 1.5653	* 1.4707	* 2.8249 *
10	* 1.4232	* 1.8120	* 1.4539	* 1.8254	* 1.5290	* 1.7331	* 1.0980	*
	* 1.5636	* 1.2312	* 1.5351	* 1.2212	* 1.4562	* 1.2856	* 2.0274	*
11	* 1.8187	* 1.5194	* 1.8219	* 1.4420	* 1.7659	* 1.6944	* 0.8660	*
	* 1.2257	* 1.4666	* 1.2235	* 1.5429	* 1.2595	* 1.3126	* 2.5594	*
12	* 1.5295	* 1.8519	* 1.5240	* 1.7642	* 1.7199	* 1.0471	*	
	* 1.4569	* 1.2042	* 1.4609	* 1.2607	* 1.2915	* 2.1157	*	
13	* 1.2711	* 1.4141	* 1.7270	* 1.6925	* 1.0472	*		
	* 1.7527	* 1.5754	* 1.2900	* 1.3140	* 2.1153	*		
14	* 1.5427	* 1.5164	* 1.0941	* 0.8634	*			
	* 1.4522	* 1.4743	* 2.0344	* 2.5670	*			
15	* 0.8543	* 0.7787	* F-SUB-Q					
	* 2.6006	* 2.8540	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 44 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6778	* 1.4131	* 1.4124	* 1.7936	* 1.5145	* 1.2745	* 1.5139	* 0.8480 *
	* 1.3154	* 1.5611	* 1.5620	* 1.2310	* 1.4574	* 1.7313	* 1.4629	* 2.6024 *
9	* 1.4131	* 1.5731	* 1.7876	* 1.5095	* 1.8363	* 1.4075	* 1.4925	* 0.7904 *
	* 1.5611	* 1.4043	* 1.2360	* 1.4623	* 1.2029	* 1.5677	* 1.4816	* 2.7899 *
10	* 1.4124	* 1.7872	* 1.4419	* 1.8023	* 1.5173	* 1.7085	* 1.1005	*
	* 1.5620	* 1.2363	* 1.5327	* 1.2250	* 1.4536	* 1.2915	* 2.0027	*
11	* 1.7936	* 1.5073	* 1.7987	* 1.4321	* 1.7456	* 1.6756	* 0.8764	*
	* 1.2310	* 1.4645	* 1.2273	* 1.5390	* 1.2624	* 1.3149	* 2.5060	*
12	* 1.5145	* 1.8275	* 1.5123	* 1.7439	* 1.7023	* 1.0662	*	
	* 1.4574	* 1.2085	* 1.4583	* 1.2635	* 1.2930	* 2.0597	*	
13	* 1.2745	* 1.3982	* 1.7024	* 1.6739	* 1.0659	*		
	* 1.7313	* 1.5779	* 1.2960	* 1.3163	* 2.0603	*		
14	* 1.5139	* 1.4887	* 1.0965	* 0.8735	*			
	* 1.4629	* 1.4853	* 2.0097	* 2.5140	*			
15	* 0.8480	* 0.7807	* F-SUB-Q					
	* 2.6024	* 2.8245	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7351	* 1.4165	* 1.4385	* 1.8580	* 1.5461	* 1.2715	* 1.5542	* 0.8488 *
	* 1.2700	* 1.5545	* 1.5301	* 1.1857	* 1.4242	* 1.7301	* 1.4179	* 2.5875 *
9	* 1.4165	* 1.5941	* 1.8557	* 1.5400	* 1.9050	* 1.4360	* 1.5338	* 0.7796 *
	* 1.5545	* 1.3823	* 1.1875	* 1.4299	* 1.1566	* 1.5324	* 1.4358	* 2.8163 *
10	* 1.4385	* 1.8553	* 1.4715	* 1.8696	* 1.5492	* 1.7719	* 1.0961	*
	* 1.5301	* 1.1877	* 1.4965	* 1.1780	* 1.4204	* 1.2419	* 2.0048	*
11	* 1.8580	* 1.5377	* 1.8662	* 1.4630	* 1.8154	* 1.7370	* 0.8669	*
	* 1.1857	* 1.4320	* 1.1801	* 1.5029	* 1.2110	* 1.2654	* 2.5275	*
12	* 1.5461	* 1.8965	* 1.5440	* 1.8140	* 1.7789	* 1.0622	*	
	* 1.4242	* 1.1617	* 1.4251	* 1.2119	* 1.2347	* 2.0636	*	
13	* 1.2715	* 1.4262	* 1.7660	* 1.7354	* 1.0624	*		
	* 1.7301	* 1.5428	* 1.2460	* 1.2666	* 2.0633	*		
14	* 1.5542	* 1.5299	* 1.0919	* 0.8644	*			
	* 1.4179	* 1.4394	* 2.0122	* 2.5348	*			
15	* 0.8488	* 0.7708	* F-SUB-Q					
	* 2.5875	* 2.8480	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 45 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7540	* 1.4230	* 1.4492	* 1.8845	* 1.5579	* 1.2743	* 1.5669	* 0.8480 *
	* 1.2500	* 1.5388	* 1.5110	* 1.1642	* 1.4066	* 1.7150	* 1.3961	* 2.5644 *
9	* 1.4230	* 1.6074	* 1.8844	* 1.5523	* 1.9344	* 1.4461	* 1.5472	* 0.7772 *
	* 1.5388	* 1.3642	* 1.1643	* 1.4118	* 1.1344	* 1.5130	* 1.4133	* 2.7969 *
10	* 1.4492	* 1.8840	* 1.4836	* 1.8984	* 1.5624	* 1.7977	* 1.0959	*
	* 1.5110	* 1.1645	* 1.4763	* 1.1554	* 1.4018	* 1.2178	* 1.9906	*
11	* 1.8845	* 1.5499	* 1.8949	* 1.4767	* 1.8475	* 1.7652	* 0.8666	*
	* 1.1642	* 1.4139	* 1.1574	* 1.4815	* 1.1849	* 1.2394	* 2.5094	*
12	* 1.5579	* 1.9256	* 1.5571	* 1.8461	* 1.8160	* 1.0678	*	
	* 1.4066	* 1.1394	* 1.4064	* 1.1857	* 1.2041	* 2.0403	*	
13	* 1.2743	* 1.4360	* 1.7933	* 1.7636	* 1.0682	*		
	* 1.7150	* 1.5234	* 1.2204	* 1.2404	* 2.0395	*		
14	* 1.5669	* 1.5433	* 1.0918	* 0.8634	*			
	* 1.3961	* 1.4168	* 1.9979	* 2.5186	*			
15	* 0.8480	* 0.7667	* F-SUB-Q					
	* 2.5644	* 2.8352	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7504	* 1.4242	* 1.4480	* 1.8866	* 1.5579	* 1.2735	* 1.5653	* 0.8468 *
	* 1.2508	* 1.5360	* 1.5100	* 1.1606	* 1.4037	* 1.7134	* 1.3916	* 2.5560 *
9	* 1.4242	* 1.6139	* 1.8858	* 1.5526	* 1.9379	* 1.4449	* 1.5459	* 0.7789 *
	* 1.5360	* 1.3565	* 1.1612	* 1.4090	* 1.1298	* 1.5103	* 1.4088	* 2.7785 *
10	* 1.4480	* 1.8854	* 1.4827	* 1.9017	* 1.5638	* 1.8012	* 1.0989	*
	* 1.5100	* 1.1615	* 1.4746	* 1.1510	* 1.3977	* 1.2121	* 1.9788	*
11	* 1.8866	* 1.5502	* 1.8981	* 1.4777	* 1.8521	* 1.7703	* 0.8713	*
	* 1.1606	* 1.4112	* 1.1531	* 1.4778	* 1.1795	* 1.2327	* 2.4893	*
12	* 1.5579	* 1.9289	* 1.5584	* 1.8507	* 1.8221	* 1.0772	*	
	* 1.4037	* 1.1349	* 1.4024	* 1.1803	* 1.1975	* 2.0184	*	
13	* 1.2735	* 1.4346	* 1.7971	* 1.7688	* 1.0775	*		
	* 1.7134	* 1.5209	* 1.2147	* 1.2337	* 2.0178	*		
14	* 1.5653	* 1.5419	* 1.0947	* 0.8688	*			
	* 1.3916	* 1.4123	* 1.9862	* 2.4963	*			
15	* 0.8468	* 0.7701	* F-SUB-Q					
	* 2.5560	* 2.8099	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 46 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7077	* 1.4297	* 1.4345	* 1.8511	* 1.5387	* 1.2819	* 1.5375	* 0.8446 *
	* 1.2861	* 1.5353	* 1.5302	* 1.1863	* 1.4250	* 1.7059	* 1.4174	* 2.5625 *
9	* 1.4297	* 1.6111	* 1.8475	* 1.5352	* 1.9020	* 1.4308	* 1.5180	* 0.7891 *
	* 1.5353	* 1.3634	* 1.1891	* 1.4296	* 1.1540	* 1.5295	* 1.4355	* 2.7422 *
10	* 1.4345	* 1.8470	* 1.4650	* 1.8668	* 1.5473	* 1.7678	* 1.1056	*
	* 1.5302	* 1.1894	* 1.4974	* 1.1758	* 1.4165	* 1.2373	* 1.9694	*
11	* 1.8511	* 1.5326	* 1.8628	* 1.4621	* 1.8187	* 1.7425	* 0.8838	*
	* 1.1863	* 1.4319	* 1.1782	* 1.4983	* 1.2044	* 1.2548	* 2.4582	*
12	* 1.5387	* 1.8925	* 1.5418	* 1.8173	* 1.7877	* 1.0948	*	
	* 1.4250	* 1.1596	* 1.4214	* 1.2052	* 1.2234	* 1.9906	*	
13	* 1.2819	* 1.4222	* 1.7636	* 1.7410	* 1.0948	*		
	* 1.7059	* 1.5385	* 1.2401	* 1.2558	* 1.9905	*		
14	* 1.5375	* 1.5139	* 1.1014	* 0.8810	*			
	* 1.4174	* 1.4392	* 1.9765	* 2.4656	*			
15	* 0.8446	* 0.7788	* F-SUB-Q					
	* 2.5625	* 2.7782	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7630	* 1.4238	* 1.4536	* 1.9159	* 1.5685	* 1.2727	* 1.5881	* 0.8467 *
	* 1.2375	* 1.5310	* 1.4991	* 1.1387	* 1.3897	* 1.7084	* 1.3682	* 2.5529 *
9	* 1.4238	* 1.6242	* 1.9141	* 1.5608	* 1.9711	* 1.4548	* 1.5686	* 0.7771 *
	* 1.5310	* 1.3425	* 1.1397	* 1.3966	* 1.1068	* 1.4959	* 1.3850	* 2.7809 *
10	* 1.4536	* 1.9136	* 1.4897	* 1.9334	* 1.5754	* 1.8362	* 1.0973	*
	* 1.4991	* 1.1400	* 1.4625	* 1.1279	* 1.3829	* 1.1855	* 1.9773	*
11	* 1.9159	* 1.5581	* 1.9294	* 1.4877	* 1.8871	* 1.8061	* 0.8678	*
	* 1.1387	* 1.3990	* 1.1303	* 1.4631	* 1.1539	* 1.2049	* 2.4950	*
12	* 1.5685	* 1.9609	* 1.5694	* 1.8856	* 1.8616	* 1.0794	*	
	* 1.3897	* 1.1124	* 1.3881	* 1.1548	* 1.1686	* 2.0094	*	
13	* 1.2727	* 1.4437	* 1.8317	* 1.8044	* 1.0799	*		
	* 1.7084	* 1.5072	* 1.1883	* 1.2059	* 2.0085	*		
14	* 1.5881	* 1.5643	* 1.0928	* 0.8646	*			
	* 1.3682	* 1.3887	* 1.9851	* 2.5041	*			
15	* 0.8467	* 0.7662	* F-SUB-Q					
	* 2.5529	* 2.8203	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 47 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7421	* 1.4078	* 1.4384	* 1.9016	* 1.5562	* 1.2611	* 1.5853	* 0.8420 *
	* 1.2390	* 1.5321	* 1.4989	* 1.1347	* 1.3852	* 1.7047	* 1.3538	* 2.5354 *
9	* 1.4078	* 1.6095	* 1.8968	* 1.5459	* 1.9584	* 1.4449	* 1.5652	* 0.7734 *
	* 1.5321	* 1.3404	* 1.1376	* 1.3949	* 1.1015	* 1.4890	* 1.3711	* 2.7600 *
10	* 1.4384	* 1.8961	* 1.4744	* 1.9195	* 1.5631	* 1.8269	* 1.0893	*
	* 1.4989	* 1.1381	* 1.4620	* 1.1236	* 1.3784	* 1.1778	* 1.9684	*
11	* 1.9016	* 1.5430	* 1.9148	* 1.4739	* 1.8743	* 1.8000	* 0.8596	*
	* 1.1346	* 1.3975	* 1.1262	* 1.4610	* 1.1489	* 1.1951	* 2.4900	*
12	* 1.5562	* 1.9474	* 1.5569	* 1.8725	* 1.8493	* 1.0712	*	
	* 1.3852	* 1.1075	* 1.3839	* 1.1499	* 1.1631	* 2.0022	*	
13	* 1.2611	* 1.4334	* 1.8222	* 1.7982	* 1.0717	*		
	* 1.7047	* 1.5006	* 1.1808	* 1.1962	* 2.0013	*		
14	* 1.5853	* 1.5606	* 1.0846	* 0.8564	*			
	* 1.3538	* 1.3751	* 1.9766	* 2.4992	*			
15	* 0.8420	* 0.7616	* F-SUB-Q					
	* 2.5354	* 2.8025	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6870	* 1.3784	* 1.4019	* 1.8455	* 1.5215	* 1.2376	* 1.5589	* 0.8298 *
	* 1.2691	* 1.5525	* 1.5260	* 1.1595	* 1.4051	* 1.7222	* 1.3635	* 2.5480 *
9	* 1.3784	* 1.5692	* 1.8321	* 1.5074	* 1.8986	* 1.4154	* 1.5373	* 0.7767 *
	* 1.5525	* 1.3641	* 1.1683	* 1.4192	* 1.1265	* 1.5068	* 1.3826	* 2.7218 *
10	* 1.4019	* 1.8312	* 1.4363	* 1.8617	* 1.5273	* 1.7732	* 1.0711	*
	* 1.5260	* 1.1688	* 1.4890	* 1.1488	* 1.3991	* 1.2026	* 1.9835	*
11	* 1.8455	* 1.5044	* 1.8568	* 1.4364	* 1.8154	* 1.7536	* 0.8416	*
	* 1.1595	* 1.4221	* 1.1518	* 1.4872	* 1.1760	* 1.2155	* 2.5204	*
12	* 1.5215	* 1.8864	* 1.5208	* 1.8132	* 1.7830	* 1.0567	*	
	* 1.4051	* 1.1336	* 1.4050	* 1.1774	* 1.1957	* 2.0119	*	
13	* 1.2376	* 1.4037	* 1.7681	* 1.7515	* 1.0571	*		
	* 1.7222	* 1.5189	* 1.2060	* 1.2169	* 2.0109	*		
14	* 1.5589	* 1.5323	* 1.0664	* 0.8384	*			
	* 1.3635	* 1.3869	* 1.9921	* 2.5299	*			
15	* 0.8298	* 0.7515	* F-SUB-Q					
	* 2.5480	* 2.8128	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 48 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5796	* 1.3239	* 1.3321	* 1.7252	* 1.4504	* 1.1904	* 1.4861	* 0.7986 *
	* 1.3465	* 1.6064	* 1.5962	* 1.2320	* 1.4641	* 1.7785	* 1.4188	* 2.6263 *
9	* 1.3239	* 1.4934	* 1.6980	* 1.4335	* 1.7680	* 1.3528	* 1.4638	* 0.7447 *
	* 1.6064	* 1.4243	* 1.2524	* 1.4831	* 1.2012	* 1.5651	* 1.4404	* 2.8154 *
10	* 1.3321	* 1.6971	* 1.3633	* 1.7371	* 1.4538	* 1.6563	* 1.0310	*
	* 1.5962	* 1.2531	* 1.5592	* 1.2229	* 1.4601	* 1.2783	* 2.0450	*
11	* 1.7252	* 1.4302	* 1.7318	* 1.3621	* 1.6849	* 1.6465	* 0.8055	*
	* 1.2320	* 1.4864	* 1.2266	* 1.5584	* 1.2582	* 1.2846	* 2.6136	*
12	* 1.4504	* 1.7560	* 1.4475	* 1.6825	* 1.6756	* 1.0017	*	
	* 1.4641	* 1.2092	* 1.4664	* 1.2600	* 1.2641	* 2.1064	*	
13	* 1.1904	* 1.3415	* 1.6483	* 1.6443	* 1.0019	*		
	* 1.7785	* 1.5779	* 1.2843	* 1.2863	* 2.1059	*		
14	* 1.4861	* 1.4588	* 1.0262	* 0.8022	*			
	* 1.4189	* 1.4451	* 2.0543	* 2.6241	*			
15	* 0.7986	* 0.7253	* F-SUB-Q					
	* 2.6263	* 2.8909	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4347	* 1.2199	* 1.2200	* 1.5442	* 1.3349	* 1.1016	* 1.3557	* 0.7298 *
	* 1.4736	* 1.7335	* 1.7331	* 1.3681	* 1.5811	* 1.9094	* 1.5441	* 2.8534 *
9	* 1.2199	* 1.3615	* 1.5143	* 1.3148	* 1.5831	* 1.2477	* 1.3327	* 0.6838 *
	* 1.7335	* 1.5533	* 1.3961	* 1.6076	* 1.3330	* 1.6860	* 1.5706	* 3.0448 *
10	* 1.2200	* 1.5140	* 1.2458	* 1.5508	* 1.3342	* 1.4850	* 0.9478	*
	* 1.7331	* 1.3964	* 1.6967	* 1.3616	* 1.5813	* 1.4160	* 2.2094	*
11	* 1.5442	* 1.3119	* 1.5461	* 1.2424	* 1.4950	* 1.4791	* 0.7400	*
	* 1.3681	* 1.6111	* 1.3657	* 1.6986	* 1.4090	* 1.4199	* 2.8257	*
12	* 1.3349	* 1.5727	* 1.3285	* 1.4927	* 1.4987	* 0.9108	*	
	* 1.5811	* 1.3416	* 1.5879	* 1.4111	* 1.4039	* 2.3012	*	
13	* 1.1016	* 1.2376	* 1.4781	* 1.4768	* 0.9106	*		
	* 1.9094	* 1.6995	* 1.4226	* 1.4220	* 2.3014	*		
14	* 1.3557	* 1.3281	* 0.9433	* 0.7367	*			
	* 1.5441	* 1.5759	* 2.2195	* 2.8381	*			
15	* 0.7298	* 0.6672	* F-SUB-Q					
	* 2.8534	* 3.1208	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 49 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 275 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2029	* 1.0149	* 0.9995	* 1.2455	* 1.1033	* 0.9072	* 1.0730	* 0.5838 *
	* 1.7476	* 2.0719	* 2.1036	* 1.6864	* 1.9016	* 2.3048	* 1.9377	* 3.5454 *
9	* 1.0149	* 1.1204	* 1.2335	* 1.0801	* 1.2925	* 1.0280	* 1.0590	* 0.5522 *
	* 2.0719	* 1.8772	* 1.7045	* 1.9457	* 1.6230	* 2.0334	* 1.9634	* 3.7479 *
10	* 0.9995	* 1.2331	* 1.0184	* 1.2496	* 1.0925	* 1.2025	* 0.7695	*
	* 2.1036	* 1.7050	* 2.0640	* 1.6801	* 1.9195	* 1.7376	* 2.7038	*
11	* 1.2455	* 1.0780	* 1.2467	* 1.0127	* 1.2042	* 1.1691	* 0.6085	*
	* 1.6864	* 1.9493	* 1.6839	* 2.0720	* 1.7387	* 1.7846	* 3.4157	*
12	* 1.1033	* 1.2859	* 1.0883	* 1.2028	* 1.1799	* 0.7428	*	
	* 1.9016	* 1.6311	* 1.9267	* 1.7406	* 1.7720	* 2.8044	*	
13	* 0.9072	* 1.0204	* 1.1979	* 1.1673	* 0.7424	*		
	* 2.3048	* 2.0482	* 1.7441	* 1.7873	* 2.8058	*		
14	* 1.0730	* 1.0553	* 0.7661	* 0.6056	*			
	* 1.9377	* 1.9701	* 2.7154	* 3.4313	*			
15	* 0.5838	* 0.5426	* F-SUB-Q					
	* 3.5454	* 3.8144	* M-SUB-Q					

AT 100% POWER, 275 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5353	* 0.4803	* 0.4933	* 0.5717	* 0.5183	* 0.4452	* 0.4472	* 0.2723 *
	* 3.9070	* 4.3543	* 4.2388	* 3.6556	* 4.0261	* 4.6704	* 4.6257	* 7.5683 *
9	* 0.4803	* 0.5198	* 0.5655	* 0.5137	* 0.5657	* 0.4806	* 0.4397	* 0.2553 *
	* 4.3543	* 4.0243	* 3.6985	* 4.0686	* 3.6881	* 4.3265	* 4.7052	* 8.0719 *
10	* 0.4933	* 0.5657	* 0.5023	* 0.5720	* 0.5133	* 0.5177	* 0.3645	*
	* 4.2388	* 3.6978	* 4.1616	* 3.6506	* 4.0624	* 4.0142	* 5.6799	*
11	* 0.5717	* 0.5128	* 0.5713	* 0.4974	* 0.5452	* 0.4883	* 0.2840	*
	* 3.6556	* 4.0750	* 3.6550	* 4.1954	* 3.8194	* 4.2517	* 7.2853	*
12	* 0.5183	* 0.5630	* 0.5116	* 0.5445	* 0.5017	* 0.3539	*	
	* 4.0261	* 3.7052	* 4.0760	* 3.8237	* 4.1413	* 5.8579	*	
13	* 0.4452	* 0.4775	* 0.5157	* 0.4874	* 0.3535	*		
	* 4.6704	* 4.3536	* 4.0296	* 4.2590	* 5.8637	*		
14	* 0.4472	* 0.4381	* 0.3630	* 0.2826	*			
	* 4.6257	* 4.7218	* 5.7032	* 7.3195	*			
15	* 0.2723	* 0.2542	* F-SUB-Q					
	* 7.5683	* 8.1064	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 50 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6870	* 0.6495	* 0.6454	* 0.7112	* 0.6629	* 0.5915	* 0.5289	* 0.3494 *
	* 3.0680	* 3.2389	* 3.2464	* 2.9542	* 3.1691	* 3.4928	* 3.4664	* 5.2399 *
9	* 0.6495	* 0.6584	* 0.7024	* 0.6574	* 0.7001	* 0.6169	* 0.5561	* 0.3442 *
	* 3.2389	* 3.1328	* 2.9355	* 3.1658	* 2.9988	* 3.3859	* 3.5740	* 5.5729 *
10	* 0.6454	* 0.7023	* 0.5960	* 0.7022	* 0.6501	* 0.6438	* 0.4822	*
	* 3.2464	* 2.9349	* 3.1623	* 2.9417	* 3.2297	* 3.2619	* 4.2890	*
11	* 0.7112	* 0.6562	* 0.7015	* 0.6298	* 0.6702	* 0.6025	* 0.3884	*
	* 2.9542	* 3.1670	* 2.9422	* 3.2860	* 3.1487	* 3.5126	* 5.4225	*
12	* 0.6629	* 0.6978	* 0.6492	* 0.6698	* 0.6131	* 0.4559	*	
	* 3.1691	* 3.0082	* 3.2343	* 3.1502	* 3.4597	* 4.6148	*	
13	* 0.5915	* 0.6150	* 0.6425	* 0.6017	* 0.4541	*		
	* 3.4928	* 3.3957	* 3.2683	* 3.5171	* 4.6329	*		
14	* 0.5289	* 0.5550	* 0.4811	* 0.3871	*			
	* 3.4664	* 3.5804	* 4.2984	* 5.4395	*			
15	* 0.3494	* 0.3418	* F-SUB-Q					
	* 5.2399	* 5.6102	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2924	* 1.1465	* 1.1201	* 1.2983	* 1.1966	* 1.0428	* 1.1379	* 0.6865 *
	* 1.6385	* 1.8429	* 1.8844	* 1.6273	* 1.7650	* 2.0022	* 1.7625	* 2.8786 *
9	* 1.1465	* 1.2031	* 1.2845	* 1.1764	* 1.3317	* 1.1248	* 1.1291	* 0.6430 *
	* 1.8429	* 1.7409	* 1.6242	* 1.7826	* 1.5849	* 1.8690	* 1.8053	* 3.1013 *
10	* 1.1201	* 1.2844	* 1.1210	* 1.2896	* 1.1763	* 1.2461	* 0.8732	*
	* 1.8844	* 1.6241	* 1.8419	* 1.6242	* 1.7971	* 1.6932	* 2.3874	*
11	* 1.2983	* 1.1758	* 1.2884	* 1.1077	* 1.2394	* 1.1923	* 0.7050	*
	* 1.6273	* 1.7834	* 1.6246	* 1.8973	* 1.7116	* 1.7809	* 2.9999	*
12	* 1.1966	* 1.3271	* 1.1745	* 1.2386	* 1.1977	* 0.8087	*	
	* 1.7650	* 1.5904	* 1.7998	* 1.7126	* 1.7775	* 2.6264	*	
13	* 1.0428	* 1.1210	* 1.2437	* 1.1909	* 0.8068	*		
	* 2.0022	* 1.8752	* 1.6964	* 1.7830	* 2.6327	*		
14	* 1.1379	* 1.1272	* 0.8711	* 0.7029	*			
	* 1.7625	* 1.8082	* 2.3929	* 3.0088	*			
15	* 0.6865	* 0.6341	* F-SUB-Q					
	* 2.8786	* 3.1447	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 51 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4822	* 1.2958	* 1.2875	* 1.5209	* 1.3690	* 1.1983	* 1.3468	* 0.8237 *
	* 1.4398	* 1.6455	* 1.6548	* 1.4004	* 1.5551	* 1.7617	* 1.5295	* 2.4723 *
9	* 1.2958	* 1.3816	* 1.5078	* 1.3604	* 1.5474	* 1.2901	* 1.3245	* 0.7708 *
	* 1.6455	* 1.5361	* 1.4050	* 1.5614	* 1.3752	* 1.6438	* 1.5669	* 2.6527 *
10	* 1.2875	* 1.5078	* 1.3058	* 1.5146	* 1.3616	* 1.4519	* 1.0346	*
	* 1.6548	* 1.4049	* 1.6186	* 1.4014	* 1.5662	* 1.4644	* 2.0359	*
11	* 1.5209	* 1.3595	* 1.5130	* 1.2850	* 1.4539	* 1.4021	* 0.8372	*
	* 1.4004	* 1.5623	* 1.4019	* 1.6566	* 1.4702	* 1.5244	* 2.5446	*
12	* 1.3690	* 1.5411	* 1.3592	* 1.4528	* 1.4102	* 0.9634	*	
	* 1.5551	* 1.3808	* 1.5688	* 1.4713	* 1.5187	* 2.2071	*	
13	* 1.1983	* 1.2854	* 1.4486	* 1.4005	* 0.9619	*		
	* 1.7617	* 1.6497	* 1.4676	* 1.5261	* 2.2104	*		
14	* 1.3468	* 1.3222	* 1.0321	* 0.8348	*			
	* 1.5295	* 1.5695	* 2.0405	* 2.5520	*			
15	* 0.8237	* 0.7624	* F-SUB-Q					
	* 2.4723	* 2.6820	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6650	* 1.4039	* 1.4040	* 1.7150	* 1.5000	* 1.2998	* 1.5049	* 0.8953 *
	* 1.2946	* 1.5356	* 1.5345	* 1.2545	* 1.4342	* 1.6444	* 1.3922	* 2.3193 *
9	* 1.4039	* 1.5146	* 1.7110	* 1.4897	* 1.7584	* 1.4153	* 1.4827	* 0.8226 *
	* 1.5356	* 1.4185	* 1.2537	* 1.4434	* 1.2223	* 1.5149	* 1.4208	* 2.5329 *
10	* 1.4040	* 1.7110	* 1.4303	* 1.7170	* 1.4959	* 1.6548	* 1.1159	*
	* 1.5345	* 1.2537	* 1.4994	* 1.2514	* 1.4402	* 1.2975	* 1.9107	*
11	* 1.7150	* 1.4887	* 1.7155	* 1.4119	* 1.6674	* 1.5911	* 0.8894	*
	* 1.2545	* 1.4443	* 1.2518	* 1.5256	* 1.2941	* 1.3514	* 2.4196	*
12	* 1.5000	* 1.7538	* 1.4933	* 1.6663	* 1.6183	* 1.0357	*	
	* 1.4342	* 1.2260	* 1.4427	* 1.2948	* 1.3206	* 2.0458	*	
13	* 1.2998	* 1.4098	* 1.6514	* 1.5895	* 1.0349	*		
	* 1.6444	* 1.5208	* 1.3001	* 1.3527	* 2.0475	*		
14	* 1.5049	* 1.4801	* 1.1130	* 0.8872	*			
	* 1.3922	* 1.4231	* 1.9156	* 2.4254	*			
15	* 0.8953	* 0.8142	* F-SUB-Q					
	* 2.3193	* 2.5594	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 52 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6949	* 1.4130	* 1.4194	* 1.7480	* 1.5196	* 1.3095	* 1.5251	* 0.9075 *
	* 1.2835	* 1.5412	* 1.5332	* 1.2424	* 1.4293	* 1.6540	* 1.3986	* 2.3362 *
9	* 1.4130	* 1.5348	* 1.7462	* 1.5096	* 1.8015	* 1.4342	* 1.5040	* 0.8393 *
	* 1.5412	* 1.4157	* 1.2424	* 1.4394	* 1.2043	* 1.5105	* 1.4239	* 2.5322 *
10	* 1.4194	* 1.7462	* 1.4489	* 1.7547	* 1.5188	* 1.6973	* 1.1401	*
	* 1.5332	* 1.2424	* 1.4977	* 1.2369	* 1.4302	* 1.2756	* 1.8938	*
11	* 1.7480	* 1.5086	* 1.7533	* 1.4358	* 1.7153	* 1.6349	* 0.9142	*
	* 1.2424	* 1.4403	* 1.2379	* 1.5135	* 1.2605	* 1.3046	* 2.3503	*
12	* 1.5196	* 1.7975	* 1.5162	* 1.7145	* 1.6823	* 1.0741	*	
	* 1.4293	* 1.2069	* 1.4326	* 1.2612	* 1.2612	* 1.9619	*	
13	* 1.3095	* 1.4285	* 1.6940	* 1.6336	* 1.0734	*		
	* 1.6540	* 1.5165	* 1.2779	* 1.3056	* 1.9633	*		
14	* 1.5251	* 1.5015	* 1.1375	* 0.9120	*			
	* 1.3986	* 1.4262	* 1.8980	* 2.3561	*			
15	* 0.9075	* 0.8296	* F-SUB-Q					
	* 2.3362	* 2.5621	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6873	* 1.3995	* 1.4055	* 1.7388	* 1.5067	* 1.2971	* 1.5119	* 0.8995 *
	* 1.2842	* 1.5568	* 1.5479	* 1.2455	* 1.4375	* 1.6742	* 1.4304	* 2.3980 *
9	* 1.3995	* 1.5288	* 1.7381	* 1.4968	* 1.7968	* 1.4228	* 1.4921	* 0.8342 *
	* 1.5568	* 1.4233	* 1.2500	* 1.4524	* 1.2033	* 1.5212	* 1.4496	* 2.5889 *
10	* 1.4055	* 1.7382	* 1.4360	* 1.7480	* 1.5090	* 1.6935	* 1.1375	*
	* 1.5479	* 1.2500	* 1.5139	* 1.2399	* 1.4313	* 1.2680	* 1.9017	*
11	* 1.7388	* 1.4958	* 1.7467	* 1.4275	* 1.7158	* 1.6363	* 0.9166	*
	* 1.2455	* 1.4535	* 1.2409	* 1.5163	* 1.2477	* 1.2925	* 2.3179	*
12	* 1.5067	* 1.7930	* 1.5065	* 1.7152	* 1.6955	* 1.0841	*	
	* 1.4375	* 1.2059	* 1.4337	* 1.2482	* 1.2423	* 1.9333	*	
13	* 1.2971	* 1.4172	* 1.6908	* 1.6354	* 1.0836	*		
	* 1.6742	* 1.5272	* 1.2692	* 1.2933	* 1.9342	*		
14	* 1.5119	* 1.4896	* 1.1351	* 0.9144	*			
	* 1.4304	* 1.4519	* 1.9058	* 2.3233	*			
15	* 0.8995	* 0.8251	* F-SUB-Q					
	* 2.3980	* 2.6175	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 53 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6886	* 1.3838	* 1.3931	* 1.7373	* 1.4963	* 1.2810	* 1.5094	* 0.8862 *
	* 1.2747	* 1.5620	* 1.5507	* 1.2382	* 1.4372	* 1.6836	* 1.4331	* 2.4403 *
9	* 1.3838	* 1.5139	* 1.7370	* 1.4846	* 1.7997	* 1.4140	* 1.4904	* 0.8178 *
	* 1.5620	* 1.4292	* 1.2434	* 1.4540	* 1.1927	* 1.5196	* 1.4478	* 2.6443 *
10	* 1.3931	* 1.7372	* 1.4239	* 1.7483	* 1.4996	* 1.6984	* 1.1203	*
	* 1.5507	* 1.2433	* 1.5185	* 1.2303	* 1.4288	* 1.2518	* 1.9164	*
11	* 1.7373	* 1.4836	* 1.7472	* 1.4188	* 1.7221	* 1.6451	* 0.9010	*
	* 1.2382	* 1.4551	* 1.2310	* 1.5070	* 1.2311	* 1.2783	* 2.3377	*
12	* 1.4963	* 1.7963	* 1.4972	* 1.7217	* 1.7142	* 1.0713	*	
	* 1.4372	* 1.1950	* 1.4311	* 1.2313	* 1.2233	* 1.9507	*	
13	* 1.2810	* 1.4085	* 1.6960	* 1.6444	* 1.0711	*		
	* 1.6836	* 1.5256	* 1.2527	* 1.2788	* 1.9510	*		
14	* 1.5093	* 1.4881	* 1.1181	* 0.8991	*			
	* 1.4331	* 1.4501	* 1.9201	* 2.3424	*			
15	* 0.8862	* 0.8094	* F-SUB-Q					
	* 2.4403	* 2.6716	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6623	* 1.3553	* 1.3654	* 1.7077	* 1.4673	* 1.2535	* 1.4826	* 0.8683 *
	* 1.2892	* 1.5854	* 1.5729	* 1.2526	* 1.4572	* 1.7093	* 1.4508	* 2.4712 *
9	* 1.3553	* 1.4895	* 1.7081	* 1.4553	* 1.7716	* 1.3875	* 1.4646	* 0.8032 *
	* 1.5854	* 1.4479	* 1.2588	* 1.4751	* 1.2043	* 1.5361	* 1.4673	* 2.6711 *
10	* 1.3654	* 1.7083	* 1.3955	* 1.7196	* 1.4719	* 1.6733	* 1.1005	*
	* 1.5729	* 1.2586	* 1.5425	* 1.2419	* 1.4475	* 1.2658	* 1.9353	*
11	* 1.7077	* 1.4544	* 1.7186	* 1.3928	* 1.6977	* 1.6243	* 0.8865	*
	* 1.2526	* 1.4761	* 1.2425	* 1.5285	* 1.2457	* 1.2943	* 2.3693	*
12	* 1.4673	* 1.7683	* 1.4696	* 1.6976	* 1.6978	* 1.0590	*	
	* 1.4572	* 1.2065	* 1.4497	* 1.2458	* 1.2363	* 1.9772	*	
13	* 1.2535	* 1.3821	* 1.6713	* 1.6239	* 1.0590	*		
	* 1.7093	* 1.5421	* 1.2665	* 1.2945	* 1.9771	*		
14	* 1.4826	* 1.4623	* 1.0985	* 0.8849	*			
	* 1.4508	* 1.4695	* 1.9388	* 2.3736	*			
15	* 0.8683	* 0.7940	* F-SUB-Q					
	* 2.4712	* 2.7017	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 54 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6588	* 1.3410	* 1.3504	* 1.7013	* 1.4536	* 1.2365	* 1.4774	* 0.8527 *
	* 1.2805	* 1.5874	* 1.5758	* 1.2482	* 1.4623	* 1.7232	* 1.4468	* 2.4982 *
9	* 1.3410	* 1.4728	* 1.7028	* 1.4391	* 1.7674	* 1.3742	* 1.4601	* 0.7805 *
	* 1.5874	* 1.4452	* 1.2491	* 1.4786	* 1.2008	* 1.5469	* 1.4609	* 2.7278 *
10	* 1.3504	* 1.7031	* 1.3798	* 1.7138	* 1.4570	* 1.6708	* 1.0766	*
	* 1.5758	* 1.2489	* 1.5465	* 1.2385	* 1.4572	* 1.2694	* 1.9764	*
11	* 1.7013	* 1.4382	* 1.7130	* 1.3784	* 1.6950	* 1.6244	* 0.8643	*
	* 1.2482	* 1.4795	* 1.2390	* 1.5415	* 1.2487	* 1.3020	* 2.4416	*
12	* 1.4536	* 1.7644	* 1.4548	* 1.6950	* 1.7014	* 1.0367	*	
	* 1.4623	* 1.2028	* 1.4593	* 1.2487	* 1.2414	* 2.0359	*	
13	* 1.2365	* 1.3688	* 1.6690	* 1.6243	* 1.0371	*		
	* 1.7232	* 1.5530	* 1.2707	* 1.3020	* 2.0350	*		
14	* 1.4774	* 1.4580	* 1.0744	* 0.8627	*			
	* 1.4468	* 1.4630	* 1.9803	* 2.4457	*			
15	* 0.8527	* 0.7730	* F-SUB-Q					
	* 2.4982	* 2.7539	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5928	* 1.3090	* 1.3018	* 1.6291	* 1.3977	* 1.2094	* 1.4119	* 0.8317 *
	* 1.3242	* 1.6152	* 1.6219	* 1.2933	* 1.5094	* 1.7479	* 1.5030	* 2.5583 *
9	* 1.3090	* 1.4397	* 1.6308	* 1.3875	* 1.6923	* 1.3222	* 1.3948	* 0.7760 *
	* 1.6152	* 1.4681	* 1.2942	* 1.5220	* 1.2441	* 1.5959	* 1.5183	* 2.7403 *
10	* 1.3018	* 1.6311	* 1.3290	* 1.6412	* 1.4045	* 1.5987	* 1.0625	*
	* 1.6219	* 1.2939	* 1.5931	* 1.2830	* 1.5002	* 1.3165	* 1.9887	*
11	* 1.6291	* 1.3866	* 1.6405	* 1.3284	* 1.6233	* 1.5551	* 0.8621	*
	* 1.2933	* 1.5230	* 1.2835	* 1.5872	* 1.2936	* 1.3498	* 2.4449	*
12	* 1.3977	* 1.6895	* 1.4025	* 1.6234	* 1.6297	* 1.0365	*	
	* 1.5094	* 1.2463	* 1.5023	* 1.2935	* 1.2859	* 2.0257	*	
13	* 1.2094	* 1.3172	* 1.5972	* 1.5552	* 1.0367	*		
	* 1.7479	* 1.6007	* 1.3168	* 1.3496	* 2.0254	*		
14	* 1.4119	* 1.3929	* 1.0608	* 0.8607	*			
	* 1.5030	* 1.5205	* 1.9920	* 2.4490	*			
15	* 0.8317	* 0.7679	* F-SUB-Q					
	* 2.5583	* 2.7690	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 55 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6134	* 1.2925	* 1.3008	* 1.6467	* 1.4008	* 1.1870	* 1.4289	* 0.8206 *
	* 1.3007	* 1.6245	* 1.6140	* 1.2734	* 1.4981	* 1.7716	* 1.4776	* 2.5733 *
9	* 1.2925	* 1.4252	* 1.6506	* 1.3864	* 1.7133	* 1.3243	* 1.4126	* 0.7555 *
	* 1.6245	* 1.4747	* 1.2723	* 1.5146	* 1.2237	* 1.5850	* 1.4916	* 2.7927 *
10	* 1.3008	* 1.6509	* 1.3284	* 1.6593	* 1.4047	* 1.6203	* 1.0398	*
	* 1.6140	* 1.2720	* 1.5844	* 1.2631	* 1.4920	* 1.2924	* 2.0202	*
11	* 1.6467	* 1.3856	* 1.6589	* 1.3282	* 1.6440	* 1.5789	* 0.8369	*
	* 1.2734	* 1.5154	* 1.2634	* 1.5782	* 1.2714	* 1.3234	* 2.4978	*
12	* 1.4008	* 1.7108	* 1.4027	* 1.6443	* 1.6583	* 1.0094	*	
	* 1.4981	* 1.2255	* 1.4941	* 1.2711	* 1.2583	* 2.0668	*	
13	* 1.1870	* 1.3191	* 1.6191	* 1.5793	* 1.0102	*		
	* 1.7716	* 1.5912	* 1.2924	* 1.3230	* 2.0652	*		
14	* 1.4289	* 1.4107	* 1.0382	* 0.8358	*			
	* 1.4776	* 1.4936	* 2.0233	* 2.5010	*			
15	* 0.8206	* 0.7482	* F-SUB-Q					
	* 2.5733	* 2.8198	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5949	* 1.2742	* 1.2823	* 1.6258	* 1.3799	* 1.1678	* 1.4091	* 0.8086 *
	* 1.3038	* 1.6315	* 1.6205	* 1.2781	* 1.5062	* 1.7815	* 1.4828	* 2.5793 *
9	* 1.2742	* 1.4113	* 1.6312	* 1.3664	* 1.6919	* 1.3044	* 1.3930	* 0.7464 *
	* 1.6315	* 1.4749	* 1.2754	* 1.5215	* 1.2284	* 1.5934	* 1.4969	* 2.7923 *
10	* 1.2823	* 1.6316	* 1.3091	* 1.6383	* 1.3843	* 1.6000	* 1.0264	*
	* 1.6205	* 1.2751	* 1.5911	* 1.2677	* 1.4995	* 1.2964	* 2.0245	*
11	* 1.6258	* 1.3657	* 1.6380	* 1.3092	* 1.6245	* 1.5606	* 0.8276	*
	* 1.2781	* 1.5223	* 1.2679	* 1.5849	* 1.2751	* 1.3271	* 2.5007	*
12	* 1.3799	* 1.6896	* 1.3825	* 1.6250	* 1.6416	* 1.0014	*	
	* 1.5062	* 1.2301	* 1.5014	* 1.2748	* 1.2601	* 2.0634	*	
13	* 1.1678	* 1.2993	* 1.6001	* 1.5612	* 1.0020	*		
	* 1.7815	* 1.5994	* 1.2962	* 1.3265	* 2.0620	*		
14	* 1.4091	* 1.3913	* 1.0250	* 0.8266	*			
	* 1.4828	* 1.4988	* 2.0273	* 2.5035	*			
15	* 0.8086	* 0.7400	* F-SUB-Q					
	* 2.5793	* 2.8164	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 56 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5560	* 1.2619	* 1.2518	* 1.5816	* 1.3445	* 1.1572	* 1.3682	* 0.7955 *
	* 1.3386	* 1.6509	* 1.6623	* 1.3150	* 1.5472	* 1.7988	* 1.5250	* 2.6182 *
9	* 1.2619	* 1.3949	* 1.5874	* 1.3342	* 1.6456	* 1.2713	* 1.3523	* 0.7433 *
	* 1.6509	* 1.4937	* 1.3114	* 1.5598	* 1.2636	* 1.6355	* 1.5406	* 2.8006 *
10	* 1.2518	* 1.5879	* 1.2775	* 1.5937	* 1.3513	* 1.5562	* 1.0171	*
	* 1.6623	* 1.3111	* 1.6315	* 1.3040	* 1.5374	* 1.3335	* 2.0434	*
11	* 1.5816	* 1.3334	* 1.5935	* 1.2780	* 1.5805	* 1.5179	* 0.8262	*
	* 1.3150	* 1.5606	* 1.3041	* 1.6252	* 1.3109	* 1.3653	* 2.5077	*
12	* 1.3445	* 1.6434	* 1.3496	* 1.5810	* 1.5980	* 1.0024	*	
	* 1.5472	* 1.2653	* 1.5394	* 1.3105	* 1.2958	* 2.0642	*	
13	* 1.1572	* 1.2677	* 1.5566	* 1.5188	* 1.0030	*		
	* 1.7988	* 1.6398	* 1.3331	* 1.3646	* 2.0630	*		
14	* 1.3682	* 1.3506	* 1.0158	* 0.8251	*			
	* 1.5250	* 1.5425	* 2.0461	* 2.5107	*			
15	* 0.7955	* 0.7354	* F-SUB-Q					
	* 2.6182	* 2.8307	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5837	* 1.2496	* 1.2582	* 1.6061	* 1.3540	* 1.1390	* 1.3911	* 0.7894 *
	* 1.3332	* 1.6894	* 1.6758	* 1.3111	* 1.5553	* 1.8487	* 1.5137	* 2.6578 *
9	* 1.2496	* 1.3881	* 1.6146	* 1.3396	* 1.6734	* 1.2796	* 1.3761	* 0.7272 *
	* 1.6894	* 1.5201	* 1.3054	* 1.5730	* 1.2577	* 1.6436	* 1.5292	* 2.8836 *
10	* 1.2582	* 1.6151	* 1.2842	* 1.6185	* 1.3577	* 1.5859	* 1.0006	*
	* 1.6758	* 1.3050	* 1.6423	* 1.2998	* 1.5491	* 1.3239	* 2.1006	*
11	* 1.6061	* 1.3389	* 1.6185	* 1.2843	* 1.6099	* 1.5493	* 0.8069	*
	* 1.3111	* 1.5738	* 1.2998	* 1.6356	* 1.3026	* 1.3538	* 2.5956	*
12	* 1.3540	* 1.6714	* 1.3561	* 1.6105	* 1.6346	* 0.9829	*	
	* 1.5553	* 1.2592	* 1.5510	* 1.3021	* 1.2823	* 2.1319	*	
13	* 1.1390	* 1.2750	* 1.5868	* 1.5505	* 0.9839	*		
	* 1.8487	* 1.6496	* 1.3232	* 1.3527	* 2.1296	*		
14	* 1.3911	* 1.3745	* 0.9991	* 0.8063	*			
	* 1.5137	* 1.5310	* 2.1038	* 2.5975	*			
15	* 0.7894	* 0.7195	* F-SUB-Q					
	* 2.6578	* 2.9141	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 57 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5918	* 1.2482	* 1.2575	* 1.6119	* 1.3530	* 1.1341	* 1.3952	* 0.7856 *
	* 1.3148	* 1.6706	* 1.6591	* 1.2984	* 1.5430	* 1.8318	* 1.4897	* 2.6193 *
9	* 1.2482	* 1.3879	* 1.6224	* 1.3380	* 1.6801	* 1.2789	* 1.3806	* 0.7204 *
	* 1.6706	* 1.5067	* 1.2907	* 1.5612	* 1.2464	* 1.6277	* 1.5048	* 2.8554 *
10	* 1.2576	* 1.6230	* 1.2837	* 1.6243	* 1.3561	* 1.5943	* 0.9933	*
	* 1.6591	* 1.2902	* 1.6269	* 1.2881	* 1.5388	* 1.3087	* 2.0857	*
11	* 1.6119	* 1.3373	* 1.6245	* 1.2838	* 1.6195	* 1.5589	* 0.7995	*
	* 1.2984	* 1.5619	* 1.2879	* 1.6214	* 1.2889	* 1.3371	* 2.5802	*
12	* 1.3530	* 1.6783	* 1.3545	* 1.6202	* 1.6478	* 0.9789	*	
	* 1.5430	* 1.2476	* 1.5404	* 1.2884	* 1.2662	* 2.1170	*	
13	* 1.1341	* 1.2743	* 1.5955	* 1.5604	* 0.9802	*		
	* 1.8318	* 1.6334	* 1.3077	* 1.3358	* 2.1142	*		
14	* 1.3952	* 1.3791	* 0.9920	* 0.7984	*			
	* 1.4897	* 1.5063	* 2.0882	* 2.5836	*			
15	* 0.7856	* 0.7133	* F-SUB-Q					
	* 2.6193	* 2.8831	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5968	* 1.2482	* 1.2569	* 1.6129	* 1.3512	* 1.1313	* 1.3933	* 0.7851 *
	* 1.2975	* 1.6543	* 1.6433	* 1.2837	* 1.5284	* 1.8153	* 1.4715	* 2.5843 *
9	* 1.2482	* 1.3946	* 1.6248	* 1.3376	* 1.6813	* 1.2765	* 1.3787	* 0.7245 *
	* 1.6543	* 1.4843	* 1.2751	* 1.5454	* 1.2317	* 1.6119	* 1.4868	* 2.8000 *
10	* 1.2569	* 1.6254	* 1.2829	* 1.6253	* 1.3552	* 1.5949	* 0.9965	*
	* 1.6433	* 1.2746	* 1.6109	* 1.2733	* 1.5232	* 1.2931	* 2.0536	*
11	* 1.6129	* 1.3369	* 1.6256	* 1.2825	* 1.6212	* 1.5598	* 0.8046	*
	* 1.2837	* 1.5461	* 1.2731	* 1.6059	* 1.2735	* 1.3211	* 2.5343	*
12	* 1.3512	* 1.6796	* 1.3538	* 1.6220	* 1.6501	* 0.9862	*	
	* 1.5284	* 1.2328	* 1.5247	* 1.2729	* 1.2505	* 2.0787	*	
13	* 1.1313	* 1.2720	* 1.5964	* 1.5614	* 0.9878	*		
	* 1.8153	* 1.6174	* 1.2919	* 1.3197	* 2.0754	*		
14	* 1.3933	* 1.3773	* 0.9955	* 0.8043	*			
	* 1.4715	* 1.4882	* 2.0554	* 2.5353	*			
15	* 0.7851	* 0.7166	* F-SUB-Q					
	* 2.5843	* 2.8301	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 58 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5834	* 1.2648	* 1.2526	* 1.5995	* 1.3420	* 1.1476	* 1.3757	* 0.7879 *
	* 1.3055	* 1.6307	* 1.6467	* 1.2912	* 1.5341	* 1.7860	* 1.4809	* 2.5576 *
9	* 1.2648	* 1.4088	* 1.6108	* 1.3328	* 1.6652	* 1.2706	* 1.3607	* 0.7379 *
	* 1.6307	* 1.4663	* 1.2831	* 1.5473	* 1.2393	* 1.6158	* 1.4973	* 2.7304 *
10	* 1.2526	* 1.6114	* 1.2777	* 1.6113	* 1.3494	* 1.5783	* 1.0095	*
	* 1.6467	* 1.2826	* 1.6141	* 1.2807	* 1.5252	* 1.3011	* 2.0168	*
11	* 1.5995	* 1.3322	* 1.6120	* 1.2770	* 1.6072	* 1.5429	* 0.8214	*
	* 1.2912	* 1.5480	* 1.2802	* 1.6083	* 1.2801	* 1.3299	* 2.4715	*
12	* 1.3420	* 1.6636	* 1.3481	* 1.6080	* 1.6333	* 1.0092	*	
	* 1.5341	* 1.2404	* 1.5266	* 1.2795	* 1.2586	* 2.0240	*	
13	* 1.1476	* 1.2676	* 1.5798	* 1.5447	* 1.0103	*		
	* 1.7860	* 1.6195	* 1.2998	* 1.3283	* 2.0217	*		
14	* 1.3757	* 1.3593	* 1.0086	* 0.8209	*			
	* 1.4809	* 1.4987	* 2.0185	* 2.4728	*			
15	* 0.7879	* 0.7295	* F-SUB-Q					
	* 2.5576	* 2.7612	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6497	* 1.2765	* 1.2870	* 1.6647	* 1.3834	* 1.1507	* 1.4322	* 0.7963 *
	* 1.2461	* 1.6055	* 1.5926	* 1.2340	* 1.4817	* 1.7727	* 1.4212	* 2.5271 *
9	* 1.2765	* 1.4312	* 1.6804	* 1.3692	* 1.7359	* 1.3053	* 1.4179	* 0.7314 *
	* 1.6055	* 1.4343	* 1.2228	* 1.4980	* 1.1836	* 1.5656	* 1.4355	* 2.7512 *
10	* 1.2870	* 1.6812	* 1.3142	* 1.6777	* 1.3869	* 1.6477	* 1.0096	*
	* 1.5926	* 1.2223	* 1.5601	* 1.2240	* 1.4775	* 1.2430	* 2.0140	*
11	* 1.6647	* 1.3685	* 1.6783	* 1.3147	* 1.6779	* 1.6133	* 0.8136	*
	* 1.2340	* 1.4987	* 1.2236	* 1.5560	* 1.2219	* 1.2686	* 2.4932	*
12	* 1.3834	* 1.7345	* 1.3856	* 1.6788	* 1.7117	* 1.0050	*	
	* 1.4817	* 1.1844	* 1.4788	* 1.2212	* 1.1972	* 2.0275	*	
13	* 1.1507	* 1.3008	* 1.6497	* 1.6155	* 1.0066	*		
	* 1.7727	* 1.5709	* 1.2415	* 1.2670	* 2.0243	*		
14	* 1.4322	* 1.4165	* 1.0085	* 0.8128	*			
	* 1.4212	* 1.4368	* 2.0161	* 2.4955	*			
15	* 0.7963	* 0.7240	* F-SUB-Q					
	* 2.5271	* 2.7789	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 59 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6749	* 1.2910	* 1.3035	* 1.6910	* 1.4017	* 1.1623	* 1.4517	* 0.8041 *
	* 1.2082	* 1.5632	* 1.5481	* 1.1952	* 1.4387	* 1.7260	* 1.3774	* 2.4649 *
9	* 1.2910	* 1.4529	* 1.7078	* 1.3874	* 1.7639	* 1.3220	* 1.4374	* 0.7393 *
	* 1.5632	* 1.3910	* 1.1843	* 1.4551	* 1.1455	* 1.5198	* 1.3912	* 2.6808 *
10	* 1.3035	* 1.7085	* 1.3318	* 1.7045	* 1.4055	* 1.6747	* 1.0205	*
	* 1.5481	* 1.1837	* 1.5158	* 1.1852	* 1.4344	* 1.2021	* 1.9583	*
11	* 1.6910	* 1.3868	* 1.7052	* 1.3326	* 1.7071	* 1.6403	* 0.8221	*
	* 1.1952	* 1.4557	* 1.1847	* 1.5102	* 1.1808	* 1.2265	* 2.4259	*
12	* 1.4017	* 1.7625	* 1.4043	* 1.7080	* 1.7425	* 1.0194	*	*
	* 1.4387	* 1.1463	* 1.4356	* 1.1802	* 1.1562	* 1.9655	*	*
13	* 1.1623	* 1.3174	* 1.6768	* 1.6426	* 1.0211	*	*	*
	* 1.7260	* 1.5250	* 1.2005	* 1.2248	* 1.9623	*	*	*
14	* 1.4517	* 1.4358	* 1.0194	* 0.8212	*	*	*	*
	* 1.3774	* 1.3926	* 1.9603	* 2.4286	*	*	*	*
15	* 0.8041	* 0.7311	* F-SUB-Q					
	* 2.4649	* 2.7106	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6902	* 1.3035	* 1.3164	* 1.7092	* 1.4163	* 1.1730	* 1.4597	* 0.8095 *
	* 1.1835	* 1.5317	* 1.5161	* 1.1690	* 1.4071	* 1.6892	* 1.3510	* 2.4146 *
9	* 1.3035	* 1.4705	* 1.7243	* 1.4030	* 1.7798	* 1.3344	* 1.4448	* 0.7590 *
	* 1.5317	* 1.3593	* 1.1594	* 1.4228	* 1.1215	* 1.4868	* 1.3650	* 2.5748 *
10	* 1.3164	* 1.7250	* 1.3454	* 1.7220	* 1.4210	* 1.6861	* 1.0308	*
	* 1.5161	* 1.1589	* 1.4839	* 1.1595	* 1.4020	* 1.1784	* 1.9133	*
11	* 1.7092	* 1.4024	* 1.7229	* 1.3445	* 1.7206	* 1.6504	* 0.8286	*
	* 1.1690	* 1.4234	* 1.1588	* 1.4792	* 1.1569	* 1.2031	* 2.3759	*
12	* 1.4163	* 1.7782	* 1.4196	* 1.7216	* 1.7532	* 1.0372	*	*
	* 1.4071	* 1.1224	* 1.4033	* 1.1562	* 1.1344	* 1.9074	*	*
13	* 1.1730	* 1.3295	* 1.6881	* 1.6526	* 1.0391	*	*	*
	* 1.6892	* 1.4921	* 1.1770	* 1.2014	* 1.9040	*	*	*
14	* 1.4597	* 1.4430	* 1.0296	* 0.8274	*	*	*	*
	* 1.3510	* 1.3666	* 1.9154	* 2.3790	*	*	*	*
15	* 0.8095	* 0.7372	* F-SUB-Q					
	* 2.4146	* 2.6509	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 60 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6696	* 1.3044	* 1.3081	* 1.6972	* 1.4087	* 1.1689	* 1.4340	* 0.8008 *
	* 1.1873	* 1.5177	* 1.5129	* 1.1666	* 1.4016	* 1.6807	* 1.3597	* 2.4137 *
9	* 1.3044	* 1.4672	* 1.7072	* 1.3964	* 1.7541	* 1.3252	* 1.4182	* 0.7485 *
	* 1.5177	* 1.3507	* 1.1610	* 1.4172	* 1.1268	* 1.4821	* 1.3750	* 2.5814 *
10	* 1.3081	* 1.7087	* 1.3371	* 1.7091	* 1.4132	* 1.6556	* 1.0255	*
	* 1.5129	* 1.1600	* 1.4806	* 1.1574	* 1.3967	* 1.1874	* 1.9029	*
11	* 1.6972	* 1.3957	* 1.7100	* 1.3327	* 1.6912	* 1.6164	* 0.8213	*
	* 1.1666	* 1.4178	* 1.1568	* 1.4794	* 1.1647	* 1.2152	* 2.3717	*
12	* 1.4087	* 1.7521	* 1.4117	* 1.6926	* 1.7122	* 1.0257	*	
	* 1.4016	* 1.1280	* 1.3981	* 1.1638	* 1.1492	* 1.9086	*	
13	* 1.1689	* 1.3201	* 1.6572	* 1.6183	* 1.0273	*		
	* 1.6807	* 1.4876	* 1.1862	* 1.2137	* 1.9057	*		
14	* 1.4340	* 1.4163	* 1.0239	* 0.8199	*			
	* 1.3597	* 1.3768	* 1.9056	* 2.3758	*			
15	* 0.8008	* 0.7309	* F-SUB-Q					
	* 2.4137	* 2.6437	* M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5694	* 1.2514	* 1.2513	* 1.6083	* 1.3504	* 1.1203	* 1.3559	* 0.7566 *
	* 1.2524	* 1.5698	* 1.5693	* 1.2205	* 1.4497	* 1.7366	* 1.4234	* 2.5291 *
9	* 1.2514	* 1.3987	* 1.6126	* 1.3385	* 1.6604	* 1.2684	* 1.3382	* 0.7101 *
	* 1.5698	* 1.4053	* 1.2190	* 1.4666	* 1.1799	* 1.5349	* 1.4424	* 2.6943 *
10	* 1.2513	* 1.6139	* 1.2782	* 1.6184	* 1.3544	* 1.5564	* 0.9748	*
	* 1.5693	* 1.2180	* 1.5367	* 1.2119	* 1.4449	* 1.2511	* 1.9827	*
11	* 1.6083	* 1.3378	* 1.6189	* 1.2720	* 1.5871	* 1.5160	* 0.7811	*
	* 1.2205	* 1.4674	* 1.2114	* 1.5395	* 1.2301	* 1.2828	* 2.4703	*
12	* 1.3504	* 1.6574	* 1.3527	* 1.5879	* 1.5904	* 0.9691	*	
	* 1.4497	* 1.1819	* 1.4466	* 1.2294	* 1.2251	* 2.0011	*	
13	* 1.1203	* 1.2630	* 1.5560	* 1.5172	* 0.9702	*		
	* 1.7366	* 1.5412	* 1.2509	* 1.2817	* 1.9988	*		
14	* 1.3559	* 1.3361	* 0.9731	* 0.7794	*			
	* 1.4234	* 1.4446	* 1.9859	* 2.4755	*			
15	* 0.7566	* 0.6946	* F-SUB-Q					
	* 2.5291	* 2.7546	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 61 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 375 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2968 *	* 1.0763 *	* 1.0607 *	* 1.3191 *	* 1.1566 *	* 0.9552 *	* 1.1215 *	* 0.6286 *
	* 1.5022 *	* 1.8094 *	* 1.8358 *	* 1.4747 *	* 1.6775 *	* 2.0185 *	* 1.7040 *	* 3.0163 *
9	* 1.0763 *	* 1.1876 *	* 1.3192 *	* 1.1394 *	* 1.3689 *	* 1.0828 *	* 1.1090 *	* 0.5951 *
	* 1.8094 *	* 1.6410 *	* 1.4765 *	* 1.7080 *	* 1.4176 *	* 1.7810 *	* 1.7234 *	* 3.1864 *
10	* 1.0607 *	* 1.3196 *	* 1.0821 *	* 1.3256 *	* 1.1503 *	* 1.2765 *	* 0.8198 *	
	* 1.8358 *	* 1.4760 *	* 1.8001 *	* 1.4663 *	* 1.6860 *	* 1.5107 *	* 2.3350 *	
11	* 1.3191 *	* 1.1388 *	* 1.3258 *	* 1.0756 *	* 1.2952 *	* 1.2455 *	* 0.6629 *	
	* 1.4747 *	* 1.7089 *	* 1.4661 *	* 1.8050 *	* 1.4946 *	* 1.5458 *	* 2.8844 *	
12	* 1.1566 *	* 1.3659 *	* 1.1487 *	* 1.2957 *	* 1.2885 *	* 0.8140 *		
	* 1.6775 *	* 1.4205 *	* 1.6882 *	* 1.4940 *	* 1.4973 *	* 2.3603 *		
13	* 0.9552 *	* 1.0782 *	* 1.2753 *	* 1.2462 *	* 0.8145 *			
	* 2.0185 *	* 1.7884 *	* 1.5120 *	* 1.5449 *	* 2.3588 *			
14	* 1.1215 *	* 1.1071 *	* 0.8184 *	* 0.6613 *				
	* 1.7040 *	* 1.7261 *	* 2.3388 *	* 2.8910 *				
15	* 0.6286 *	* 0.5855 *	F-SUB-Q					
	* 3.0163 *	* 3.2380 *	M-SUB-Q					

AT 100% POWER, 375 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5997 *	* 0.5388 *	* 0.5519 *	* 0.6336 *	* 0.5751 *	* 0.4957 *	* 0.5000 *	* 0.3087 *
	* 3.2173 *	* 3.5806 *	* 3.4943 *	* 3.0400 *	* 3.3414 *	* 3.8503 *	* 3.7862 *	* 6.0931 *
9	* 0.5388 *	* 0.5818 *	* 0.6327 *	* 0.5729 *	* 0.6291 *	* 0.5354 *	* 0.4928 *	* 0.2896 *
	* 3.5806 *	* 3.3174 *	* 3.0486 *	* 3.3630 *	* 3.0537 *	* 3.5667 *	* 3.8423 *	* 6.4953 *
10	* 0.5519 *	* 0.6328 *	* 0.5621 *	* 0.6362 *	* 0.5726 *	* 0.5800 *	* 0.4080 *	
	* 3.4943 *	* 3.0478 *	* 3.4296 *	* 3.0249 *	* 3.3535 *	* 3.2917 *	* 4.6501 *	
11	* 0.6336 *	* 0.5726 *	* 0.6362 *	* 0.5580 *	* 0.6154 *	* 0.5536 *	* 0.3243 *	
	* 3.0400 *	* 3.3647 *	* 3.0251 *	* 3.4453 *	* 3.1142 *	* 3.4453 *	* 5.8461 *	
12	* 0.5751 *	* 0.6276 *	* 0.5718 *	* 0.6155 *	* 0.5753 *	* 0.4045 *		
	* 3.3414 *	* 3.0609 *	* 3.3579 *	* 3.1138 *	* 3.3208 *	* 4.7077 *		
13	* 0.4957 *	* 0.5334 *	* 0.5792 *	* 0.5537 *	* 0.4045 *			
	* 3.8503 *	* 3.5798 *	* 3.2959 *	* 3.4447 *	* 4.7075 *			
14	* 0.5000 *	* 0.4918 *	* 0.4073 *	* 0.3236 *				
	* 3.7862 *	* 3.8498 *	* 4.6578 *	* 5.8598 *				
15	* 0.3087 *	* 0.2885 *	F-SUB-Q					
	* 6.0931 *	* 6.5197 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 62 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7563	* 0.7157	* 0.7109	* 0.7859	* 0.7349	* 0.6639	* 0.5967	* 0.4061
	* 2.7153	* 2.8609	* 2.8714	* 2.6059	* 2.7860	* 3.0296	* 2.9589	* 4.3685
9	* 0.7157	* 0.7245	* 0.7744	* 0.7267	* 0.7773	* 0.6936	* 0.6312	* 0.3997
	* 2.8609	* 2.7691	* 2.5851	* 2.7873	* 2.6331	* 2.9356	* 3.0575	* 4.6506
10	* 0.7109	* 0.7744	* 0.6471	* 0.7805	* 0.7263	* 0.7273	* 0.5461	*
	* 2.8714	* 2.5844	* 2.7724	* 2.5806	* 2.8197	* 2.8167	* 3.6891	*
11	* 0.7859	* 0.7256	* 0.7801	* 0.7036	* 0.7578	* 0.6870	* 0.4490	*
	* 2.6059	* 2.7880	* 2.5804	* 2.8670	* 2.7180	* 3.0085	* 4.5770	*
12	* 0.7349	* 0.7752	* 0.7255	* 0.7576	* 0.7016	* 0.5217	*	*
	* 2.7860	* 2.6399	* 2.8224	* 2.7184	* 2.9541	* 3.9391	*	*
13	* 0.6639	* 0.6920	* 0.7263	* 0.6864	* 0.5200	*	*	*
	* 3.0296	* 2.9421	* 2.8205	* 3.0109	* 3.9523	*	*	*
14	* 0.5967	* 0.6303	* 0.5453	* 0.4479	*	*	*	*
	* 2.9589	* 3.0615	* 3.6945	* 4.5880	*	*	*	*
15	* 0.4061	* 0.3968	* F-SUB-Q					
	* 4.3685	* 4.6842	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3303	* 1.1748	* 1.1526	* 1.3349	* 1.2321	* 1.0908	* 1.1885	* 0.7444
	* 1.5503	* 1.7517	* 1.7836	* 1.5422	* 1.6705	* 1.8637	* 1.6378	* 2.5742
9	* 1.1748	* 1.2322	* 1.3223	* 1.2093	* 1.3815	* 1.1746	* 1.1822	* 0.6974
	* 1.7517	* 1.6541	* 1.5349	* 1.6886	* 1.4890	* 1.7444	* 1.6761	* 2.7750
10	* 1.1526	* 1.3224	* 1.1556	* 1.3349	* 1.2211	* 1.3134	* 0.9286	*
	* 1.7836	* 1.5346	* 1.7368	* 1.5315	* 1.6880	* 1.5666	* 2.1870	*
11	* 1.3349	* 1.2089	* 1.3343	* 1.1556	* 1.3100	* 1.2602	* 0.7649	*
	* 1.5422	* 1.6891	* 1.5316	* 1.7724	* 1.5801	* 1.6448	* 2.6974	*
12	* 1.2321	* 1.3794	* 1.2199	* 1.3096	* 1.2880	* 0.8743	*	*
	* 1.6705	* 1.4917	* 1.6896	* 1.5805	* 1.6140	* 2.3756	*	*
13	* 1.0908	* 1.1716	* 1.3118	* 1.2593	* 0.8724	*	*	*
	* 1.8637	* 1.7487	* 1.5684	* 1.6458	* 2.3807	*	*	*
14	* 1.1885	* 1.1808	* 0.9271	* 0.7631	*	*	*	*
	* 1.6378	* 1.6780	* 2.1905	* 2.7035	*	*	*	*
15	* 0.7444	* 0.6883	* F-SUB-Q					
	* 2.5742	* 2.8115	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 63 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4892	* 1.2847	* 1.2762	* 1.5119	* 1.3616	* 1.2097	* 1.3567	* 0.8632 *
	* 1.3955	* 1.6162	* 1.6260	* 1.3724	* 1.5234	* 1.6994	* 1.4762	* 2.2919 *
9	* 1.2847	* 1.3643	* 1.5024	* 1.3486	* 1.5628	* 1.3032	* 1.3390	* 0.8102 *
	* 1.6162	* 1.5142	* 1.3725	* 1.5341	* 1.3269	* 1.5855	* 1.5077	* 2.4529 *
10	* 1.2762	* 1.5026	* 1.2968	* 1.5161	* 1.3628	* 1.4896	* 1.0661	*
	* 1.6260	* 1.3723	* 1.5866	* 1.3664	* 1.5253	* 1.3912	* 1.9246	*
11	* 1.5119	* 1.3480	* 1.5153	* 1.2903	* 1.4929	* 1.4296	* 0.8806	*
	* 1.3724	* 1.5347	* 1.3669	* 1.6080	* 1.3966	* 1.4584	* 2.3595	*
12	* 1.3616	* 1.5605	* 1.3614	* 1.4924	* 1.4770	* 1.0115	*	
	* 1.5234	* 1.3288	* 1.5268	* 1.3970	* 1.4157	* 2.0543	*	
13	* 1.2097	* 1.2998	* 1.4880	* 1.4288	* 1.0104	*		
	* 1.6994	* 1.5896	* 1.3927	* 1.4592	* 2.0567	*		
14	* 1.3567	* 1.3374	* 1.0645	* 0.8787	*			
	* 1.4762	* 1.5094	* 1.9274	* 2.3646	*			
15	* 0.8632	* 0.8023	* F-SUB-Q					
	* 2.2919	* 2.4773	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6043	* 1.3527	* 1.3512	* 1.6336	* 1.4473	* 1.2782	* 1.4789	* 0.9168 *
	* 1.3084	* 1.5522	* 1.5531	* 1.2829	* 1.4480	* 1.6286	* 1.3780	* 2.2029 *
9	* 1.3527	* 1.4496	* 1.6286	* 1.4304	* 1.6963	* 1.3850	* 1.4606	* 0.8444 *
	* 1.5522	* 1.4431	* 1.2825	* 1.4643	* 1.2349	* 1.5081	* 1.4034	* 2.4005 *
10	* 1.3512	* 1.6287	* 1.3769	* 1.6420	* 1.4483	* 1.6248	* 1.1175	*
	* 1.5531	* 1.2823	* 1.5166	* 1.2761	* 1.4498	* 1.2877	* 1.8585	*
11	* 1.6336	* 1.4298	* 1.6413	* 1.3726	* 1.6274	* 1.5689	* 0.9100	*
	* 1.2829	* 1.4649	* 1.2766	* 1.5294	* 1.2928	* 1.3386	* 2.3058	*
12	* 1.4473	* 1.6940	* 1.4468	* 1.6271	* 1.6291	* 1.0540	*	
	* 1.4480	* 1.2365	* 1.4513	* 1.2930	* 1.2809	* 1.9630	*	
13	* 1.2782	* 1.3812	* 1.6232	* 1.5684	* 1.0534	*		
	* 1.6286	* 1.5123	* 1.2889	* 1.3390	* 1.9641	*		
14	* 1.4789	* 1.4590	* 1.1160	* 0.9083	*			
	* 1.3780	* 1.4050	* 1.8611	* 2.3099	*			
15	* 0.9168	* 0.8372	* F-SUB-Q					
	* 2.2029	* 2.4212	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 64 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5958	* 1.3367	* 1.3396	* 1.6273	* 1.4347	* 1.2635	* 1.4747	* 0.9157 *
	* 1.3279	* 1.5874	* 1.5831	* 1.3003	* 1.4751	* 1.6701	* 1.4078	* 2.2538 *
9	* 1.3367	* 1.4398	* 1.6238	* 1.4182	* 1.6918	* 1.3732	* 1.4569	* 0.8485 *
	* 1.5874	* 1.4702	* 1.3014	* 1.4928	* 1.2495	* 1.5373	* 1.4312	* 2.4389 *
10	* 1.3396	* 1.6240	* 1.3661	* 1.6375	* 1.4374	* 1.6220	* 1.1200	*
	* 1.5831	* 1.3013	* 1.5473	* 1.2914	* 1.4728	* 1.3009	* 1.8788	*
11	* 1.6273	* 1.4176	* 1.6369	* 1.3647	* 1.6261	* 1.5716	* 0.9153	*
	* 1.3003	* 1.4934	* 1.2918	* 1.5501	* 1.2917	* 1.3241	* 2.2933	*
12	* 1.4347	* 1.6896	* 1.4359	* 1.6259	* 1.6372	* 1.0654	*	
	* 1.4751	* 1.2511	* 1.4743	* 1.2917	* 1.2639	* 1.9292	*	
13	* 1.2635	* 1.3693	* 1.6207	* 1.5713	* 1.0650	*		
	* 1.6701	* 1.5417	* 1.3018	* 1.3243	* 1.9299	*		
14	* 1.4747	* 1.4553	* 1.1185	* 0.9136	*			
	* 1.4078	* 1.4328	* 1.8813	* 2.2973	*			
15	* 0.9157	* 0.8398	* F-SUB-Q					
	* 2.2538	* 2.4642	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5696	* 1.3096	* 1.3117	* 1.5981	* 1.4043	* 1.2364	* 1.4493	* 0.9010 *
	* 1.3445	* 1.6200	* 1.6159	* 1.3199	* 1.5026	* 1.7107	* 1.4540	* 2.3329 *
9	* 1.3096	* 1.4155	* 1.5959	* 1.3884	* 1.6627	* 1.3448	* 1.4319	* 0.8374 *
	* 1.6200	* 1.4968	* 1.3254	* 1.5245	* 1.2666	* 1.5685	* 1.4719	* 2.5132 *
10	* 1.3117	* 1.5961	* 1.3378	* 1.6089	* 1.4083	* 1.5943	* 1.1053	*
	* 1.6159	* 1.3253	* 1.5815	* 1.3117	* 1.4938	* 1.3106	* 1.9069	*
11	* 1.5981	* 1.3877	* 1.6084	* 1.3382	* 1.5997	* 1.5477	* 0.9052	*
	* 1.3199	* 1.5252	* 1.3121	* 1.5624	* 1.2971	* 1.3316	* 2.2901	*
12	* 1.4043	* 1.6607	* 1.4068	* 1.5996	* 1.6150	* 1.0574	*	
	* 1.5026	* 1.2680	* 1.4954	* 1.2971	* 1.2703	* 1.9310	*	
13	* 1.2364	* 1.3410	* 1.5933	* 1.5476	* 1.0572	*		
	* 1.7107	* 1.5728	* 1.3109	* 1.3317	* 1.9314	*		
14	* 1.4493	* 1.4303	* 1.1038	* 0.9037	*			
	* 1.4540	* 1.4734	* 1.9094	* 2.2938	*			
15	* 0.9010	* 0.8293	* F-SUB-Q					
	* 2.3329	* 2.5378	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 65 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5610	* 1.2903	* 1.2945	* 1.5864	* 1.3871	* 1.2182	* 1.4424	* 0.8856 *
	* 1.3424	* 1.6301	* 1.6238	* 1.3204	* 1.5105	* 1.7242	* 1.4612	* 2.3802 *
9	* 1.2903	* 1.3968	* 1.5852	* 1.3688	* 1.6523	* 1.3287	* 1.4257	* 0.8198 *
	* 1.6301	* 1.5062	* 1.3255	* 1.5344	* 1.2649	* 1.5737	* 1.4746	* 2.5719 *
10	* 1.2945	* 1.5854	* 1.3197	* 1.5973	* 1.3896	* 1.5857	* 1.0828	*
	* 1.6238	* 1.3253	* 1.5925	* 1.3096	* 1.5016	* 1.3042	* 1.9313	*
11	* 1.5864	* 1.3682	* 1.5969	* 1.3214	* 1.5902	* 1.5428	* 0.8834	*
	* 1.3204	* 1.5351	* 1.3099	* 1.5627	* 1.2933	* 1.3269	* 2.3241	*
12	* 1.3871	* 1.6504	* 1.3881	* 1.5903	* 1.6108	* 1.0346	*	*
	* 1.5105	* 1.2662	* 1.5031	* 1.2932	* 1.2665	* 1.9662	*	*
13	* 1.2182	* 1.3249	* 1.5849	* 1.5429	* 1.0346	*	*	*
	* 1.7242	* 1.5781	* 1.3042	* 1.3268	* 1.9661	*	*	*
14	* 1.4424	* 1.4242	* 1.0814	* 0.8822	*	*	*	*
	* 1.4612	* 1.4761	* 1.9336	* 2.3273	*	*	*	*
15	* 0.8856	* 0.8113	* F-SUB-Q					
	* 2.3802	* 2.5989	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5383	* 1.2663	* 1.2705	* 1.5606	* 1.3613	* 1.1942	* 1.4208	* 0.8706 *
	* 1.3473	* 1.6406	* 1.6359	* 1.3302	* 1.5264	* 1.7443	* 1.4725	* 2.4039 *
9	* 1.2663	* 1.3732	* 1.5601	* 1.3428	* 1.6261	* 1.3048	* 1.4044	* 0.8068 *
	* 1.6406	* 1.5138	* 1.3327	* 1.5488	* 1.2762	* 1.5906	* 1.4859	* 2.5933 *
10	* 1.2705	* 1.5603	* 1.2947	* 1.5711	* 1.3636	* 1.5613	* 1.0652	*
	* 1.6359	* 1.3325	* 1.6109	* 1.3210	* 1.5207	* 1.3201	* 1.9496	*
11	* 1.5606	* 1.3422	* 1.5708	* 1.2972	* 1.5654	* 1.5206	* 0.8690	*
	* 1.3303	* 1.5495	* 1.3212	* 1.5867	* 1.3116	* 1.3454	* 2.3556	*
12	* 1.3613	* 1.6243	* 1.3622	* 1.5656	* 1.5887	* 1.0200	*	*
	* 1.5264	* 1.2776	* 1.5222	* 1.3114	* 1.2851	* 1.9976	*	*
13	* 1.1942	* 1.3012	* 1.5606	* 1.5209	* 1.0202	*	*	*
	* 1.7443	* 1.5950	* 1.3199	* 1.3451	* 1.9972	*	*	*
14	* 1.4208	* 1.4030	* 1.0639	* 0.8679	*	*	*	*
	* 1.4725	* 1.4873	* 1.9518	* 2.3586	*	*	*	*
15	* 0.8706	* 0.7985	* F-SUB-Q					
	* 2.4039	* 2.6204	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 66 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5409 *	* 1.2593 *	* 1.2631 *	* 1.5603 *	* 1.3541 *	* 1.1859 *	* 1.4235 *	* 0.8600 *
	* 1.3189 *	* 1.6181 *	* 1.6133 *	* 1.3037 *	* 1.5039 *	* 1.7226 *	* 1.4403 *	* 2.3900 *
9	* 1.2593 *	* 1.3682 *	* 1.5610 *	* 1.3333 *	* 1.6271 *	* 1.2982 *	* 1.4078 *	* 0.7897 *
	* 1.6181 *	* 1.4894 *	* 1.3052 *	* 1.5288 *	* 1.2495 *	* 1.5690 *	* 1.4529 *	* 2.6005 *
10	* 1.2631 *	* 1.5612 *	* 1.2864 *	* 1.5704 *	* 1.3545 *	* 1.5634 *	* 1.0469 *	
	* 1.6133 *	* 1.3050 *	* 1.5895 *	* 1.2948 *	* 1.5017 *	* 1.2998 *	* 1.9482 *	
11	* 1.5603 *	* 1.3328 *	* 1.5702 *	* 1.2891 *	* 1.5660 *	* 1.5245 *	* 0.8501 *	
	* 1.3037 *	* 1.5294 *	* 1.2949 *	* 1.5741 *	* 1.2946 *	* 1.3289 *	* 2.3915 *	
12	* 1.3541 *	* 1.6255 *	* 1.3531 *	* 1.5663 *	* 1.5928 *	* 1.0006 *		
	* 1.5039 *	* 1.2508 *	* 1.5032 *	* 1.2944 *	* 1.2700 *	* 2.0241 *		
13	* 1.1859 *	* 1.2945 *	* 1.5628 *	* 1.5249 *	* 1.0012 *			
	* 1.7226 *	* 1.5735 *	* 1.3002 *	* 1.3285 *	* 2.0228 *			
14	* 1.4235 *	* 1.4064 *	* 1.0455 *	* 0.8493 *				
	* 1.4403 *	* 1.4542 *	* 1.9507 *	* 2.3936 *				
15	* 0.8600 *	* 0.7823 *	F-SUB-Q					
	* 2.3900 *	* 2.6251 *	M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4952 *	* 1.2399 *	* 1.2266 *	* 1.5090 *	* 1.3132 *	* 1.1640 *	* 1.3741 *	* 0.8478 *
	* 1.3413 *	* 1.6206 *	* 1.6375 *	* 1.3301 *	* 1.5302 *	* 1.7300 *	* 1.4737 *	* 2.3919 *
9	* 1.2398 *	* 1.3462 *	* 1.5098 *	* 1.2966 *	* 1.5727 *	* 1.2595 *	* 1.3572 *	* 0.7927 *
	* 1.6206 *	* 1.4939 *	* 1.3309 *	* 1.5500 *	* 1.2761 *	* 1.5962 *	* 1.4886 *	* 2.5558 *
10	* 1.2266 *	* 1.5101 *	* 1.2486 *	* 1.5184 *	* 1.3167 *	* 1.5092 *	* 1.0433 *	
	* 1.6375 *	* 1.3306 *	* 1.6134 *	* 1.3212 *	* 1.5239 *	* 1.3293 *	* 1.9293 *	
11	* 1.5090 *	* 1.2961 *	* 1.5183 *	* 1.2513 *	* 1.5130 *	* 1.4699 *	* 0.8552 *	
	* 1.3301 *	* 1.5506 *	* 1.3212 *	* 1.5987 *	* 1.3214 *	* 1.3606 *	* 2.3436 *	
12	* 1.3132 *	* 1.5712 *	* 1.3154 *	* 1.5134 *	* 1.5373 *	* 1.0079 *		
	* 1.5302 *	* 1.2774 *	* 1.5253 *	* 1.3212 *	* 1.2987 *	* 1.9812 *		
13	* 1.1640 *	* 1.2560 *	* 1.5089 *	* 1.4705 *	* 1.0082 *			
	* 1.7300 *	* 1.6003 *	* 1.3295 *	* 1.3600 *	* 1.9806 *			
14	* 1.3741 *	* 1.3559 *	* 1.0422 *	* 0.8541 *				
	* 1.4737 *	* 1.4899 *	* 1.9313 *	* 2.3464 *				
15	* 0.8478 *	* 0.7852 *	F-SUB-Q					
	* 2.3919 *	* 2.5801 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 67 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5241	* 1.2348	* 1.2373	* 1.5355	* 1.3266	* 1.1586	* 1.4030	* 0.8440 *
	* 1.3008	* 1.6074	* 1.6041	* 1.2908	* 1.4960	* 1.7182	* 1.4250	* 2.3732 *
9	* 1.2348	* 1.3454	* 1.5376	* 1.3056	* 1.6025	* 1.2725	* 1.3872	* 0.7781 *
	* 1.6074	* 1.4757	* 1.2907	* 1.5206	* 1.2368	* 1.5604	* 1.4379	* 2.5723 *
10	* 1.2373	* 1.5379	* 1.2589	* 1.5447	* 1.3264	* 1.5398	* 1.0289	*
	* 1.6041	* 1.2904	* 1.5809	* 1.2824	* 1.4940	* 1.2868	* 1.9328	*
11	* 1.5355	* 1.3051	* 1.5447	* 1.2622	* 1.5409	* 1.5027	* 0.8362	*
	* 1.2908	* 1.5212	* 1.2824	* 1.5657	* 1.2806	* 1.3144	* 2.3671	*
12	* 1.3266	* 1.6012	* 1.3252	* 1.5414	* 1.5715	* 0.9876	*	
	* 1.4960	* 1.2378	* 1.4954	* 1.2803	* 1.2547	* 1.9982	*	
13	* 1.1586	* 1.2689	* 1.5396	* 1.5035	* 0.9884	*		
	* 1.7182	* 1.5648	* 1.2866	* 1.3137	* 1.9965	*		
14	* 1.4030	* 1.3860	* 1.0280	* 0.8354	*			
	* 1.4250	* 1.4391	* 1.9346	* 2.3692	*			
15	* 0.8440	* 0.7724	* F-SUB-Q					
	* 2.3732	* 2.5911	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5206	* 1.2291	* 1.2311	* 1.5302	* 1.3192	* 1.1510	* 1.3983	* 0.8408 *
	* 1.2937	* 1.6011	* 1.5977	* 1.2849	* 1.4918	* 1.7134	* 1.4174	* 2.3567 *
9	* 1.2291	* 1.3408	* 1.5332	* 1.2986	* 1.5969	* 1.2656	* 1.3822	* 0.7780 *
	* 1.6011	* 1.4681	* 1.2837	* 1.5153	* 1.2316	* 1.5555	* 1.4306	* 2.5449 *
10	* 1.2311	* 1.5336	* 1.2519	* 1.5388	* 1.3190	* 1.5344	* 1.0262	*
	* 1.5977	* 1.2834	* 1.5752	* 1.2769	* 1.4897	* 1.2813	* 1.9202	*
11	* 1.5302	* 1.2980	* 1.5390	* 1.2555	* 1.5360	* 1.4976	* 0.8349	*
	* 1.2849	* 1.5159	* 1.2767	* 1.5603	* 1.2745	* 1.3086	* 2.3501	*
12	* 1.3192	* 1.5957	* 1.3178	* 1.5364	* 1.5673	* 0.9874	*	
	* 1.4918	* 1.2325	* 1.4909	* 1.2741	* 1.2484	* 1.9813	*	
13	* 1.1510	* 1.2620	* 1.5343	* 1.4986	* 0.9882	*		
	* 1.7134	* 1.5598	* 1.2808	* 1.3077	* 1.9797	*		
14	* 1.3983	* 1.3811	* 1.0252	* 0.8342	*			
	* 1.4174	* 1.4317	* 1.9219	* 2.3520	*			
15	* 0.8408	* 0.7714	* F-SUB-Q					
	* 2.3567	* 2.5667	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 68 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4986	* 1.2277	* 1.2122	* 1.5035	* 1.2974	* 1.1459	* 1.3724	* 0.8365 *
	* 1.3209	* 1.6135	* 1.6322	* 1.3144	* 1.5245	* 1.7290	* 1.4482	* 2.3759 *
9	* 1.2277	* 1.3380	* 1.5068	* 1.2795	* 1.5683	* 1.2452	* 1.3555	* 0.7832 *
	* 1.6135	* 1.4802	* 1.3127	* 1.5460	* 1.2598	* 1.5883	* 1.4635	* 2.5362 *
10	* 1.2122	* 1.5072	* 1.2324	* 1.5116	* 1.2994	* 1.5058	* 1.0278	*
	* 1.6322	* 1.3124	* 1.6084	* 1.3062	* 1.5198	* 1.3112	* 1.9258	*
11	* 1.5035	* 1.2790	* 1.5118	* 1.2359	* 1.5093	* 1.4691	* 0.8416	*
	* 1.3144	* 1.5466	* 1.3059	* 1.5935	* 1.3033	* 1.3404	* 2.3439	*
12	* 1.2974	* 1.5672	* 1.2983	* 1.5098	* 1.5387	* 0.9974	*	
	* 1.5245	* 1.2607	* 1.5210	* 1.3029	* 1.2778	* 1.9725	*	
13	* 1.1459	* 1.2418	* 1.5059	* 1.4702	* 0.9980	*		
	* 1.7290	* 1.5926	* 1.3104	* 1.3394	* 1.9713	*		
14	* 1.3724	* 1.3545	* 1.0269	* 0.8408	*			
	* 1.4482	* 1.4647	* 1.9274	* 2.3460	*			
15	* 0.8365	* 0.7755	* F-SUB-Q					
	* 2.3759	* 2.5614	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5331	* 1.2253	* 1.2273	* 1.5352	* 1.3153	* 1.1441	* 1.4072	* 0.8372 *
	* 1.3191	* 1.6514	* 1.6462	* 1.3134	* 1.5339	* 1.7655	* 1.4359	* 2.4141 *
9	* 1.2253	* 1.3415	* 1.5398	* 1.2930	* 1.6035	* 1.2632	* 1.3913	* 0.7728 *
	* 1.6514	* 1.5066	* 1.3105	* 1.5610	* 1.2565	* 1.5958	* 1.4511	* 2.6150 *
10	* 1.2273	* 1.5402	* 1.2477	* 1.5430	* 1.3137	* 1.5423	* 1.0183	*
	* 1.6462	* 1.3102	* 1.6198	* 1.3050	* 1.5333	* 1.3042	* 1.9806	*
11	* 1.5352	* 1.2925	* 1.5434	* 1.2519	* 1.5441	* 1.5086	* 0.8275	*
	* 1.3134	* 1.5617	* 1.3047	* 1.6048	* 1.2992	* 1.3307	* 2.4310	*
12	* 1.3153	* 1.6025	* 1.3126	* 1.5447	* 1.5799	* 0.9836	*	
	* 1.5339	* 1.2572	* 1.5345	* 1.2987	* 1.2690	* 2.0407	*	
13	* 1.1441	* 1.2597	* 1.5427	* 1.5099	* 0.9848	*		
	* 1.7655	* 1.6004	* 1.3032	* 1.3295	* 2.0381	*		
14	* 1.4072	* 1.3903	* 1.0176	* 0.8270	*			
	* 1.4359	* 1.4521	* 1.9820	* 2.4324	*			
15	* 0.8372	* 0.7656	* F-SUB-Q					
	* 2.4141	* 2.6395	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 69 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5495	* 1.2321	* 1.2342	* 1.5494	* 1.3227	* 1.1487	* 1.4226	* 0.8402 *
	* 1.3182	* 1.6521	* 1.6496	* 1.3172	* 1.5404	* 1.7674	* 1.4299	* 2.4003 *
9	* 1.2321	* 1.3514	* 1.5551	* 1.2991	* 1.6189	* 1.2711	* 1.4069	* 0.7714 *
	* 1.6521	* 1.5094	* 1.3129	* 1.5684	* 1.2612	* 1.5994	* 1.4448	* 2.6131 *
10	* 1.2342	* 1.5555	* 1.2546	* 1.5568	* 1.3200	* 1.5583	* 1.0181	*
	* 1.6496	* 1.3125	* 1.6240	* 1.3099	* 1.5419	* 1.3064	* 1.9898	*
11	* 1.5494	* 1.2986	* 1.5573	* 1.2594	* 1.5604	* 1.5263	* 0.8246	*
	* 1.3172	* 1.5689	* 1.3095	* 1.6115	* 1.3033	* 1.3315	* 2.4438	*
12	* 1.3227	* 1.6181	* 1.3190	* 1.5610	* 1.5993	* 0.9840	*	
	* 1.5404	* 1.2617	* 1.5430	* 1.3028	* 1.2712	* 2.0546	*	
13	* 1.1487	* 1.2676	* 1.5595	* 1.5279	* 0.9859	*		
	* 1.7674	* 1.6037	* 1.3051	* 1.3302	* 2.0508	*		
14	* 1.4226	* 1.4060	* 1.0172	* 0.8243	*			
	* 1.4299	* 1.4456	* 1.9914	* 2.4448	*			
15	* 0.8402	* 0.7641	* F-SUB-Q					
	* 2.4003	* 2.6376	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5616	* 1.2374	* 1.2387	* 1.5571	* 1.3270	* 1.1510	* 1.4292	* 0.8453 *
	* 1.3103	* 1.6484	* 1.6463	* 1.3116	* 1.5361	* 1.7631	* 1.4194	* 2.3780 *
9	* 1.2374	* 1.3587	* 1.5637	* 1.3041	* 1.6271	* 1.2751	* 1.4130	* 0.7813 *
	* 1.6484	* 1.5035	* 1.3069	* 1.5640	* 1.2552	* 1.5936	* 1.4350	* 2.5717 *
10	* 1.2387	* 1.5642	* 1.2589	* 1.5644	* 1.3248	* 1.5656	* 1.0276	*
	* 1.6463	* 1.3065	* 1.6204	* 1.3044	* 1.5372	* 1.2994	* 1.9691	*
11	* 1.5571	* 1.3036	* 1.5650	* 1.2632	* 1.5686	* 1.5335	* 0.8351	*
	* 1.3116	* 1.5646	* 1.3039	* 1.6080	* 1.2969	* 1.3250	* 2.4124	*
12	* 1.3270	* 1.6264	* 1.3239	* 1.5693	* 1.6079	* 0.9969	*	
	* 1.5361	* 1.2555	* 1.5382	* 1.2964	* 1.2647	* 2.0290	*	
13	* 1.1510	* 1.2716	* 1.5673	* 1.5352	* 0.9984	*		
	* 1.7631	* 1.5978	* 1.2980	* 1.3235	* 2.0260	*		
14	* 1.4292	* 1.4122	* 1.0270	* 0.8348	*			
	* 1.4194	* 1.4357	* 1.9700	* 2.4132	*			
15	* 0.8453	* 0.7740	* F-SUB-Q					
	* 2.3780	* 2.5957	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 70 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5569	* 1.2576	* 1.2375	* 1.5506	* 1.3253	* 1.1655	* 1.4193	* 0.8540 *
	* 1.3308	* 1.6438	* 1.6687	* 1.3325	* 1.5556	* 1.7625	* 1.4397	* 2.3690 *
9	* 1.2576	* 1.3781	* 1.5576	* 1.3044	* 1.6189	* 1.2722	* 1.4019	* 0.8013 *
	* 1.6438	* 1.5013	* 1.3281	* 1.5829	* 1.2753	* 1.6133	* 1.4572	* 2.5242 *
10	* 1.2375	* 1.5581	* 1.2578	* 1.5576	* 1.3246	* 1.5566	* 1.0476	*
	* 1.6687	* 1.3276	* 1.6423	* 1.3251	* 1.5548	* 1.3197	* 1.9482	*
11	* 1.5506	* 1.3039	* 1.5583	* 1.2620	* 1.5623	* 1.5226	* 0.8573	*
	* 1.3325	* 1.5834	* 1.3245	* 1.6280	* 1.3162	* 1.3475	* 2.3715	*
12	* 1.3253	* 1.6183	* 1.3238	* 1.5630	* 1.5984	* 1.0244	*	
	* 1.5556	* 1.2755	* 1.5558	* 1.3156	* 1.2855	* 1.9949	*	
13	* 1.1655	* 1.2700	* 1.5584	* 1.5244	* 1.0255	*		
	* 1.7625	* 1.6173	* 1.3182	* 1.3459	* 1.9929	*		
14	* 1.4193	* 1.4011	* 1.0471	* 0.8570	*			
	* 1.4397	* 1.4579	* 1.9491	* 2.3724	*			
15	* 0.8540	* 0.7928	* F-SUB-Q					
	* 2.3690	* 2.5508	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6219	* 1.2738	* 1.2755	* 1.6144	* 1.3668	* 1.1819	* 1.4835	* 0.8668 *
	* 1.2953	* 1.6444	* 1.6415	* 1.2984	* 1.5307	* 1.7614	* 1.3987	* 2.3666 *
9	* 1.2738	* 1.4039	* 1.6232	* 1.3420	* 1.6881	* 1.3139	* 1.4670	* 0.7972 *
	* 1.6444	* 1.4938	* 1.2922	* 1.5602	* 1.2414	* 1.5865	* 1.4141	* 2.5727 *
10	* 1.2755	* 1.6238	* 1.2965	* 1.6218	* 1.3636	* 1.6269	* 1.0506	*
	* 1.6415	* 1.2918	* 1.6152	* 1.2916	* 1.5331	* 1.2831	* 1.9742	*
11	* 1.6144	* 1.3416	* 1.6226	* 1.3022	* 1.6310	* 1.5952	* 0.8511	*
	* 1.2984	* 1.5607	* 1.2909	* 1.6023	* 1.2809	* 1.3073	* 2.4287	*
12	* 1.3668	* 1.6876	* 1.3628	* 1.6318	* 1.6752	* 1.0223	*	
	* 1.5307	* 1.2415	* 1.5340	* 1.2802	* 1.2464	* 2.0322	*	
13	* 1.1819	* 1.3104	* 1.6291	* 1.5973	* 1.0244	*		
	* 1.7614	* 1.5907	* 1.2813	* 1.3056	* 2.0281	*		
14	* 1.4835	* 1.4662	* 1.0499	* 0.8508	*			
	* 1.3987	* 1.4148	* 1.9755	* 2.4295	*			
15	* 0.8668	* 0.7896	* F-SUB-Q					
	* 2.3666	* 2.5975	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 71 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6528	* 1.2938	* 1.2961	* 1.6448	* 1.3901	* 1.1997	* 1.5124	* 0.8812 *
	* 1.2675	* 1.6148	* 1.6110	* 1.2700	* 1.4993	* 1.7275	* 1.3661	* 2.3239 *
9	* 1.2938	* 1.4291	* 1.6540	* 1.3643	* 1.7206	* 1.3369	* 1.4956	* 0.8110 *
	* 1.6148	* 1.4637	* 1.2645	* 1.5300	* 1.2129	* 1.5522	* 1.3813	* 2.5242 *
10	* 1.2961	* 1.6546	* 1.3180	* 1.6526	* 1.3868	* 1.6603	* 1.0679	*
	* 1.6110	* 1.2640	* 1.5846	* 1.2629	* 1.5018	* 1.2515	* 1.9331	*
11	* 1.6448	* 1.3639	* 1.6535	* 1.3249	* 1.6654	* 1.6287	* 0.8649	*
	* 1.2700	* 1.5305	* 1.2621	* 1.5689	* 1.2492	* 1.2747	* 2.3802	*
12	* 1.3901	* 1.7204	* 1.3860	* 1.6663	* 1.7120	* 1.0424	*	
	* 1.4993	* 1.2129	* 1.5026	* 1.2485	* 1.2145	* 1.9844	*	
13	* 1.1997	* 1.3333	* 1.6627	* 1.6310	* 1.0446	*		
	* 1.7275	* 1.5563	* 1.2497	* 1.2729	* 1.9802	*		
14	* 1.5124	* 1.4947	* 1.0672	* 0.8648	*			
	* 1.3661	* 1.3820	* 1.9343	* 2.3805	*			
15	* 0.8812	* 0.8027	* F-SUB-Q					
	* 2.3239	* 2.5503	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6821	* 1.3154	* 1.3171	* 1.6708	* 1.4150	* 1.2186	* 1.5332	* 0.8951 *
	* 1.2465	* 1.5903	* 1.5872	* 1.2506	* 1.4730	* 1.6993	* 1.3436	* 2.2793 *
9	* 1.3154	* 1.4535	* 1.6840	* 1.3884	* 1.7485	* 1.3606	* 1.5165	* 0.8400 *
	* 1.5903	* 1.4407	* 1.2430	* 1.5050	* 1.1933	* 1.5235	* 1.3582	* 2.4281 *
10	* 1.3171	* 1.6846	* 1.3397	* 1.6791	* 1.4119	* 1.6857	* 1.0880	*
	* 1.5872	* 1.2426	* 1.5607	* 1.2433	* 1.4752	* 1.2309	* 1.8933	*
11	* 1.6708	* 1.3880	* 1.6801	* 1.3471	* 1.6929	* 1.6536	* 0.8802	*
	* 1.2506	* 1.5054	* 1.2426	* 1.5428	* 1.2281	* 1.2533	* 2.3341	*
12	* 1.4150	* 1.7483	* 1.4111	* 1.6938	* 1.7389	* 1.0695	*	
	* 1.4730	* 1.1932	* 1.4759	* 1.2274	* 1.1942	* 1.9316	*	
13	* 1.2186	* 1.3569	* 1.6882	* 1.6560	* 1.0713	*		
	* 1.6993	* 1.5275	* 1.2291	* 1.2516	* 1.9283	*		
14	* 1.5332	* 1.5154	* 1.0873	* 0.8803	*			
	* 1.3436	* 1.3591	* 1.8944	* 2.3337	*			
15	* 0.8951	* 0.8168	* F-SUB-Q					
	* 2.2793	* 2.4972	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 72 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6919	* 1.3256	* 1.3245	* 1.6779	* 1.4274	* 1.2281	* 1.5268	* 0.8980 *
	* 1.2411	* 1.5811	* 1.5815	* 1.2479	* 1.4615	* 1.6869	* 1.3464	* 2.2659 *
9	* 1.3256	* 1.4636	* 1.6887	* 1.4011	* 1.7518	* 1.3714	* 1.5115	* 0.8403 *
	* 1.5811	* 1.4337	* 1.2425	* 1.4938	* 1.1909	* 1.5109	* 1.3600	* 2.4204 *
10	* 1.3245	* 1.6899	* 1.3477	* 1.6860	* 1.4254	* 1.6821	* 1.0987	*
	* 1.5815	* 1.2416	* 1.5547	* 1.2401	* 1.4625	* 1.2325	* 1.8721	*
11	* 1.6779	* 1.4007	* 1.6871	* 1.3540	* 1.6914	* 1.6486	* 0.8860	*
	* 1.2479	* 1.4942	* 1.2393	* 1.5362	* 1.2290	* 1.2560	* 2.3154	*
12	* 1.4274	* 1.7495	* 1.4247	* 1.6926	* 1.7323	* 1.0762	*	
	* 1.4615	* 1.1928	* 1.4632	* 1.2283	* 1.1983	* 1.9176	*	
13	* 1.2281	* 1.3677	* 1.6845	* 1.6509	* 1.0779	*		
	* 1.6869	* 1.5148	* 1.2308	* 1.2543	* 1.9146	*		
14	* 1.5268	* 1.5103	* 1.0979	* 0.8850	*			
	* 1.3464	* 1.3610	* 1.8734	* 2.3180	*			
15	* 0.8980	* 0.8217	* F-SUB-Q					
	* 2.2659	* 2.4754	* M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6457	* 1.3048	* 1.2954	* 1.6310	* 1.4008	* 1.2047	* 1.4785	* 0.8681 *
	* 1.2719	* 1.6018	* 1.6141	* 1.2830	* 1.4878	* 1.7169	* 1.3856	* 2.3345 *
9	* 1.3048	* 1.4324	* 1.6389	* 1.3753	* 1.7034	* 1.3449	* 1.4595	* 0.8149 *
	* 1.6018	* 1.4606	* 1.2773	* 1.5214	* 1.2229	* 1.5377	* 1.4035	* 2.4861 *
10	* 1.2954	* 1.6400	* 1.3176	* 1.6382	* 1.3992	* 1.6314	* 1.0700	*
	* 1.6141	* 1.2765	* 1.5873	* 1.2753	* 1.4884	* 1.2685	* 1.9167	*
11	* 1.6310	* 1.3750	* 1.6392	* 1.3195	* 1.6363	* 1.5898	* 0.8644	*
	* 1.2830	* 1.5217	* 1.2745	* 1.5745	* 1.2682	* 1.2990	* 2.3663	*
12	* 1.4008	* 1.7006	* 1.3984	* 1.6376	* 1.6686	* 1.0458	*	
	* 1.4878	* 1.2251	* 1.4892	* 1.2672	* 1.2410	* 1.9686	*	
13	* 1.2047	* 1.3412	* 1.6323	* 1.5917	* 1.0472	*		
	* 1.7169	* 1.5418	* 1.2677	* 1.2975	* 1.9660	*		
14	* 1.4785	* 1.4581	* 1.0691	* 0.8632	*			
	* 1.3856	* 1.4048	* 1.9183	* 2.3697	*			
15	* 0.8681	* 0.7990	* F-SUB-Q					
	* 2.3345	* 2.5360	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 73 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 100% POWER, 475 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4102 *	* 1.1635 *	* 1.1367 *	* 1.3997 *	* 1.2438 *	* 1.0606 *	* 1.2701 *	* 0.7447 *
	* 1.4736 *	* 1.7844 *	* 1.8267 *	* 1.4856 *	* 1.6681 *	* 1.9403 *	* 1.6026 *	* 2.7046 *
9	* 1.1635 *	* 1.2680 *	* 1.3974 *	* 1.2138 *	* 1.4612 *	* 1.1898 *	* 1.2553 *	* 0.7049 *
	* 1.7844 *	* 1.6384 *	* 1.4871 *	* 1.7123 *	* 1.4196 *	* 1.7298 *	* 1.6216 *	* 2.8568 *
10	* 1.1367 *	* 1.3984 *	* 1.1552 *	* 1.4052 *	* 1.2336 *	* 1.3988 *	* 0.9308 *	
	* 1.8267 *	* 1.4861 *	* 1.7978 *	* 1.4797 *	* 1.6807 *	* 1.4712 *	* 2.1902 *	
11	* 1.3997 *	* 1.2136 *	* 1.4059 *	* 1.1532 *	* 1.3933 *	* 1.3600 *	* 0.7584 *	
	* 1.4856 *	* 1.7126 *	* 1.4792 *	* 1.7981 *	* 1.4844 *	* 1.5097 *	* 2.6819 *	
12	* 1.2438 *	* 1.4601 *	* 1.2329 *	* 1.3943 *	* 1.4113 *	* 0.9087 *		
	* 1.6681 *	* 1.4209 *	* 1.6816 *	* 1.4834 *	* 1.4589 *	* 2.2532 *		
13	* 1.0606 *	* 1.1864 *	* 1.3992 *	* 1.3613 *	* 0.9094 *			
	* 1.9403 *	* 1.7344 *	* 1.4707 *	* 1.5082 *	* 2.2514 *			
14	* 1.2701 *	* 1.2540 *	* 0.9301 *	* 0.7571 *				
	* 1.6026 *	* 1.6232 *	* 2.1918 *	* 2.6864 *				
15	* 0.7447 *	* 0.6945 *	F-SUB-Q					
	* 2.7046 *	* 2.8995 *	M-SUB-Q					

AT 100% POWER, 475 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6933 *	* 0.6231 *	* 0.6334 *	* 0.7232 *	* 0.6629 *	* 0.5893 *	* 0.6101 *	* 0.3879 *
	* 2.9685 *	* 3.3019 *	* 3.2495 *	* 2.8481 *	* 3.1019 *	* 3.4600 *	* 3.3069 *	* 5.1514 *
9	* 0.6231 *	* 0.6670 *	* 0.7206 *	* 0.6550 *	* 0.7229 *	* 0.6312 *	* 0.6011 *	* 0.3636 *
	* 3.3019 *	* 3.0856 *	* 2.8576 *	* 3.1444 *	* 2.8453 *	* 3.2316 *	* 3.3565 *	* 5.4958 *
10	* 0.6334 *	* 0.7208 *	* 0.6430 *	* 0.7256 *	* 0.6597 *	* 0.6825 *	* 0.4914 *	
	* 3.2495 *	* 2.8565 *	* 3.2014 *	* 2.8390 *	* 3.1144 *	* 2.9878 *	* 4.1136 *	
11	* 0.7232 *	* 0.6548 *	* 0.7256 *	* 0.6415 *	* 0.7119 *	* 0.6518 *	* 0.3936 *	
	* 2.8481 *	* 3.1450 *	* 2.8392 *	* 3.2090 *	* 2.8789 *	* 3.1229 *	* 5.1276 *	
12	* 0.6629 *	* 0.7219 *	* 0.6593 *	* 0.7122 *	* 0.6751 *	* 0.4785 *		
	* 3.1019 *	* 2.8490 *	* 3.1163 *	* 2.8776 *	* 3.0221 *	* 4.2431 *		
13	* 0.5893 *	* 0.6295 *	* 0.6822 *	* 0.6522 *	* 0.4786 *			
	* 3.4600 *	* 3.2398 *	* 2.9887 *	* 3.1210 *	* 4.2421 *			
14	* 0.6101 *	* 0.6003 *	* 0.4910 *	* 0.3929 *				
	* 3.3069 *	* 3.3607 *	* 4.1170 *	* 5.1366 *				
15	* 0.3879 *	* 0.3622 *	F-SUB-Q					
	* 5.1514 *	* 5.5165 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 74 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6403	* 0.5877	* 0.5402	* 0.6073	* 0.5639	* 0.4766	* 0.3354	* 0.1772
	* 3.0654	* 3.3393	* 3.6210	* 3.2226	* 3.4762	* 4.0984	* 4.3855	* 7.0092
9	* 0.5877	* 0.5639	* 0.5754	* 0.5557	* 0.5939	* 0.5087	* 0.3829	* 0.1879
	* 3.3393	* 3.4749	* 3.2824	* 3.5264	* 3.2990	* 3.8520	* 4.5072	* 7.4561
10	* 0.5402	* 0.5758	* 0.4608	* 0.5569	* 0.5316	* 0.5172	* 0.3731	*
	* 3.6210	* 3.2808	* 3.5746	* 3.4002	* 3.6754	* 3.7774	* 5.1589	*
11	* 0.6073	* 0.5523	* 0.5557	* 0.4922	* 0.5320	* 0.4716	* 0.2923	*
	* 3.2226	* 3.5482	* 3.4021	* 3.8419	* 3.6441	* 4.1200	* 6.6212	*
12	* 0.5639	* 0.5900	* 0.5299	* 0.5313	* 0.4744	* 0.3555	*	*
	* 3.4762	* 3.3202	* 3.6873	* 3.6491	* 4.0632	* 5.3995	*	*
13	* 0.4766	* 0.5059	* 0.5151	* 0.4702	* 0.3539	*	*	*
	* 4.0984	* 3.8736	* 3.7930	* 4.1323	* 5.4239	*	*	*
14	* 0.3354	* 0.3809	* 0.3712	* 0.2908	*	*	*	*
	* 4.3855	* 4.5220	* 5.1830	* 6.6560	*	*	*	*
15	* 0.1772	* 0.1863	* F-SUB-Q					
	* 7.0092	* 7.4994	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3516	* 1.1779	* 1.0488	* 1.2371	* 1.1517	* 0.9459	* 0.7704	* 0.3757
	* 1.5084	* 1.7306	* 1.9239	* 1.6428	* 1.7682	* 2.0771	* 1.9712	* 3.4862
9	* 1.1779	* 1.1491	* 1.1603	* 1.1041	* 1.2696	* 1.0378	* 0.8781	* 0.3874
	* 1.7306	* 1.7365	* 1.6776	* 1.8420	* 1.6035	* 1.9617	* 2.0183	* 3.7742
10	* 1.0488	* 1.1610	* 0.8862	* 1.1399	* 1.0811	* 1.1446	* 0.7576	*
	* 1.9239	* 1.6766	* 1.8950	* 1.7122	* 1.8756	* 1.7727	* 2.6060	*
11	* 1.2371	* 1.1004	* 1.1374	* 0.9703	* 1.0954	* 1.0526	* 0.5884	*
	* 1.6428	* 1.8484	* 1.7131	* 2.0063	* 1.8368	* 1.9160	* 3.4172	*
12	* 1.1517	* 1.2603	* 1.0776	* 1.0938	* 1.0434	* 0.6829	*	*
	* 1.7682	* 1.6155	* 1.8820	* 1.8396	* 1.9221	* 2.9156	*	*
13	* 0.9459	* 1.0317	* 1.1400	* 1.0496	* 0.6807	*	*	*
	* 2.0771	* 1.9742	* 1.7801	* 1.9216	* 2.9254	*	*	*
14	* 0.7704	* 0.8735	* 0.7535	* 0.5852	*	*	*	*
	* 1.9712	* 2.0249	* 2.6188	* 3.4361	*	*	*	*
15	* 0.3757	* 0.3807	* F-SUB-Q					
	* 3.4862	* 3.8282	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 75 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4290	* 1.3602	* 1.2217	* 1.3506	* 1.3249	* 1.1380	* 0.9721	* 0.4856 *
	* 1.4877	* 1.5621	* 1.7187	* 1.5717	* 1.6036	* 1.7912	* 1.7483	* 2.9785 *
9	* 1.3602	* 1.3404	* 1.2528	* 1.2772	* 1.3618	* 1.2151	* 1.0545	* 0.4861 *
	* 1.5621	* 1.5783	* 1.6574	* 1.6647	* 1.5619	* 1.7265	* 1.7666	* 3.2139 *
10	* 1.2217	* 1.2552	* 1.0301	* 1.2365	* 1.2519	* 1.2800	* 0.9291	*
	* 1.7187	* 1.6551	* 1.7139	* 1.6327	* 1.6905	* 1.6475	* 2.2097	*
11	* 1.3506	* 1.2678	* 1.2332	* 1.1360	* 1.1875	* 1.2353	* 0.7054	*
	* 1.5717	* 1.6706	* 1.6350	* 1.7879	* 1.7661	* 1.6957	* 2.9654	*
12	* 1.3249	* 1.3498	* 1.2472	* 1.1847	* 1.1982	* 0.7902	*	
	* 1.6036	* 1.5761	* 1.6971	* 1.7704	* 1.7397	* 2.6135	*	
13	* 1.1380	* 1.2082	* 1.2750	* 1.2314	* 0.7882	*		
	* 1.7912	* 1.7393	* 1.6543	* 1.7013	* 2.6204	*		
14	* 0.9721	* 1.0487	* 0.9238	* 0.7015	*			
	* 1.7483	* 1.7728	* 2.2215	* 2.9823	*			
15	* 0.4856	* 0.4804	* F-SUB-Q					
	* 2.9785	* 3.2521	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6137	* 1.5137	* 1.3645	* 1.5320	* 1.4877	* 1.3033	* 1.2092	* 0.6046 *
	* 1.3893	* 1.4815	* 1.6241	* 1.4632	* 1.4934	* 1.6560	* 1.5633	* 2.7599 *
9	* 1.5137	* 1.5039	* 1.4350	* 1.4154	* 1.5529	* 1.3818	* 1.2711	* 0.5832 *
	* 1.4815	* 1.4843	* 1.5340	* 1.5722	* 1.4434	* 1.5978	* 1.5781	* 3.0313 *
10	* 1.3645	* 1.4376	* 1.1722	* 1.4205	* 1.4073	* 1.4778	* 1.0550	*
	* 1.6241	* 1.5310	* 1.6627	* 1.5152	* 1.5861	* 1.5053	* 2.0620	*
11	* 1.5320	* 1.4094	* 1.4163	* 1.2547	* 1.3550	* 1.4154	* 0.7689	*
	* 1.4632	* 1.5786	* 1.5177	* 1.7143	* 1.6307	* 1.5548	* 2.8618	*
12	* 1.4877	* 1.5388	* 1.4016	* 1.3514	* 1.3592	* 0.8480	*	
	* 1.4934	* 1.4567	* 1.5922	* 1.6352	* 1.6134	* 2.5513	*	
13	* 1.3033	* 1.3714	* 1.4694	* 1.4105	* 0.8462	*		
	* 1.6560	* 1.6117	* 1.5123	* 1.5604	* 2.5568	*		
14	* 1.2092	* 1.2637	* 1.0482	* 0.7641	*			
	* 1.5633	* 1.5842	* 2.0746	* 2.8802	*			
15	* 0.6046	* 0.5764	* F-SUB-Q					
	* 2.7599	* 3.0776	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 76 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6971	* 1.5767	* 1.4335	* 1.6265	* 1.5787	* 1.3985	* 1.3985	* 0.7433 *
	* 1.4087	* 1.5085	* 1.6472	* 1.4582	* 1.4908	* 1.6574	* 1.5425	* 2.7372 *
9	* 1.5767	* 1.5719	* 1.5220	* 1.4909	* 1.6480	* 1.4714	* 1.4170	* 0.6973 *
	* 1.5085	* 1.5052	* 1.5459	* 1.5857	* 1.4392	* 1.5968	* 1.5576	* 3.0035 *
10	* 1.4335	* 1.5251	* 1.3318	* 1.5315	* 1.4904	* 1.5771	* 1.1451	*
	* 1.6472	* 1.5426	* 1.6726	* 1.5126	* 1.5861	* 1.5009	* 2.0315	*
11	* 1.6265	* 1.4841	* 1.5276	* 1.3444	* 1.4406	* 1.5054	* 0.8174	*
	* 1.4582	* 1.5929	* 1.5156	* 1.7130	* 1.6321	* 1.5499	* 2.8586	*
12	* 1.5787	* 1.6319	* 1.4838	* 1.4365	* 1.4422	* 0.8945	*	
	* 1.4908	* 1.4536	* 1.5931	* 1.6371	* 1.6145	* 2.5552	*	
13	* 1.3985	* 1.4593	* 1.5674	* 1.4997	* 0.8927	*		
	* 1.6574	* 1.6119	* 1.5087	* 1.5561	* 2.5606	*		
14	* 1.3985	* 1.4084	* 1.1375	* 0.8123	*			
	* 1.5425	* 1.5644	* 2.0448	* 2.8771	*			
15	* 0.7433	* 0.6878	* F-SUB-Q					
	* 2.7372	* 3.0436	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7561	* 1.6248	* 1.4884	* 1.7001	* 1.6544	* 1.4751	* 1.5538	* 0.8581 *
	* 1.4201	* 1.5313	* 1.6720	* 1.4580	* 1.4913	* 1.6667	* 1.5420	* 2.7476 *
9	* 1.6248	* 1.6237	* 1.5880	* 1.5529	* 1.7226	* 1.5443	* 1.5502	* 0.7886 *
	* 1.5313	* 1.5271	* 1.5666	* 1.5970	* 1.4392	* 1.5947	* 1.5557	* 3.0047 *
10	* 1.4884	* 1.5915	* 1.4529	* 1.6235	* 1.5584	* 1.6548	* 1.2169	*
	* 1.6720	* 1.5630	* 1.6926	* 1.5191	* 1.5868	* 1.4894	* 2.0175	*
11	* 1.7001	* 1.5453	* 1.6198	* 1.4309	* 1.5088	* 1.5748	* 0.8563	*
	* 1.4580	* 1.6050	* 1.5225	* 1.7192	* 1.6325	* 1.5492	* 2.8510	*
12	* 1.6544	* 1.7051	* 1.5510	* 1.5051	* 1.5076	* 0.9328	*	
	* 1.4913	* 1.4543	* 1.5947	* 1.6379	* 1.6198	* 2.5742	*	
13	* 1.4751	* 1.5308	* 1.6439	* 1.5684	* 0.9309	*		
	* 1.6667	* 1.6090	* 1.4981	* 1.5558	* 2.5797	*		
14	* 1.5538	* 1.5428	* 1.2083	* 0.8507	*			
	* 1.5420	* 1.5631	* 2.0319	* 2.8703	*			
15	* 0.8581	* 0.7786	* F-SUB-Q					
	* 2.7476	* 3.0429	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 77 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8263	* 1.6858	* 1.5465	* 1.7826	* 1.7346	* 1.5492	* 1.6733	* 0.9211 *
	* 1.4198	* 1.5404	* 1.6814	* 1.4477	* 1.4835	* 1.6592	* 1.5234	* 2.7557 *
9	* 1.6858	* 1.6940	* 1.6630	* 1.6184	* 1.8103	* 1.6211	* 1.6639	* 0.8405 *
	* 1.5404	* 1.5314	* 1.5632	* 1.5982	* 1.4258	* 1.5831	* 1.5344	* 3.0225 *
10	* 1.5465	* 1.6668	* 1.5154	* 1.7150	* 1.6298	* 1.7458	* 1.2715	*
	* 1.6814	* 1.5595	* 1.7148	* 1.5068	* 1.5789	* 1.4645	* 2.0153	*
11	* 1.7826	* 1.6100	* 1.7108	* 1.4982	* 1.5861	* 1.6556	* 0.8817	*
	* 1.4477	* 1.6068	* 1.5105	* 1.7280	* 1.6116	* 1.5327	* 2.8780	*
12	* 1.7346	* 1.7914	* 1.6212	* 1.5820	* 1.5835	* 0.9612	*	
	* 1.4836	* 1.4413	* 1.5875	* 1.6170	* 1.6037	* 2.6015	*	
13	* 1.5492	* 1.6058	* 1.7335	* 1.6485	* 0.9594	*		
	* 1.6592	* 1.5982	* 1.4738	* 1.5395	* 2.6065	*		
14	* 1.6733	* 1.6557	* 1.2620	* 0.8753	*			
	* 1.5234	* 1.5421	* 2.0303	* 2.8992	*			
15	* 0.9211	* 0.8281	* F-SUB-Q					
	* 2.7557	* 3.0673	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8565	* 1.7141	* 1.5741	* 1.8244	* 1.7791	* 1.5891	* 1.7344	* 0.9550 *
	* 1.4551	* 1.5764	* 1.7184	* 1.4715	* 1.5026	* 1.6837	* 1.5420	* 2.7908 *
9	* 1.7141	* 1.7298	* 1.6955	* 1.6516	* 1.8542	* 1.6641	* 1.7221	* 0.8708 *
	* 1.5764	* 1.5638	* 1.5953	* 1.6278	* 1.4474	* 1.6004	* 1.5519	* 3.0621 *
10	* 1.5741	* 1.6996	* 1.5485	* 1.7590	* 1.6679	* 1.7936	* 1.3072	*
	* 1.7184	* 1.5914	* 1.7540	* 1.5284	* 1.6030	* 1.4804	* 2.0356	*
11	* 1.8244	* 1.6425	* 1.7544	* 1.5365	* 1.6261	* 1.6988	* 0.9015	*
	* 1.4715	* 1.6370	* 1.5325	* 1.7554	* 1.6324	* 1.5517	* 2.9201	*
12	* 1.7791	* 1.8342	* 1.6585	* 1.6216	* 1.6230	* 0.9823	*	
	* 1.5026	* 1.4636	* 1.6121	* 1.6383	* 1.6241	* 2.6506	*	
13	* 1.5891	* 1.6474	* 1.7802	* 1.6911	* 0.9805	*		
	* 1.6837	* 1.6165	* 1.4902	* 1.5590	* 2.6555	*		
14	* 1.7344	* 1.7132	* 1.2970	* 0.8946	*			
	* 1.5420	* 1.5601	* 2.0516	* 2.9426	*			
15	* 0.9550	* 0.8582	* F-SUB-Q					
	* 2.7908	* 3.1069	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 78 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9070	* 1.7538	* 1.6100	* 1.8840	* 1.8344	* 1.6352	* 1.8049	* 0.9800 *
	* 1.4803	* 1.6118	* 1.7568	* 1.4896	* 1.5225	* 1.7069	* 1.5382	* 2.8257 *
9	* 1.7538	* 1.7751	* 1.7473	* 1.6929	* 1.9184	* 1.7163	* 1.7921	* 0.8895 *
	* 1.6118	* 1.5914	* 1.6181	* 1.6599	* 1.4621	* 1.6196	* 1.5499	* 3.1130 *
10	* 1.6100	* 1.7515	* 1.5705	* 1.8176	* 1.7148	* 1.8614	* 1.3338	*
	* 1.7568	* 1.6142	* 1.7925	* 1.5435	* 1.6267	* 1.4865	* 2.0798	*
11	* 1.8840	* 1.6831	* 1.8125	* 1.5641	* 1.6820	* 1.7594	* 0.9107	*
	* 1.4896	* 1.6697	* 1.5479	* 1.7985	* 1.6386	* 1.5592	* 3.0030	*
12	* 1.8344	* 1.8973	* 1.7045	* 1.6772	* 1.6793	* 0.9969	*	
	* 1.5225	* 1.4787	* 1.6366	* 1.6447	* 1.6326	* 2.7244	*	
13	* 1.6352	* 1.6984	* 1.8467	* 1.7510	* 0.9951	*		
	* 1.7069	* 1.6367	* 1.4969	* 1.5667	* 2.7289	*		
14	* 1.8049	* 1.7825	* 1.3226	* 0.9043	*			
	* 1.5382	* 1.5583	* 2.0972	* 3.0238	*			
15	* 0.9800	* 0.8731	* F-SUB-Q					
	* 2.8257	* 3.1708	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8577	* 1.7192	* 1.5811	* 1.8427	* 1.8083	* 1.6123	* 1.7707	* 0.9807 *
	* 1.5894	* 1.7187	* 1.8687	* 1.5894	* 1.6122	* 1.8096	* 1.6417	* 2.9506 *
9	* 1.7192	* 1.7419	* 1.6980	* 1.6754	* 1.8725	* 1.6915	* 1.7558	* 0.9021 *
	* 1.7187	* 1.6974	* 1.7407	* 1.7516	* 1.5620	* 1.7126	* 1.6570	* 3.2081 *
10	* 1.5811	* 1.7026	* 1.5724	* 1.7780	* 1.6914	* 1.8229	* 1.3422	*
	* 1.8687	* 1.7360	* 1.8839	* 1.6428	* 1.7218	* 1.5797	* 2.1544	*
11	* 1.8427	* 1.6583	* 1.7727	* 1.5690	* 1.6471	* 1.7223	* 0.9263	*
	* 1.5894	* 1.7698	* 1.6484	* 1.8718	* 1.7493	* 1.6650	* 3.0813	*
12	* 1.8083	* 1.8507	* 1.6809	* 1.6421	* 1.6427	* 1.0108	*	
	* 1.6122	* 1.5812	* 1.7326	* 1.7559	* 1.7444	* 2.8129	*	
13	* 1.6123	* 1.6732	* 1.8096	* 1.7135	* 1.0085	*		
	* 1.8096	* 1.7312	* 1.5911	* 1.6732	* 2.8187	*		
14	* 1.7707	* 1.7458	* 1.3308	* 0.9188	*			
	* 1.6417	* 1.6664	* 2.1726	* 3.1054	*			
15	* 0.9807	* 0.8883	* F-SUB-Q					
	* 2.9506	* 3.2573	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 79 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9107	* 1.7562	* 1.6116	* 1.9033	* 1.8598	* 1.6532	* 1.8405	* 0.9928 *
	* 1.6264	* 1.7700	* 1.9289	* 1.6173	* 1.6460	* 1.8497	* 1.6491	* 3.0389 *
9	* 1.7562	* 1.7833	* 1.7542	* 1.7016	* 1.9413	* 1.7415	* 1.8268	* 0.9026 *
	* 1.7700	* 1.7406	* 1.7702	* 1.8109	* 1.5833	* 1.7453	* 1.6620	* 3.3414 *
10	* 1.6116	* 1.7586	* 1.5774	* 1.8367	* 1.7325	* 1.8924	* 1.3513	*
	* 1.9289	* 1.7657	* 1.9552	* 1.6679	* 1.7638	* 1.5990	* 2.2399	*
11	* 1.9033	* 1.6908	* 1.8308	* 1.5777	* 1.7059	* 1.7873	* 0.9193	*
	* 1.6173	* 1.8224	* 1.6738	* 1.9519	* 1.7737	* 1.6864	* 3.2575	*
12	* 1.8598	* 1.9186	* 1.7209	* 1.6999	* 1.7030	* 1.0085	*	
	* 1.6460	* 1.6021	* 1.7754	* 1.7805	* 1.7690	* 2.9644	*	
13	* 1.6532	* 1.7215	* 1.8763	* 1.7778	* 1.0067	*		
	* 1.8497	* 1.7651	* 1.6109	* 1.6949	* 2.9691	*		
14	* 1.8405	* 1.8161	* 1.3390	* 0.9123	*			
	* 1.6491	* 1.6716	* 2.2595	* 3.2809	*			
15	* 0.9928	* 0.8858	* F-SUB-Q					
	* 3.0389	* 3.4039	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8992	* 1.7451	* 1.6017	* 1.9009	* 1.8596	* 1.6503	* 1.8447	* 0.9925 *
	* 1.6210	* 1.7638	* 1.9205	* 1.6191	* 1.6581	* 1.8691	* 1.6795	* 3.1193 *
9	* 1.7451	* 1.7757	* 1.7450	* 1.6950	* 1.9388	* 1.7420	* 1.8302	* 0.9037 *
	* 1.7638	* 1.7348	* 1.7635	* 1.8156	* 1.5881	* 1.7695	* 1.6906	* 3.4233 *
10	* 1.6017	* 1.7495	* 1.5708	* 1.8347	* 1.7301	* 1.8945	* 1.3525	*
	* 1.9205	* 1.7590	* 1.9617	* 1.6771	* 1.7779	* 1.6256	* 2.2793	*
11	* 1.9009	* 1.6838	* 1.8285	* 1.5768	* 1.7076	* 1.7897	* 0.9203	*
	* 1.6191	* 1.8277	* 1.6831	* 1.9512	* 1.7981	* 1.7164	* 3.3349	*
12	* 1.8596	* 1.9155	* 1.7179	* 1.7003	* 1.7043	* 1.0100	*	
	* 1.6581	* 1.6073	* 1.7906	* 1.8057	* 1.7991	* 3.0315	*	
13	* 1.6503	* 1.7210	* 1.8792	* 1.7797	* 1.0082	*		
	* 1.8691	* 1.7910	* 1.6389	* 1.7261	* 3.0371	*		
14	* 1.8447	* 1.8190	* 1.3399	* 0.9127	*			
	* 1.6795	* 1.7011	* 2.3007	* 3.3627	*			
15	* 0.9925	* 0.8887	* F-SUB-Q					
	* 3.1193	* 3.4800	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 80 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8406	* 1.6982	* 1.5596	* 1.8489	* 1.8198	* 1.6146	* 1.7995	* 0.9797 *
	* 1.6443	* 1.7817	* 1.9377	* 1.6365	* 1.6672	* 1.8793	* 1.6954	* 3.1095 *
9	* 1.6982	* 1.7297	* 1.6887	* 1.6615	* 1.8838	* 1.7047	* 1.7841	* 0.9014 *
	* 1.7817	* 1.7509	* 1.7907	* 1.8209	* 1.6068	* 1.7782	* 1.7081	* 3.3760 *
10	* 1.5596	* 1.6935	* 1.5474	* 1.7854	* 1.6917	* 1.8501	* 1.3414	*
	* 1.9377	* 1.7858	* 1.9538	* 1.6917	* 1.7862	* 1.6362	* 2.2581	*
11	* 1.8489	* 1.6430	* 1.7788	* 1.5589	* 1.6637	* 1.7447	* 0.9192	*
	* 1.6365	* 1.8412	* 1.6986	* 1.9370	* 1.8105	* 1.7273	* 3.2698	*
12	* 1.8198	* 1.8601	* 1.6792	* 1.6571	* 1.6606	* 1.0080	*	
	* 1.6672	* 1.6270	* 1.7994	* 1.8176	* 1.8092	* 2.9704	*	
13	* 1.6146	* 1.6833	* 1.8344	* 1.7344	* 1.0059	*		
	* 1.8793	* 1.8005	* 1.6501	* 1.7375	* 2.9767	*		
14	* 1.7995	* 1.7725	* 1.3284	* 0.9106	*			
	* 1.6954	* 1.7192	* 2.2801	* 3.3005	*			
15	* 0.9797	* 0.8869	* F-SUB-Q					
	* 3.1095	* 3.4300	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8608	* 1.7036	* 1.5634	* 1.8737	* 1.8386	* 1.6269	* 1.8368	* 0.9747 *
	* 1.5831	* 1.7286	* 1.8795	* 1.5714	* 1.6060	* 1.8123	* 1.6109	* 3.0127 *
9	* 1.7036	* 1.7389	* 1.7125	* 1.6607	* 1.9173	* 1.7250	* 1.8234	* 0.8868 *
	* 1.7286	* 1.6941	* 1.7172	* 1.7712	* 1.5361	* 1.7091	* 1.6212	* 3.3077 *
10	* 1.5634	* 1.7171	* 1.5376	* 1.8115	* 1.7044	* 1.8854	* 1.3276	*
	* 1.8795	* 1.7128	* 1.9088	* 1.6216	* 1.7249	* 1.5625	* 2.2132	*
11	* 1.8737	* 1.6486	* 1.8037	* 1.5394	* 1.6938	* 1.7791	* 0.8966	*
	* 1.5714	* 1.7838	* 1.6284	* 1.9041	* 1.7273	* 1.6450	* 3.2396	*
12	* 1.8386	* 1.8929	* 1.6910	* 1.6858	* 1.6912	* 0.9909	*	
	* 1.6060	* 1.5553	* 1.7381	* 1.7352	* 1.7227	* 2.9185	*	
13	* 1.6269	* 1.7022	* 1.8686	* 1.7682	* 0.9891	*		
	* 1.8123	* 1.7314	* 1.5761	* 1.6549	* 2.9235	*		
14	* 1.8368	* 1.8112	* 1.3139	* 0.8890	*			
	* 1.6109	* 1.6319	* 2.2358	* 3.2665	*			
15	* 0.9746	* 0.8692	* F-SUB-Q					
	* 3.0127	* 3.3726	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 81 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8403 *	* 1.6789 *	* 1.5408 *	* 1.8575 *	* 1.8234 *	* 1.6106 *	* 1.8305 *	* 0.9620 *
	* 1.5137 *	* 1.6581 *	* 1.8016 *	* 1.4990 *	* 1.5323 *	* 1.7305 *	* 1.5276 *	* 2.8793 *
9	* 1.6789 *	* 1.7170 *	* 1.6943 *	* 1.6398 *	* 1.9040 *	* 1.7127 *	* 1.8176 *	* 0.8737 *
	* 1.6581 *	* 1.6214 *	* 1.6402 *	* 1.6957 *	* 1.4630 *	* 1.6282 *	* 1.5373 *	* 3.1677 *
10	* 1.5408 *	* 1.6989 *	* 1.5178 *	* 1.7978 *	* 1.6873 *	* 1.8777 *	* 1.3093 *	
	* 1.8016 *	* 1.6359 *	* 1.8247 *	* 1.5442 *	* 1.6473 *	* 1.4842 *	* 2.1196 *	
11	* 1.8575 *	* 1.6273 *	* 1.7898 *	* 1.5217 *	* 1.6850 *	* 1.7719 *	* 0.8802 *	
	* 1.4990 *	* 1.7082 *	* 1.5509 *	* 1.8179 *	* 1.6433 *	* 1.5635 *	* 3.1217 *	
12	* 1.8234 *	* 1.8792 *	* 1.6734 *	* 1.6767 *	* 1.6828 *	* 0.9760 *		
	* 1.5323 *	* 1.4816 *	* 1.6605 *	* 1.6511 *	* 1.6391 *	* 2.8076 *		
13	* 1.6106 *	* 1.6889 *	* 1.8602 *	* 1.7605 *	* 0.9738 *			
	* 1.7305 *	* 1.6503 *	* 1.4976 *	* 1.5732 *	* 2.8136 *			
14	* 1.8305 *	* 1.8049 *	* 1.2952 *	* 0.8725 *				
	* 1.5276 *	* 1.5477 *	* 2.1419 *	* 3.1482 *				
15	* 0.9620 *	* 0.8553 *	F-SUB-Q					
	* 2.8793 *	* 3.2339 *	M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7988 *	* 1.6421 *	* 1.5065 *	* 1.8217 *	* 1.7914 *	* 1.5796 *	* 1.7989 *	* 0.9451 *
	* 1.4763 *	* 1.6156 *	* 1.7563 *	* 1.4570 *	* 1.4860 *	* 1.6808 *	* 1.4788 *	* 2.7871 *
9	* 1.6421 *	* 1.6814 *	* 1.6569 *	* 1.6053 *	* 1.8673 *	* 1.6821 *	* 1.7858 *	* 0.8610 *
	* 1.6156 *	* 1.5776 *	* 1.5985 *	* 1.6513 *	* 1.4222 *	* 1.5800 *	* 1.4891 *	* 3.0577 *
10	* 1.5065 *	* 1.6615 *	* 1.4851 *	* 1.7646 *	* 1.6558 *	* 1.8467 *	* 1.2889 *	
	* 1.7563 *	* 1.5943 *	* 1.7775 *	* 1.5003 *	* 1.6009 *	* 1.4389 *	* 2.0517 *	
11	* 1.8217 *	* 1.5927 *	* 1.7563 *	* 1.4917 *	* 1.6549 *	* 1.7408 *	* 0.8680 *	
	* 1.4570 *	* 1.6639 *	* 1.5071 *	* 1.7687 *	* 1.5969 *	* 1.5189 *	* 3.0213 *	
12	* 1.7914 *	* 1.8424 *	* 1.6416 *	* 1.6464 *	* 1.6527 *	* 0.9631 *		
	* 1.4860 *	* 1.4408 *	* 1.6142 *	* 1.6047 *	* 1.5937 *	* 2.7184 *		
13	* 1.5796 *	* 1.6580 *	* 1.8289 *	* 1.7292 *	* 0.9613 *			
	* 1.6808 *	* 1.6021 *	* 1.4524 *	* 1.5286 *	* 2.7231 *			
14	* 1.7989 *	* 1.7729 *	* 1.2746 *	* 0.8601 *				
	* 1.4788 *	* 1.4995 *	* 2.0740 *	* 3.0481 *				
15	* 0.9451 *	* 0.8435 *	F-SUB-Q					
	* 2.7871 *	* 3.1194 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 82 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7210	* 1.5823	* 1.4525	* 1.7518	* 1.7312	* 1.5261	* 1.7298	* 0.9227 *
	* 1.4835	* 1.6113	* 1.7509	* 1.4560	* 1.4770	* 1.6711	* 1.4760	* 2.7404 *
9	* 1.5823	* 1.6215	* 1.5853	* 1.5546	* 1.7915	* 1.6245	* 1.7152	* 0.8501 *
	* 1.6113	* 1.5719	* 1.6044	* 1.6393	* 1.4249	* 1.5716	* 1.4882	* 2.9732 *
10	* 1.4525	* 1.5901	* 1.4451	* 1.6978	* 1.6004	* 1.7785	* 1.2663	*
	* 1.7509	* 1.6012	* 1.7557	* 1.4989	* 1.5921	* 1.4355	* 2.0064	*
11	* 1.7518	* 1.5370	* 1.6896	* 1.4622	* 1.5916	* 1.6739	* 0.8620	*
	* 1.4560	* 1.6573	* 1.5059	* 1.7353	* 1.5966	* 1.5186	* 2.9263	*
12	* 1.7312	* 1.7664	* 1.5863	* 1.5832	* 1.5892	* 0.9522	*	
	* 1.4770	* 1.4444	* 1.6057	* 1.6048	* 1.5942	* 2.6459	*	
13	* 1.5261	* 1.6007	* 1.7607	* 1.6624	* 0.9502	*		
	* 1.6711	* 1.5942	* 1.4494	* 1.5287	* 2.6513	*		
14	* 1.7298	* 1.7022	* 1.2521	* 0.8528	*			
	* 1.4760	* 1.4992	* 2.0284	* 2.9567	*			
15	* 0.9227	* 0.8358	* F-SUB-Q					
	* 2.7404	* 3.0221	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7442	* 1.5827	* 1.4510	* 1.7702	* 1.7385	* 1.5263	* 1.7547	* 0.9075 *
	* 1.4112	* 1.5534	* 1.6913	* 1.3917	* 1.4209	* 1.6153	* 1.4063	* 2.6938 *
9	* 1.5827	* 1.6260	* 1.6069	* 1.5487	* 1.8178	* 1.6324	* 1.7423	* 0.8255 *
	* 1.5534	* 1.5121	* 1.5291	* 1.5892	* 1.3567	* 1.5123	* 1.4162	* 2.9608 *
10	* 1.4510	* 1.6114	* 1.4316	* 1.7163	* 1.6027	* 1.8021	* 1.2384	*
	* 1.6913	* 1.5249	* 1.7132	* 1.4337	* 1.5371	* 1.3702	* 1.9843	*
11	* 1.7702	* 1.5357	* 1.7077	* 1.4419	* 1.6129	* 1.6981	* 0.8291	*
	* 1.3917	* 1.6022	* 1.4407	* 1.7018	* 1.5247	* 1.4486	* 2.9446	*
12	* 1.7385	* 1.7926	* 1.5880	* 1.6042	* 1.6108	* 0.9247	*	
	* 1.4209	* 1.3753	* 1.5509	* 1.5327	* 1.5226	* 2.6384	*	
13	* 1.5263	* 1.6075	* 1.7835	* 1.6861	* 0.9225	*		
	* 1.6153	* 1.5350	* 1.3840	* 1.4585	* 2.6443	*		
14	* 1.7547	* 1.7289	* 1.2238	* 0.8212	*			
	* 1.4063	* 1.4268	* 2.0072	* 2.9719	*			
15	* 0.9075	* 0.8072	* F-SUB-Q					
	* 2.6938	* 3.0257	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 83 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7033	* 1.5447	* 1.4149	* 1.7256	* 1.6971	* 1.4870	* 1.7098	* 0.8804 *
	* 1.3836	* 1.5237	* 1.6610	* 1.3676	* 1.3941	* 1.5886	* 1.3841	* 2.6736 *
9	* 1.5447	* 1.5877	* 1.5681	* 1.5094	* 1.7737	* 1.5922	* 1.6984	* 0.8017 *
	* 1.5237	* 1.4828	* 1.5007	* 1.5620	* 1.3322	* 1.4858	* 1.3931	* 2.9359 *
10	* 1.4149	* 1.5726	* 1.3942	* 1.6725	* 1.5628	* 1.7579	* 1.2038	*
	* 1.6610	* 1.4965	* 1.6858	* 1.4098	* 1.5104	* 1.3464	* 1.9594	*
11	* 1.7256	* 1.4964	* 1.6640	* 1.4047	* 1.5720	* 1.6556	* 0.8047	*
	* 1.3676	* 1.5753	* 1.4169	* 1.6744	* 1.5007	* 1.4259	* 2.9211	*
12	* 1.6971	* 1.7486	* 1.5481	* 1.5633	* 1.5696	* 0.8997	*	
	* 1.3941	* 1.3509	* 1.5244	* 1.5090	* 1.5007	* 2.6105	*	
13	* 1.4870	* 1.5673	* 1.7393	* 1.6436	* 0.8976	*		
	* 1.5886	* 1.5089	* 1.3605	* 1.4361	* 2.6166	*		
14	* 1.7098	* 1.6849	* 1.1892	* 0.7969	*			
	* 1.3841	* 1.4041	* 1.9832	* 2.9493	*			
15	* 0.8804	* 0.7833	* F-SUB-Q					
	* 2.6736	* 3.0030	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6622	* 1.5033	* 1.3750	* 1.6672	* 1.6429	* 1.4380	* 1.6429	* 0.8458 *
	* 1.3681	* 1.5105	* 1.6497	* 1.3661	* 1.3896	* 1.5861	* 1.3913	* 2.6916 *
9	* 1.5033	* 1.5422	* 1.5290	* 1.4644	* 1.7238	* 1.5380	* 1.6405	* 0.7892 *
	* 1.5105	* 1.4728	* 1.4854	* 1.5542	* 1.3232	* 1.4850	* 1.3929	* 2.8847 *
10	* 1.3750	* 1.5334	* 1.3509	* 1.6138	* 1.5138	* 1.7023	* 1.1628	*
	* 1.6497	* 1.4812	* 1.6798	* 1.4107	* 1.5053	* 1.3421	* 1.9601	*
11	* 1.6672	* 1.4518	* 1.6055	* 1.3589	* 1.5154	* 1.6013	* 0.7773	*
	* 1.3661	* 1.5675	* 1.4178	* 1.6714	* 1.5037	* 1.4240	* 2.9245	*
12	* 1.6429	* 1.6992	* 1.4996	* 1.5079	* 1.5182	* 0.8883	*	
	* 1.3896	* 1.3420	* 1.5193	* 1.5096	* 1.4990	* 2.5570	*	
13	* 1.4380	* 1.5138	* 1.6820	* 1.5896	* 0.8861	*		
	* 1.5861	* 1.5083	* 1.3581	* 1.4343	* 2.5633	*		
14	* 1.6429	* 1.6276	* 1.1487	* 0.7696	*			
	* 1.3913	* 1.4037	* 1.9840	* 2.9535	*			
15	* 0.8458	* 0.7551	* F-SUB-Q					
	* 2.6916	* 3.0133	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 84 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6048	* 1.4473	* 1.3227	* 1.5838	* 1.5655	* 1.3696	* 1.5543	* 0.7969 *
	* 1.3776	* 1.5253	* 1.6676	* 1.3990	* 1.4177	* 1.6199	* 1.4305	* 2.7836 *
9	* 1.4473	* 1.4804	* 1.4759	* 1.4070	* 1.6554	* 1.4605	* 1.5537	* 0.7424 *
	* 1.5253	* 1.4914	* 1.4962	* 1.5729	* 1.3396	* 1.5208	* 1.4309	* 2.9875 *
10	* 1.3227	* 1.4801	* 1.2962	* 1.5265	* 1.4485	* 1.6240	* 1.1066	*
	* 1.6676	* 1.4919	* 1.7029	* 1.4502	* 1.5296	* 1.3681	* 2.0050	*
11	* 1.5838	* 1.3952	* 1.5188	* 1.3033	* 1.4495	* 1.5236	* 0.7425	*
	* 1.3990	* 1.5861	* 1.4575	* 1.6940	* 1.5276	* 1.4560	* 2.9824	*
12	* 1.5655	* 1.6323	* 1.4353	* 1.4439	* 1.4463	* 0.8475	*	
	* 1.4177	* 1.3584	* 1.5436	* 1.5335	* 1.5311	* 2.6097	*	
13	* 1.3696	* 1.4380	* 1.6049	* 1.5126	* 0.8453	*		
	* 1.6199	* 1.5443	* 1.3842	* 1.4665	* 2.6165	*		
14	* 1.5543	* 1.5412	* 1.0931	* 0.7350	*			
	* 1.4305	* 1.4424	* 2.0296	* 3.0127	*			
15	* 0.7969	* 0.7161	* F-SUB-Q					
	* 2.7836	* 3.0963	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4956	* 1.3635	* 1.2492	* 1.4832	* 1.4634	* 1.2692	* 1.4049	* 0.7254 *
	* 1.4470	* 1.5847	* 1.7289	* 1.4608	* 1.4842	* 1.7117	* 1.5501	* 2.9997 *
9	* 1.3635	* 1.4058	* 1.3797	* 1.3361	* 1.5478	* 1.3581	* 1.4043	* 0.6796 *
	* 1.5847	* 1.5369	* 1.5667	* 1.6211	* 1.4020	* 1.6008	* 1.5506	* 3.2019 *
10	* 1.2491	* 1.3836	* 1.2285	* 1.4305	* 1.3669	* 1.4968	* 1.0173	*
	* 1.7289	* 1.5624	* 1.7590	* 1.5135	* 1.5864	* 1.4528	* 2.1373	*
11	* 1.4832	* 1.3254	* 1.4244	* 1.2305	* 1.3463	* 1.4038	* 0.6928	*
	* 1.4608	* 1.6341	* 1.5199	* 1.7566	* 1.6102	* 1.5473	* 3.1342	*
12	* 1.4634	* 1.5268	* 1.3550	* 1.3412	* 1.3441	* 0.7980	*	
	* 1.4842	* 1.4212	* 1.6003	* 1.6162	* 1.6132	* 2.7165	*	
13	* 1.2692	* 1.3379	* 1.4798	* 1.3938	* 0.7958	*		
	* 1.7117	* 1.6249	* 1.4695	* 1.5583	* 2.7239	*		
14	* 1.4049	* 1.3934	* 1.0053	* 0.6857	*			
	* 1.5501	* 1.5627	* 2.1627	* 3.1666	*			
15	* 0.7254	* 0.6577	* F-SUB-Q					
	* 2.9997	* 3.3070	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 85 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3366	* 1.1399	* 1.0615	* 1.3145	* 1.2197	* 1.0301	* 1.1384	* 0.5855
	* 1.5931	* 1.8672	* 2.0043	* 1.6218	* 1.7522	* 2.0781	* 1.8849	* 3.6674
9	* 1.1399	* 1.2029	* 1.2410	* 1.1407	* 1.3672	* 1.1321	* 1.1194	* 0.5515
	* 1.8672	* 1.7683	* 1.7138	* 1.8702	* 1.5626	* 1.8913	* 1.9170	* 3.8939
10	* 1.0615	* 1.2417	* 1.0621	* 1.2769	* 1.1573	* 1.2618	* 0.8241	*
	* 2.0043	* 1.7128	* 2.0018	* 1.6695	* 1.8436	* 1.6968	* 2.6013	*
11	* 1.3145	* 1.1301	* 1.2702	* 1.0459	* 1.1714	* 1.1419	* 0.5811	*
	* 1.6218	* 1.8871	* 1.6783	* 2.0356	* 1.8223	* 1.8732	* 3.6867	*
12	* 1.2197	* 1.3476	* 1.1480	* 1.1669	* 1.1179	* 0.6764	*	*
	* 1.7522	* 1.5852	* 1.8585	* 1.8292	* 1.9102	* 3.1608	*	*
13	* 1.0301	* 1.1163	* 1.2492	* 1.1341	* 0.6743	*	*	*
	* 2.0781	* 1.9179	* 1.7140	* 1.8861	* 3.1704	*	*	*
14	* 1.1384	* 1.1103	* 0.8150	* 0.5751	*	*	*	*
	* 1.8849	* 1.9326	* 2.6305	* 3.7251	*	*	*	*
15	* 0.5855	* 0.5406	* F-SUB-Q					
	* 3.6674	* 3.9709	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5681	* 0.5083	* 0.4977	* 0.5776	* 0.5379	* 0.4686	* 0.4458	* 0.2632
	* 3.7038	* 4.1416	* 4.2291	* 3.6464	* 3.9243	* 4.5183	* 4.7609	* 8.0790
9	* 0.5083	* 0.5277	* 0.5584	* 0.5180	* 0.5721	* 0.4953	* 0.4363	* 0.2453
	* 4.1416	* 3.9859	* 3.7663	* 4.0717	* 3.6914	* 4.2727	* 4.8650	* 8.6689
10	* 0.4977	* 0.5585	* 0.4972	* 0.5587	* 0.5113	* 0.5070	* 0.3695	*
	* 4.2291	* 3.7654	* 4.2293	* 3.7706	* 4.1300	* 4.1754	* 5.7410	*
11	* 0.5776	* 0.5143	* 0.5569	* 0.4804	* 0.5072	* 0.4414	* 0.2621	*
	* 3.6464	* 4.0998	* 3.7830	* 4.3842	* 4.1634	* 4.7946	* 8.0944	*
12	* 0.5379	* 0.5657	* 0.5073	* 0.5053	* 0.4405	* 0.3160	*	*
	* 3.9243	* 3.7331	* 4.1627	* 4.1788	* 4.7978	* 6.6959	*	*
13	* 0.4686	* 0.4893	* 0.5021	* 0.4387	* 0.3149	*	*	*
	* 4.5183	* 4.3254	* 4.2160	* 4.8241	* 6.7194	*	*	*
14	* 0.4458	* 0.4329	* 0.3657	* 0.2595	*	*	*	*
	* 4.7609	* 4.9026	* 5.8005	* 8.1744	*	*	*	*
15	* 0.2632	* 0.2443	* F-SUB-Q					
	* 8.0790	* 8.7033	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 86 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5668	* 0.5177	* 0.4868	* 0.5590	* 0.5180	* 0.4378	* 0.3136	* 0.1690 *
	* 3.3779	* 3.6958	* 3.9128	* 3.4072	* 3.6816	* 4.2934	* 4.4676	* 7.0593 *
9	* 0.5177	* 0.4989	* 0.5221	* 0.5034	* 0.5509	* 0.4694	* 0.3629	* 0.1797 *
	* 3.6958	* 3.7618	* 3.5146	* 3.7837	* 3.4582	* 4.0562	* 4.5957	* 7.5082 *
10	* 0.4868	* 0.5219	* 0.4065	* 0.5210	* 0.4937	* 0.4910	* 0.3496	*
	* 3.9128	* 3.5130	* 3.8966	* 3.5725	* 3.8432	* 3.8665	* 5.3373	*
11	* 0.5590	* 0.5019	* 0.5199	* 0.4566	* 0.5079	* 0.4528	* 0.2813	*
	* 3.4072	* 3.7948	* 3.5743	* 4.1032	* 3.7111	* 4.1597	* 6.6924	*
12	* 0.5180	* 0.5477	* 0.4922	* 0.5073	* 0.4597	* 0.3425	*	*
	* 3.6816	* 3.4779	* 3.8553	* 3.7157	* 4.0789	* 5.4543	*	*
13	* 0.4378	* 0.4670	* 0.4892	* 0.4517	* 0.3411	*	*	*
	* 4.2934	* 4.0770	* 3.8812	* 4.1704	* 5.4778	*	*	*
14	* 0.3136	* 0.3612	* 0.3480	* 0.2800	*	*	*	*
	* 4.4676	* 4.6095	* 5.3598	* 6.7248	*	*	*	*
15	* 0.1690	* 0.1781	* F-SUB-Q					
	* 7.0593	* 7.5555	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1860	* 1.0298	* 0.9401	* 1.1289	* 1.0488	* 0.8642	* 0.7156	* 0.3565 *
	* 1.6787	* 1.9332	* 2.0906	* 1.7537	* 1.8908	* 2.2003	* 2.0211	* 3.5278 *
9	* 1.0298	* 1.0067	* 1.0400	* 1.0040	* 1.1643	* 0.9590	* 0.8269	* 0.3687 *
	* 1.9332	* 1.8990	* 1.8108	* 1.9728	* 1.7016	* 2.0648	* 2.0614	* 3.8112 *
10	* 0.9401	* 1.0398	* 0.7801	* 1.0553	* 1.0023	* 1.0730	* 0.7065	*
	* 2.0906	* 1.8099	* 2.0738	* 1.8175	* 1.9681	* 1.8392	* 2.7081	*
11	* 1.1289	* 1.0008	* 1.0531	* 0.8928	* 1.0360	* 1.0039	* 0.5643	*
	* 1.7537	* 1.9792	* 1.8184	* 2.1626	* 1.8887	* 1.9473	* 3.4676	*
12	* 1.0488	* 1.1566	* 0.9991	* 1.0346	* 0.9951	* 0.6576	*	*
	* 1.8908	* 1.7132	* 1.9746	* 1.8914	* 1.9612	* 2.9481	*	*
13	* 0.8642	* 0.9537	* 1.0691	* 1.0015	* 0.6555	*	*	*
	* 2.2003	* 2.0766	* 1.8462	* 1.9523	* 2.9575	*	*	*
14	* 0.7156	* 0.8231	* 0.7031	* 0.5614	*	*	*	*
	* 2.0211	* 2.0675	* 2.7201	* 3.4856	*	*	*	*
15	* 0.3565	* 0.3625	* F-SUB-Q					
	* 3.5278	* 3.8648	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 87 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2861	* 1.1929	* 1.0905	* 1.2588	* 1.2209	* 1.0443	* 0.9098	* 0.4645 *
	* 1.6155	* 1.7414	* 1.8720	* 1.6435	* 1.6961	* 1.8909	* 1.7693	* 2.9707 *
9	* 1.1929	* 1.1758	* 1.1376	* 1.1688	* 1.2700	* 1.1358	* 1.0062	* 0.4684 *
	* 1.7414	* 1.7090	* 1.7507	* 1.7630	* 1.6315	* 1.8058	* 1.7922	* 3.1992 *
10	* 1.0905	* 1.1366	* 0.9201	* 1.1786	* 1.1747	* 1.2281	* 0.8737	*
	* 1.8720	* 1.7486	* 1.8654	* 1.6935	* 1.7534	* 1.6703	* 2.2763	*
11	* 1.2588	* 1.1646	* 1.1756	* 1.0584	* 1.1523	* 1.1994	* 0.6865	*
	* 1.6435	* 1.7690	* 1.6957	* 1.9040	* 1.7696	* 1.6992	* 2.9667	*
12	* 1.2209	* 1.2605	* 1.1705	* 1.1503	* 1.1639	* 0.7759	*	
	* 1.6961	* 1.6441	* 1.7600	* 1.7732	* 1.7420	* 2.5923	*	
13	* 1.0443	* 1.1286	* 1.2237	* 1.1960	* 0.7740	*		
	* 1.8909	* 1.8167	* 1.6766	* 1.7042	* 2.5988	*		
14	* 0.9098	* 1.0010	* 0.8692	* 0.6830	*			
	* 1.7693	* 1.7978	* 2.2871	* 2.9823	*			
15	* 0.4645	* 0.4627	* F-SUB-Q					
	* 2.9707	* 3.2348	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4687	* 1.3348	* 1.2252	* 1.4497	* 1.3855	* 1.2023	* 1.1317	* 0.5784 *
	* 1.4937	* 1.6393	* 1.7608	* 1.5082	* 1.5658	* 1.7376	* 1.5602	* 2.7177 *
9	* 1.3348	* 1.3252	* 1.3121	* 1.3163	* 1.4667	* 1.3032	* 1.2286	* 0.5664 *
	* 1.6393	* 1.5994	* 1.6152	* 1.6502	* 1.4868	* 1.6571	* 1.5795	* 2.9739 *
10	* 1.2252	* 1.3109	* 1.0479	* 1.3717	* 1.3324	* 1.4357	* 1.0011	*
	* 1.7608	* 1.6132	* 1.7567	* 1.5487	* 1.6365	* 1.5045	* 2.1055	*
11	* 1.4497	* 1.3110	* 1.3678	* 1.1849	* 1.3349	* 1.3962	* 0.7584	*
	* 1.5082	* 1.6567	* 1.5513	* 1.7976	* 1.6091	* 1.5331	* 2.8254	*
12	* 1.3855	* 1.4554	* 1.3269	* 1.3323	* 1.3411	* 0.8478	*	
	* 1.5658	* 1.5024	* 1.6436	* 1.6128	* 1.5891	* 2.4849	*	
13	* 1.2023	* 1.2939	* 1.4300	* 1.3919	* 0.8461	*		
	* 1.7376	* 1.6687	* 1.5109	* 1.5381	* 2.4900	*		
14	* 1.1317	* 1.2221	* 0.9954	* 0.7544	*			
	* 1.5602	* 1.5857	* 2.1170	* 2.8410	*			
15	* 0.5784	* 0.5605	* F-SUB-Q					
	* 2.7177	* 3.0179	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 88 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5543	* 1.3992	* 1.3006	* 1.5531	* 1.4780	* 1.3020	* 1.3440	* 0.7202 *
	* 1.5052	* 1.6583	* 1.7729	* 1.4934	* 1.5543	* 1.7292	* 1.5270	* 2.6673 *
9	* 1.3992	* 1.3985	* 1.4107	* 1.3981	* 1.5777	* 1.4009	* 1.3847	* 0.6829 *
	* 1.6583	* 1.6103	* 1.6147	* 1.6538	* 1.4649	* 1.6388	* 1.5364	* 2.9152 *
10	* 1.3006	* 1.4096	* 1.2127	* 1.4897	* 1.4229	* 1.5481	* 1.0991	*
	* 1.7729	* 1.6126	* 1.7664	* 1.5341	* 1.6263	* 1.4860	* 2.0569	*
11	* 1.5531	* 1.3920	* 1.4852	* 1.2741	* 1.4369	* 1.5029	* 0.8166	*
	* 1.4934	* 1.6611	* 1.5369	* 1.7931	* 1.5909	* 1.5108	* 2.7897	*
12	* 1.4780	* 1.5589	* 1.4169	* 1.4339	* 1.4398	* 0.9062	*	
	* 1.5543	* 1.4833	* 1.6331	* 1.5949	* 1.5712	* 2.4565	*	
13	* 1.3020	* 1.3903	* 1.5407	* 1.4978	* 0.9045	*		
	* 1.7292	* 1.6513	* 1.4930	* 1.5162	* 2.4613	*		
14	* 1.3440	* 1.3776	* 1.0927	* 0.8115	*			
	* 1.5270	* 1.5430	* 2.0687	* 2.8077	*			
15	* 0.7202	* 0.6742	* F-SUB-Q					
	* 2.6673	* 2.9513	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6176	* 1.4549	* 1.3640	* 1.6361	* 1.5612	* 1.3871	* 1.5251	* 0.8537 *
	* 1.5154	* 1.6808	* 1.7886	* 1.4862	* 1.5493	* 1.7319	* 1.5181	* 2.6612 *
9	* 1.4549	* 1.4852	* 1.4914	* 1.4681	* 1.6689	* 1.4839	* 1.5376	* 0.7902 *
	* 1.6808	* 1.6289	* 1.6279	* 1.6571	* 1.4526	* 1.6254	* 1.5190	* 2.8967 *
10	* 1.3640	* 1.4907	* 1.3387	* 1.5873	* 1.5003	* 1.6420	* 1.1812	*
	* 1.7886	* 1.6258	* 1.7829	* 1.5266	* 1.6173	* 1.4699	* 2.0325	*
11	* 1.6361	* 1.4611	* 1.5822	* 1.3538	* 1.5199	* 1.5879	* 0.8646	*
	* 1.4862	* 1.6656	* 1.5316	* 1.7924	* 1.5861	* 1.5033	* 2.7679	*
12	* 1.5612	* 1.6474	* 1.4934	* 1.5165	* 1.5196	* 0.9551	*	
	* 1.5493	* 1.4719	* 1.6248	* 1.5904	* 1.5706	* 2.4624	*	
13	* 1.3871	* 1.4721	* 1.6335	* 1.5822	* 0.9533	*		
	* 1.7319	* 1.6386	* 1.4777	* 1.5090	* 2.4673	*		
14	* 1.5251	* 1.5304	* 1.1739	* 0.8590	*			
	* 1.5181	* 1.5260	* 2.0452	* 2.7866	*			
15	* 0.8537	* 0.7798	* F-SUB-Q					
	* 2.6612	* 2.9349	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 89 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6920	* 1.5176	* 1.4283	* 1.7290	* 1.6482	* 1.4686	* 1.6717	* 0.9348 *
	* 1.5103	* 1.6871	* 1.7903	* 1.4680	* 1.5361	* 1.7194	* 1.4918	* 2.6550 *
9	* 1.5176	* 1.5677	* 1.5781	* 1.5407	* 1.7695	* 1.5710	* 1.6794	* 0.8569 *
	* 1.6871	* 1.6291	* 1.6193	* 1.6510	* 1.4307	* 1.6051	* 1.4852	* 2.9009 *
10	* 1.4283	* 1.5801	* 1.4281	* 1.6872	* 1.5796	* 1.7461	* 1.2459	*
	* 1.7903	* 1.6172	* 1.7805	* 1.5054	* 1.6016	* 1.4362	* 2.0197	*
11	* 1.7290	* 1.5325	* 1.6815	* 1.4293	* 1.6113	* 1.6833	* 0.8981	*
	* 1.4680	* 1.6604	* 1.5106	* 1.7788	* 1.5601	* 1.4788	* 2.7770	*
12	* 1.6482	* 1.7459	* 1.5719	* 1.6075	* 1.6089	* 0.9929	*	
	* 1.5361	* 1.4505	* 1.6097	* 1.5645	* 1.5469	* 2.4729	*	
13	* 1.4686	* 1.5577	* 1.7364	* 1.6769	* 0.9913	*		
	* 1.7194	* 1.6192	* 1.4445	* 1.4848	* 2.4772	*		
14	* 1.6717	* 1.6713	* 1.2379	* 0.8921	*			
	* 1.4918	* 1.4926	* 2.0328	* 2.7962	*			
15	* 0.9348	* 0.8449	* F-SUB-Q					
	* 2.6550	* 2.9415	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7271	* 1.5494	* 1.4633	* 1.7800	* 1.7001	* 1.5161	* 1.7514	* 0.9813 *
	* 1.5443	* 1.7229	* 1.8215	* 1.4876	* 1.5516	* 1.7405	* 1.5021	* 2.6738 *
9	* 1.5494	* 1.6094	* 1.6224	* 1.5819	* 1.8266	* 1.6239	* 1.7597	* 0.8988 *
	* 1.7229	* 1.6594	* 1.6428	* 1.6761	* 1.4446	* 1.6170	* 1.4918	* 2.9220 *
10	* 1.4633	* 1.6237	* 1.4721	* 1.7417	* 1.6263	* 1.8080	* 1.2916	*
	* 1.8215	* 1.6441	* 1.8098	* 1.5176	* 1.6215	* 1.4461	* 2.0313	*
11	* 1.7800	* 1.5728	* 1.7357	* 1.4731	* 1.6634	* 1.7407	* 0.9260	*
	* 1.4876	* 1.6861	* 1.5221	* 1.7967	* 1.5726	* 1.4908	* 2.8036	*
12	* 1.7001	* 1.8013	* 1.6179	* 1.6593	* 1.6610	* 1.0231	*	
	* 1.5516	* 1.4654	* 1.6301	* 1.5772	* 1.5611	* 2.5078	*	
13	* 1.5161	* 1.6094	* 1.7974	* 1.7337	* 1.0213	*		
	* 1.7405	* 1.6318	* 1.4548	* 1.4969	* 2.5120	*		
14	* 1.7514	* 1.7507	* 1.2829	* 0.9195	*			
	* 1.5021	* 1.4997	* 2.0452	* 2.8235	*			
15	* 0.9813	* 0.8871	* F-SUB-Q					
	* 2.6738	* 2.9600	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 90 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7802	* 1.5891	* 1.5029	* 1.8474	* 1.7595	* 1.5664	* 1.8371	* 1.0152 *
	* 1.5686	* 1.7608	* 1.8589	* 1.5022	* 1.5709	* 1.7631	* 1.4932	* 2.6998 *
9	* 1.5891	* 1.6566	* 1.6818	* 1.6285	* 1.8998	* 1.6833	* 1.8487	* 0.9254 *
	* 1.7608	* 1.6875	* 1.6582	* 1.7069	* 1.4557	* 1.6341	* 1.4813	* 2.9626 *
10	* 1.5029	* 1.6797	* 1.5160	* 1.8098	* 1.6791	* 1.8855	* 1.3252	*
	* 1.8589	* 1.6610	* 1.8372	* 1.5295	* 1.6421	* 1.4474	* 2.0714	*
11	* 1.8474	* 1.6186	* 1.8040	* 1.5195	* 1.7305	* 1.8121	* 0.9408	*
	* 1.5022	* 1.7167	* 1.5342	* 1.8235	* 1.5767	* 1.4962	* 2.8776	*
12	* 1.7595	* 1.8728	* 1.6698	* 1.7260	* 1.7275	* 1.0442	*	
	* 1.5709	* 1.4771	* 1.6514	* 1.5814	* 1.5681	* 2.5733	*	
13	* 1.5664	* 1.6675	* 1.8738	* 1.8045	* 1.0426	*		
	* 1.7631	* 1.6498	* 1.4566	* 1.5025	* 2.5771	*		
14	* 1.8371	* 1.8387	* 1.3156	* 0.9349	*			
	* 1.4932	* 1.4894	* 2.0865	* 2.8956	*			
15	* 1.0152	* 0.9093	* F-SUB-Q					
	* 2.6998	* 3.0144	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7354	* 1.5615	* 1.4871	* 1.8107	* 1.7410	* 1.5516	* 1.8122	* 1.0235 *
	* 1.6850	* 1.8758	* 1.9694	* 1.6044	* 1.6629	* 1.8680	* 1.5910	* 2.8107 *
9	* 1.5615	* 1.6299	* 1.6469	* 1.6078	* 1.8673	* 1.6665	* 1.8224	* 0.9455 *
	* 1.8758	* 1.7982	* 1.7748	* 1.8088	* 1.5497	* 1.7264	* 1.5803	* 3.0439 *
10	* 1.4871	* 1.6452	* 1.4993	* 1.7775	* 1.6613	* 1.8574	* 1.3424	*
	* 1.9694	* 1.7773	* 1.9444	* 1.6276	* 1.7371	* 1.5386	* 2.1409	*
11	* 1.8107	* 1.5979	* 1.7703	* 1.5096	* 1.7014	* 1.7853	* 0.9637	*
	* 1.6044	* 1.8186	* 1.6328	* 1.9139	* 1.6820	* 1.5946	* 2.9448	*
12	* 1.7410	* 1.8396	* 1.6517	* 1.6968	* 1.7002	* 1.0659	*	
	* 1.6629	* 1.5733	* 1.7472	* 1.6866	* 1.6733	* 2.6519	*	
13	* 1.5516	* 1.6502	* 1.8454	* 1.7774	* 1.0637	*		
	* 1.8680	* 1.7434	* 1.5486	* 1.6016	* 2.6570	*		
14	* 1.8122	* 1.8122	* 1.3325	* 0.9564	*			
	* 1.5910	* 1.5891	* 2.1565	* 2.9665	*			
15	* 1.0235	* 0.9317	* F-SUB-Q					
	* 2.8107	* 3.0884	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 91 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7893	* 1.5956	* 1.5132	* 1.8779	* 1.7942	* 1.5934	* 1.8952	* 1.0415 *
	* 1.7222	* 1.9339	* 2.0365	* 1.6314	* 1.7003	* 1.9131	* 1.5970	* 2.8971 *
9	* 1.5956	* 1.6706	* 1.7057	* 1.6476	* 1.9400	* 1.7207	* 1.9102	* 0.9511 *
	* 1.9339	* 1.8453	* 1.8015	* 1.8607	* 1.5719	* 1.7613	* 1.5809	* 3.1721 *
10	* 1.5132	* 1.7024	* 1.5313	* 1.8451	* 1.7075	* 1.9363	* 1.3559	*
	* 2.0365	* 1.8049	* 2.0043	* 1.6522	* 1.7831	* 1.5566	* 2.2280	*
11	* 1.8779	* 1.6373	* 1.8382	* 1.5416	* 1.7696	* 1.8594	* 0.9602	*
	* 1.6314	* 1.8704	* 1.6576	* 1.9789	* 1.7078	* 1.6175	* 3.1165	*
12	* 1.7942	* 1.9107	* 1.6970	* 1.7645	* 1.7684	* 1.0681	*	
	* 1.7003	* 1.5961	* 1.7938	* 1.7125	* 1.6999	* 2.7975	*	
13	* 1.5934	* 1.7030	* 1.9231	* 1.8508	* 1.0664	*		
	* 1.9131	* 1.7794	* 1.5670	* 1.6247	* 2.8014	*		
14	* 1.8952	* 1.8990	* 1.3452	* 0.9536	*			
	* 1.5970	* 1.5901	* 2.2451	* 3.1367	*			
15	* 1.0415	* 0.9348	* F-SUB-Q					
	* 2.8971	* 3.2264	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7798	* 1.5868	* 1.5076	* 1.8791	* 1.7977	* 1.5946	* 1.9080	* 1.0464 *
	* 1.7308	* 1.9403	* 2.0401	* 1.6383	* 1.7151	* 1.9344	* 1.6260	* 2.9621 *
9	* 1.5868	* 1.6652	* 1.7043	* 1.6450	* 1.9444	* 1.7262	* 1.9243	* 0.9572 *
	* 1.9403	* 1.8505	* 1.8071	* 1.8707	* 1.5851	* 1.7856	* 1.6090	* 3.2355 *
10	* 1.5076	* 1.7008	* 1.5279	* 1.8483	* 1.7094	* 1.9464	* 1.3627	*
	* 2.0401	* 1.8109	* 2.0162	* 1.6638	* 1.7991	* 1.5823	* 2.2630	*
11	* 1.8791	* 1.6347	* 1.8417	* 1.5419	* 1.7761	* 1.8694	* 0.9658	*
	* 1.6383	* 1.8822	* 1.6697	* 1.9920	* 1.7283	* 1.6433	* 3.1777	*
12	* 1.7977	* 1.9141	* 1.6984	* 1.7707	* 1.7765	* 1.0745	*	
	* 1.7151	* 1.6100	* 1.8108	* 1.7336	* 1.7257	* 2.8489	*	
13	* 1.5946	* 1.7077	* 1.9325	* 1.8603	* 1.0728	*		
	* 1.9344	* 1.8049	* 1.5937	* 1.6514	* 2.8536	*		
14	* 1.9080	* 1.9125	* 1.3518	* 0.9587	*			
	* 1.6260	* 1.6190	* 2.2813	* 3.2012	*			
15	* 1.0464	* 0.9426	* F-SUB-Q					
	* 2.9621	* 3.2851	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 92 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7243	* 1.5456	* 1.4757	* 1.8297	* 1.7630	* 1.5646	* 1.8686	* 1.0383
	* 1.7546	* 1.9562	* 2.0472	* 1.6540	* 1.7211	* 1.9399	* 1.6349	* 2.9381
9	* 1.5456	* 1.6238	* 1.6576	* 1.6092	* 1.8982	* 1.6943	* 1.8837	* 0.9601
	* 1.9562	* 1.8643	* 1.8244	* 1.8790	* 1.5973	* 1.7896	* 1.6193	* 3.1757
10	* 1.4757	* 1.6540	* 1.4967	* 1.8033	* 1.6764	* 1.9059	* 1.3579	*
	* 2.0472	* 1.8284	* 2.0174	* 1.6754	* 1.8019	* 1.5892	* 2.2333	*
11	* 1.8297	* 1.5990	* 1.7958	* 1.5144	* 1.7360	* 1.8308	* 0.9694	*
	* 1.6540	* 1.8899	* 1.6816	* 1.9885	* 1.7348	* 1.6469	* 3.1019	*
12	* 1.7629	* 1.8675	* 1.6652	* 1.7305	* 1.7385	* 1.0781	*	*
	* 1.7211	* 1.6232	* 1.8140	* 1.7403	* 1.7280	* 2.7778	*	*
13	* 1.5646	* 1.6755	* 1.8916	* 1.8215	* 1.0759	*	*	*
	* 1.9399	* 1.8095	* 1.6010	* 1.6553	* 2.7836	*	*	*
14	* 1.8686	* 1.8716	* 1.3466	* 0.9613	*	*	*	*
	* 1.6349	* 1.6298	* 2.2519	* 3.1280	*	*	*	*
15	* 1.0383	* 0.9451	* F-SUB-Q					
	* 2.9381	* 3.2256	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7431	* 1.5497	* 1.4762	* 1.8604	* 1.7834	* 1.5777	* 1.9177	* 1.0376
	* 1.6876	* 1.8964	* 1.9871	* 1.5839	* 1.6571	* 1.8708	* 1.5476	* 2.8443
9	* 1.5497	* 1.6331	* 1.6834	* 1.6185	* 1.9340	* 1.7183	* 1.9374	* 0.9484
	* 1.8964	* 1.8019	* 1.7456	* 1.8174	* 1.5269	* 1.7185	* 1.5305	* 3.1089
10	* 1.4762	* 1.6794	* 1.5007	* 1.8357	* 1.6911	* 1.9506	* 1.3476	*
	* 1.9871	* 1.7497	* 1.9553	* 1.6012	* 1.7390	* 1.5134	* 2.1865	*
11	* 1.8604	* 1.6080	* 1.8284	* 1.5225	* 1.7717	* 1.8730	* 0.9490	*
	* 1.5839	* 1.8282	* 1.6073	* 1.9227	* 1.6532	* 1.5665	* 3.0702	*
12	* 1.7834	* 1.9018	* 1.6790	* 1.7658	* 1.7756	* 1.0632	*	*
	* 1.6571	* 1.5520	* 1.7511	* 1.6585	* 1.6433	* 2.7283	*	*
13	* 1.5777	* 1.6981	* 1.9352	* 1.8630	* 1.0615	*	*	*
	* 1.8708	* 1.7384	* 1.5251	* 1.5746	* 2.7324	*	*	*
14	* 1.9177	* 1.9244	* 1.3356	* 0.9418	*	*	*	*
	* 1.5476	* 1.5407	* 2.2057	* 3.0931	*	*	*	*
15	* 1.0376	* 0.9310	* F-SUB-Q					
	* 2.8443	* 3.1659	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 93 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7212	* 1.5268	* 1.4563	* 1.8471	* 1.7705	* 1.5636	* 1.9185	* 1.0281 *
	* 1.6186	* 1.8223	* 1.9068	* 1.5114	* 1.5823	* 1.7881	* 1.4667	* 2.7141 *
9	* 1.5268	* 1.6130	* 1.6697	* 1.6002	* 1.9237	* 1.7090	* 1.9401	* 0.9382 *
	* 1.8223	* 1.7268	* 1.6654	* 1.7411	* 1.4552	* 1.6379	* 1.4493	* 2.9719 *
10	* 1.4563	* 1.6654	* 1.4827	* 1.8252	* 1.6763	* 1.9480	* 1.3329	*
	* 1.9068	* 1.6696	* 1.8718	* 1.5259	* 1.6632	* 1.4370	* 2.0937	*
11	* 1.8471	* 1.5895	* 1.8177	* 1.5081	* 1.7654	* 1.8708	* 0.9350	*
	* 1.5114	* 1.7520	* 1.5320	* 1.8392	* 1.5745	* 1.4889	* 2.9557	*
12	* 1.7705	* 1.8905	* 1.6637	* 1.7590	* 1.7713	* 1.0504	*	
	* 1.5823	* 1.4798	* 1.6753	* 1.5801	* 1.5647	* 2.6242	*	
13	* 1.5636	* 1.6880	* 1.9319	* 1.8604	* 1.0483	*		
	* 1.7881	* 1.6576	* 1.4485	* 1.4969	* 2.6290	*		
14	* 1.9185	* 1.9264	* 1.3206	* 0.9277	*			
	* 1.4667	* 1.4592	* 2.1126	* 2.9780	*			
15	* 1.0281	* 0.9200	* F-SUB-Q					
	* 2.7141	* 3.0295	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6814	* 1.4924	* 1.4239	* 1.8107	* 1.7395	* 1.5342	* 1.8877	* 1.0118 *
	* 1.5838	* 1.7819	* 1.8643	* 1.4736	* 1.5385	* 1.7403	* 1.4210	* 2.6281 *
9	* 1.4924	* 1.5784	* 1.6349	* 1.5670	* 1.8890	* 1.6795	* 1.9087	* 0.9260 *
	* 1.7819	* 1.6862	* 1.6256	* 1.6994	* 1.4162	* 1.5925	* 1.4047	* 2.8701 *
10	* 1.4239	* 1.6306	* 1.4508	* 1.7912	* 1.6456	* 1.9168	* 1.3142	*
	* 1.8643	* 1.6299	* 1.8287	* 1.4867	* 1.6202	* 1.3960	* 2.0283	*
11	* 1.8107	* 1.5565	* 1.7836	* 1.4788	* 1.7350	* 1.8404	* 0.9233	*
	* 1.4736	* 1.7104	* 1.4929	* 1.7941	* 1.5332	* 1.4482	* 2.8641	*
12	* 1.7395	* 1.8556	* 1.6328	* 1.7284	* 1.7414	* 1.0381	*	
	* 1.5385	* 1.4407	* 1.6324	* 1.5389	* 1.5239	* 2.5437	*	
13	* 1.5342	* 1.6582	* 1.9004	* 1.8297	* 1.0364	*		
	* 1.7403	* 1.6123	* 1.4075	* 1.4563	* 2.5477	*		
14	* 1.8877	* 1.8948	* 1.3016	* 0.9158	*			
	* 1.4210	* 1.4147	* 2.0473	* 2.8867	*			
15	* 1.0118	* 0.9089	* F-SUB-Q					
	* 2.6281	* 2.9228	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 94 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6082	* 1.4365	* 1.3751	* 1.7370	* 1.6801	* 1.4827	* 1.8138	* 0.9885 *
	* 1.5956	* 1.7842	* 1.8619	* 1.4801	* 1.5344	* 1.7345	* 1.4223	* 2.5878 *
9	* 1.4365	* 1.5200	* 1.5665	* 1.5125	* 1.8139	* 1.6217	* 1.8315	* 0.9159 *
	* 1.7842	* 1.6873	* 1.6353	* 1.6975	* 1.4207	* 1.5886	* 1.4081	* 2.7918 *
10	* 1.3751	* 1.5623	* 1.4040	* 1.7198	* 1.5904	* 1.8434	* 1.2925	*
	* 1.8619	* 1.6397	* 1.8224	* 1.4925	* 1.6159	* 1.3983	* 1.9863	*
11	* 1.7370	* 1.5017	* 1.7122	* 1.4328	* 1.6675	* 1.7707	* 0.9175	*
	* 1.4801	* 1.7089	* 1.4989	* 1.7872	* 1.5381	* 1.4508	* 2.7792	*
12	* 1.6801	* 1.7810	* 1.5777	* 1.6608	* 1.6750	* 1.0275	*	
	* 1.5344	* 1.4462	* 1.6285	* 1.5442	* 1.5280	* 2.4796	*	
13	* 1.4827	* 1.6007	* 1.8271	* 1.7601	* 1.0252	*		
	* 1.7345	* 1.6088	* 1.4102	* 1.4592	* 2.4848	*		
14	* 1.8138	* 1.8177	* 1.2800	* 0.9088	*			
	* 1.4223	* 1.4185	* 2.0050	* 2.8050	*			
15	* 0.9885	* 0.9004	* F-SUB-Q					
	* 2.5878	* 2.8387	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6196	* 1.4317	* 1.3660	* 1.7533	* 1.6825	* 1.4779	* 1.8398	* 0.9709 *
	* 1.5304	* 1.7291	* 1.8099	* 1.4162	* 1.4801	* 1.6818	* 1.3547	* 2.5520 *
9	* 1.4317	* 1.5192	* 1.5809	* 1.5066	* 1.8321	* 1.6256	* 1.8613	* 0.8872 *
	* 1.7291	* 1.6305	* 1.5665	* 1.6466	* 1.3590	* 1.5320	* 1.3387	* 2.7922 *
10	* 1.3660	* 1.5763	* 1.3932	* 1.7368	* 1.5873	* 1.8667	* 1.2612	*
	* 1.8099	* 1.5710	* 1.7749	* 1.4288	* 1.5652	* 1.3351	* 1.9691	*
11	* 1.7533	* 1.4958	* 1.7289	* 1.4242	* 1.6869	* 1.7919	* 0.8808	*
	* 1.4162	* 1.6582	* 1.4352	* 1.7377	* 1.4720	* 1.3874	* 2.8078	*
12	* 1.6825	* 1.7981	* 1.5742	* 1.6793	* 1.6932	* 0.9946	*	
	* 1.4801	* 1.3841	* 1.5780	* 1.4783	* 1.4645	* 2.4851	*	
13	* 1.4779	* 1.6036	* 1.8496	* 1.7808	* 0.9926	*		
	* 1.6818	* 1.5526	* 1.3471	* 1.3959	* 2.4902	*		
14	* 1.8398	* 1.8466	* 1.2483	* 0.8734	*			
	* 1.3547	* 1.3492	* 1.9891	* 2.8315	*			
15	* 0.9709	* 0.8692	* F-SUB-Q					
	* 2.5520	* 2.8490	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 95 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5731	* 1.3910	* 1.3254	* 1.7022	* 1.6357	* 1.4341	* 1.7869	* 0.9391 *
	* 1.5110	* 1.7067	* 1.7893	* 1.3988	* 1.4597	* 1.6623	* 1.3374	* 2.5334 *
9	* 1.3910	* 1.4768	* 1.5344	* 1.4622	* 1.7791	* 1.5795	* 1.8072	* 0.8589 *
	* 1.7067	* 1.6085	* 1.5484	* 1.6275	* 1.3421	* 1.5121	* 1.3220	* 2.7695 *
10	* 1.3254	* 1.5298	* 1.3510	* 1.6856	* 1.5414	* 1.8142	* 1.2223	*
	* 1.7893	* 1.5530	* 1.7560	* 1.4120	* 1.5460	* 1.3173	* 1.9497	*
11	* 1.7022	* 1.4513	* 1.6778	* 1.3816	* 1.6376	* 1.7413	* 0.8521	*
	* 1.3988	* 1.6393	* 1.4185	* 1.7186	* 1.4552	* 1.3697	* 2.7880	*
12	* 1.6357	* 1.7452	* 1.5283	* 1.6296	* 1.6437	* 0.9643	*	
	* 1.4597	* 1.3677	* 1.5590	* 1.4616	* 1.4479	* 2.4621	*	
13	* 1.4341	* 1.5576	* 1.7972	* 1.7303	* 0.9623	*		
	* 1.6623	* 1.5330	* 1.3296	* 1.3783	* 2.4672	*		
14	* 1.7869	* 1.7923	* 1.2094	* 0.8447	*			
	* 1.3374	* 1.3329	* 1.9702	* 2.8122	*			
15	* 0.9391	* 0.8408	* F-SUB-Q					
	* 2.5334	* 2.8284	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5168	* 1.3453	* 1.2780	* 1.6328	* 1.5730	* 1.3789	* 1.7007	* 0.8956 *
	* 1.5145	* 1.7054	* 1.7941	* 1.4092	* 1.4666	* 1.6714	* 1.3581	* 2.5712 *
9	* 1.3453	* 1.4248	* 1.4814	* 1.4085	* 1.7060	* 1.5154	* 1.7151	* 0.8377 *
	* 1.7054	* 1.6113	* 1.5504	* 1.6333	* 1.3525	* 1.5231	* 1.3463	* 2.7484 *
10	* 1.2780	* 1.4770	* 1.3004	* 1.6144	* 1.4825	* 1.7310	* 1.1729	*
	* 1.7941	* 1.5550	* 1.7639	* 1.4250	* 1.5536	* 1.3341	* 1.9649	*
11	* 1.6328	* 1.3977	* 1.6069	* 1.3278	* 1.5641	* 1.6711	* 0.8168	*
	* 1.4092	* 1.6455	* 1.4316	* 1.7290	* 1.4726	* 1.3797	* 2.8150	*
12	* 1.5730	* 1.6781	* 1.4699	* 1.5563	* 1.5774	* 0.9419	*	
	* 1.4666	* 1.3758	* 1.5667	* 1.4799	* 1.4591	* 2.4396	*	
13	* 1.3789	* 1.4942	* 1.7146	* 1.6604	* 0.9399	*		
	* 1.6714	* 1.5445	* 1.3468	* 1.3885	* 2.4448	*		
14	* 1.7007	* 1.7003	* 1.1605	* 0.8096	*			
	* 1.3581	* 1.3579	* 1.9858	* 2.8400	*			
15	* 0.8956	* 0.8042	* F-SUB-Q					
	* 2.5712	* 2.8627	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 96 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4414	* 1.2856	* 1.2171	* 1.5322	* 1.4841	* 1.3030	* 1.5733	* 0.8335 *
	* 1.5519	* 1.7378	* 1.8352	* 1.4623	* 1.5133	* 1.7230	* 1.4297	* 2.6940 *
9	* 1.2856	* 1.3542	* 1.4107	* 1.3386	* 1.6015	* 1.4245	* 1.5778	* 0.7785 *
	* 1.7378	* 1.6506	* 1.5855	* 1.6735	* 1.4024	* 1.5774	* 1.4256	* 2.8837 *
10	* 1.2171	* 1.4068	* 1.2360	* 1.5108	* 1.4038	* 1.6150	* 1.1052	*
	* 1.8352	* 1.5900	* 1.8078	* 1.4829	* 1.5975	* 1.3921	* 2.0320	*
11	* 1.5322	* 1.3285	* 1.5038	* 1.2567	* 1.4590	* 1.5697	* 0.7708	*
	* 1.4623	* 1.6859	* 1.4896	* 1.7797	* 1.5374	* 1.4302	* 2.9085	*
12	* 1.4841	* 1.5845	* 1.3922	* 1.4518	* 1.4847	* 0.8867	*	
	* 1.5133	* 1.4187	* 1.6107	* 1.5449	* 1.5102	* 2.5256	*	
13	* 1.3030	* 1.4050	* 1.5981	* 1.5597	* 0.8847	*		
	* 1.7230	* 1.5991	* 1.4067	* 1.4394	* 2.5313	*		
14	* 1.5733	* 1.5668	* 1.0935	* 0.7637	*			
	* 1.4297	* 1.4357	* 2.0537	* 2.9355	*			
15	* 0.8335	* 0.7532	* F-SUB-Q					
	* 2.6940	* 2.9805	* M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3302	* 1.2034	* 1.1403	* 1.4142	* 1.3699	* 1.1956	* 1.3998	* 0.7462 *
	* 1.6490	* 1.8208	* 1.9206	* 1.5525	* 1.6067	* 1.8413	* 1.5757	* 2.9546 *
9	* 1.2034	* 1.2694	* 1.3045	* 1.2524	* 1.4715	* 1.3075	* 1.4034	* 0.7000 *
	* 1.8208	* 1.7259	* 1.6807	* 1.7532	* 1.4940	* 1.6848	* 1.5718	* 3.1488 *
10	* 1.1403	* 1.3012	* 1.1546	* 1.3897	* 1.3059	* 1.4659	* 1.0021	*
	* 1.9206	* 1.6850	* 1.8974	* 1.5798	* 1.6829	* 1.5032	* 2.1986	*
11	* 1.4142	* 1.2436	* 1.3836	* 1.1676	* 1.3294	* 1.4186	* 0.7069	*
	* 1.5525	* 1.7653	* 1.5867	* 1.8778	* 1.6538	* 1.5513	* 3.1128	*
12	* 1.3699	* 1.4541	* 1.2957	* 1.3231	* 1.3548	* 0.8180	*	
	* 1.6067	* 1.5118	* 1.6961	* 1.6604	* 1.6224	* 2.6861	*	
13	* 1.1956	* 1.2903	* 1.4512	* 1.4098	* 0.8160	*		
	* 1.8413	* 1.7072	* 1.5184	* 1.5609	* 2.6924	*		
14	* 1.3998	* 1.3939	* 0.9918	* 0.7004	*			
	* 1.5757	* 1.5825	* 2.2213	* 3.1415	*			
15	* 0.7462	* 0.6794	* F-SUB-Q					
	* 2.9546	* 3.2443	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 97 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 75 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1786 *	* 1.0027 *	* 0.9591 *	* 1.2232 *	* 1.1335 *	* 0.9669 *	* 1.1276 *	* 0.5926 *
	* 1.8343 *	* 2.1558 *	* 2.2520 *	* 1.7687 *	* 1.9142 *	* 2.2457 *	* 1.9296 *	* 3.6741 *
9	* 1.0027 *	* 1.0771 *	* 1.1451 *	* 1.0544 *	* 1.2866 *	* 1.0771 *	* 1.1158 *	* 0.5587 *
	* 2.1558 *	* 2.0056 *	* 1.8861 *	* 2.0530 *	* 1.6845 *	* 2.0169 *	* 1.9499 *	* 3.8971 *
10	* 0.9591 *	* 1.1440 *	* 0.9676 *	* 1.2070 *	* 1.0871 *	* 1.2229 *	* 0.8029 *	
	* 2.2520 *	* 1.8880 *	* 2.2328 *	* 1.7924 *	* 1.9930 *	* 1.7759 *	* 2.7080 *	
11	* 1.2232 *	* 1.0474 *	* 1.2012 *	* 0.9715 *	* 1.1428 *	* 1.1276 *	* 0.5834 *	
	* 1.7687 *	* 2.0665 *	* 1.8010 *	* 2.2256 *	* 1.8951 *	* 1.9242 *	* 3.7240 *	
12	* 1.1335 *	* 1.2699 *	* 1.0792 *	* 1.1391 *	* 1.1043 *	* 0.6807 *		
	* 1.9142 *	* 1.7066 *	* 2.0075 *	* 1.9013 *	* 1.9620 *	* 3.1855 *		
13	* 0.9669 *	* 1.0639 *	* 1.2123 *	* 1.1210 *	* 0.6790 *			
	* 2.2457 *	* 2.0420 *	* 1.7914 *	* 1.9356 *	* 3.1938 *			
14	* 1.1276 *	* 1.1078 *	* 0.7953 *	* 0.5781 *				
	* 1.9296 *	* 1.9640 *	* 2.7342 *	* 3.7586 *				
15	* 0.5926 *	* 0.5484 *	F-SUB-Q					
	* 3.6741 *	* 3.9706 *	M-SUB-Q					

AT 75% POWER, 75 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5060 *	* 0.4505 *	* 0.4567 *	* 0.5402 *	* 0.5041 *	* 0.4460 *	* 0.4437 *	* 0.2658 *
	* 4.2271 *	* 4.7497 *	* 4.6826 *	* 3.9606 *	* 4.2523 *	* 4.8197 *	* 4.8548 *	* 8.1157 *
9	* 0.4505 *	* 0.4789 *	* 0.5167 *	* 0.4846 *	* 0.5459 *	* 0.4748 *	* 0.4340 *	* 0.2482 *
	* 4.7497 *	* 4.4634 *	* 4.1358 *	* 4.4200 *	* 3.9278 *	* 4.5258 *	* 4.9632 *	* 8.6939 *
10	* 0.4567 *	* 0.5167 *	* 0.4607 *	* 0.5318 *	* 0.4879 *	* 0.4975 *	* 0.3622 *	
	* 4.6826 *	* 4.1362 *	* 4.6419 *	* 4.0247 *	* 4.3942 *	* 4.3192 *	* 5.9444 *	
11	* 0.5402 *	* 0.4813 *	* 0.5301 *	* 0.4583 *	* 0.4990 *	* 0.4439 *	* 0.2633 *	
	* 3.9606 *	* 4.4499 *	* 4.0365 *	* 4.6705 *	* 4.2961 *	* 4.8390 *	* 8.1758 *	
12	* 0.5041 *	* 0.5404 *	* 0.4845 *	* 0.4974 *	* 0.4433 *	* 0.3179 *		
	* 4.2523 *	* 3.9682 *	* 4.4252 *	* 4.3099 *	* 4.8393 *	* 6.7562 *		
13	* 0.4460 *	* 0.4697 *	* 0.4933 *	* 0.4415 *	* 0.3170 *			
	* 4.8197 *	* 4.5747 *	* 4.3559 *	* 4.8648 *	* 6.7768 *			
14	* 0.4437 *	* 0.4311 *	* 0.3590 *	* 0.2610 *				
	* 4.8548 *	* 4.9963 *	* 5.9976 *	* 8.2482 *				
15	* 0.2658 *	* 0.2470 *	F-SUB-Q					
	* 8.1157 *	* 8.7341 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 98 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5067	* 0.4641	* 0.4428	* 0.5130	* 0.4762	* 0.4031	* 0.2944	* 0.1605 *
	* 3.6093	* 3.9377	* 4.1084	* 3.5451	* 3.8226	* 4.4431	* 4.5131	* 7.0576 *
9	* 0.4641	* 0.4482	* 0.4757	* 0.4624	* 0.5077	* 0.4365	* 0.3437	* 0.1709 *
	* 3.9377	* 4.0053	* 3.7280	* 3.9315	* 3.5813	* 4.1602	* 4.6392	* 7.5083 *
10	* 0.4428	* 0.4756	* 0.3646	* 0.4832	* 0.4589	* 0.4623	* 0.3268	*
	* 4.1084	* 3.7269	* 4.1119	* 3.7387	* 3.9454	* 3.9176	* 5.4782	*
11	* 0.5130	* 0.4609	* 0.4823	* 0.4281	* 0.4793	* 0.4328	* 0.2687	*
	* 3.5451	* 3.9439	* 3.7431	* 4.1973	* 3.7540	* 4.1569	* 6.6860	*
12	* 0.4762	* 0.5051	* 0.4576	* 0.4788	* 0.4403	* 0.3266	*	*
	* 3.8226	* 3.5993	* 3.9566	* 3.7581	* 4.0689	* 5.4666	*	*
13	* 0.4031	* 0.4344	* 0.4608	* 0.4318	* 0.3252	*	*	*
	* 4.4431	* 4.1800	* 3.9310	* 4.1664	* 5.4892	*	*	*
14	* 0.2944	* 0.3422	* 0.3254	* 0.2675	*	*	*	*
	* 4.5131	* 4.6522	* 5.4990	* 6.7154	*	*	*	*
15	* 0.1605	* 0.1694	* F-SUB-Q					
	* 7.0576	* 7.5591	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0530	* 0.9122	* 0.8480	* 1.0264	* 0.9568	* 0.7907	* 0.6615	* 0.3355 *
	* 1.8090	* 2.0879	* 2.2343	* 1.8435	* 1.9804	* 2.3067	* 2.0644	* 3.5532 *
9	* 0.9122	* 0.8932	* 0.9419	* 0.9137	* 1.0637	* 0.8854	* 0.7739	* 0.3483 *
	* 2.0879	* 2.0438	* 1.9338	* 2.0712	* 1.7793	* 2.1349	* 2.0972	* 3.8303 *
10	* 0.8480	* 0.9416	* 0.7003	* 0.9687	* 0.9221	* 0.9969	* 0.6565	*
	* 2.2343	* 1.9329	* 2.2082	* 1.9200	* 2.0437	* 1.8897	* 2.7959	*
11	* 1.0264	* 0.9107	* 0.9669	* 0.8291	* 0.9678	* 0.9558	* 0.5363	*
	* 1.8435	* 2.0783	* 1.9227	* 2.2508	* 1.9315	* 1.9542	* 3.4850	*
12	* 0.9568	* 1.0573	* 0.9194	* 0.9667	* 0.9409	* 0.6261	*	*
	* 1.9804	* 1.7901	* 2.0498	* 1.9338	* 1.9760	* 2.9607	*	*
13	* 0.7907	* 0.8808	* 0.9936	* 0.9537	* 0.6242	*	*	*
	* 2.3067	* 2.1463	* 1.8961	* 1.9586	* 2.9698	*	*	*
14	* 0.6615	* 0.7706	* 0.6536	* 0.5338	*	*	*	*
	* 2.0644	* 2.1029	* 2.8070	* 3.5015	*	*	*	*
15	* 0.3355	* 0.3426	* F-SUB-Q					
	* 3.5532	* 3.8862	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 99 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1715	* 1.0634	* 0.9959	* 1.1685	* 1.1249	* 0.9577	* 0.8456	* 0.4391
	* 1.6976	* 1.8705	* 1.9819	* 1.6920	* 1.7597	* 1.9772	* 1.7850	* 2.9576
9	* 1.0634	* 1.0476	* 1.0508	* 1.0776	* 1.1927	* 1.0557	* 0.9613	* 0.4461
	* 1.8704	* 1.8193	* 1.8180	* 1.8365	* 1.6596	* 1.8717	* 1.7706	* 3.1801
10	* 0.9959	* 1.0500	* 0.8405	* 1.1108	* 1.0952	* 1.1640	* 0.8163	*
	* 1.9819	* 1.8177	* 1.9576	* 1.7525	* 1.7962	* 1.6828	* 2.3364	*
11	* 1.1685	* 1.0735	* 1.1082	* 0.9830	* 1.1023	* 1.1426	* 0.6607	*
	* 1.6920	* 1.8436	* 1.7559	* 1.9840	* 1.7651	* 1.6980	* 2.9443	*
12	* 1.1249	* 1.1836	* 1.0915	* 1.1006	* 1.1135	* 0.7522	*	*
	* 1.7597	* 1.6725	* 1.8025	* 1.7683	* 1.7398	* 2.5567	*	*
13	* 0.9577	* 1.0495	* 1.1602	* 1.1398	* 0.7505	*	*	*
	* 1.9772	* 1.8823	* 1.6885	* 1.7023	* 2.5624	*	*	*
14	* 0.8456	* 0.9568	* 0.8126	* 0.6575	*	*	*	*
	* 1.7850	* 1.7761	* 2.3463	* 2.9587	*	*	*	*
15	* 0.4391	* 0.4405	* F-SUB-Q					
	* 2.9576	* 3.2164	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3553	* 1.1991	* 1.1317	* 1.3677	* 1.2899	* 1.1067	* 1.0498	* 0.5449
	* 1.5509	* 1.7548	* 1.8450	* 1.5308	* 1.6236	* 1.8096	* 1.5503	* 2.6814
9	* 1.1991	* 1.1901	* 1.2292	* 1.2265	* 1.4003	* 1.2220	* 1.1757	* 0.5404
	* 1.7548	* 1.6859	* 1.6480	* 1.7111	* 1.4964	* 1.7042	* 1.5379	* 2.9287
10	* 1.1317	* 1.2289	* 0.9615	* 1.3113	* 1.2547	* 1.3766	* 0.9414	*
	* 1.8450	* 1.6486	* 1.8216	* 1.5753	* 1.6586	* 1.4977	* 2.1478	*
11	* 1.3677	* 1.2213	* 1.3078	* 1.1235	* 1.2966	* 1.3600	* 0.7369	*
	* 1.5308	* 1.7188	* 1.5789	* 1.8305	* 1.5753	* 1.4937	* 2.7760	*
12	* 1.2899	* 1.3884	* 1.2498	* 1.2943	* 1.3004	* 0.8340	*	*
	* 1.6236	* 1.5096	* 1.6653	* 1.5792	* 1.5648	* 2.4137	*	*
13	* 1.1067	* 1.2140	* 1.3717	* 1.3565	* 0.8325	*	*	*
	* 1.8096	* 1.7151	* 1.5034	* 1.4977	* 2.4181	*	*	*
14	* 1.0498	* 1.1699	* 0.9366	* 0.7333	*	*	*	*
	* 1.5503	* 1.5431	* 2.1581	* 2.7899	*	*	*	*
15	* 0.5449	* 0.5349	* F-SUB-Q					
	* 2.6814	* 2.9729	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 100 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4463 *	* 1.2679 *	* 1.2135 *	* 1.4802 *	* 1.3851 *	* 1.2062 *	* 1.2559 *	* 0.6818 *
	* 1.5557 *	* 1.7739 *	* 1.8439 *	* 1.5168 *	* 1.6110 *	* 1.7956 *	* 1.5031 *	* 2.6192 *
9	* 1.2679 *	* 1.2840 *	* 1.3472 *	* 1.3165 *	* 1.5208 *	* 1.3235 *	* 1.3348 *	* 0.6504 *
	* 1.7739 *	* 1.6852 *	* 1.6272 *	* 1.7050 *	* 1.4746 *	* 1.6772 *	* 1.4957 *	* 2.8576 *
10	* 1.2135 *	* 1.3464 *	* 1.1213 *	* 1.4370 *	* 1.3499 *	* 1.4962 *	* 1.0400 *	
	* 1.8439 *	* 1.6279 *	* 1.8173 *	* 1.5442 *	* 1.6532 *	* 1.4687 *	* 2.0916 *	
11	* 1.4802 *	* 1.3104 *	* 1.4330 *	* 1.2144 *	* 1.4085 *	* 1.4774 *	* 0.7997 *	
	* 1.5168 *	* 1.7123 *	* 1.5484 *	* 1.8169 *	* 1.5401 *	* 1.4551 *	* 2.7207 *	
12	* 1.3851 *	* 1.5069 *	* 1.3444 *	* 1.4058 *	* 1.4092 *	* 0.9003 *		
	* 1.6110 *	* 1.4903 *	* 1.6606 *	* 1.5442 *	* 1.5321 *	* 2.3619 *		
13	* 1.2062 *	* 1.3143 *	* 1.4900 *	* 1.4734 *	* 0.8989 *			
	* 1.7956 *	* 1.6886 *	* 1.4748 *	* 1.4593 *	* 2.3659 *			
14	* 1.2559 *	* 1.3295 *	* 1.0347 *	* 0.7953 *				
	* 1.5031 *	* 1.5012 *	* 2.1021 *	* 2.7364 *				
15	* 0.6818 *	* 0.6421 *	F-SUB-Q					
	* 2.6192 *	* 2.8930 *	M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5170 *	* 1.3324 *	* 1.2846 *	* 1.5733 *	* 1.4679 *	* 1.2953 *	* 1.4761 *	* 0.8257 *
	* 1.5771 *	* 1.7900 *	* 1.8503 *	* 1.5055 *	* 1.6029 *	* 1.7962 *	* 1.4906 *	* 2.6148 *
9	* 1.3324 *	* 1.3868 *	* 1.4498 *	* 1.3943 *	* 1.6208 *	* 1.4114 *	* 1.5116 *	* 0.7691 *
	* 1.7900 *	* 1.6959 *	* 1.6243 *	* 1.6996 *	* 1.4570 *	* 1.6610 *	* 1.4820 *	* 2.8376 *
10	* 1.2846 *	* 1.4490 *	* 1.2641 *	* 1.5449 *	* 1.4334 *	* 1.5950 *	* 1.1255 *	
	* 1.8503 *	* 1.6253 *	* 1.8247 *	* 1.5259 *	* 1.6486 *	* 1.4731 *	* 2.0651 *	
11	* 1.5733 *	* 1.3875 *	* 1.5403 *	* 1.2964 *	* 1.5013 *	* 1.5715 *	* 0.8522 *	
	* 1.5055 *	* 1.7079 *	* 1.5305 *	* 1.8217 *	* 1.5466 *	* 1.4580 *	* 2.7329 *	
12	* 1.4679 *	* 1.6053 *	* 1.4274 *	* 1.4983 *	* 1.4984 *	* 0.9567 *		
	* 1.6029 *	* 1.4725 *	* 1.6557 *	* 1.5510 *	* 1.5385 *	* 2.3638 *		
13	* 1.2953 *	* 1.4012 *	* 1.5881 *	* 1.5670 *	* 0.9553 *			
	* 1.7962 *	* 1.6733 *	* 1.4800 *	* 1.4624 *	* 2.3675 *			
14	* 1.4761 *	* 1.5056 *	* 1.1195 *	* 0.8473 *				
	* 1.4906 *	* 1.4878 *	* 2.0761 *	* 2.7492 *				
15	* 0.8257 *	* 0.7581 *	F-SUB-Q					
	* 2.6148 *	* 2.8782 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 101 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6001	* 1.4001	* 1.3565	* 1.6772	* 1.5592	* 1.3807	* 1.6534	* 0.9204 *
	* 1.5628	* 1.7890	* 1.8426	* 1.4779	* 1.5848	* 1.7820	* 1.4583	* 2.6083 *
9	* 1.4001	* 1.4791	* 1.5562	* 1.4743	* 1.7320	* 1.5026	* 1.6672	* 0.8456 *
	* 1.7890	* 1.6879	* 1.6000	* 1.6848	* 1.4274	* 1.6368	* 1.4508	* 2.8453 *
10	* 1.3565	* 1.5551	* 1.3686	* 1.6571	* 1.5190	* 1.7064	* 1.1946	*
	* 1.8426	* 1.6010	* 1.8135	* 1.4953	* 1.6258	* 1.4331	* 2.0506	*
11	* 1.6772	* 1.4671	* 1.6519	* 1.3774	* 1.6036	* 1.6793	* 0.8900	*
	* 1.4779	* 1.6938	* 1.5002	* 1.7948	* 1.5189	* 1.4331	* 2.7318	*
12	* 1.5592	* 1.7146	* 1.5122	* 1.6003	* 1.5965	* 0.9994	*	
	* 1.5848	* 1.4426	* 1.6334	* 1.5234	* 1.5187	* 2.3949	*	
13	* 1.3807	* 1.4910	* 1.6986	* 1.6744	* 0.9980	*		
	* 1.7820	* 1.6499	* 1.4399	* 1.4376	* 2.3983	*		
14	* 1.6534	* 1.6604	* 1.1881	* 0.8848	*			
	* 1.4583	* 1.4568	* 2.0620	* 2.7484	*			
15	* 0.9204	* 0.8352	* F-SUB-Q					
	* 2.6083	* 2.8803	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6446	* 1.4386	* 1.3999	* 1.7395	* 1.6170	* 1.4328	* 1.7523	* 0.9756 *
	* 1.5910	* 1.8203	* 1.8664	* 1.4905	* 1.5966	* 1.8011	* 1.4615	* 2.6206 *
9	* 1.4386	* 1.5306	* 1.6188	* 1.5246	* 1.7999	* 1.5609	* 1.7576	* 0.8953 *
	* 1.8203	* 1.7107	* 1.6138	* 1.7024	* 1.4355	* 1.6454	* 1.4569	* 2.8591 *
10	* 1.3999	* 1.6176	* 1.4224	* 1.7232	* 1.5733	* 1.7761	* 1.2451	*
	* 1.8664	* 1.6150	* 1.8341	* 1.5014	* 1.6410	* 1.4388	* 2.0591	*
11	* 1.7395	* 1.5177	* 1.7175	* 1.4293	* 1.6664	* 1.7478	* 0.9226	*
	* 1.4905	* 1.7105	* 1.5065	* 1.8098	* 1.5261	* 1.4396	* 2.7496	*
12	* 1.6170	* 1.7809	* 1.5659	* 1.6628	* 1.6586	* 1.0358	*	
	* 1.5966	* 1.4521	* 1.6490	* 1.5307	* 1.5272	* 2.4202	*	
13	* 1.4328	* 1.5483	* 1.7675	* 1.7424	* 1.0344	*		
	* 1.8011	* 1.6590	* 1.4461	* 1.4442	* 2.4235	*		
14	* 1.7523	* 1.7503	* 1.2381	* 0.9170	*			
	* 1.4615	* 1.4632	* 2.0710	* 2.7666	*			
15	* 0.9756	* 0.8842	* F-SUB-Q					
	* 2.6206	* 2.8945	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 102 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7055 *	* 1.4823 *	* 1.4455 *	* 1.8160 *	* 1.6796 *	* 1.4853 *	* 1.8528 *	* 1.0149 *
	* 1.6090 *	* 1.8574 *	* 1.9006 *	* 1.4990 *	* 1.6154 *	* 1.8240 *	* 1.4477 *	* 2.6443 *
9	* 1.4823 *	* 1.5841 *	* 1.6899 *	* 1.5779 *	* 1.8824 *	* 1.6228 *	* 1.8513 *	* 0.9262 *
	* 1.8574 *	* 1.7357 *	* 1.6230 *	* 1.7281 *	* 1.4415 *	* 1.6628 *	* 1.4478 *	* 2.8982 *
10	* 1.4455 *	* 1.6886 *	* 1.4725 *	* 1.8013 *	* 1.6311 *	* 1.8613 *	* 1.2816 *	
	* 1.9006 *	* 1.6243 *	* 1.8592 *	* 1.5077 *	* 1.6573 *	* 1.4345 *	* 2.0995 *	
11	* 1.8160 *	* 1.5706 *	* 1.7950 *	* 1.4810 *	* 1.7430 *	* 1.8321 *	* 0.9412 *	
	* 1.4990 *	* 1.7368 *	* 1.5132 *	* 1.8263 *	* 1.5274 *	* 1.4402 *	* 2.8186 *	
12	* 1.6796 *	* 1.8618 *	* 1.6230 *	* 1.7390 *	* 1.7322 *	* 1.0612 *		
	* 1.6154 *	* 1.4544 *	* 1.6658 *	* 1.5322 *	* 1.5326 *	* 2.4816 *		
13	* 1.4853 *	* 1.6090 *	* 1.8519 *	* 1.8262 *	* 1.0600 *			
	* 1.8240 *	* 1.6772 *	* 1.4420 *	* 1.4449 *	* 2.4844 *			
14	* 1.8528 *	* 1.8434 *	* 1.2738 *	* 0.9362 *				
	* 1.4477 *	* 1.4540 *	* 2.1124 *	* 2.8338 *				
15	* 1.0149 *	* 0.9110 *	F-SUB-Q					
	* 2.6443 *	* 2.9464 *	M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6689 *	* 1.4646 *	* 1.4345 *	* 1.7890 *	* 1.6689 *	* 1.4772 *	* 1.8335 *	* 1.0284 *
	* 1.7265 *	* 1.9709 *	* 2.0111 *	* 1.5980 *	* 1.7065 *	* 1.9295 *	* 1.5432 *	* 2.7493 *
9	* 1.4646 *	* 1.5671 *	* 1.6619 *	* 1.5668 *	* 1.8565 *	* 1.6136 *	* 1.8328 *	* 0.9517 *
	* 1.9709 *	* 1.8428 *	* 1.7332 *	* 1.8249 *	* 1.5335 *	* 1.7529 *	* 1.5431 *	* 2.9722 *
10	* 1.4345 *	* 1.6604 *	* 1.4609 *	* 1.7763 *	* 1.6221 *	* 1.8378 *	* 1.3041 *	
	* 2.0111 *	* 1.7347 *	* 1.9673 *	* 1.6027 *	* 1.7504 *	* 1.5276 *	* 2.1661 *	
11	* 1.7890 *	* 1.5588 *	* 1.7698 *	* 1.4719 *	* 1.7204 *	* 1.8092 *	* 0.9687 *	
	* 1.5980 *	* 1.8343 *	* 1.6086 *	* 1.9290 *	* 1.6300 *	* 1.5379 *	* 2.8807 *	
12	* 1.6689 *	* 1.8356 *	* 1.6136 *	* 1.7163 *	* 1.7149 *	* 1.0925 *		
	* 1.7065 *	* 1.5466 *	* 1.7596 *	* 1.6351 *	* 1.6323 *	* 2.5454 *		
13	* 1.4772 *	* 1.5996 *	* 1.8281 *	* 1.8032 *	* 1.0907 *			
	* 1.9295 *	* 1.7683 *	* 1.5357 *	* 1.5430 *	* 2.5497 *			
14	* 1.8335 *	* 1.8248 *	* 1.2961 *	* 0.9625 *				
	* 1.5432 *	* 1.5499 *	* 2.1792 *	* 2.8990 *				
15	* 1.0284 *	* 0.9383 *	F-SUB-Q					
	* 2.7493 *	* 3.0143 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 103 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7305	* 1.5006	* 1.4693	* 1.8655	* 1.7243	* 1.5199	* 1.9310	* 1.0501 *
	* 1.7600	* 2.0328	* 2.0738	* 1.6222	* 1.7464	* 1.9788	* 1.5434	* 2.8345 *
9	* 1.5006	* 1.6129	* 1.7309	* 1.6119	* 1.9398	* 1.6691	* 1.9227	* 0.9603 *
	* 2.0328	* 1.8900	* 1.7568	* 1.8770	* 1.5523	* 1.7915	* 1.5475	* 3.0996 *
10	* 1.4693	* 1.7293	* 1.5013	* 1.8543	* 1.6727	* 1.9263	* 1.3198	*
	* 2.0738	* 1.7584	* 2.0214	* 1.6251	* 1.7980	* 1.5440	* 2.2577	*
11	* 1.8655	* 1.6035	* 1.8471	* 1.5156	* 1.7993	* 1.8985	* 0.9685	*
	* 1.6222	* 1.8869	* 1.6313	* 1.9843	* 1.6514	* 1.5544	* 3.0510	*
12	* 1.7243	* 1.9170	* 1.6635	* 1.7948	* 1.7902	* 1.0959	*	
	* 1.7464	* 1.5648	* 1.8078	* 1.6567	* 1.6561	* 2.6781	*	
13	* 1.5199	* 1.6537	* 1.9157	* 1.8920	* 1.0947	*		
	* 1.9788	* 1.8080	* 1.5523	* 1.5595	* 2.6808	*		
14	* 1.9310	* 1.9140	* 1.3112	* 0.9629	*			
	* 1.5434	* 1.5545	* 2.2721	* 3.0678	*			
15	* 1.0501	* 0.9461	* F-SUB-Q					
	* 2.8345	* 3.1453	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7281	* 1.4979	* 1.4700	* 1.8747	* 1.7329	* 1.5252	* 1.9523	* 1.0591 *
	* 1.7791	* 2.0510	* 2.0882	* 1.6395	* 1.7765	* 2.0200	* 1.5897	* 2.9281 *
9	* 1.4979	* 1.6142	* 1.7362	* 1.6163	* 1.9518	* 1.6792	* 1.9414	* 0.9701 *
	* 2.0510	* 1.9051	* 1.7708	* 1.9001	* 1.5766	* 1.8332	* 1.5953	* 3.1939 *
10	* 1.4700	* 1.7345	* 1.5042	* 1.8655	* 1.6810	* 1.9436	* 1.3306	*
	* 2.0882	* 1.7726	* 2.0439	* 1.6460	* 1.8261	* 1.5815	* 2.3161	*
11	* 1.8747	* 1.6074	* 1.8580	* 1.5218	* 1.8152	* 1.9176	* 0.9783	*
	* 1.6395	* 1.9104	* 1.6527	* 2.0139	* 1.6883	* 1.5992	* 3.1338	*
12	* 1.7329	* 1.9287	* 1.6713	* 1.8090	* 1.8065	* 1.1075	*	
	* 1.7765	* 1.5947	* 1.8366	* 1.6937	* 1.6944	* 2.7601	*	
13	* 1.5252	* 1.6631	* 1.9324	* 1.9108	* 1.1063	*		
	* 2.0200	* 1.8509	* 1.5906	* 1.6049	* 2.7632	*		
14	* 1.9523	* 1.9323	* 1.3220	* 0.9717	*			
	* 1.5897	* 1.6028	* 2.3312	* 3.1551	*			
15	* 1.0591	* 0.9567	* F-SUB-Q					
	* 2.9281	* 3.2384	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 104 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6794	* 1.4658	* 1.4431	* 1.8338	* 1.7059	* 1.5019	* 1.9182	* 1.0559 *
	* 1.7971	* 2.0569	* 2.0891	* 1.6478	* 1.7758	* 2.0186	* 1.5927	* 2.8905 *
9	* 1.4658	* 1.5810	* 1.6943	* 1.5891	* 1.9119	* 1.6549	* 1.9087	* 0.9779 *
	* 2.0569	* 1.9098	* 1.7818	* 1.8983	* 1.5835	* 1.8301	* 1.5982	* 3.1188 *
10	* 1.4431	* 1.6924	* 1.4774	* 1.8273	* 1.6561	* 1.9086	* 1.3316	*
	* 2.0891	* 1.7838	* 2.0413	* 1.6508	* 1.8206	* 1.5836	* 2.2771	*
11	* 1.8338	* 1.5799	* 1.8195	* 1.4983	* 1.7832	* 1.8855	* 0.9863	*
	* 1.6478	* 1.9092	* 1.6578	* 2.0044	* 1.6868	* 1.5968	* 3.0469	*
12	* 1.7059	* 1.8915	* 1.6461	* 1.7768	* 1.7778	* 1.1200	*	
	* 1.7758	* 1.5997	* 1.8315	* 1.6928	* 1.6878	* 2.6713	*	
13	* 1.5019	* 1.6387	* 1.8971	* 1.8786	* 1.1184	*		
	* 2.0186	* 1.8480	* 1.5930	* 1.6026	* 2.6753	*		
14	* 1.9182	* 1.8995	* 1.3226	* 0.9794	*			
	* 1.5927	* 1.6060	* 2.2925	* 3.0682	*			
15	* 1.0559	* 0.9634	* F-SUB-Q					
	* 2.8905	* 3.1653	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7068	* 1.4731	* 1.4521	* 1.8756	* 1.7308	* 1.5222	* 1.9834	* 1.0599 *
	* 1.7209	* 1.9912	* 2.0191	* 1.5704	* 1.7054	* 1.9436	* 1.4978	* 2.7947 *
9	* 1.4731	* 1.5964	* 1.7293	* 1.6053	* 1.9606	* 1.6825	* 1.9680	* 0.9699 *
	* 1.9912	* 1.8418	* 1.7006	* 1.8308	* 1.5058	* 1.7542	* 1.5081	* 3.0526 *
10	* 1.4521	* 1.7272	* 1.4907	* 1.8716	* 1.6776	* 1.9656	* 1.3254	*
	* 2.0191	* 1.7026	* 1.9677	* 1.5705	* 1.7510	* 1.4989	* 2.2273	*
11	* 1.8756	* 1.5955	* 1.8632	* 1.5172	* 1.8356	* 1.9455	* 0.9703	*
	* 1.5704	* 1.8416	* 1.5775	* 1.9271	* 1.5964	* 1.5079	* 3.0109	*
12	* 1.7308	* 1.9419	* 1.6670	* 1.8287	* 1.8246	* 1.1076	*	
	* 1.7054	* 1.5192	* 1.7620	* 1.6023	* 1.6015	* 2.6258	*	
13	* 1.5222	* 1.6650	* 1.9532	* 1.9381	* 1.1064	*		
	* 1.9436	* 1.7724	* 1.5082	* 1.5136	* 2.6283	*		
14	* 1.9834	* 1.9580	* 1.3159	* 0.9644	*			
	* 1.4978	* 1.5157	* 2.2433	* 3.0289	*			
15	* 1.0599	* 0.9544	* F-SUB-Q					
	* 2.7947	* 3.1013	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 105 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6923	* 1.4554	* 1.4383	* 1.8713	* 1.7238	* 1.5174	* 1.9957	* 1.0555 *
	* 1.6511	* 1.9162	* 1.9383	* 1.4992	* 1.6318	* 1.8573	* 1.4209	* 2.6660 *
9	* 1.4554	* 1.5828	* 1.7213	* 1.5941	* 1.9616	* 1.6789	* 1.9781	* 0.9640 *
	* 1.9162	* 1.7653	* 1.6238	* 1.7556	* 1.4346	* 1.6755	* 1.4321	* 2.9170 *
10	* 1.4383	* 1.7192	* 1.4789	* 1.8699	* 1.6700	* 1.9728	* 1.3160	*
	* 1.9383	* 1.6257	* 1.8849	* 1.4980	* 1.6770	* 1.4256	* 2.1348	*
11	* 1.8713	* 1.5839	* 1.8610	* 1.5103	* 1.8420	* 1.9566	* 0.9606	*
	* 1.4992	* 1.7661	* 1.5048	* 1.8447	* 1.5191	* 1.4328	* 2.8970	*
12	* 1.7238	* 1.9433	* 1.6589	* 1.8348	* 1.8297	* 1.0999	*	
	* 1.6318	* 1.4475	* 1.6878	* 1.5249	* 1.5248	* 2.5243	*	
13	* 1.5174	* 1.6608	* 1.9598	* 1.9488	* 1.0984	*		
	* 1.8573	* 1.6932	* 1.4347	* 1.4382	* 2.5273	*		
14	* 1.9957	* 1.9677	* 1.3061	* 0.9547	*			
	* 1.4209	* 1.4394	* 2.1503	* 2.9145	*			
15	* 1.0555	* 0.9464	* F-SUB-Q					
	* 2.6660	* 2.9701	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6560	* 1.4262	* 1.4095	* 1.8392	* 1.6982	* 1.4950	* 1.9709	* 1.0431 *
	* 1.6207	* 1.8786	* 1.9001	* 1.4651	* 1.5902	* 1.8065	* 1.3772	* 2.5815 *
9	* 1.4262	* 1.5522	* 1.6880	* 1.5657	* 1.9329	* 1.6547	* 1.9540	* 0.9555 *
	* 1.8786	* 1.7288	* 1.5904	* 1.7175	* 1.3984	* 1.6322	* 1.3885	* 2.8169 *
10	* 1.4095	* 1.6857	* 1.4510	* 1.8398	* 1.6441	* 1.9464	* 1.3023	*
	* 1.9001	* 1.5925	* 1.8458	* 1.4630	* 1.6372	* 1.3883	* 2.0700	*
11	* 1.8392	* 1.5553	* 1.8307	* 1.4857	* 1.8167	* 1.9318	* 0.9524	*
	* 1.4651	* 1.7283	* 1.4700	* 1.8035	* 1.4814	* 1.3954	* 2.8095	*
12	* 1.6982	* 1.9144	* 1.6327	* 1.8093	* 1.8051	* 1.0916	*	
	* 1.5902	* 1.4114	* 1.6481	* 1.4872	* 1.4872	* 2.4486	*	
13	* 1.4950	* 1.6363	* 1.9331	* 1.9238	* 1.0902	*		
	* 1.8065	* 1.6500	* 1.3974	* 1.4009	* 2.4514	*		
14	* 1.9709	* 1.9433	* 1.2923	* 0.9462	*			
	* 1.3772	* 1.3957	* 2.0855	* 2.8272	*			
15	* 1.0431	* 0.9403	* F-SUB-Q					
	* 2.5815	* 2.8612	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 106 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5839	* 1.3760	* 1.3629	* 1.7663	* 1.6445	* 1.4507	* 1.8973	* 1.0234 *
	* 1.6411	* 1.8862	* 1.9058	* 1.4773	* 1.5897	* 1.8003	* 1.3820	* 2.5422 *
9	* 1.3760	* 1.4969	* 1.6172	* 1.5144	* 1.8590	* 1.6032	* 1.8848	* 0.9496 *
	* 1.8862	* 1.7362	* 1.6079	* 1.7201	* 1.4077	* 1.6307	* 1.3909	* 2.7389 *
10	* 1.3629	* 1.6149	* 1.4024	* 1.7682	* 1.5928	* 1.8755	* 1.2862	*
	* 1.9058	* 1.6101	* 1.8505	* 1.4745	* 1.6372	* 1.3955	* 2.0281	*
11	* 1.7663	* 1.5041	* 1.7592	* 1.4392	* 1.7493	* 1.8620	* 0.9498	*
	* 1.4773	* 1.7315	* 1.4817	* 1.8044	* 1.4905	* 1.4020	* 2.7294	*
12	* 1.6445	* 1.8407	* 1.5815	* 1.7419	* 1.7423	* 1.0867	*	
	* 1.5897	* 1.4211	* 1.6484	* 1.4965	* 1.4935	* 2.3845	*	
13	* 1.4507	* 1.5851	* 1.8616	* 1.8541	* 1.0848	*		
	* 1.8003	* 1.6487	* 1.4053	* 1.4077	* 2.3885	*		
14	* 1.8973	* 1.8742	* 1.2763	* 0.9424	*			
	* 1.3820	* 1.3985	* 2.0432	* 2.7502	*			
15	* 1.0234	* 0.9345	* F-SUB-Q					
	* 2.5422	* 2.7820	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5973	* 1.3689	* 1.3544	* 1.7860	* 1.6473	* 1.4505	* 1.9358	* 1.0086 *
	* 1.5780	* 1.8384	* 1.8572	* 1.4153	* 1.5377	* 1.7454	* 1.3119	* 2.5041 *
9	* 1.3689	* 1.4954	* 1.6321	* 1.5092	* 1.8850	* 1.6077	* 1.9193	* 0.9224 *
	* 1.8384	* 1.6847	* 1.5443	* 1.6730	* 1.3454	* 1.5766	* 1.3234	* 2.7379 *
10	* 1.3544	* 1.6297	* 1.3964	* 1.7891	* 1.5910	* 1.9061	* 1.2569	*
	* 1.8572	* 1.5466	* 1.8022	* 1.4126	* 1.5891	* 1.3312	* 2.0130	*
11	* 1.7860	* 1.4986	* 1.7797	* 1.4364	* 1.7762	* 1.8956	* 0.9145	*
	* 1.4153	* 1.6845	* 1.4199	* 1.7546	* 1.4245	* 1.3366	* 2.7562	*
12	* 1.6473	* 1.8656	* 1.5793	* 1.7684	* 1.7632	* 1.0516	*	
	* 1.5377	* 1.3590	* 1.6006	* 1.4307	* 1.4330	* 2.3958	*	
13	* 1.4505	* 1.5887	* 1.8915	* 1.8873	* 1.0501	*		
	* 1.7454	* 1.5950	* 1.3408	* 1.3423	* 2.3991	*		
14	* 1.9358	* 1.9080	* 1.2466	* 0.9083	*			
	* 1.3119	* 1.3310	* 2.0294	* 2.7747	*			
15	* 1.0086	* 0.9048	* F-SUB-Q					
	* 2.5041	* 2.7902	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 107 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5482	* 1.3270	* 1.3118	* 1.7323	* 1.6010	* 1.4096	* 1.8841	* 0.9784 *
	* 1.5626	* 1.8210	* 1.8417	* 1.4010	* 1.5192	* 1.7247	* 1.2933	* 2.4796 *
9	* 1.3270	* 1.4506	* 1.5795	* 1.4632	* 1.8302	* 1.5629	* 1.8708	* 0.8956 *
	* 1.8210	* 1.6674	* 1.5325	* 1.6576	* 1.3305	* 1.5573	* 1.3027	* 2.7086 *
10	* 1.3118	* 1.5771	* 1.3524	* 1.7352	* 1.5444	* 1.8546	* 1.2205	*
	* 1.8417	* 1.5348	* 1.7876	* 1.3985	* 1.5723	* 1.3134	* 1.9909	*
11	* 1.7323	* 1.4525	* 1.7258	* 1.3926	* 1.7252	* 1.8456	* 0.8861	*
	* 1.4010	* 1.6693	* 1.4060	* 1.7389	* 1.4084	* 1.3178	* 2.7338	*
12	* 1.6010	* 1.8108	* 1.5328	* 1.7174	* 1.7125	* 1.0207	*	
	* 1.5192	* 1.3443	* 1.5840	* 1.4146	* 1.4172	* 2.3722	*	
13	* 1.4096	* 1.5440	* 1.8399	* 1.8372	* 1.0192	*		
	* 1.7247	* 1.5761	* 1.3237	* 1.3237	* 2.3754	*		
14	* 1.8841	* 1.8593	* 1.2102	* 0.8800	*			
	* 1.2933	* 1.3106	* 2.0075	* 2.7527	*			
15	* 0.9784	* 0.8779	* F-SUB-Q					
	* 2.4796	* 2.7628	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4843	* 1.2775	* 1.2577	* 1.6512	* 1.5353	* 1.3499	* 1.7864	* 0.9329 *
	* 1.5752	* 1.8283	* 1.8570	* 1.4199	* 1.5305	* 1.7404	* 1.3172	* 2.5154 *
9	* 1.2775	* 1.3917	* 1.5033	* 1.4022	* 1.7411	* 1.4972	* 1.7804	* 0.8719 *
	* 1.8283	* 1.6796	* 1.5561	* 1.6714	* 1.3500	* 1.5707	* 1.3220	* 2.6913 *
10	* 1.2577	* 1.5010	* 1.2951	* 1.6523	* 1.4788	* 1.7648	* 1.1711	*
	* 1.8570	* 1.5584	* 1.8045	* 1.4189	* 1.5867	* 1.3330	* 2.0056	*
11	* 1.6512	* 1.3921	* 1.6434	* 1.3318	* 1.6383	* 1.7528	* 0.8483	*
	* 1.4199	* 1.6834	* 1.4265	* 1.7577	* 1.4331	* 1.3404	* 2.7628	*
12	* 1.5353	* 1.7226	* 1.4677	* 1.6308	* 1.6370	* 0.9913	*	
	* 1.5305	* 1.3652	* 1.5985	* 1.4395	* 1.4329	* 2.3623	*	
13	* 1.3499	* 1.4787	* 1.7510	* 1.7446	* 0.9899	*		
	* 1.7404	* 1.5899	* 1.3431	* 1.3466	* 2.3656	*		
14	* 1.7864	* 1.7689	* 1.1610	* 0.8421	*			
	* 1.3172	* 1.3305	* 2.0228	* 2.7828	*			
15	* 0.9329	* 0.8394	* F-SUB-Q					
	* 2.5154	* 2.7950	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 108 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3922 *	* 1.2119 *	* 1.1867 *	* 1.5310 *	* 1.4402 *	* 1.2623 *	* 1.6256 *	* 0.8642 *
	* 1.6357 *	* 1.8768 *	* 1.9172 *	* 1.4906 *	* 1.5882 *	* 1.8129 *	* 1.4090 *	* 2.6467 *
9	* 1.2119 *	* 1.3109 *	* 1.4085 *	* 1.3204 *	* 1.6161 *	* 1.4008 *	* 1.6316 *	* 0.8072 *
	* 1.8768 *	* 1.7362 *	* 1.6173 *	* 1.7282 *	* 1.4155 *	* 1.6339 *	* 1.4040 *	* 2.8335 *
10	* 1.1867 *	* 1.4049 *	* 1.2193 *	* 1.5289 *	* 1.3880 *	* 1.6267 *	* 1.0993 *	
	* 1.9172 *	* 1.6215 *	* 1.8669 *	* 1.4926 *	* 1.6457 *	* 1.4072 *	* 2.0811 *	
11	* 1.5310 *	* 1.3111 *	* 1.5208 *	* 1.2488 *	* 1.5049 *	* 1.6055 *	* 0.7954 *	
	* 1.4906 *	* 1.7402 *	* 1.5005 *	* 1.8257 *	* 1.5187 *	* 1.4242 *	* 2.8719 *	
12	* 1.4402 *	* 1.5944 *	* 1.3779 *	* 1.4981 *	* 1.5272 *	* 0.9254 *		
	* 1.5882 *	* 1.4346 *	* 1.6577 *	* 1.5254 *	* 1.4951 *	* 2.4656 *		
13	* 1.2623 *	* 1.3841 *	* 1.6144 *	* 1.5978 *	* 0.9239 *			
	* 1.8129 *	* 1.6534 *	* 1.4178 *	* 1.4310 *	* 2.4694 *			
14	* 1.6256 *	* 1.6209 *	* 1.0898 *	* 0.7893 *				
	* 1.4090 *	* 1.4132 *	* 2.0992 *	* 2.8936 *				
15	* 0.8642 *	* 0.7824 *	F-SUB-Q					
	* 2.6467 *	* 2.9235 *	M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2734 *	* 1.1232 *	* 1.0949 *	* 1.3861 *	* 1.3141 *	* 1.1456 *	* 1.4160 *	* 0.7649 *
	* 1.7538 *	* 1.9864 *	* 2.0376 *	* 1.6131 *	* 1.7059 *	* 1.9572 *	* 1.5859 *	* 2.9359 *
9	* 1.1232 *	* 1.2106 *	* 1.2793 *	* 1.2159 *	* 1.4588 *	* 1.2723 *	* 1.4331 *	* 0.7178 *
	* 1.9864 *	* 1.8433 *	* 1.7455 *	* 1.8395 *	* 1.5365 *	* 1.7631 *	* 1.5670 *	* 3.1286 *
10	* 1.0949 *	* 1.2765 *	* 1.1217 *	* 1.3808 *	* 1.2727 *	* 1.4504 *	* 0.9887 *	
	* 2.0376 *	* 1.7495 *	* 1.9896 *	* 1.6197 *	* 1.7590 *	* 1.5465 *	* 2.2699 *	
11	* 1.3861 *	* 1.2080 *	* 1.3740 *	* 1.1412 *	* 1.3430 *	* 1.4256 *	* 0.7212 *	
	* 1.6131 *	* 1.8513 *	* 1.6276 *	* 1.9581 *	* 1.6675 *	* 1.5721 *	* 3.1084 *	
12	* 1.3141 *	* 1.4379 *	* 1.2640 *	* 1.3379 *	* 1.3704 *	* 0.8406 *		
	* 1.7059 *	* 1.5587 *	* 1.7711 *	* 1.6726 *	* 1.6332 *	* 2.6628 *		
13	* 1.1456 *	* 1.2578 *	* 1.4405 *	* 1.4187 *	* 0.8392 *			
	* 1.9572 *	* 1.7833 *	* 1.5570 *	* 1.5797 *	* 2.6674 *			
14	* 1.4160 *	* 1.4238 *	* 0.9803 *	* 0.7157 *				
	* 1.5859 *	* 1.5772 *	* 2.2891 *	* 3.1324 *				
15	* 0.7649 *	* 0.6983 *	F-SUB-Q					
	* 2.9359 *	* 3.2157 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 109 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0972	* 0.9325	* 0.9093	* 1.1679	* 1.0768	* 0.9239	* 1.1173	* 0.5990 *
	* 2.0074	* 2.3622	* 2.4208	* 1.8873	* 2.0529	* 2.3944	* 1.9835	* 3.7035 *
9	* 0.9325	* 1.0131	* 1.1006	* 1.0087	* 1.2358	* 1.0370	* 1.1082	* 0.5656 *
	* 2.3622	* 2.1727	* 1.9996	* 2.1867	* 1.7865	* 2.1340	* 1.9998	* 3.9226 *
10	* 0.9093	* 1.0996	* 0.9276	* 1.1634	* 1.0460	* 1.1911	* 0.7858	*
	* 2.4208	* 2.0013	* 2.3734	* 1.8947	* 2.1103	* 1.8571	* 2.8190	*
11	* 1.1679	* 1.0028	* 1.1586	* 0.9379	* 1.1228	* 1.1218	* 0.5871	*
	* 1.8873	* 2.1996	* 1.9024	* 2.3492	* 1.9648	* 1.9706	* 3.7716	*
12	* 1.0768	* 1.2218	* 1.0395	* 1.1199	* 1.0950	* 0.6874	*	
	* 2.0529	* 1.8070	* 2.1235	* 1.9700	* 2.0158	* 3.2150	*	
13	* 0.9239	* 1.0259	* 1.1826	* 1.1170	* 0.6860	*		
	* 2.3944	* 2.1570	* 1.8704	* 1.9791	* 3.2214	*		
14	* 1.1173	* 1.1016	* 0.7796	* 0.5825	*			
	* 1.9835	* 2.0117	* 2.8413	* 3.8009	*			
15	* 0.5990	* 0.5554	* F-SUB-Q					
	* 3.7035	* 3.9949	* M-SUB-Q					

AT 75% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4759	* 0.4245	* 0.4369	* 0.5208	* 0.4851	* 0.4327	* 0.4432	* 0.2690 *
	* 4.5834	* 5.1384	* 4.9905	* 4.1915	* 4.5065	* 5.0639	* 4.9540	* 8.1765 *
9	* 0.4245	* 0.4563	* 0.4979	* 0.4676	* 0.5302	* 0.4631	* 0.4338	* 0.2515 *
	* 5.1384	* 4.7777	* 4.3782	* 4.6703	* 4.1231	* 4.7312	* 5.0611	* 8.7461 *
10	* 0.4369	* 0.4975	* 0.4454	* 0.5181	* 0.4748	* 0.4915	* 0.3572	*
	* 4.9905	* 4.3819	* 4.8966	* 4.2139	* 4.6035	* 4.4561	* 6.1440	*
11	* 0.5208	* 0.4651	* 0.5160	* 0.4471	* 0.4954	* 0.4482	* 0.2655	*
	* 4.1915	* 4.6954	* 4.2300	* 4.8815	* 4.4117	* 4.8855	* 8.2663	*
12	* 0.4851	* 0.5255	* 0.4720	* 0.4941	* 0.4485	* 0.3209	*	
	* 4.5065	* 4.1601	* 4.6312	* 4.4231	* 4.8762	* 6.8249	*	
13	* 0.4327	* 0.4588	* 0.4881	* 0.4463	* 0.3201	*		
	* 5.0639	* 4.7753	* 4.4874	* 4.9060	* 6.8414	*		
14	* 0.4432	* 0.4314	* 0.3546	* 0.2636	*			
	* 4.9540	* 5.0897	* 6.1892	* 8.3274	*			
15	* 0.2690	* 0.2503	* F-SUB-Q					
	* 8.1765	* 8.7881	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 110 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4887	* 0.4510	* 0.4356	* 0.5021	* 0.4672	* 0.3933	* 0.2905	* 0.1574 *
	* 3.5743	* 3.8704	* 3.9908	* 3.4659	* 3.7294	* 4.4170	* 4.5370	* 7.0909 *
9	* 0.4510	* 0.4370	* 0.4659	* 0.4550	* 0.4977	* 0.4303	* 0.3428	* 0.1687 *
	* 3.8704	* 3.9910	* 3.7201	* 3.8235	* 3.4977	* 4.0391	* 4.6736	* 7.5532 *
10	* 0.4356	* 0.4657	* 0.3538	* 0.4772	* 0.4550	* 0.4614	* 0.3210	*
	* 3.9908	* 3.7209	* 4.2109	* 3.6255	* 3.8166	* 3.7649	* 5.3937	*
11	* 0.5021	* 0.4537	* 0.4765	* 0.4315	* 0.4807	* 0.4408	* 0.2717	*
	* 3.4659	* 3.8343	* 3.6312	* 4.0042	* 3.6001	* 3.9306	* 6.3451	*
12	* 0.4672	* 0.4955	* 0.4539	* 0.4803	* 0.4490	* 0.3320	*	*
	* 3.7294	* 3.5125	* 3.8259	* 3.6032	* 3.8481	* 5.1887	*	*
13	* 0.3933	* 0.4285	* 0.4600	* 0.4399	* 0.3307	*	*	*
	* 4.4170	* 4.0560	* 3.7759	* 3.9382	* 5.2099	*	*	*
14	* 0.2905	* 0.3415	* 0.3199	* 0.2706	*	*	*	*
	* 4.5370	* 4.6855	* 5.4128	* 6.3716	*	*	*	*
15	* 0.1574	* 0.1672	* F-SUB-Q					
	* 7.0909	* 7.6067	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9960	* 0.8627	* 0.8184	* 0.9891	* 0.9178	* 0.7530	* 0.6288	* 0.3189 *
	* 1.8251	* 2.1071	* 2.2102	* 1.8287	* 1.9754	* 2.4022	* 2.1212	* 3.6342 *
9	* 0.8627	* 0.8469	* 0.9109	* 0.8805	* 1.0226	* 0.8512	* 0.7450	* 0.3342 *
	* 2.1071	* 2.1377	* 1.9776	* 2.0559	* 1.7702	* 2.1246	* 2.1711	* 3.9203 *
10	* 0.8184	* 0.9106	* 0.6726	* 0.9409	* 0.8936	* 0.9693	* 0.6295	*
	* 2.2102	* 1.9781	* 2.2974	* 1.9100	* 2.0209	* 1.8633	* 2.8639	*
11	* 0.9891	* 0.8779	* 0.9393	* 0.8194	* 0.9539	* 0.9505	* 0.5321	*
	* 1.8287	* 2.0621	* 1.9132	* 2.1906	* 1.8835	* 1.8922	* 3.3699	*
12	* 0.9178	* 1.0179	* 0.8913	* 0.9530	* 0.9426	* 0.6295	*	*
	* 1.9754	* 1.7783	* 2.0262	* 1.8854	* 1.9021	* 2.8424	*	*
13	* 0.7530	* 0.8471	* 0.9664	* 0.9487	* 0.6277	*	*	*
	* 2.4022	* 2.1346	* 1.8687	* 1.8957	* 2.8502	*	*	*
14	* 0.6288	* 0.7422	* 0.6271	* 0.5299	*	*	*	*
	* 2.1212	* 2.1763	* 2.8747	* 3.3835	*	*	*	*
15	* 0.3189	* 0.3287	* F-SUB-Q					
	* 3.6342	* 3.9793	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 111 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1483	* 1.0119	* 0.9784	* 1.1663	* 1.0905	* 0.9112	* 0.7884	* 0.4076 *
	* 1.6519	* 1.8748	* 1.9308	* 1.6172	* 1.7324	* 2.0753	* 1.7886	* 3.0254 *
9	* 1.0119	* 1.0033	* 1.0666	* 1.0517	* 1.1912	* 1.0158	* 0.9180	* 0.4196 *
	* 1.8748	* 1.8689	* 1.7681	* 1.7951	* 1.5850	* 1.8545	* 1.8270	* 3.2581 *
10	* 0.9784	* 1.0664	* 0.8241	* 1.1164	* 1.0725	* 1.1555	* 0.7779	*
	* 1.9308	* 1.7685	* 1.9889	* 1.6797	* 1.7534	* 1.6233	* 2.4193	*
11	* 1.1663	* 1.0481	* 1.1141	* 0.9822	* 1.1219	* 1.1578	* 0.6569	*
	* 1.6172	* 1.8012	* 1.6831	* 1.8979	* 1.6651	* 1.6100	* 2.8353	*
12	* 1.0905	* 1.1844	* 1.0693	* 1.1204	* 1.1279	* 0.7706	*	
	* 1.7324	* 1.5941	* 1.7586	* 1.6673	* 1.6527	* 2.4064	*	
13	* 0.9112	* 1.0105	* 1.1522	* 1.1555	* 0.7690	*		
	* 2.0753	* 1.8643	* 1.6279	* 1.6130	* 2.4112	*		
14	* 0.7884	* 0.9143	* 0.7749	* 0.6542	*			
	* 1.7886	* 1.8317	* 2.4287	* 2.8469	*			
15	* 0.4076	* 0.4145	* F-SUB-Q					
	* 3.0254	* 3.2972	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3540	* 1.1479	* 1.1267	* 1.3967	* 1.2558	* 1.0349	* 0.9426	* 0.4825 *
	* 1.4791	* 1.7471	* 1.7778	* 1.4252	* 1.5863	* 1.9279	* 1.5782	* 2.7705 *
9	* 1.1479	* 1.1567	* 1.2863	* 1.2104	* 1.4228	* 1.1694	* 1.0947	* 0.4904 *
	* 1.7471	* 1.6952	* 1.5562	* 1.6479	* 1.3987	* 1.7000	* 1.6181	* 3.0355 *
10	* 1.1267	* 1.2860	* 0.9484	* 1.3370	* 1.2345	* 1.3675	* 0.8855	*
	* 1.7778	* 1.5564	* 1.8138	* 1.4851	* 1.6053	* 1.4391	* 2.2533	*
11	* 1.3967	* 1.2059	* 1.3341	* 1.1323	* 1.3423	* 1.3738	* 0.7299	*
	* 1.4252	* 1.6543	* 1.4884	* 1.7301	* 1.4605	* 1.4185	* 2.6760	*
12	* 1.2558	* 1.4138	* 1.2306	* 1.3404	* 1.3327	* 0.8599	*	
	* 1.5863	* 1.4079	* 1.6105	* 1.4626	* 1.4652	* 2.2528	*	
13	* 1.0349	* 1.1626	* 1.3634	* 1.3711	* 0.8587	*		
	* 1.9279	* 1.7101	* 1.4432	* 1.4212	* 2.2560	*		
14	* 0.9426	* 1.0903	* 0.8817	* 0.7267	*			
	* 1.5782	* 1.6224	* 2.2631	* 2.6879	*			
15	* 0.4825	* 0.4842	* F-SUB-Q					
	* 2.7705	* 3.0756	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 112 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4607	* 1.2299	* 1.2204	* 1.5259	* 1.3505	* 1.1201	* 1.0769	* 0.5720 *
	* 1.4692	* 1.7605	* 1.7715	* 1.3974	* 1.5791	* 1.9227	* 1.5640	* 2.7531 *
9	* 1.2299	* 1.2690	* 1.4272	* 1.3056	* 1.5545	* 1.2581	* 1.2035	* 0.5629 *
	* 1.7605	* 1.6656	* 1.5049	* 1.6409	* 1.3702	* 1.6955	* 1.6025	* 3.0019 *
10	* 1.2204	* 1.4268	* 1.0842	* 1.4779	* 1.3333	* 1.4814	* 0.9659	*
	* 1.7715	* 1.5052	* 1.7831	* 1.4519	* 1.5927	* 1.4099	* 2.2259	*
11	* 1.5259	* 1.3005	* 1.4746	* 1.2245	* 1.4694	* 1.4845	* 0.7876	*
	* 1.3974	* 1.6477	* 1.4554	* 1.7050	* 1.4187	* 1.3878	* 2.6338	*
12	* 1.3505	* 1.5440	* 1.3289	* 1.4674	* 1.4520	* 0.9308	*	
	* 1.5791	* 1.3798	* 1.5981	* 1.4215	* 1.4247	* 2.1970	*	
13	* 1.1201	* 1.2504	* 1.4758	* 1.4817	* 0.9297	*		
	* 1.9227	* 1.7063	* 1.4140	* 1.3905	* 2.1996	*		
14	* 1.0769	* 1.1987	* 0.9620	* 0.7845	*			
	* 1.5640	* 1.6068	* 2.2344	* 2.6444	*			
15	* 0.5720	* 0.5571	* F-SUB-Q					
	* 2.7531	* 3.0396	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5472	* 1.3045	* 1.3044	* 1.6335	* 1.4303	* 1.1995	* 1.2476	* 0.6997 *
	* 1.5017	* 1.8109	* 1.8074	* 1.4128	* 1.6127	* 1.9372	* 1.5918	* 2.8126 *
9	* 1.3045	* 1.3909	* 1.5584	* 1.3885	* 1.6635	* 1.3340	* 1.3279	* 0.6673 *
	* 1.8109	* 1.6565	* 1.4822	* 1.6754	* 1.3849	* 1.7311	* 1.6237	* 3.0502 *
10	* 1.3044	* 1.5581	* 1.2483	* 1.6062	* 1.4198	* 1.5761	* 1.0367	*
	* 1.8074	* 1.4826	* 1.7739	* 1.4531	* 1.6206	* 1.4219	* 2.2228	*
11	* 1.6335	* 1.3832	* 1.6025	* 1.3097	* 1.5741	* 1.5680	* 0.8339	*
	* 1.4128	* 1.6827	* 1.4565	* 1.7248	* 1.4234	* 1.4016	* 2.6661	*
12	* 1.4303	* 1.6526	* 1.4150	* 1.5719	* 1.5482	* 0.9916	*	
	* 1.6127	* 1.3933	* 1.6265	* 1.4263	* 1.4286	* 2.1955	*	
13	* 1.1995	* 1.3256	* 1.5700	* 1.5652	* 0.9903	*		
	* 1.9372	* 1.7410	* 1.4262	* 1.4043	* 2.1983	*		
14	* 1.2476	* 1.3238	* 1.0325	* 0.8306	*			
	* 1.5918	* 1.6282	* 2.2315	* 2.6769	*			
15	* 0.6997	* 0.6583	* F-SUB-Q					
	* 2.8126	* 3.0910	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 113 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6486	* 1.3815	* 1.3884	* 1.7524	* 1.5132	* 1.2658	* 1.4820	* 0.8123 *
	* 1.5091	* 1.8027	* 1.7894	* 1.4093	* 1.6320	* 1.9369	* 1.5942	* 2.8644 *
9	* 1.3815	* 1.5082	* 1.7018	* 1.4799	* 1.7867	* 1.4129	* 1.4706	* 0.7509 *
	* 1.8027	* 1.6359	* 1.4429	* 1.6666	* 1.3793	* 1.7394	* 1.6212	* 3.1195 *
10	* 1.3884	* 1.7013	* 1.3962	* 1.7434	* 1.5078	* 1.6830	* 1.0932	*
	* 1.7894	* 1.4433	* 1.7538	* 1.4143	* 1.6355	* 1.4319	* 2.2322	*
11	* 1.7524	* 1.4774	* 1.7394	* 1.3997	* 1.6905	* 1.6624	* 0.8647	*
	* 1.4093	* 1.6695	* 1.4176	* 1.7526	* 1.4270	* 1.4153	* 2.7621	*
12	* 1.5132	* 1.7775	* 1.5026	* 1.6881	* 1.6511	* 1.0295	*	
	* 1.6320	* 1.3861	* 1.6413	* 1.4299	* 1.4280	* 2.2595	*	
13	* 1.2658	* 1.4036	* 1.6764	* 1.6594	* 1.0288	*		
	* 1.9369	* 1.7510	* 1.4362	* 1.4180	* 2.2613	*		
14	* 1.4820	* 1.4663	* 1.0889	* 0.8615	*			
	* 1.5942	* 1.6259	* 2.2411	* 2.7728	*			
15	* 0.8123	* 0.7421	* F-SUB-Q					
	* 2.8644	* 3.1560	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7083	* 1.4291	* 1.4422	* 1.8241	* 1.5650	* 1.3092	* 1.5643	* 0.8645 *
	* 1.5246	* 1.8247	* 1.8035	* 1.4165	* 1.6502	* 1.9677	* 1.6253	* 2.9218 *
9	* 1.4291	* 1.5776	* 1.7953	* 1.5451	* 1.8627	* 1.4607	* 1.5428	* 0.7970 *
	* 1.8247	* 1.6488	* 1.4440	* 1.6782	* 1.3826	* 1.7577	* 1.6524	* 3.1764 *
10	* 1.4422	* 1.7948	* 1.4691	* 1.8249	* 1.5628	* 1.7463	* 1.1327	*
	* 1.8035	* 1.4445	* 1.7677	* 1.4136	* 1.6500	* 1.4655	* 2.2592	*
11	* 1.8241	* 1.5425	* 1.8209	* 1.4616	* 1.7628	* 1.7183	* 0.8907	*
	* 1.4165	* 1.6811	* 1.4168	* 1.7684	* 1.4504	* 1.4652	* 2.8507	*
12	* 1.5650	* 1.8536	* 1.5573	* 1.7604	* 1.7166	* 1.0655	*	
	* 1.6502	* 1.3896	* 1.6559	* 1.4525	* 1.4669	* 2.3340	*	
13	* 1.3092	* 1.4510	* 1.7393	* 1.7154	* 1.0650	*		
	* 1.9677	* 1.7697	* 1.4707	* 1.4678	* 2.3353	*		
14	* 1.5643	* 1.5384	* 1.1282	* 0.8874	*			
	* 1.6253	* 1.6573	* 2.2683	* 2.8613	*			
15	* 0.8645	* 0.7876	* F-SUB-Q					
	* 2.9218	* 3.2141	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 114 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7827	* 1.4765	* 1.4921	* 1.9061	* 1.6170	* 1.3466	* 1.6315	* 0.8925 *
	* 1.5362	* 1.8575	* 1.8334	* 1.4243	* 1.6771	* 2.0077	* 1.6377	* 2.9870 *
9	* 1.4765	* 1.6387	* 1.8873	* 1.6004	* 1.9503	* 1.5076	* 1.6069	* 0.8155 *
	* 1.8575	* 1.6691	* 1.4442	* 1.7032	* 1.3852	* 1.7875	* 1.6629	* 3.2711 *
10	* 1.4921	* 1.8867	* 1.5250	* 1.9111	* 1.6151	* 1.8218	* 1.1551	*
	* 1.8334	* 1.4446	* 1.7902	* 1.4185	* 1.6722	* 1.4670	* 2.3237	*
11	* 1.9061	* 1.5977	* 1.9069	* 1.5141	* 1.8454	* 1.7853	* 0.9026	*
	* 1.4243	* 1.7062	* 1.4217	* 1.7941	* 1.4465	* 1.4790	* 2.9371	*
12	* 1.6170	* 1.9406	* 1.6093	* 1.8430	* 1.7880	* 1.0852	*	
	* 1.6771	* 1.3924	* 1.6783	* 1.4484	* 1.4764	* 2.4313	*	
13	* 1.3466	* 1.4972	* 1.8145	* 1.7825	* 1.0849	*		
	* 2.0077	* 1.8000	* 1.4724	* 1.4815	* 2.4320	*		
14	* 1.6315	* 1.6023	* 1.1502	* 0.8988	*			
	* 1.6377	* 1.6676	* 2.3336	* 2.9496	*			
15	* 0.8925	* 0.8058	* F-SUB-Q					
	* 2.9870	* 3.3102	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7490	* 1.4839	* 1.4885	* 1.8753	* 1.6030	* 1.3543	* 1.6021	* 0.8963 *
	* 1.6438	* 1.9466	* 1.9328	* 1.5185	* 1.7735	* 2.0974	* 1.7565	* 3.1314 *
9	* 1.4839	* 1.6460	* 1.8579	* 1.5918	* 1.9185	* 1.4919	* 1.5774	* 0.8334 *
	* 1.9466	* 1.7534	* 1.5443	* 1.7990	* 1.4759	* 1.8894	* 1.7842	* 3.3694 *
10	* 1.4885	* 1.8573	* 1.5167	* 1.8818	* 1.6040	* 1.7887	* 1.1691	*
	* 1.9328	* 1.5447	* 1.8949	* 1.5090	* 1.7652	* 1.5659	* 2.4034	*
11	* 1.8753	* 1.5892	* 1.8777	* 1.5067	* 1.8155	* 1.7563	* 0.9239	*
	* 1.5185	* 1.8023	* 1.5125	* 1.8882	* 1.5448	* 1.5810	* 3.0104	*
12	* 1.6030	* 1.9087	* 1.5982	* 1.8132	* 1.7694	* 1.1152	*	
	* 1.7735	* 1.4836	* 1.7717	* 1.5468	* 1.5790	* 2.4916	*	
13	* 1.3543	* 1.4818	* 1.7815	* 1.7536	* 1.1144	*		
	* 2.0974	* 1.9025	* 1.5723	* 1.5835	* 2.4934	*		
14	* 1.6021	* 1.5729	* 1.1645	* 0.9205	*			
	* 1.7565	* 1.7893	* 2.4130	* 3.0215	*			
15	* 0.8963	* 0.8230	* F-SUB-Q					
	* 3.1314	* 3.4118	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 115 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8230	* 1.4997	* 1.5193	* 1.9547	* 1.6440	* 1.3588	* 1.6533	* 0.9022 *
	* 1.6558	* 2.0139	* 1.9859	* 1.5396	* 1.8258	* 2.1968	* 1.7838	* 3.2580 *
9	* 1.4997	* 1.6769	* 1.9421	* 1.6313	* 2.0041	* 1.5285	* 1.6290	* 0.8272 *
	* 2.0139	* 1.8019	* 1.5538	* 1.8498	* 1.4922	* 1.9433	* 1.8086	* 3.5541 *
10	* 1.5193	* 1.9416	* 1.5549	* 1.9634	* 1.6443	* 1.8641	* 1.1699	*
	* 1.9859	* 1.5543	* 1.9449	* 1.5281	* 1.8195	* 1.5857	* 2.5236	*
11	* 1.9547	* 1.6288	* 1.9590	* 1.5441	* 1.8971	* 1.8248	* 0.9166	*
	* 1.5396	* 1.8528	* 1.5315	* 1.9452	* 1.5644	* 1.6098	* 3.2023	*
12	* 1.6440	* 1.9943	* 1.6383	* 1.8949	* 1.8448	* 1.1122	*	
	* 1.8258	* 1.4997	* 1.8261	* 1.5663	* 1.5954	* 2.6457	*	
13	* 1.3588	* 1.5178	* 1.8566	* 1.8222	* 1.1122	*		
	* 2.1968	* 1.9571	* 1.5920	* 1.6120	* 2.6458	*		
14	* 1.6533	* 1.6244	* 1.1653	* 0.9135	*			
	* 1.7838	* 1.8137	* 2.5335	* 3.2131	*			
15	* 0.9022	* 0.8178	* F-SUB-Q					
	* 3.2580	* 3.5945	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8258	* 1.4998	* 1.5204	* 1.9620	* 1.6440	* 1.3579	* 1.6474	* 0.8985 *
	* 1.6474	* 2.0053	* 1.9758	* 1.5314	* 1.8291	* 2.2195	* 1.8445	* 3.3881 *
9	* 1.4998	* 1.6854	* 1.9515	* 1.6334	* 2.0121	* 1.5263	* 1.6239	* 0.8273 *
	* 2.0053	* 1.7860	* 1.5412	* 1.8401	* 1.4939	* 1.9726	* 1.8669	* 3.6765 *
10	* 1.5204	* 1.9510	* 1.5567	* 1.9722	* 1.6459	* 1.8691	* 1.1689	*
	* 1.9758	* 1.5416	* 1.9342	* 1.5226	* 1.8239	* 1.6085	* 2.5821	*
11	* 1.9620	* 1.6308	* 1.9678	* 1.5471	* 1.9081	* 1.8305	* 0.9187	*
	* 1.5314	* 1.8431	* 1.5260	* 1.9388	* 1.5698	* 1.6378	* 3.2698	*
12	* 1.6440	* 2.0022	* 1.6399	* 1.9059	* 1.8588	* 1.1198	*	
	* 1.8291	* 1.5013	* 1.8307	* 1.5716	* 1.6097	* 2.6725	*	
13	* 1.3579	* 1.5154	* 1.8617	* 1.8281	* 1.1199	*		
	* 2.2195	* 1.9868	* 1.6149	* 1.6401	* 2.6724	*		
14	* 1.6474	* 1.6193	* 1.1643	* 0.9156	*			
	* 1.8445	* 1.8723	* 2.5924	* 3.2809	*			
15	* 0.8984	* 0.8184	* F-SUB-Q					
	* 3.3881	* 3.7163	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 116 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7793	* 1.4951	* 1.5009	* 1.9179	* 1.6143	* 1.3516	* 1.6045	* 0.8865 *
	* 1.6756	* 1.9926	* 1.9841	* 1.5536	* 1.8464	* 2.2104	* 1.8815	* 3.4097 *
9	* 1.4951	* 1.6730	* 1.9079	* 1.6069	* 1.9686	* 1.4993	* 1.5823	* 0.8261 *
	* 1.9926	* 1.7833	* 1.5629	* 1.8531	* 1.5143	* 1.9889	* 1.9039	* 3.6569 *
10	* 1.5009	* 1.9073	* 1.5313	* 1.9296	* 1.6194	* 1.8268	* 1.1630	*
	* 1.9841	* 1.5634	* 1.9467	* 1.5423	* 1.8359	* 1.6313	* 2.5716	*
11	* 1.9179	* 1.6043	* 1.9254	* 1.5236	* 1.8691	* 1.7941	* 0.9230	*
	* 1.5536	* 1.8562	* 1.5458	* 1.9478	* 1.5861	* 1.6538	* 3.2146	*
12	* 1.6143	* 1.9582	* 1.6135	* 1.8670	* 1.8231	* 1.1311	*	*
	* 1.8464	* 1.5221	* 1.8426	* 1.5877	* 1.6229	* 2.6119	*	*
13	* 1.3516	* 1.4903	* 1.8195	* 1.7918	* 1.1306	*	*	*
	* 2.2104	* 2.0008	* 1.6373	* 1.6559	* 2.6129	*	*	*
14	* 1.6045	* 1.5778	* 1.1584	* 0.9198	*	*	*	*
	* 1.8815	* 1.9093	* 2.5818	* 3.2259	*	*	*	*
15	* 0.8865	* 0.8155	* F-SUB-Q					
	* 3.4097	* 3.7037	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8209	* 1.4816	* 1.5081	* 1.9649	* 1.6301	* 1.3322	* 1.6307	* 0.8792 *
	* 1.6140	* 1.9810	* 1.9434	* 1.4942	* 1.8013	* 2.2074	* 1.8143	* 3.3565 *
9	* 1.4816	* 1.6770	* 1.9589	* 1.6214	* 2.0198	* 1.5113	* 1.6097	* 0.8073 *
	* 1.9810	* 1.7510	* 1.4984	* 1.8086	* 1.4544	* 1.9441	* 1.8358	* 3.6524 *
10	* 1.5081	* 1.9584	* 1.5458	* 1.9796	* 1.6352	* 1.8740	* 1.1468	*
	* 1.9434	* 1.4988	* 1.8965	* 1.4813	* 1.7904	* 1.5644	* 2.5641	*
11	* 1.9649	* 1.6188	* 1.9754	* 1.5394	* 1.9224	* 1.8396	* 0.9041	*
	* 1.4942	* 1.8116	* 1.4843	* 1.8973	* 1.5183	* 1.5878	* 3.2212	*
12	* 1.6301	* 2.0098	* 1.6291	* 1.9203	* 1.8843	* 1.1152	*	*
	* 1.8013	* 1.4615	* 1.7969	* 1.5197	* 1.5456	* 2.6052	*	*
13	* 1.3322	* 1.5002	* 1.8670	* 1.8375	* 1.1153	*	*	*
	* 2.2074	* 1.9583	* 1.5683	* 1.5896	* 2.6051	*	*	*
14	* 1.6307	* 1.6051	* 1.1421	* 0.9012	*	*	*	*
	* 1.8143	* 1.8410	* 2.5744	* 3.2312	*	*	*	*
15	* 0.8792	* 0.7979	* F-SUB-Q					
	* 3.3565	* 3.6946	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 117 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8184	* 1.4700	* 1.5010	* 1.9677	* 1.6222	* 1.3177	* 1.6245	* 0.8689 *
	* 1.5412	* 1.9004	* 1.8623	* 1.4284	* 1.7298	* 2.1235	* 1.7350	* 3.2217 *
9	* 1.4700	* 1.6702	* 1.9640	* 1.6140	* 2.0248	* 1.5034	* 1.6045	* 0.7963 *
	* 1.9004	* 1.6785	* 1.4294	* 1.7354	* 1.3897	* 1.8651	* 1.7547	* 3.5131 *
10	* 1.5010	* 1.9635	* 1.5393	* 1.9843	* 1.6285	* 1.8787	* 1.1334	*
	* 1.8623	* 1.4298	* 1.8169	* 1.4153	* 1.7202	* 1.4933	* 2.4686	*
11	* 1.9677	* 1.6114	* 1.9802	* 1.5345	* 1.9313	* 1.8460	* 0.8936	*
	* 1.4284	* 1.7381	* 1.4180	* 1.8194	* 1.4496	* 1.5179	* 3.1087	*
12	* 1.6222	* 2.0147	* 1.6224	* 1.9295	* 1.8993	* 1.1079	*	
	* 1.7298	* 1.3962	* 1.7262	* 1.4507	* 1.4722	* 2.5088	*	
13	* 1.3177	* 1.4922	* 1.8740	* 1.8440	* 1.1082	*		
	* 2.1235	* 1.8785	* 1.4968	* 1.5194	* 2.5080	*		
14	* 1.6245	* 1.6000	* 1.1287	* 0.8900	*			
	* 1.7350	* 1.7595	* 2.4783	* 3.1207	*			
15	* 0.8689	* 0.7852	* F-SUB-Q					
	* 3.2217	* 3.5619	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7920	* 1.4555	* 1.4811	* 1.9440	* 1.6015	* 1.3043	* 1.6026	* 0.8578 *
	* 1.5019	* 1.8449	* 1.8124	* 1.3880	* 1.6823	* 2.0617	* 1.6828	* 3.1198 *
9	* 1.4555	* 1.6557	* 1.9399	* 1.5939	* 2.0016	* 1.4834	* 1.5832	* 0.7889 *
	* 1.8449	* 1.6253	* 1.3891	* 1.6874	* 1.3498	* 1.8146	* 1.7026	* 3.3911 *
10	* 1.4811	* 1.9393	* 1.5190	* 1.9615	* 1.6091	* 1.8582	* 1.1228	*
	* 1.8124	* 1.3894	* 1.7676	* 1.3748	* 1.6726	* 1.4508	* 2.3905	*
11	* 1.9440	* 1.5912	* 1.9574	* 1.5161	* 1.9106	* 1.8272	* 0.8879	*
	* 1.3880	* 1.6902	* 1.3776	* 1.7695	* 1.4087	* 1.4744	* 3.0073	*
12	* 1.6015	* 1.9914	* 1.6030	* 1.9089	* 1.8806	* 1.1039	*	
	* 1.6823	* 1.3564	* 1.6786	* 1.4098	* 1.4304	* 2.4234	*	
13	* 1.3043	* 1.4721	* 1.8535	* 1.8253	* 1.1041	*		
	* 2.0617	* 1.8279	* 1.4542	* 1.4758	* 2.4228	*		
14	* 1.6026	* 1.5787	* 1.1182	* 0.8851	*			
	* 1.6828	* 1.7072	* 2.4000	* 3.0163	*			
15	* 0.8578	* 0.7797	* F-SUB-Q					
	* 3.1198	* 3.4301	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 118 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7256	* 1.4427	* 1.4517	* 1.8813	* 1.5611	* 1.2963	* 1.5535	* 0.8455 *
	* 1.5120	* 1.8049	* 1.7957	* 1.3898	* 1.6727	* 2.0099	* 1.6781	* 3.0591 *
9	* 1.4427	* 1.6311	* 1.8746	* 1.5554	* 1.9374	* 1.4529	* 1.5342	* 0.7899 *
	* 1.8049	* 1.5992	* 1.3931	* 1.6765	* 1.3513	* 1.7973	* 1.6989	* 3.2736 *
10	* 1.4517	* 1.8739	* 1.4815	* 1.8989	* 1.5711	* 1.7987	* 1.1155	*
	* 1.7957	* 1.3935	* 1.7572	* 1.3763	* 1.6609	* 1.4524	* 2.3300	*
11	* 1.8813	* 1.5526	* 1.8945	* 1.4806	* 1.8502	* 1.7736	* 0.8896	*
	* 1.3898	* 1.6794	* 1.3794	* 1.7575	* 1.4105	* 1.4723	* 2.9099	*
12	* 1.5611	* 1.9269	* 1.5650	* 1.8485	* 1.8196	* 1.1075	*	*
	* 1.6727	* 1.3582	* 1.6671	* 1.4116	* 1.4337	* 2.3436	*	*
13	* 1.2963	* 1.4436	* 1.7940	* 1.7717	* 1.1075	*	*	*
	* 2.0099	* 1.8083	* 1.4559	* 1.4737	* 2.3436	*	*	*
14	* 1.5535	* 1.5298	* 1.1110	* 0.8866	*	*	*	*
	* 1.6781	* 1.7036	* 2.3390	* 2.9192	*	*	*	*
15	* 0.8455	* 0.7793	* F-SUB-Q					
	* 3.0591	* 3.3173	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7578	* 1.4177	* 1.4480	* 1.9201	* 1.5693	* 1.2668	* 1.5833	* 0.8369 *
	* 1.4354	* 1.7764	* 1.7398	* 1.3183	* 1.6127	* 1.9941	* 1.6021	* 3.0098 *
9	* 1.4177	* 1.6220	* 1.9153	* 1.5596	* 1.9797	* 1.4540	* 1.5643	* 0.7682 *
	* 1.7764	* 1.5547	* 1.3190	* 1.6189	* 1.2814	* 1.7419	* 1.6214	* 3.2788 *
10	* 1.4480	* 1.9147	* 1.4858	* 1.9392	* 1.5773	* 1.8422	* 1.0926	*
	* 1.7398	* 1.3194	* 1.6964	* 1.3057	* 1.6044	* 1.3774	* 2.3143	*
11	* 1.9201	* 1.5566	* 1.9347	* 1.4857	* 1.8929	* 1.8127	* 0.8623	*
	* 1.3183	* 1.6218	* 1.3085	* 1.6984	* 1.3379	* 1.3999	* 2.9251	*
12	* 1.5693	* 1.9687	* 1.5709	* 1.8911	* 1.8683	* 1.0775	*	*
	* 1.6127	* 1.2882	* 1.6107	* 1.3390	* 1.3563	* 2.3430	*	*
13	* 1.2668	* 1.4423	* 1.8373	* 1.8108	* 1.0779	*	*	*
	* 1.9941	* 1.7556	* 1.3809	* 1.4013	* 2.3420	*	*	*
14	* 1.5833	* 1.5597	* 1.0879	* 0.8589	*	*	*	*
	* 1.6021	* 1.6261	* 2.3242	* 2.9364	*	*	*	*
15	* 0.8369	* 0.7571	* F-SUB-Q					
	* 3.0098	* 3.3257	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 119 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7146	* 1.3841	* 1.4145	* 1.8801	* 1.5366	* 1.2395	* 1.5602	* 0.8225 *
	* 1.4093	* 1.7433	* 1.7060	* 1.2889	* 1.5775	* 1.9521	* 1.5549	* 2.9369 *
9	* 1.3841	* 1.5864	* 1.8726	* 1.5245	* 1.9402	* 1.4254	* 1.5408	* 0.7556 *
	* 1.7433	* 1.5225	* 1.2916	* 1.5862	* 1.2518	* 1.7016	* 1.5745	* 3.1969 *
10	* 1.4145	* 1.8719	* 1.4515	* 1.8990	* 1.5444	* 1.8082	* 1.0712	*
	* 1.7060	* 1.2921	* 1.6634	* 1.2764	* 1.5695	* 1.3432	* 2.2598	*
11	* 1.8801	* 1.5215	* 1.8941	* 1.4526	* 1.8546	* 1.7822	* 0.8438	*
	* 1.2889	* 1.5893	* 1.2796	* 1.6640	* 1.3078	* 1.3630	* 2.8638	*
12	* 1.5366	* 1.9288	* 1.5378	* 1.8525	* 1.8310	* 1.0558	*	
	* 1.5775	* 1.2590	* 1.5760	* 1.3090	* 1.3253	* 2.2910	*	
13	* 1.2395	* 1.4135	* 1.8032	* 1.7802	* 1.0562	*		
	* 1.9521	* 1.7155	* 1.3469	* 1.3645	* 2.2900	*		
14	* 1.5602	* 1.5360	* 1.0664	* 0.8405	*			
	* 1.5549	* 1.5793	* 2.2698	* 2.8749	*			
15	* 0.8225	* 0.7438	* F-SUB-Q					
	* 2.9369	* 3.2468	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6411	* 1.3396	* 1.3627	* 1.8022	* 1.4845	* 1.2036	* 1.5162	* 0.8019 *
	* 1.4186	* 1.7364	* 1.7076	* 1.2954	* 1.5735	* 1.9396	* 1.5419	* 2.9065 *
9	* 1.3396	* 1.5284	* 1.7868	* 1.4692	* 1.8576	* 1.3800	* 1.4957	* 0.7507 *
	* 1.7364	* 1.5232	* 1.3043	* 1.5871	* 1.2591	* 1.6939	* 1.5632	* 3.1049 *
10	* 1.3627	* 1.7858	* 1.3977	* 1.8191	* 1.4910	* 1.7336	* 1.0415	*
	* 1.7076	* 1.3050	* 1.6661	* 1.2838	* 1.5669	* 1.3497	* 2.2414	*
11	* 1.8022	* 1.4659	* 1.8140	* 1.3990	* 1.7740	* 1.7146	* 0.8170	*
	* 1.2954	* 1.5904	* 1.2873	* 1.6662	* 1.3171	* 1.3647	* 2.8535	*
12	* 1.4845	* 1.8452	* 1.4844	* 1.7717	* 1.7435	* 1.0293	*	
	* 1.5735	* 1.2674	* 1.5737	* 1.3187	* 1.3410	* 2.2658	*	
13	* 1.2036	* 1.3681	* 1.7282	* 1.7124	* 1.0297	*		
	* 1.9396	* 1.7083	* 1.3538	* 1.3664	* 2.2649	*		
14	* 1.5162	* 1.4906	* 1.0366	* 0.8137	*			
	* 1.5419	* 1.5684	* 2.2518	* 2.8649	*			
15	* 0.8019	* 0.7262	* F-SUB-Q					
	* 2.9065	* 3.2093	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 120 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5207	* 1.2733	* 1.2816	* 1.6662	* 1.3999	* 1.1474	* 1.4304	* 0.7645 *
	* 1.4874	* 1.7751	* 1.7643	* 1.3603	* 1.6208	* 1.9780	* 1.5886	* 2.9672 *
9	* 1.2733	* 1.4389	* 1.6377	* 1.3823	* 1.7103	* 1.3051	* 1.4092	* 0.7129 *
	* 1.7751	* 1.5715	* 1.3818	* 1.6387	* 1.3278	* 1.7406	* 1.6126	* 3.1816 *
10	* 1.2816	* 1.6367	* 1.3128	* 1.6784	* 1.4040	* 1.6010	* 0.9923	*
	* 1.7643	* 1.3826	* 1.7234	* 1.3509	* 1.6165	* 1.4197	* 2.2878	*
11	* 1.6662	* 1.3790	* 1.6730	* 1.3127	* 1.6280	* 1.5916	* 0.7742	*
	* 1.3603	* 1.6425	* 1.3551	* 1.7254	* 1.3937	* 1.4278	* 2.9296	*
12	* 1.3999	* 1.6983	* 1.3976	* 1.6255	* 1.6195	* 0.9652	*	
	* 1.6208	* 1.3371	* 1.6237	* 1.3958	* 1.4018	* 2.3488	*	
13	* 1.1474	* 1.2938	* 1.5929	* 1.5892	* 0.9653	*		
	* 1.9780	* 1.7556	* 1.4269	* 1.4299	* 2.3485	*		
14	* 1.4304	* 1.4041	* 0.9875	* 0.7708	*			
	* 1.5886	* 1.6182	* 2.2989	* 2.9422	*			
15	* 0.7645	* 0.6943	* F-SUB-Q					
	* 2.9672	* 3.2671	* M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3680	* 1.1622	* 1.1622	* 1.4759	* 1.2754	* 1.0499	* 1.2921	* 0.6925 *
	* 1.6188	* 1.9045	* 1.9045	* 1.5027	* 1.7412	* 2.1163	* 1.7225	* 3.2127 *
9	* 1.1622	* 1.2986	* 1.4452	* 1.2550	* 1.5151	* 1.1916	* 1.2703	* 0.6490 *
	* 1.9045	* 1.7042	* 1.5319	* 1.7662	* 1.4663	* 1.8665	* 1.7521	* 3.4286 *
10	* 1.1622	* 1.4449	* 1.1875	* 1.4826	* 1.2752	* 1.4205	* 0.9035	*
	* 1.9045	* 1.5322	* 1.8645	* 1.4961	* 1.7416	* 1.5661	* 2.4622	*
11	* 1.4759	* 1.2521	* 1.4778	* 1.1851	* 1.4292	* 1.4143	* 0.7046	*
	* 1.5027	* 1.7702	* 1.5009	* 1.8704	* 1.5534	* 1.5721	* 3.1552	*
12	* 1.2754	* 1.5048	* 1.2696	* 1.4269	* 1.4329	* 0.8688	*	
	* 1.7412	* 1.4762	* 1.7492	* 1.5559	* 1.5502	* 2.5558	*	
13	* 1.0499	* 1.1817	* 1.4135	* 1.4119	* 0.8686	*		
	* 2.1163	* 1.8821	* 1.5738	* 1.5747	* 2.5563	*		
14	* 1.2921	* 1.2657	* 0.8991	* 0.7013	*			
	* 1.7225	* 1.7584	* 2.4742	* 3.1699	*			
15	* 0.6925	* 0.6331	* F-SUB-Q					
	* 3.2127	* 3.5146	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 121 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 275 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1355 *	* 0.9572 *	* 0.9430 *	* 1.1779 *	* 1.0438 *	* 0.8569 *	* 1.0128 *	* 0.5493 *
	* 1.9210 *	* 2.2790 *	* 2.3129 *	* 1.8544 *	* 2.0961 *	* 2.5569 *	* 2.1669 *	* 3.9998 *
9	* 0.9572 *	* 1.0578 *	* 1.1650 *	* 1.0207 *	* 1.2238 *	* 0.9723 *	* 0.9998 *	* 0.5197 *
	* 2.2790 *	* 2.0619 *	* 1.8718 *	* 2.1393 *	* 1.7876 *	* 2.2546 *	* 2.1954 *	* 4.2285 *
10	* 0.9430 *	* 1.1646 *	* 0.9613 *	* 1.1819 *	* 1.0337 *	* 1.1383 *	* 0.7267 *	
	* 2.3129 *	* 1.8724 *	* 2.2695 *	* 1.8482 *	* 2.1164 *	* 1.9255 *	* 3.0192 *	
11	* 1.1779 *	* 1.0186 *	* 1.1790 *	* 0.9565 *	* 1.1388 *	* 1.1062 *	* 0.5742 *	
	* 1.8544 *	* 2.1435 *	* 1.8527 *	* 2.2832 *	* 1.9199 *	* 1.9802 *	* 3.8206 *	
12	* 1.0438 *	* 1.2174 *	* 1.0296 *	* 1.1374 *	* 1.1164 *	* 0.7020 *		
	* 2.0961 *	* 1.7969 *	* 2.1248 *	* 1.9223 *	* 1.9596 *	* 3.1199 *		
13	* 0.8569 *	* 0.9649 *	* 1.1337 *	* 1.1043 *	* 0.7015 *			
	* 2.5569 *	* 2.2718 *	* 1.9333 *	* 1.9836 *	* 3.1218 *			
14	* 1.0128 *	* 0.9962 *	* 0.7234 *	* 0.5714 *				
	* 2.1669 *	* 2.2033 *	* 3.0330 *	* 3.8391 *				
15	* 0.5493 *	* 0.5105 *	F-SUB-Q					
	* 3.9998 *	* 4.3040 *	M-SUB-Q					

AT 75% POWER, 275 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4987 *	* 0.4474 *	* 0.4597 *	* 0.5334 *	* 0.4839 *	* 0.4154 *	* 0.4168 *	* 0.2532 *
	* 4.3288 *	* 4.8260 *	* 4.6964 *	* 4.0507 *	* 4.4728 *	* 5.2232 *	* 5.2165 *	* 8.6011 *
9	* 0.4474 *	* 0.4844 *	* 0.5272 *	* 0.4792 *	* 0.5284 *	* 0.4488 *	* 0.4099 *	* 0.2375 *
	* 4.8260 *	* 4.4555 *	* 4.0941 *	* 4.5090 *	* 4.0961 *	* 4.8337 *	* 5.3032 *	* 9.1721 *
10	* 0.4597 *	* 0.5272 *	* 0.4682 *	* 0.5339 *	* 0.4794 *	* 0.4836 *	* 0.3401 *	
	* 4.6964 *	* 4.0927 *	* 4.6116 *	* 4.0479 *	* 4.5157 *	* 4.4862 *	* 6.3919 *	
11	* 0.5334 *	* 0.4784 *	* 0.5331 *	* 0.4639 *	* 0.5090 *	* 0.4559 *	* 0.2648 *	
	* 4.0507 *	* 4.5166 *	* 4.0532 *	* 4.6598 *	* 4.2529 *	* 4.7566 *	* 8.2084 *	
12	* 0.4839 *	* 0.5259 *	* 0.4776 *	* 0.5084 *	* 0.4683 *	* 0.3303 *		
	* 4.4728 *	* 4.1160 *	* 4.5318 *	* 4.2581 *	* 4.6258 *	* 6.5678 *		
13	* 0.4154 *	* 0.4459 *	* 0.4816 *	* 0.4551 *	* 0.3299 *			
	* 5.2232 *	* 4.8655 *	* 4.5047 *	* 4.7657 *	* 6.5749 *			
14	* 0.4168 *	* 0.4083 *	* 0.3386 *	* 0.2635 *				
	* 5.2165 *	* 5.3239 *	* 6.4200 *	* 8.2490 *				
15	* 0.2532 *	* 0.2364 *	F-SUB-Q					
	* 8.6011 *	* 9.2123 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 122 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6297	* 0.5844	* 0.5730	* 0.6585	* 0.6109	* 0.5117	* 0.3771	* 0.2063
	* 3.2127	* 3.4595	* 3.5204	* 3.0738	* 3.3161	* 3.9416	* 4.3471	* 6.7880
9	* 0.5844	* 0.5685	* 0.6132	* 0.5979	* 0.6514	* 0.5623	* 0.4500	* 0.2227
	* 3.4595	* 3.5517	* 3.2816	* 3.3827	* 3.1093	* 3.5966	* 4.4536	* 7.2082
10	* 0.5730	* 0.6131	* 0.4613	* 0.6323	* 0.6014	* 0.6077	* 0.4189	*
	* 3.5204	* 3.2821	* 3.9026	* 3.1903	* 3.3652	* 3.3331	* 4.8064	*
11	* 0.6585	* 0.5964	* 0.6314	* 0.5818	* 0.6441	* 0.5919	* 0.3640	*
	* 3.0738	* 3.3912	* 3.1945	* 3.4763	* 3.1449	* 3.4253	* 5.5352	*
12	* 0.6109	* 0.6488	* 0.6001	* 0.6436	* 0.6087	* 0.4484	*	*
	* 3.3161	* 3.1216	* 3.3722	* 3.1469	* 3.3303	* 4.5083	*	*
13	* 0.5117	* 0.5602	* 0.6062	* 0.5910	* 0.4466	*	*	*
	* 3.9416	* 3.6096	* 3.3410	* 3.4303	* 4.5263	*	*	*
14	* 0.3771	* 0.4486	* 0.4177	* 0.3627	*	*	*	*
	* 4.3471	* 4.4628	* 4.8197	* 5.5543	*	*	*	*
15	* 0.2063	* 0.2209	* F-SUB-Q					
	* 6.7881	* 7.2587	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2265	* 1.0578	* 1.0271	* 1.2438	* 1.1406	* 0.9266	* 0.7643	* 0.3936
	* 1.7041	* 1.9752	* 2.0282	* 1.6794	* 1.8341	* 2.2489	* 2.1627	* 3.6582
9	* 1.0578	* 1.0498	* 1.1547	* 1.1005	* 1.2827	* 1.0550	* 0.9156	* 0.4170
	* 1.9752	* 1.9824	* 1.7978	* 1.8982	* 1.6303	* 1.9789	* 2.2008	* 3.9340
10	* 1.0271	* 1.1544	* 0.8427	* 1.1960	* 1.1234	* 1.2196	* 0.7795	*
	* 2.0282	* 1.7981	* 2.2184	* 1.7392	* 1.8598	* 1.7148	* 2.6682	*
11	* 1.2438	* 1.0975	* 1.1943	* 1.0570	* 1.2290	* 1.2087	* 0.6795	*
	* 1.6794	* 1.9033	* 1.7415	* 1.9738	* 1.6992	* 1.7293	* 3.0606	*
12	* 1.1406	* 1.2770	* 1.1209	* 1.2280	* 1.2276	* 0.8184	*	*
	* 1.8341	* 1.6374	* 1.8635	* 1.7005	* 1.7022	* 2.5474	*	*
13	* 0.9266	* 1.0506	* 1.2173	* 1.2070	* 0.8163	*	*	*
	* 2.2489	* 1.9869	* 1.7178	* 1.7317	* 2.5536	*	*	*
14	* 0.7643	* 0.9129	* 0.7771	* 0.6772	*	*	*	*
	* 2.1627	* 2.2050	* 2.6760	* 3.0706	*	*	*	*
15	* 0.3936	* 0.4104	* F-SUB-Q					
	* 3.6582	* 3.9908	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 123 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4236 *	* 1.2066 *	* 1.1960 *	* 1.4751 *	* 1.3216 *	* 1.0956 *	* 0.9200 *	* 0.4817 *
	* 1.5163 *	* 1.7893 *	* 1.8002 *	* 1.4606 *	* 1.6329 *	* 1.9692 *	* 1.8702 *	* 3.1240 *
9	* 1.2066 *	* 1.2091 *	* 1.3645 *	* 1.2837 *	* 1.5077 *	* 1.2279 *	* 1.0883 *	* 0.5017 *
	* 1.7893 *	* 1.7807 *	* 1.5732 *	* 1.6796 *	* 1.4305 *	* 1.7562 *	* 1.9033 *	* 3.3458 *
10	* 1.1960 *	* 1.3643 *	* 1.0146 *	* 1.4204 *	* 1.3154 *	* 1.4378 *	* 0.9356 *	
	* 1.8002 *	* 1.5735 *	* 1.9432 *	* 1.5107 *	* 1.6368 *	* 1.4956 *	* 2.2973 *	
11	* 1.4751 *	* 1.2799 *	* 1.4182 *	* 1.2420 *	* 1.4572 *	* 1.4369 *	* 0.8175 *	
	* 1.4606 *	* 1.6845 *	* 1.5129 *	* 1.7278 *	* 1.4741 *	* 1.4944 *	* 2.6192 *	
12	* 1.3216 *	* 1.5001 *	* 1.3125 *	* 1.4558 *	* 1.4433 *	* 0.9860 *		
	* 1.6329 *	* 1.4370 *	* 1.6403 *	* 1.4754 *	* 1.4867 *	* 2.1720 *		
13	* 1.0956 *	* 1.2234 *	* 1.4349 *	* 1.4349 *	* 0.9844 *			
	* 1.9692 *	* 1.7626 *	* 1.4985 *	* 1.4963 *	* 2.1754 *			
14	* 0.9200 *	* 1.0850 *	* 0.9328 *	* 0.8148 *				
	* 1.8702 *	* 1.9070 *	* 2.3040 *	* 2.6276 *				
15	* 0.4817 *	* 0.4955 *	F-SUB-Q					
	* 3.1240 *	* 3.3848 *	M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6235 *	* 1.3235 *	* 1.3257 *	* 1.6871 *	* 1.4681 *	* 1.1960 *	* 1.0481 *	* 0.5420 *
	* 1.3865 *	* 1.7041 *	* 1.6987 *	* 1.3305 *	* 1.5307 *	* 1.8847 *	* 1.7016 *	* 2.9245 *
9	* 1.3235 *	* 1.3403 *	* 1.5729 *	* 1.4244 *	* 1.7382 *	* 1.3638 *	* 1.2416 *	* 0.5586 *
	* 1.7041 *	* 1.6830 *	* 1.4299 *	* 1.5783 *	* 1.2905 *	* 1.6453 *	* 1.7260 *	* 3.1872 *
10	* 1.3257 *	* 1.5727 *	* 1.1166 *	* 1.6368 *	* 1.4654 *	* 1.6668 *	* 1.0275 *	
	* 1.6987 *	* 1.4300 *	* 1.8032 *	* 1.3680 *	* 1.5288 *	* 1.3363 *	* 2.1876 *	
11	* 1.6871 *	* 1.4201 *	* 1.6346 *	* 1.3890 *	* 1.6924 *	* 1.6474 *	* 0.8794 *	
	* 1.3305 *	* 1.5830 *	* 1.3695 *	* 1.6024 *	* 1.3149 *	* 1.3474 *	* 2.5246 *	
12	* 1.4681 *	* 1.7321 *	* 1.4621 *	* 1.6911 *	* 1.6917 *	* 1.0704 *		
	* 1.5307 *	* 1.2943 *	* 1.5322 *	* 1.3153 *	* 1.3095 *	* 2.0665 *		
13	* 1.1960 *	* 1.3574 *	* 1.6639 *	* 1.6455 *	* 1.0694 *			
	* 1.8847 *	* 1.6530 *	* 1.3386 *	* 1.3489 *	* 2.0682 *			
14	* 1.0481 *	* 1.2380 *	* 1.0243 *	* 0.8770 *				
	* 1.7016 *	* 1.7293 *	* 2.1945 *	* 2.5313 *				
15	* 0.5420 *	* 0.5515 *	F-SUB-Q					
	* 2.9245 *	* 3.2224 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 124 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6877	* 1.3636	* 1.3735	* 1.7520	* 1.5154	* 1.2517	* 1.1309	* 0.6043
	* 1.4098	* 1.7595	* 1.7441	* 1.3539	* 1.5660	* 1.9137	* 1.6809	* 2.9198
9	* 1.3636	* 1.4077	* 1.6511	* 1.4725	* 1.8145	* 1.4117	* 1.3091	* 0.6080
	* 1.7595	* 1.6509	* 1.4371	* 1.6167	* 1.3040	* 1.6811	* 1.6995	* 3.1569
10	* 1.3735	* 1.6510	* 1.1992	* 1.7158	* 1.5176	* 1.7394	* 1.0796	*
	* 1.7441	* 1.4370	* 1.7539	* 1.3845	* 1.5585	* 1.3413	* 2.2167	*
11	* 1.7520	* 1.4682	* 1.7138	* 1.4430	* 1.7700	* 1.7123	* 0.9184	*
	* 1.3539	* 1.6215	* 1.3854	* 1.6200	* 1.3117	* 1.3530	* 2.5338	*
12	* 1.5154	* 1.8096	* 1.5143	* 1.7696	* 1.7784	* 1.1221	*	*
	* 1.5660	* 1.3076	* 1.5609	* 1.3119	* 1.2986	* 2.0536	*	*
13	* 1.2517	* 1.4052	* 1.7367	* 1.7107	* 1.1213	*	*	*
	* 1.9137	* 1.6886	* 1.3433	* 1.3542	* 2.0551	*	*	*
14	* 1.1309	* 1.3055	* 1.0767	* 0.9159	*	*	*	*
	* 1.6809	* 1.7029	* 2.2229	* 2.5406	*	*	*	*
15	* 0.6043	* 0.6011	* F-SUB-Q					
	* 2.9198	* 3.1959	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7186	* 1.3901	* 1.4047	* 1.7847	* 1.5387	* 1.2905	* 1.2733	* 0.7119
	* 1.4796	* 1.8393	* 1.8230	* 1.4210	* 1.6473	* 1.9735	* 1.6946	* 2.9281
9	* 1.3901	* 1.4762	* 1.7128	* 1.4991	* 1.8544	* 1.4397	* 1.3711	* 0.6841
	* 1.8393	* 1.6668	* 1.4535	* 1.6980	* 1.3631	* 1.7506	* 1.7161	* 3.1603
10	* 1.4047	* 1.7129	* 1.3292	* 1.7718	* 1.5474	* 1.7707	* 1.1181	*
	* 1.8230	* 1.4534	* 1.7771	* 1.4338	* 1.6309	* 1.3931	* 2.2610	*
11	* 1.7847	* 1.4954	* 1.7701	* 1.4699	* 1.8054	* 1.7375	* 0.9383	*
	* 1.4210	* 1.6995	* 1.4351	* 1.6883	* 1.3564	* 1.4039	* 2.6234	*
12	* 1.5387	* 1.8497	* 1.5444	* 1.8052	* 1.8158	* 1.1466	*	*
	* 1.6473	* 1.3667	* 1.6332	* 1.3565	* 1.3374	* 2.1106	*	*
13	* 1.2905	* 1.4345	* 1.7687	* 1.7363	* 1.1460	*	*	*
	* 1.9735	* 1.7570	* 1.3947	* 1.4048	* 2.1117	*	*	*
14	* 1.2733	* 1.3676	* 1.1152	* 0.9359	*	*	*	*
	* 1.6946	* 1.7194	* 2.2665	* 2.6301	*	*	*	*
15	* 0.7119	* 0.6761	* F-SUB-Q					
	* 2.9281	* 3.1969	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 125 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7601	* 1.4194	* 1.4355	* 1.8266	* 1.5651	* 1.3123	* 1.4600	* 0.8174 *
	* 1.5177	* 1.8761	* 1.8519	* 1.4577	* 1.7024	* 2.0189	* 1.7197	* 3.0132 *
9	* 1.4194	* 1.5445	* 1.7819	* 1.5336	* 1.9037	* 1.4707	* 1.4702	* 0.7624 *
	* 1.8761	* 1.6984	* 1.4666	* 1.7241	* 1.3964	* 1.8060	* 1.7364	* 3.2653 *
10	* 1.4355	* 1.7822	* 1.4373	* 1.8348	* 1.5776	* 1.8087	* 1.1422	*
	* 1.8519	* 1.4664	* 1.8055	* 1.4434	* 1.6872	* 1.4473	* 2.3077	*
11	* 1.8266	* 1.5309	* 1.8333	* 1.4952	* 1.8453	* 1.7713	* 0.9397	*
	* 1.4577	* 1.7255	* 1.4445	* 1.7683	* 1.4054	* 1.4558	* 2.7800	*
12	* 1.5651	* 1.8993	* 1.5746	* 1.8452	* 1.8599	* 1.1468	*	
	* 1.7024	* 1.3996	* 1.6904	* 1.4054	* 1.3788	* 2.2251	*	
13	* 1.3123	* 1.4643	* 1.8071	* 1.7704	* 1.1466	*		
	* 2.0189	* 1.8140	* 1.4486	* 1.4565	* 2.2256	*		
14	* 1.4600	* 1.4674	* 1.1396	* 0.9376	*			
	* 1.7197	* 1.7396	* 2.3130	* 2.7862	*			
15	* 0.8174	* 0.7541	* F-SUB-Q					
	* 3.0132	* 3.3007	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7655	* 1.4233	* 1.4409	* 1.8299	* 1.5643	* 1.3204	* 1.5256	* 0.8661 *
	* 1.5306	* 1.8997	* 1.8747	* 1.4746	* 1.7275	* 2.0446	* 1.7450	* 3.0616 *
9	* 1.4233	* 1.5707	* 1.8145	* 1.5434	* 1.9094	* 1.4743	* 1.5169	* 0.8032 *
	* 1.8997	* 1.7128	* 1.4815	* 1.7466	* 1.4126	* 1.8314	* 1.7599	* 3.3082 *
10	* 1.4409	* 1.8147	* 1.4710	* 1.8479	* 1.5782	* 1.8083	* 1.1533	*
	* 1.8747	* 1.4813	* 1.8320	* 1.4585	* 1.7129	* 1.4956	* 2.3378	*
11	* 1.8299	* 1.5422	* 1.8466	* 1.4931	* 1.8445	* 1.7679	* 0.9388	*
	* 1.4746	* 1.7480	* 1.4595	* 1.8146	* 1.4662	* 1.5321	* 2.8960	*
12	* 1.5643	* 1.9053	* 1.5755	* 1.8442	* 1.8599	* 1.1445	*	
	* 1.7275	* 1.4156	* 1.7159	* 1.4663	* 1.4556	* 2.3518	*	
13	* 1.3204	* 1.4679	* 1.8071	* 1.7674	* 1.1445	*		
	* 2.0446	* 1.8394	* 1.4965	* 1.5325	* 2.3518	*		
14	* 1.5256	* 1.5142	* 1.1508	* 0.9369	*			
	* 1.7450	* 1.7630	* 2.3428	* 2.9017	*			
15	* 0.8661	* 0.7938	* F-SUB-Q					
	* 3.0616	* 3.3477	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 126 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7846	* 1.4298	* 1.4465	* 1.8457	* 1.5695	* 1.3177	* 1.5654	* 0.8825 *
	* 1.5363	* 1.9220	* 1.8975	* 1.4824	* 1.7462	* 2.0833	* 1.7480	* 3.1065 *
9	* 1.4298	* 1.5810	* 1.8407	* 1.5508	* 1.9274	* 1.4803	* 1.5511	* 0.8083 *
	* 1.9220	* 1.7343	* 1.4874	* 1.7683	* 1.4186	* 1.8515	* 1.7632	* 3.3929 *
10	* 1.4465	* 1.8410	* 1.4821	* 1.8662	* 1.5806	* 1.8227	* 1.1475	*
	* 1.8975	* 1.4871	* 1.8548	* 1.4658	* 1.7337	* 1.5008	* 2.3914	*
11	* 1.8457	* 1.5496	* 1.8652	* 1.4928	* 1.8573	* 1.7805	* 0.9246	*
	* 1.4824	* 1.7697	* 1.4666	* 1.8365	* 1.4727	* 1.5370	* 2.9779	*
12	* 1.5695	* 1.9236	* 1.5780	* 1.8573	* 1.8746	* 1.1273	*	
	* 1.7462	* 1.4214	* 1.7367	* 1.4727	* 1.4586	* 2.4369	*	
13	* 1.3177	* 1.4739	* 1.8219	* 1.7803	* 1.1277	*		
	* 2.0833	* 1.8596	* 1.5015	* 1.5371	* 2.4359	*		
14	* 1.5654	* 1.5485	* 1.1450	* 0.9229	*			
	* 1.7480	* 1.7662	* 2.3967	* 2.9835	*			
15	* 0.8825	* 0.8003	* F-SUB-Q					
	* 3.1065	* 3.4272	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7233	* 1.4081	* 1.4084	* 1.7762	* 1.5174	* 1.3043	* 1.5148	* 0.8756 *
	* 1.6170	* 1.9834	* 1.9790	* 1.5649	* 1.8348	* 2.1403	* 1.8493	* 3.2157 *
9	* 1.4081	* 1.5586	* 1.7744	* 1.5046	* 1.8536	* 1.4369	* 1.4984	* 0.8170 *
	* 1.9834	* 1.7903	* 1.5692	* 1.8517	* 1.4983	* 1.9370	* 1.8667	* 3.4459 *
10	* 1.4084	* 1.7748	* 1.4377	* 1.7953	* 1.5304	* 1.7502	* 1.1418	*
	* 1.9790	* 1.5689	* 1.9429	* 1.5471	* 1.8165	* 1.5849	* 2.4469	*
11	* 1.7762	* 1.5035	* 1.7944	* 1.4439	* 1.7827	* 1.7073	* 0.9267	*
	* 1.5649	* 1.8532	* 1.5478	* 1.9219	* 1.5531	* 1.6230	* 3.0100	*
12	* 1.5174	* 1.8500	* 1.5280	* 1.7829	* 1.7969	* 1.1289	*	
	* 1.8348	* 1.5013	* 1.8194	* 1.5528	* 1.5390	* 2.4586	*	
13	* 1.3043	* 1.4324	* 1.7497	* 1.7074	* 1.1291	*		
	* 2.1403	* 1.9431	* 1.5854	* 1.6228	* 2.4582	*		
14	* 1.5148	* 1.4960	* 1.1397	* 0.9251	*			
	* 1.8493	* 1.8698	* 2.4515	* 3.0153	*			
15	* 0.8756	* 0.8082	* F-SUB-Q					
	* 3.2157	* 3.4834	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 127 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7458	* 1.3884	* 1.4027	* 1.7941	* 1.5200	* 1.2761	* 1.5378	* 0.8687 *
	* 1.6149	* 2.0349	* 2.0103	* 1.5659	* 1.8516	* 2.2130	* 1.8453	* 3.2855 *
9	* 1.3884	* 1.5429	* 1.7953	* 1.5026	* 1.8742	* 1.4348	* 1.5214	* 0.7996 *
	* 2.0349	* 1.8288	* 1.5679	* 1.8746	* 1.4976	* 1.9634	* 1.8614	* 3.5679 *
10	* 1.4027	* 1.7957	* 1.4365	* 1.8127	* 1.5286	* 1.7718	* 1.1184	*
	* 2.0103	* 1.5675	* 1.9663	* 1.5483	* 1.8381	* 1.5823	* 2.5280	*
11	* 1.7941	* 1.5016	* 1.8121	* 1.4416	* 1.8012	* 1.7293	* 0.8989	*
	* 1.5659	* 1.8760	* 1.5489	* 1.9449	* 1.5519	* 1.6192	* 3.1394	*
12	* 1.5200	* 1.8710	* 1.5263	* 1.8016	* 1.8227	* 1.0965	*	
	* 1.8516	* 1.5002	* 1.8410	* 1.5515	* 1.5329	* 2.5589	*	
13	* 1.2761	* 1.4287	* 1.7716	* 1.7297	* 1.0974	*		
	* 2.2130	* 1.9718	* 1.5824	* 1.6188	* 2.5569	*		
14	* 1.5378	* 1.5191	* 1.1165	* 0.8977	*			
	* 1.8453	* 1.8643	* 2.5323	* 3.1437	*			
15	* 0.8687	* 0.7916	* F-SUB-Q					
	* 3.2855	* 3.6042	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7170	* 1.3625	* 1.3759	* 1.7612	* 1.4894	* 1.2542	* 1.5115	* 0.8547 *
	* 1.6573	* 2.0903	* 2.0660	* 1.6099	* 1.9062	* 2.2713	* 1.8986	* 3.3739 *
9	* 1.3625	* 1.5200	* 1.7642	* 1.4730	* 1.8397	* 1.4061	* 1.4950	* 0.7888 *
	* 2.0904	* 1.8725	* 1.6098	* 1.9280	* 1.5399	* 2.0209	* 1.9148	* 3.6535 *
10	* 1.3759	* 1.7647	* 1.4082	* 1.7788	* 1.4977	* 1.7397	* 1.0995	*
	* 2.0660	* 1.6094	* 2.0215	* 1.5914	* 1.8909	* 1.6250	* 2.5936	*
11	* 1.7612	* 1.4721	* 1.7783	* 1.4127	* 1.7687	* 1.6980	* 0.8847	*
	* 1.6099	* 1.9293	* 1.5918	* 1.9972	* 1.5918	* 1.6617	* 3.2089	*
12	* 1.4894	* 1.8367	* 1.4955	* 1.7692	* 1.7913	* 1.0811	*	
	* 1.9062	* 1.5424	* 1.8936	* 1.5914	* 1.5708	* 2.6101	*	
13	* 1.2542	* 1.4003	* 1.7399	* 1.6987	* 1.0818	*		
	* 2.2713	* 2.0294	* 1.6249	* 1.6611	* 2.6084	*		
14	* 1.5115	* 1.4929	* 1.0978	* 0.8837	*			
	* 1.8986	* 1.9176	* 2.5977	* 3.2129	*			
15	* 0.8547	* 0.7817	* F-SUB-Q					
	* 3.3739	* 3.6864	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 128 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6602	* 1.3402	* 1.3352	* 1.6973	* 1.4382	* 1.2327	* 1.4561	* 0.8355 *
	* 1.7360	* 2.1510	* 2.1544	* 1.6914	* 1.9976	* 2.3388	* 1.9966	* 3.4947 *
9	* 1.3402	* 1.4892	* 1.7009	* 1.4252	* 1.7722	* 1.3621	* 1.4398	* 0.7805 *
	* 2.1510	* 1.9352	* 1.6906	* 2.0158	* 1.6181	* 2.1075	* 2.0155	* 3.7393 *
10	* 1.3352	* 1.7014	* 1.3619	* 1.7136	* 1.4484	* 1.6758	* 1.0809	*
	* 2.1544	* 1.6901	* 2.1133	* 1.6709	* 1.9761	* 1.7046	* 2.6688	*
11	* 1.6973	* 1.4244	* 1.7133	* 1.3663	* 1.7046	* 1.6353	* 0.8760	*
	* 1.6914	* 2.0170	* 1.6711	* 2.0826	* 1.6669	* 1.7417	* 3.2667	*
12	* 1.4382	* 1.7694	* 1.4464	* 1.7051	* 1.7258	* 1.0721	*	
	* 1.9976	* 1.6206	* 1.9789	* 1.6664	* 1.6449	* 2.6507	*	
13	* 1.2327	* 1.3582	* 1.6762	* 1.6362	* 1.0727	*		
	* 2.3388	* 2.1136	* 1.7042	* 1.7407	* 2.6491	*		
14	* 1.4561	* 1.4378	* 1.0793	* 0.8748	*			
	* 1.9966	* 2.0183	* 2.6728	* 3.2708	*			
15	* 0.8355	* 0.7720	* F-SUB-Q					
	* 3.4947	* 3.7807	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6701	* 1.3097	* 1.3225	* 1.7025	* 1.4309	* 1.1957	* 1.4642	* 0.8208 *
	* 1.7282	* 2.1972	* 2.1753	* 1.6909	* 2.0105	* 2.4058	* 1.9764	* 3.5083 *
9	* 1.3097	* 1.4641	* 1.7089	* 1.4136	* 1.7797	* 1.3513	* 1.4490	* 0.7560 *
	* 2.1972	* 1.9698	* 1.6863	* 2.0350	* 1.6170	* 2.1270	* 1.9940	* 3.8059 *
10	* 1.3225	* 1.7095	* 1.3521	* 1.7186	* 1.4372	* 1.6870	* 1.0515	*
	* 2.1753	* 1.6857	* 2.1283	* 1.6721	* 1.9965	* 1.6999	* 2.7332	*
11	* 1.7025	* 1.4128	* 1.7185	* 1.3581	* 1.7148	* 1.6486	* 0.8460	*
	* 1.6909	* 2.0361	* 1.6722	* 2.1032	* 1.6669	* 1.7358	* 3.3729	*
12	* 1.4309	* 1.7773	* 1.4353	* 1.7154	* 1.7431	* 1.0386	*	
	* 2.0105	* 1.6192	* 1.9991	* 1.6663	* 1.6389	* 2.7418	*	
13	* 1.1957	* 1.3461	* 1.6878	* 1.6498	* 1.0397	*		
	* 2.4058	* 2.1351	* 1.6990	* 1.7344	* 2.7389	*		
14	* 1.4642	* 1.4471	* 1.0497	* 0.8453	*			
	* 1.9764	* 1.9965	* 2.7376	* 3.3754	*			
15	* 0.8208	* 0.7478	* F-SUB-Q					
	* 3.5083	* 3.8469	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 129 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6558	* 1.2907	* 1.3038	* 1.6846	* 1.4102	* 1.1748	* 1.4493	* 0.8071 *
	* 1.6466	* 2.0995	* 2.0809	* 1.6211	* 1.9309	* 2.3071	* 1.8822	* 3.3469 *
9	* 1.2907	* 1.4427	* 1.6930	* 1.3923	* 1.7614	* 1.3321	* 1.4348	* 0.7399 *
	* 2.0995	* 1.8872	* 1.6122	* 1.9532	* 1.5529	* 2.0409	* 1.8996	* 3.6480 *
10	* 1.3038	* 1.6936	* 1.3325	* 1.7001	* 1.4154	* 1.6720	* 1.0302	*
	* 2.0809	* 1.6117	* 2.0380	* 1.6052	* 1.9213	* 1.6308	* 2.6294	*
11	* 1.6846	* 1.3915	* 1.7002	* 1.3397	* 1.7001	* 1.6355	* 0.8274	*
	* 1.6211	* 1.9542	* 1.6050	* 2.0216	* 1.6011	* 1.6646	* 3.2503	*
12	* 1.4102	* 1.7592	* 1.4137	* 1.7008	* 1.7319	* 1.0205	*	*
	* 1.9309	* 1.5545	* 1.9234	* 1.6005	* 1.5719	* 2.6445	*	*
13	* 1.1748	* 1.3271	* 1.6732	* 1.6370	* 1.0218	*	*	*
	* 2.3071	* 2.0482	* 1.6296	* 1.6630	* 2.6410	*	*	*
14	* 1.4493	* 1.4330	* 1.0287	* 0.8262	*	*	*	*
	* 1.8822	* 1.9017	* 2.6328	* 3.2546	*	*	*	*
15	* 0.8071	* 0.7325	* F-SUB-Q					
	* 3.3469	* 3.6841	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6378	* 1.2733	* 1.2851	* 1.6614	* 1.3885	* 1.1582	* 1.4275	* 0.7963 *
	* 1.5752	* 2.0142	* 1.9976	* 1.5550	* 1.8556	* 2.2170	* 1.8025	* 3.1974 *
9	* 1.2733	* 1.4304	* 1.6711	* 1.3723	* 1.7370	* 1.3111	* 1.4131	* 0.7347 *
	* 2.0142	* 1.8007	* 1.5444	* 1.8749	* 1.4900	* 1.9619	* 1.8202	* 3.4642 *
10	* 1.2851	* 1.6718	* 1.3132	* 1.6765	* 1.3944	* 1.6484	* 1.0196	*
	* 1.9976	* 1.5438	* 1.9564	* 1.5404	* 1.8464	* 1.5665	* 2.5125	*
11	* 1.6614	* 1.3716	* 1.6767	* 1.3193	* 1.6768	* 1.6125	* 0.8217	*
	* 1.5550	* 1.8758	* 1.5401	* 1.9456	* 1.5384	* 1.5996	* 3.1013	*
12	* 1.3885	* 1.7350	* 1.3928	* 1.6776	* 1.7087	* 1.0137	*	*
	* 1.8556	* 1.4915	* 1.8484	* 1.5377	* 1.5103	* 2.5253	*	*
13	* 1.1582	* 1.3062	* 1.6498	* 1.6142	* 1.0153	*	*	*
	* 2.2170	* 1.9689	* 1.5650	* 1.5979	* 2.5212	*	*	*
14	* 1.4275	* 1.4115	* 1.0185	* 0.8213	*	*	*	*
	* 1.8025	* 1.8221	* 2.5149	* 3.1026	*	*	*	*
15	* 0.7963	* 0.7266	* F-SUB-Q					
	* 3.1974	* 3.5020	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 130 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6006 *	* 1.2741 *	* 1.2657 *	* 1.6222 *	* 1.3592 *	* 1.1594 *	* 1.3894 *	* 0.7886 *
	* 1.5439 *	* 1.9309 *	* 1.9471 *	* 1.5242 *	* 1.8152 *	* 2.1213 *	* 1.7687 *	* 3.0833 *
9	* 1.2741 *	* 1.4242 *	* 1.6322 *	* 1.3478 *	* 1.6945 *	* 1.2892 *	* 1.3747 *	* 0.7385 *
	* 1.9309 *	* 1.7322 *	* 1.5141 *	* 1.8286 *	* 1.4621 *	* 1.9136 *	* 1.7877 *	* 3.2915 *
10	* 1.2657 *	* 1.6329 *	* 1.2892 *	* 1.6368 *	* 1.3683 *	* 1.6066 *	* 1.0186 *	
	* 1.9471 *	* 1.5135 *	* 1.9089 *	* 1.5105 *	* 1.8026 *	* 1.5385 *	* 2.4062 *	
11	* 1.6222 *	* 1.3471 *	* 1.6371 *	* 1.2943 *	* 1.6369 *	* 1.5709 *	* 0.8273 *	
	* 1.5242 *	* 1.8295 *	* 1.5098 *	* 1.9007 *	* 1.5095 *	* 1.5723 *	* 2.9505 *	
12	* 1.3592 *	* 1.6926 *	* 1.3668 *	* 1.6377 *	* 1.6653 *	* 1.0223 *		
	* 1.8152 *	* 1.4635 *	* 1.8043 *	* 1.5088 *	* 1.4844 *	* 2.3999 *		
13	* 1.1594 *	* 1.2859 *	* 1.6081 *	* 1.5728 *	* 1.0235 *			
	* 2.1213 *	* 1.9182 *	* 1.5370 *	* 1.5704 *	* 2.3972 *			
14	* 1.3894 *	* 1.3731 *	* 1.0175 *	* 0.8267 *				
	* 1.7687 *	* 1.7894 *	* 2.4084 *	* 2.9521 *				
15	* 0.7886 *	* 0.7300 *	F-SUB-Q					
	* 3.0833 *	* 3.3291 *	M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6431 *	* 1.2654 *	* 1.2782 *	* 1.6635 *	* 1.3801 *	* 1.1426 *	* 1.4255 *	* 0.7860 *
	* 1.4488 *	* 1.8730 *	* 1.8570 *	* 1.4361 *	* 1.7282 *	* 2.0746 *	* 1.6635 *	* 2.9837 *
9	* 1.2654 *	* 1.4252 *	* 1.6770 *	* 1.3637 *	* 1.7394 *	* 1.3019 *	* 1.4117 *	* 0.7220 *
	* 1.8730 *	* 1.6682 *	* 1.4218 *	* 1.7454 *	* 1.3768 *	* 1.8273 *	* 1.6798 *	* 3.2480 *
10	* 1.2782 *	* 1.6777 *	* 1.3064 *	* 1.6784 *	* 1.3850 *	* 1.6517 *	* 1.0040 *	
	* 1.8570 *	* 1.4212 *	* 1.8180 *	* 1.4245 *	* 1.7217 *	* 1.4461 *	* 2.3579 *	
11	* 1.6635 *	* 1.3631 *	* 1.6790 *	* 1.3123 *	* 1.6827 *	* 1.6176 *	* 0.8077 *	
	* 1.4361 *	* 1.7462 *	* 1.4240 *	* 1.8129 *	* 1.4200 *	* 1.4757 *	* 2.9208 *	
12	* 1.3801 *	* 1.7378 *	* 1.3836 *	* 1.6837 *	* 1.7183 *	* 1.0031 *		
	* 1.7282 *	* 1.3779 *	* 1.7233 *	* 1.4192 *	* 1.3909 *	* 2.3656 *		
13	* 1.1426 *	* 1.2971 *	* 1.6536 *	* 1.6197 *	* 1.0047 *			
	* 2.0746 *	* 1.8337 *	* 1.4444 *	* 1.4737 *	* 2.3619 *			
14	* 1.4255 *	* 1.4102 *	* 1.0028 *	* 0.8069 *				
	* 1.6635 *	* 1.6815 *	* 2.3604 *	* 2.9237 *				
15	* 0.7860 *	* 0.7145 *	F-SUB-Q					
	* 2.9836 *	* 3.2812 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 131 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6451	* 1.2626	* 1.2769	* 1.6657	* 1.3788	* 1.1386	* 1.4250	* 0.7837 *
	* 1.3663	* 1.7734	* 1.7557	* 1.3538	* 1.6347	* 1.9756	* 1.5852	* 2.8674 *
9	* 1.2626	* 1.4268	* 1.6801	* 1.3627	* 1.7419	* 1.3002	* 1.4114	* 0.7205 *
	* 1.7734	* 1.5732	* 1.3395	* 1.6494	* 1.2984	* 1.7361	* 1.6008	* 3.1183 *
10	* 1.2769	* 1.6809	* 1.3056	* 1.6807	* 1.3838	* 1.6545	* 1.0013	*
	* 1.7557	* 1.3389	* 1.7180	* 1.3428	* 1.6297	* 1.3690	* 2.2505	*
11	* 1.6657	* 1.3620	* 1.6814	* 1.3114	* 1.6873	* 1.6210	* 0.8054	*
	* 1.3538	* 1.6502	* 1.3423	* 1.7182	* 1.3411	* 1.3973	* 2.7922	*
12	* 1.3788	* 1.7404	* 1.3824	* 1.6883	* 1.7237	* 1.0035	*	
	* 1.6347	* 1.2994	* 1.6312	* 1.3404	* 1.3140	* 2.2455	*	
13	* 1.1386	* 1.2954	* 1.6565	* 1.6232	* 1.0052	*		
	* 1.9756	* 1.7423	* 1.3673	* 1.3953	* 2.2417	*		
14	* 1.4250	* 1.4098	* 1.0001	* 0.8044	*			
	* 1.5852	* 1.6025	* 2.2530	* 2.7954	*			
15	* 0.7837	* 0.7124	* F-SUB-Q					
	* 2.8674	* 3.1534	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6399	* 1.2615	* 1.2743	* 1.6618	* 1.3762	* 1.1357	* 1.4156	* 0.7802 *
	* 1.3087	* 1.6969	* 1.6808	* 1.2941	* 1.5645	* 1.8934	* 1.5250	* 2.7561 *
9	* 1.2615	* 1.4269	* 1.6752	* 1.3614	* 1.7353	* 1.2965	* 1.4016	* 0.7316 *
	* 1.6969	* 1.5029	* 1.2823	* 1.5773	* 1.2443	* 1.6637	* 1.5402	* 2.9391 *
10	* 1.2743	* 1.6759	* 1.3032	* 1.6757	* 1.3818	* 1.6446	* 0.9995	*
	* 1.6808	* 1.2818	* 1.6442	* 1.2844	* 1.5587	* 1.3150	* 2.1556	*
11	* 1.6618	* 1.3607	* 1.6767	* 1.3067	* 1.6783	* 1.6100	* 0.8023	*
	* 1.2941	* 1.5780	* 1.2837	* 1.6470	* 1.2867	* 1.3429	* 2.6809	*
12	* 1.3762	* 1.7336	* 1.3804	* 1.6793	* 1.7117	* 1.0085	*	
	* 1.5645	* 1.2454	* 1.5602	* 1.2859	* 1.2628	* 2.1352	*	
13	* 1.1357	* 1.2916	* 1.6464	* 1.6121	* 1.0103	*		
	* 1.8934	* 1.6698	* 1.3135	* 1.3411	* 2.1314	*		
14	* 1.4156	* 1.3997	* 0.9982	* 0.8012	*			
	* 1.5250	* 1.5422	* 2.1582	* 2.6845	*			
15	* 0.7802	* 0.7104	* F-SUB-Q					
	* 2.7561	* 3.0263	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 132 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6028	* 1.2493	* 1.2534	* 1.6318	* 1.3543	* 1.1225	* 1.3758	* 0.7644
	* 1.2931	* 1.6552	* 1.6511	* 1.2718	* 1.5352	* 1.8531	* 1.5155	* 2.7213
9	* 1.2493	* 1.4087	* 1.6399	* 1.3407	* 1.6912	* 1.2739	* 1.3610	* 0.7143
	* 1.6552	* 1.4701	* 1.2636	* 1.5467	* 1.2318	* 1.6352	* 1.5321	* 2.9111
10	* 1.2534	* 1.6414	* 1.2818	* 1.6447	* 1.3596	* 1.5965	* 0.9840	*
	* 1.6511	* 1.2625	* 1.6148	* 1.2628	* 1.5299	* 1.3071	* 2.1159	*
11	* 1.6318	* 1.3400	* 1.6455	* 1.2804	* 1.6304	* 1.5587	* 0.7873	*
	* 1.2718	* 1.5474	* 1.2622	* 1.6213	* 1.2775	* 1.3384	* 2.6413	*
12	* 1.3543	* 1.6890	* 1.3581	* 1.6317	* 1.6521	* 0.9863	*	
	* 1.5352	* 1.2333	* 1.5315	* 1.2764	* 1.2621	* 2.1083	*	
13	* 1.1225	* 1.2689	* 1.5979	* 1.5605	* 0.9878	*		
	* 1.8531	* 1.6417	* 1.3058	* 1.3369	* 2.1051	*		
14	* 1.3758	* 1.3590	* 0.9824	* 0.7858	*			
	* 1.5155	* 1.5343	* 2.1191	* 2.6461	*			
15	* 0.7644	* 0.6976	F-SUB-Q					
	* 2.7213	* 2.9813	M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4918	* 1.1874	* 1.1874	* 1.5306	* 1.2854	* 1.0645	* 1.2881	* 0.7158
	* 1.3538	* 1.6988	* 1.6993	* 1.3210	* 1.5767	* 1.9060	* 1.5783	* 2.8374
9	* 1.1874	* 1.3293	* 1.5332	* 1.2726	* 1.5841	* 1.2076	* 1.2718	* 0.6718
	* 1.6988	* 1.5181	* 1.3166	* 1.5885	* 1.2810	* 1.6820	* 1.5986	* 3.0233
10	* 1.1874	* 1.5345	* 1.2134	* 1.5411	* 1.2901	* 1.4843	* 0.9266	*
	* 1.6993	* 1.3155	* 1.6629	* 1.3126	* 1.5713	* 1.3692	* 2.1925	*
11	* 1.5306	* 1.2719	* 1.5416	* 1.2093	* 1.5129	* 1.4463	* 0.7418	*
	* 1.3210	* 1.5894	* 1.3122	* 1.6722	* 1.3399	* 1.4048	* 2.7361	*
12	* 1.2854	* 1.5810	* 1.2884	* 1.5138	* 1.5178	* 0.9226	*	
	* 1.5767	* 1.2833	* 1.5733	* 1.3392	* 1.3375	* 2.1980	*	
13	* 1.0645	* 1.2023	* 1.4845	* 1.4475	* 0.9236	*		
	* 1.9060	* 1.6893	* 1.3692	* 1.4036	* 2.1954	*		
14	* 1.2881	* 1.2697	* 0.9249	* 0.7402	*			
	* 1.5783	* 1.6012	* 2.1964	* 2.7421	*			
15	* 0.7158	* 0.6571	* F-SUB-Q					
	* 2.8374	* 3.0910	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 133 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 375 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2199	* 1.0110	* 0.9968	* 1.2426	* 1.0901	* 0.8990	* 1.0551	* 0.5895 *
	* 1.6256	* 1.9608	* 1.9888	* 1.5977	* 1.8259	* 2.2176	* 1.8935	* 3.3906 *
9	* 1.0110	* 1.1169	* 1.2416	* 1.0726	* 1.2919	* 1.0207	* 1.0436	* 0.5581 *
	* 1.9608	* 1.7750	* 1.5971	* 1.8509	* 1.5411	* 1.9546	* 1.9145	* 3.5818 *
10	* 0.9968	* 1.2420	* 1.0172	* 1.2492	* 1.0846	* 1.2048	* 0.7717	*
	* 1.9888	* 1.5966	* 1.9487	* 1.5897	* 1.8354	* 1.6564	* 2.5873	*
11	* 1.2426	* 1.0720	* 1.2493	* 1.0125	* 1.2218	* 1.1757	* 0.6238	*
	* 1.5977	* 1.8518	* 1.5895	* 1.9619	* 1.6290	* 1.6967	* 3.2000	*
12	* 1.0901	* 1.2890	* 1.0831	* 1.2222	* 1.2165	* 0.7676	*	
	* 1.8259	* 1.5445	* 1.8379	* 1.6283	* 1.6381	* 2.5969	*	
13	* 0.8990	* 1.0163	* 1.2036	* 1.1764	* 0.7680	*		
	* 2.2176	* 1.9631	* 1.6580	* 1.6958	* 2.5953	*		
14	* 1.0551	* 1.0418	* 0.7703	* 0.6224	*			
	* 1.8935	* 1.9178	* 2.5919	* 3.2077	*			
15	* 0.5895	* 0.5491	* F-SUB-Q					
	* 3.3906	* 3.6403	* M-SUB-Q					

AT 75% POWER, 375 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5562	* 0.4995	* 0.5119	* 0.5887	* 0.5345	* 0.4604	* 0.4641	* 0.2859 *
	* 3.5165	* 3.9163	* 3.8217	* 3.3277	* 3.6724	* 4.2745	* 4.2505	* 6.9108 *
9	* 0.4995	* 0.5397	* 0.5874	* 0.5321	* 0.5852	* 0.4978	* 0.4575	* 0.2683 *
	* 3.9163	* 3.6235	* 3.3310	* 3.6812	* 3.3548	* 3.9541	* 4.3116	* 7.3656 *
10	* 0.5119	* 0.5875	* 0.5216	* 0.5913	* 0.5324	* 0.5397	* 0.3791	*
	* 3.8217	* 3.3302	* 3.7514	* 3.3137	* 3.6874	* 3.6473	* 5.2023	*
11	* 0.5887	* 0.5318	* 0.5912	* 0.5183	* 0.5725	* 0.5152	* 0.3014	*
	* 3.3277	* 3.6832	* 3.3141	* 3.7815	* 3.4302	* 3.8196	* 6.5451	*
12	* 0.5345	* 0.5838	* 0.5317	* 0.5725	* 0.5353	* 0.3763	*	
	* 3.6724	* 3.3631	* 3.6926	* 3.4296	* 3.6720	* 5.2308	*	
13	* 0.4604	* 0.4959	* 0.5389	* 0.5153	* 0.3763	*		
	* 4.2745	* 3.9693	* 3.6525	* 3.8191	* 5.2307	*		
14	* 0.4641	* 0.4565	* 0.3784	* 0.3006	*			
	* 4.2505	* 4.3205	* 5.2117	* 6.5609	*			
15	* 0.2859	* 0.2673	* F-SUB-Q					
	* 6.9108	* 7.3937	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 134 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6979	* 0.6485	* 0.6359	* 0.7339	* 0.6837	* 0.5796	* 0.4305	* 0.2429 *
	* 2.8573	* 3.0732	* 3.1297	* 2.7233	* 2.9262	* 3.4370	* 3.7599	* 5.7403 *
9	* 0.6485	* 0.6304	* 0.6807	* 0.6677	* 0.7306	* 0.6386	* 0.5205	* 0.2641 *
	* 3.0732	* 3.1570	* 2.9159	* 2.9926	* 2.7401	* 3.1314	* 3.8076	* 6.0978 *
10	* 0.6359	* 0.6806	* 0.5085	* 0.7123	* 0.6805	* 0.6979	* 0.4816	*
	* 3.1297	* 2.9160	* 3.4819	* 2.8043	* 2.9440	* 2.8812	* 4.1372	*
11	* 0.7339	* 0.6663	* 0.7120	* 0.6691	* 0.7398	* 0.6860	* 0.4275	*
	* 2.7233	* 2.9986	* 2.8054	* 3.0023	* 2.7179	* 2.9368	* 4.6799	*
12	* 0.6837	* 0.7292	* 0.6797	* 0.7395	* 0.7101	* 0.5228	*	
	* 2.9262	* 2.7456	* 2.9481	* 2.7187	* 2.8408	* 3.8495	*	
13	* 0.5796	* 0.6368	* 0.6971	* 0.6853	* 0.5210	*		
	* 3.4370	* 3.1400	* 2.8846	* 2.9394	* 3.8626	*		
14	* 0.4305	* 0.5193	* 0.4808	* 0.4264	*			
	* 3.7599	* 3.8156	* 4.1447	* 4.6920	*			
15	* 0.2429	* 0.2622	* F-SUB-Q					
	* 5.7403	* 6.1437	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2706	* 1.0891	* 1.0633	* 1.2884	* 1.1845	* 0.9775	* 0.8051	* 0.4311 *
	* 1.6182	* 1.8869	* 1.9282	* 1.5975	* 1.7408	* 2.0997	* 2.0338	* 3.3130 *
9	* 1.0891	* 1.0784	* 1.1935	* 1.1416	* 1.3450	* 1.1148	* 0.9768	* 0.4614 *
	* 1.8869	* 1.8979	* 1.7118	* 1.8034	* 1.5334	* 1.8481	* 2.0649	* 3.5632 *
10	* 1.0633	* 1.1934	* 0.8734	* 1.2552	* 1.1805	* 1.3103	* 0.8418	*
	* 1.9282	* 1.7119	* 2.1249	* 1.6370	* 1.7491	* 1.5798	* 2.4411	*
11	* 1.2884	* 1.1392	* 1.2547	* 1.1369	* 1.3248	* 1.2980	* 0.7486	*
	* 1.5975	* 1.8071	* 1.6376	* 1.8182	* 1.5639	* 1.5968	* 2.7520	*
12	* 1.1845	* 1.3424	* 1.1795	* 1.3246	* 1.3443	* 0.9012	*	
	* 1.7408	* 1.5362	* 1.7511	* 1.5641	* 1.5435	* 2.2977	*	
13	* 0.9775	* 1.1113	* 1.3089	* 1.2970	* 0.8993	*		
	* 2.0997	* 1.8537	* 1.5813	* 1.5979	* 2.3026	*		
14	* 0.8051	* 0.9748	* 0.8406	* 0.7468	*			
	* 2.0338	* 2.0677	* 2.4446	* 2.7587	*			
15	* 0.4311	* 0.4544	* F-SUB-Q					
	* 3.3130	* 3.6119	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 135 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4407 *	* 1.1986 *	* 1.1880 *	* 1.4715 *	* 1.3203 *	* 1.1157 *	* 0.9324 *	* 0.5060 *
	* 1.4682 *	* 1.7648 *	* 1.7770 *	* 1.4371 *	* 1.6044 *	* 1.8974 *	* 1.8270 *	* 2.9330 *
9	* 1.1986 *	* 1.1944 *	* 1.3591 *	* 1.2790 *	* 1.5340 *	* 1.2506 *	* 1.1251 *	* 0.5325 *
	* 1.7648 *	* 1.7649 *	* 1.5474 *	* 1.6545 *	* 1.3799 *	* 1.6960 *	* 1.8515 *	* 3.1311 *
10	* 1.1880 *	* 1.3590 *	* 1.0114 *	* 1.4361 *	* 1.3290 *	* 1.5041 *	* 0.9733 *	
	* 1.7770 *	* 1.5474 *	* 1.9354 *	* 1.4685 *	* 1.5936 *	* 1.4097 *	* 2.1695 *	
11	* 1.4715 *	* 1.2762 *	* 1.4355 *	* 1.2832 *	* 1.5278 *	* 1.4839 *	* 0.8705 *	
	* 1.4371 *	* 1.6580 *	* 1.4691 *	* 1.6502 *	* 1.3876 *	* 1.4291 *	* 2.4279 *	
12	* 1.3203 *	* 1.5311 *	* 1.3278 *	* 1.5276 *	* 1.5532 *	* 1.0518 *		
	* 1.6044 *	* 1.3824 *	* 1.5950 *	* 1.3878 *	* 1.3660 *	* 2.0144 *		
13	* 1.1157 *	* 1.2475 *	* 1.5028 *	* 1.4829 *	* 1.0506 *			
	* 1.8974 *	* 1.7001 *	* 1.4108 *	* 1.4299 *	* 2.0166 *			
14	* 0.9324 *	* 1.1231 *	* 0.9715 *	* 0.8684 *				
	* 1.8270 *	* 1.8540 *	* 2.1734 *	* 2.4335 *				
15	* 0.5060 *	* 0.5258 *	F-SUB-Q					
	* 2.9330 *	* 3.1644 *	M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5653 *	* 1.2714 *	* 1.2706 *	* 1.6037 *	* 1.4154 *	* 1.1729 *	* 1.0202 *	* 0.5470 *
	* 1.4038 *	* 1.7302 *	* 1.7289 *	* 1.3677 *	* 1.5520 *	* 1.8764 *	* 1.7050 *	* 2.8124 *
9	* 1.2714 *	* 1.2775 *	* 1.4869 *	* 1.3669 *	* 1.6786 *	* 1.3368 *	* 1.2335 *	* 0.5716 *
	* 1.7302 *	* 1.7201 *	* 1.4736 *	* 1.6065 *	* 1.3062 *	* 1.6414 *	* 1.7236 *	* 3.0566 *
10	* 1.2706 *	* 1.4869 *	* 1.0642 *	* 1.5710 *	* 1.4253 *	* 1.6562 *	* 1.0342 *	
	* 1.7289 *	* 1.4736 *	* 1.8515 *	* 1.3911 *	* 1.5358 *	* 1.3205 *	* 2.1181 *	
11	* 1.6037 *	* 1.3640 *	* 1.5705 *	* 1.3800 *	* 1.6846 *	* 1.6386 *	* 0.9069 *	
	* 1.3677 *	* 1.6100 *	* 1.3915 *	* 1.5835 *	* 1.2954 *	* 1.3322 *	* 2.4067 *	
12	* 1.4154 *	* 1.6758 *	* 1.4240 *	* 1.6845 *	* 1.7228 *	* 1.1025 *		
	* 1.5520 *	* 1.3084 *	* 1.5371 *	* 1.2955 *	* 1.2662 *	* 1.9767 *		
13	* 1.1729 *	* 1.3324 *	* 1.6551 *	* 1.6380 *	* 1.1018 *			
	* 1.8764 *	* 1.6468 *	* 1.3213 *	* 1.3327 *	* 1.9779 *			
14	* 1.0202 *	* 1.2315 *	* 1.0330 *	* 0.9051 *				
	* 1.7050 *	* 1.7258 *	* 2.1206 *	* 2.4114 *				
15	* 0.5470 *	* 0.5641 *	F-SUB-Q					
	* 2.8124 *	* 3.0844 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 136 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5813	* 1.2788	* 1.2839	* 1.6208	* 1.4236	* 1.1964	* 1.0630	* 0.5855 *
	* 1.4654	* 1.8227	* 1.8133	* 1.4259	* 1.6250	* 1.9470	* 1.6907	* 2.8174 *
9	* 1.2788	* 1.2958	* 1.5142	* 1.3754	* 1.6976	* 1.3467	* 1.2648	* 0.6001 *
	* 1.8227	* 1.7225	* 1.5126	* 1.6847	* 1.3586	* 1.7172	* 1.7066	* 3.0410 *
10	* 1.2839	* 1.5144	* 1.1012	* 1.5952	* 1.4341	* 1.6734	* 1.0558	*
	* 1.8133	* 1.5124	* 1.8157	* 1.4459	* 1.6003	* 1.3646	* 2.1933	*
11	* 1.6208	* 1.3725	* 1.5948	* 1.3907	* 1.7016	* 1.6543	* 0.9231	*
	* 1.4259	* 1.6884	* 1.4462	* 1.6433	* 1.3352	* 1.3733	* 2.4716	*
12	* 1.4236	* 1.6949	* 1.4329	* 1.7016	* 1.7436	* 1.1225	*	
	* 1.6250	* 1.3607	* 1.6017	* 1.3351	* 1.2998	* 2.0166	*	
13	* 1.1964	* 1.3422	* 1.6726	* 1.6539	* 1.1221	*		
	* 1.9470	* 1.7226	* 1.3651	* 1.3735	* 2.0173	*		
14	* 1.0630	* 1.2629	* 1.0541	* 0.9213	*			
	* 1.6907	* 1.7088	* 2.1956	* 2.4762	*			
15	* 0.5855	* 0.5929	* F-SUB-Q					
	* 2.8174	* 3.0740	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5892	* 1.2879	* 1.2956	* 1.6278	* 1.4247	* 1.2169	* 1.1612	* 0.6647 *
	* 1.5584	* 1.9212	* 1.9093	* 1.5177	* 1.7344	* 2.0188	* 1.7173	* 2.8427 *
9	* 1.2879	* 1.3360	* 1.5460	* 1.3798	* 1.7057	* 1.3553	* 1.2984	* 0.6518 *
	* 1.9212	* 1.7601	* 1.5479	* 1.7889	* 1.4436	* 1.8135	* 1.7378	* 3.0623 *
10	* 1.2956	* 1.5462	* 1.1814	* 1.6167	* 1.4355	* 1.6711	* 1.0775	*
	* 1.9093	* 1.5476	* 1.8609	* 1.5204	* 1.7019	* 1.4439	* 2.2625	*
11	* 1.6278	* 1.3769	* 1.6165	* 1.3902	* 1.6974	* 1.6485	* 0.9284	*
	* 1.5177	* 1.7899	* 1.5205	* 1.7419	* 1.4097	* 1.4499	* 2.5985	*
12	* 1.4247	* 1.7032	* 1.4342	* 1.6975	* 1.7380	* 1.1255	*	
	* 1.7344	* 1.4458	* 1.7033	* 1.4096	* 1.3692	* 2.1099	*	
13	* 1.2169	* 1.3520	* 1.6707	* 1.6483	* 1.1253	*		
	* 2.0188	* 1.8180	* 1.4443	* 1.4500	* 2.1103	*		
14	* 1.1612	* 1.2964	* 1.0758	* 0.9268	*			
	* 1.7173	* 1.7400	* 2.2659	* 2.6030	*			
15	* 0.6647	* 0.6467	* F-SUB-Q					
	* 2.8427	* 3.0935	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 137 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6202	* 1.3131	* 1.3225	* 1.6582	* 1.4438	* 1.2343	* 1.3368	* 0.7778 *
	* 1.6031	* 1.9653	* 1.9468	* 1.5598	* 1.7940	* 2.0709	* 1.7492	* 2.9320 *
9	* 1.3131	* 1.4014	* 1.6065	* 1.4040	* 1.7397	* 1.3762	* 1.3745	* 0.7354 *
	* 1.9653	* 1.7998	* 1.5707	* 1.8266	* 1.4852	* 1.8720	* 1.7651	* 3.1716 *
10	* 1.3225	* 1.6068	* 1.2838	* 1.6650	* 1.4551	* 1.6925	* 1.0974	*
	* 1.9468	* 1.5704	* 1.8998	* 1.5421	* 1.7779	* 1.5161	* 2.3232	*
11	* 1.6582	* 1.4021	* 1.6649	* 1.4033	* 1.7148	* 1.6662	* 0.9233	*
	* 1.5598	* 1.8276	* 1.5423	* 1.8431	* 1.4794	* 1.5186	* 2.7791	*
12	* 1.4438	* 1.7374	* 1.4533	* 1.7150	* 1.7553	* 1.1139	*	
	* 1.7940	* 1.4872	* 1.7800	* 1.4792	* 1.4328	* 2.2500	*	
13	* 1.2343	* 1.3719	* 1.6923	* 1.6663	* 1.1140	*		
	* 2.0709	* 1.8778	* 1.5162	* 1.5185	* 2.2498	*		
14	* 1.3368	* 1.3728	* 1.0959	* 0.9219	*			
	* 1.7492	* 1.7672	* 2.3264	* 2.7832	*			
15	* 0.7778	* 0.7274	* F-SUB-Q					
	* 2.9320	* 3.2062	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6328	* 1.3261	* 1.3365	* 1.6690	* 1.4499	* 1.2509	* 1.4488	* 0.8566 *
	* 1.6029	* 1.9741	* 1.9574	* 1.5671	* 1.8067	* 2.0905	* 1.7634	* 2.9575 *
9	* 1.3261	* 1.4391	* 1.6452	* 1.4164	* 1.7510	* 1.3865	* 1.4451	* 0.7970 *
	* 1.9741	* 1.8089	* 1.5794	* 1.8418	* 1.4932	* 1.8878	* 1.7769	* 3.1896 *
10	* 1.3365	* 1.6454	* 1.3554	* 1.6854	* 1.4614	* 1.6935	* 1.1157	*
	* 1.9574	* 1.5791	* 1.9203	* 1.5487	* 1.7911	* 1.5465	* 2.3388	*
11	* 1.6690	* 1.4156	* 1.6855	* 1.4032	* 1.7121	* 1.6628	* 0.9240	*
	* 1.5671	* 1.8428	* 1.5486	* 1.8667	* 1.5288	* 1.5760	* 2.8471	*
12	* 1.4499	* 1.7489	* 1.4598	* 1.7123	* 1.7499	* 1.1098	*	
	* 1.8067	* 1.4950	* 1.7931	* 1.5285	* 1.4965	* 2.3677	*	
13	* 1.2509	* 1.3823	* 1.6936	* 1.6631	* 1.1100	*		
	* 2.0905	* 1.8936	* 1.5463	* 1.5756	* 2.3671	*		
14	* 1.4488	* 1.4434	* 1.1143	* 0.9227	*			
	* 1.7634	* 1.7789	* 2.3418	* 2.8509	*			
15	* 0.8566	* 0.7885	* F-SUB-Q					
	* 2.9575	* 3.2242	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 138 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6632	* 1.3456	* 1.3556	* 1.6966	* 1.4666	* 1.2669	* 1.5114	* 0.8901
	* 1.5741	* 1.9496	* 1.9333	* 1.5413	* 1.7860	* 2.0712	* 1.7329	* 2.9502
9	* 1.3456	* 1.4699	* 1.6882	* 1.4389	* 1.7802	* 1.4046	* 1.4997	* 0.8182
	* 1.9496	* 1.7811	* 1.5489	* 1.8200	* 1.4682	* 1.8650	* 1.7454	* 3.2108
10	* 1.3556	* 1.6885	* 1.3842	* 1.7142	* 1.4748	* 1.7153	* 1.1212	*
	* 1.9333	* 1.5486	* 1.8950	* 1.5241	* 1.7749	* 1.5237	* 2.3401	*
11	* 1.6966	* 1.4381	* 1.7144	* 1.4116	* 1.7297	* 1.6823	* 0.9155	*
	* 1.5413	* 1.8209	* 1.5239	* 1.8531	* 1.5090	* 1.5534	* 2.8716	*
12	* 1.4666	* 1.7782	* 1.4732	* 1.7301	* 1.7680	* 1.0969	*	*
	* 1.7860	* 1.4698	* 1.7769	* 1.5088	* 1.4762	* 2.3888	*	*
13	* 1.2669	* 1.4002	* 1.7156	* 1.6828	* 1.0976	*	*	*
	* 2.0712	* 1.8708	* 1.5234	* 1.5528	* 2.3872	*	*	*
14	* 1.5114	* 1.4981	* 1.1196	* 0.9146	*	*	*	*
	* 1.7329	* 1.7473	* 2.3434	* 2.8743	*	*	*	*
15	* 0.8901	* 0.8102	* F-SUB-Q					
	* 2.9502	* 3.2422	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6285	* 1.3410	* 1.3322	* 1.6549	* 1.4348	* 1.2648	* 1.4862	* 0.8989
	* 1.6197	* 1.9722	* 1.9815	* 1.5904	* 1.8380	* 2.0906	* 1.7833	* 2.9648
9	* 1.3410	* 1.4648	* 1.6512	* 1.4138	* 1.7337	* 1.3787	* 1.4698	* 0.8404
	* 1.9722	* 1.8034	* 1.5964	* 1.8666	* 1.5169	* 1.9120	* 1.8003	* 3.1702
10	* 1.3322	* 1.6515	* 1.3587	* 1.6711	* 1.4445	* 1.6655	* 1.1305	*
	* 1.9815	* 1.5960	* 1.9470	* 1.5740	* 1.8235	* 1.5777	* 2.3407	*
11	* 1.6549	* 1.4131	* 1.6710	* 1.3774	* 1.6782	* 1.6280	* 0.9274	*
	* 1.5904	* 1.8676	* 1.5742	* 1.9094	* 1.5624	* 1.6128	* 2.8538	*
12	* 1.4348	* 1.7319	* 1.4430	* 1.6786	* 1.7105	* 1.1085	*	*
	* 1.8380	* 1.5185	* 1.8254	* 1.5621	* 1.5321	* 2.3753	*	*
13	* 1.2648	* 1.3757	* 1.6660	* 1.6287	* 1.1088	*	*	*
	* 2.0906	* 1.9163	* 1.5772	* 1.6121	* 2.3745	*	*	*
14	* 1.4862	* 1.4682	* 1.1292	* 0.9262	*	*	*	*
	* 1.7833	* 1.8022	* 2.3435	* 2.8573	*	*	*	*
15	* 0.8989	* 0.8323	* F-SUB-Q					
	* 2.9648	* 3.2014	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 139 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6636 *	* 1.3373 *	* 1.3450 *	* 1.6865 *	* 1.4519 *	* 1.2573 *	* 1.5269 *	* 0.9030 *
	* 1.6102 *	* 2.0092 *	* 1.9938 *	* 1.5833 *	* 1.8429 *	* 2.1380 *	* 1.7653 *	* 3.0070 *
9	* 1.3373 *	* 1.4663 *	* 1.6853 *	* 1.4262 *	* 1.7681 *	* 1.3923 *	* 1.5106 *	* 0.8322 *
	* 2.0092 *	* 1.8288 *	* 1.5877 *	* 1.8782 *	* 1.5083 *	* 1.9233 *	* 1.7808 *	* 3.2620 *
10	* 1.3450 *	* 1.6857 *	* 1.3723 *	* 1.7014 *	* 1.4561 *	* 1.6990 *	* 1.1185 *	
	* 1.9938 *	* 1.5873 *	* 1.9573 *	* 1.5679 *	* 1.8347 *	* 1.5677 *	* 2.4035 *	
11	* 1.6865 *	* 1.4255 *	* 1.7014 *	* 1.3882 *	* 1.7074 *	* 1.6627 *	* 0.9075 *	
	* 1.5833 *	* 1.8792 *	* 1.5679 *	* 1.9199 *	* 1.5556 *	* 1.6003 *	* 2.9585 *	
12	* 1.4519 *	* 1.7665 *	* 1.4546 *	* 1.7079 *	* 1.7452 *	* 1.0844 *		
	* 1.8429 *	* 1.5097 *	* 1.8366 *	* 1.5552 *	* 1.5210 *	* 2.4563 *		
13	* 1.2573 *	* 1.3880 *	* 1.6996 *	* 1.6636 *	* 1.0853 *			
	* 2.1380 *	* 1.9293 *	* 1.5671 *	* 1.5994 *	* 2.4541 *			
14	* 1.5269 *	* 1.5092 *	* 1.1173 *	* 0.9066 *				
	* 1.7653 *	* 1.7826 *	* 2.4061 *	* 2.9613 *				
15	* 0.9030 *	* 0.8258 *	F-SUB-Q					
	* 3.0070 *	* 3.2872 *	M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6534 *	* 1.3267 *	* 1.3334 *	* 1.6732 *	* 1.4380 *	* 1.2456 *	* 1.5190 *	* 0.8997 *
	* 1.6424 *	* 2.0509 *	* 2.0362 *	* 1.6170 *	* 1.8850 *	* 2.1868 *	* 1.8040 *	* 3.0672 *
9	* 1.3267 *	* 1.4558 *	* 1.6733 *	* 1.4127 *	* 1.7534 *	* 1.3793 *	* 1.5019 *	* 0.8321 *
	* 2.0509 *	* 1.8659 *	* 1.6199 *	* 1.9196 *	* 1.5412 *	* 1.9668 *	* 1.8198 *	* 3.3143 *
10	* 1.3334 *	* 1.6737 *	* 1.3593 *	* 1.6866 *	* 1.4411 *	* 1.6842 *	* 1.1122 *	
	* 2.0362 *	* 1.6195 *	* 2.0003 *	* 1.6013 *	* 1.8757 *	* 1.6009 *	* 2.4498 *	
11	* 1.6732 *	* 1.4121 *	* 1.6867 *	* 1.3730 *	* 1.6916 *	* 1.6474 *	* 0.9025 *	
	* 1.6170 *	* 1.9204 *	* 1.6012 *	* 1.9611 *	* 1.5870 *	* 1.6334 *	* 3.0075 *	
12	* 1.4380 *	* 1.7519 *	* 1.4397 *	* 1.6921 *	* 1.7291 *	* 1.0781 *		
	* 1.8850 *	* 1.5425 *	* 1.8776 *	* 1.5866 *	* 1.5514 *	* 2.4987 *		
13	* 1.2456 *	* 1.3752 *	* 1.6851 *	* 1.6485 *	* 1.0790 *			
	* 2.1868 *	* 1.9728 *	* 1.6000 *	* 1.6323 *	* 2.4967 *			
14	* 1.5190 *	* 1.5005 *	* 1.1111 *	* 0.9017 *				
	* 1.8040 *	* 1.8215 *	* 2.4522 *	* 3.0101 *				
15	* 0.8997 *	* 0.8248 *	F-SUB-Q					
	* 3.0672 *	* 3.3437 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 140 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6157	* 1.3164	* 1.3021	* 1.6293	* 1.4021	* 1.2344	* 1.4798	* 0.8899 *
	* 1.7183	* 2.1113	* 2.1289	* 1.6963	* 1.9741	* 2.2524	* 1.8937	* 3.1705 *
9	* 1.3164	* 1.4421	* 1.6299	* 1.3800	* 1.7061	* 1.3470	* 1.4618	* 0.8328 *
	* 2.1113	* 1.9255	* 1.6988	* 2.0059	* 1.6173	* 2.0526	* 1.9132	* 3.3867 *
10	* 1.3021	* 1.6304	* 1.3262	* 1.6412	* 1.4069	* 1.6379	* 1.1054	*
	* 2.1289	* 1.6983	* 2.0915	* 1.6784	* 1.9591	* 1.6781	* 2.5178	*
11	* 1.6293	* 1.3794	* 1.6414	* 1.3387	* 1.6455	* 1.6003	* 0.9024	*
	* 1.6963	* 2.0068	* 1.6777	* 2.0462	* 1.6601	* 1.7121	* 3.0603	*
12	* 1.4021	* 1.7048	* 1.4056	* 1.6461	* 1.6802	* 1.0788	*	
	* 1.9741	* 1.6186	* 1.9609	* 1.6595	* 1.6241	* 2.5369	*	
13	* 1.2344	* 1.3442	* 1.6389	* 1.6015	* 1.0795	*		
	* 2.2524	* 2.0570	* 1.6770	* 1.7108	* 2.5352	*		
14	* 1.4798	* 1.4605	* 1.1044	* 0.9015	*			
	* 1.8937	* 1.9150	* 2.5201	* 3.0631	*			
15	* 0.8899	* 0.8244	* F-SUB-Q					
	* 3.1705	* 3.4213	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6330	* 1.2962	* 1.3021	* 1.6426	* 1.4038	* 1.2137	* 1.5000	* 0.8814 *
	* 1.7271	* 2.1734	* 2.1602	* 1.7107	* 2.0021	* 2.3204	* 1.8887	* 3.2170 *
9	* 1.2962	* 1.4265	* 1.6446	* 1.3769	* 1.7221	* 1.3484	* 1.4832	* 0.8132 *
	* 2.1734	* 1.9748	* 1.7106	* 2.0410	* 1.6302	* 2.0833	* 1.9065	* 3.4833 *
10	* 1.3021	* 1.6451	* 1.3253	* 1.6538	* 1.4041	* 1.6570	* 1.0824	*
	* 2.1602	* 1.7101	* 2.1222	* 1.6951	* 1.9951	* 1.6881	* 2.6001	*
11	* 1.6426	* 1.3764	* 1.6542	* 1.3384	* 1.6616	* 1.6223	* 0.8767	*
	* 1.7107	* 2.0418	* 1.6946	* 2.0826	* 1.6760	* 1.7199	* 3.1889	*
12	* 1.4038	* 1.7210	* 1.4029	* 1.6622	* 1.7025	* 1.0504	*	
	* 2.0021	* 1.6311	* 1.9969	* 1.6754	* 1.6349	* 2.6498	*	
13	* 1.2137	* 1.3443	* 1.6584	* 1.6238	* 1.0518	*		
	* 2.3204	* 2.0895	* 1.6866	* 1.7184	* 2.6463	*		
14	* 1.5000	* 1.4820	* 1.0815	* 0.8762	*			
	* 1.8887	* 1.9080	* 2.6021	* 3.1908	*			
15	* 0.8814	* 0.8054	* F-SUB-Q					
	* 3.2169	* 3.5164	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 141 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6263	* 1.2847	* 1.2902	* 1.6329	* 1.3908	* 1.2012	* 1.4951	* 0.8730 *
	* 1.6710	* 2.1026	* 2.0955	* 1.6654	* 1.9512	* 2.2520	* 1.8241	* 3.0966 *
9	* 1.2847	* 1.4159	* 1.6359	* 1.3629	* 1.7123	* 1.3370	* 1.4787	* 0.8012 *
	* 2.1026	* 1.9151	* 1.6613	* 1.9875	* 1.5909	* 2.0283	* 1.8421	* 3.3711 *
10	* 1.2902	* 1.6364	* 1.3130	* 1.6432	* 1.3897	* 1.6498	* 1.0669	*
	* 2.0955	* 1.6608	* 2.0613	* 1.6533	* 1.9493	* 1.6469	* 2.5354	*
11	* 1.6329	* 1.3623	* 1.6437	* 1.3260	* 1.6537	* 1.6166	* 0.8616	*
	* 1.6654	* 1.9882	* 1.6528	* 2.0344	* 1.6387	* 1.6774	* 3.1143	*
12	* 1.3908	* 1.7114	* 1.3886	* 1.6544	* 1.6970	* 1.0355	*	
	* 1.9512	* 1.5915	* 1.9507	* 1.6381	* 1.5973	* 2.5973	*	
13	* 1.2012	* 1.3330	* 1.6514	* 1.6182	* 1.0375	*		
	* 2.2520	* 2.0340	* 1.6453	* 1.6757	* 2.5924	*		
14	* 1.4951	* 1.4776	* 1.0659	* 0.8612	*			
	* 1.8241	* 1.8432	* 2.5375	* 3.1156	*			
15	* 0.8730	* 0.7934	* F-SUB-Q					
	* 3.0966	* 3.4032	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6138	* 1.2709	* 1.2752	* 1.6153	* 1.3738	* 1.1857	* 1.4792	* 0.8659 *
	* 1.6060	* 2.0271	* 2.0215	* 1.6048	* 1.8831	* 2.1731	* 1.7516	* 2.9642 *
9	* 1.2709	* 1.4016	* 1.6191	* 1.3470	* 1.6935	* 1.3207	* 1.4625	* 0.8001 *
	* 2.0271	* 1.8440	* 1.5993	* 1.9170	* 1.5334	* 1.9571	* 1.7703	* 3.2060 *
10	* 1.2752	* 1.6197	* 1.2973	* 1.6249	* 1.3730	* 1.6315	* 1.0608	*
	* 2.0215	* 1.5988	* 1.9881	* 1.5941	* 1.8819	* 1.5889	* 2.4292	*
11	* 1.6153	* 1.3465	* 1.6255	* 1.3091	* 1.6355	* 1.5981	* 0.8596	*
	* 1.6048	* 1.9177	* 1.5935	* 1.9676	* 1.5823	* 1.6197	* 2.9797	*
12	* 1.3738	* 1.6929	* 1.3720	* 1.6362	* 1.6783	* 1.0328	*	
	* 1.8831	* 1.5339	* 1.8832	* 1.5816	* 1.5426	* 2.4886	*	
13	* 1.1857	* 1.3169	* 1.6333	* 1.6000	* 1.0344	*		
	* 2.1731	* 1.9625	* 1.5871	* 1.6178	* 2.4848	*		
14	* 1.4792	* 1.4615	* 1.0602	* 0.8593	*			
	* 1.7516	* 1.7714	* 2.4305	* 2.9807	*			
15	* 0.8659	* 0.7924	* F-SUB-Q					
	* 2.9642	* 3.2363	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 142 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5826	* 1.2728	* 1.2543	* 1.5818	* 1.3508	* 1.1850	* 1.4453	* 0.8616 *
	* 1.5829	* 1.9586	* 1.9876	* 1.5830	* 1.8510	* 2.1043	* 1.7267	* 2.8681 *
9	* 1.2728	* 1.4000	* 1.5861	* 1.3255	* 1.6567	* 1.2986	* 1.4276	* 0.8082 *
	* 1.9586	* 1.7848	* 1.5774	* 1.8826	* 1.5138	* 1.9243	* 1.7474	* 3.0564 *
10	* 1.2543	* 1.5867	* 1.2753	* 1.5908	* 1.3504	* 1.5947	* 1.0645	*
	* 1.9876	* 1.5768	* 1.9546	* 1.5730	* 1.8490	* 1.5696	* 2.3359	*
11	* 1.5818	* 1.3250	* 1.5915	* 1.2864	* 1.6010	* 1.5600	* 0.8688	*
	* 1.5830	* 1.8833	* 1.5723	* 1.9360	* 1.5619	* 1.6028	* 2.8479	*
12	* 1.3508	* 1.6561	* 1.3495	* 1.6018	* 1.6398	* 1.0442	*	
	* 1.8510	* 1.5141	* 1.8501	* 1.5612	* 1.5256	* 2.3799	*	
13	* 1.1850	* 1.2962	* 1.5966	* 1.5620	* 1.0453	*		
	* 2.1043	* 1.9277	* 1.5677	* 1.6008	* 2.3774	*		
14	* 1.4453	* 1.4267	* 1.0639	* 0.8685	*			
	* 1.7267	* 1.7484	* 2.3371	* 2.8490	*			
15	* 0.8616	* 0.7995	* F-SUB-Q					
	* 2.8681	* 3.0890	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6208	* 1.2661	* 1.2702	* 1.6183	* 1.3680	* 1.1782	* 1.4851	* 0.8606 *
	* 1.5105	* 1.9227	* 1.9167	* 1.5107	* 1.7831	* 2.0590	* 1.6364	* 2.7950 *
9	* 1.2661	* 1.4006	* 1.6243	* 1.3403	* 1.6973	* 1.3159	* 1.4687	* 0.7913 *
	* 1.9227	* 1.7426	* 1.5045	* 1.8187	* 1.4422	* 1.8496	* 1.6543	* 3.0388 *
10	* 1.2702	* 1.6249	* 1.2921	* 1.6274	* 1.3660	* 1.6377	* 1.0497	*
	* 1.9167	* 1.5040	* 1.8848	* 1.5015	* 1.7845	* 1.4912	* 2.3093	*
11	* 1.6183	* 1.3398	* 1.6282	* 1.3042	* 1.6419	* 1.6058	* 0.8483	*
	* 1.5107	* 1.8193	* 1.5006	* 1.8646	* 1.4868	* 1.5193	* 2.8455	*
12	* 1.3680	* 1.6970	* 1.3651	* 1.6428	* 1.6883	* 1.0243	*	
	* 1.7831	* 1.4424	* 1.7855	* 1.4861	* 1.4465	* 2.3688	*	
13	* 1.1782	* 1.3122	* 1.6399	* 1.6080	* 1.0264	*		
	* 2.0590	* 1.8546	* 1.4891	* 1.5173	* 2.3641	*		
14	* 1.4851	* 1.4679	* 1.0489	* 0.8480	*			
	* 1.6364	* 1.6551	* 2.3109	* 2.8465	*			
15	* 0.8606	* 0.7835	* F-SUB-Q					
	* 2.7950	* 3.0684	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 143 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6251	* 1.2657	* 1.2702	* 1.6215	* 1.3688	* 1.1771	* 1.4897	* 0.8616 *
	* 1.4294	* 1.8271	* 1.8224	* 1.4353	* 1.6997	* 1.9738	* 1.5677	* 2.6966 *
9	* 1.2657	* 1.4027	* 1.6279	* 1.3405	* 1.7013	* 1.3173	* 1.4733	* 0.7930 *
	* 1.8271	* 1.6527	* 1.4269	* 1.7305	* 1.3721	* 1.7695	* 1.5851	* 2.9294 *
10	* 1.2702	* 1.6285	* 1.2925	* 1.6307	* 1.3665	* 1.6435	* 1.0503	*
	* 1.8224	* 1.4264	* 1.7915	* 1.4280	* 1.7029	* 1.4230	* 2.2169	*
11	* 1.6215	* 1.3400	* 1.6317	* 1.3052	* 1.6484	* 1.6124	* 0.8487	*
	* 1.4353	* 1.7311	* 1.4271	* 1.7817	* 1.4167	* 1.4502	* 2.7371	*
12	* 1.3688	* 1.7011	* 1.3657	* 1.6493	* 1.6964	* 1.0277	*	
	* 1.6997	* 1.3723	* 1.7038	* 1.4159	* 1.3783	* 2.2646	*	
13	* 1.1771	* 1.3136	* 1.6459	* 1.6147	* 1.0300	*		
	* 1.9738	* 1.7742	* 1.4209	* 1.4481	* 2.2597	*		
14	* 1.4897	* 1.4724	* 1.0495	* 0.8486	*			
	* 1.5677	* 1.5860	* 2.2184	* 2.7374	*			
15	* 0.8616	* 0.7846	* F-SUB-Q					
	* 2.6966	* 2.9602	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6301	* 1.2691	* 1.2727	* 1.6231	* 1.3734	* 1.1791	* 1.4886	* 0.8637 *
	* 1.3638	* 1.7453	* 1.7415	* 1.3719	* 1.6216	* 1.8873	* 1.5019	* 2.5786 *
9	* 1.2691	* 1.4064	* 1.6335	* 1.3447	* 1.7032	* 1.3215	* 1.4725	* 0.8104 *
	* 1.7453	* 1.5778	* 1.3606	* 1.6515	* 1.3111	* 1.6887	* 1.5182	* 2.7475 *
10	* 1.2727	* 1.6341	* 1.2954	* 1.6325	* 1.3712	* 1.6438	* 1.0551	*
	* 1.7415	* 1.3601	* 1.7114	* 1.3647	* 1.6243	* 1.3612	* 2.1138	*
11	* 1.6231	* 1.3443	* 1.6335	* 1.3079	* 1.6504	* 1.6125	* 0.8519	*
	* 1.3719	* 1.6520	* 1.3639	* 1.7017	* 1.3535	* 1.3871	* 2.6130	*
12	* 1.3734	* 1.7031	* 1.3705	* 1.6513	* 1.6971	* 1.0393	*	
	* 1.6216	* 1.3113	* 1.6252	* 1.3527	* 1.3177	* 2.1441	*	
13	* 1.1791	* 1.3178	* 1.6463	* 1.6149	* 1.0411	*		
	* 1.8873	* 1.6934	* 1.3592	* 1.3851	* 2.1404	*		
14	* 1.4886	* 1.4714	* 1.0544	* 0.8521	*			
	* 1.5019	* 1.5193	* 2.1152	* 2.6125	*			
15	* 0.8637	* 0.7879	* F-SUB-Q					
	* 2.5786	* 2.8259	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 144 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6190	* 1.2639	* 1.2645	* 1.6085	* 1.3682	* 1.1744	* 1.4639	* 0.8565 *
	* 1.3282	* 1.6965	* 1.6964	* 1.3378	* 1.5746	* 1.8341	* 1.4772	* 2.5181 *
9	* 1.2639	* 1.4005	* 1.6166	* 1.3404	* 1.6851	* 1.3155	* 1.4493	* 0.8012 *
	* 1.6965	* 1.5334	* 1.3290	* 1.6030	* 1.2820	* 1.6411	* 1.4921	* 2.6911 *
10	* 1.2645	* 1.6178	* 1.2873	* 1.6174	* 1.3671	* 1.6189	* 1.0526	*
	* 1.6964	* 1.3281	* 1.6666	* 1.3308	* 1.5761	* 1.3359	* 2.0506	*
11	* 1.6085	* 1.3400	* 1.6185	* 1.2982	* 1.6271	* 1.5864	* 0.8473	*
	* 1.3378	* 1.6034	* 1.3299	* 1.6586	* 1.3267	* 1.3629	* 2.5434	*
12	* 1.3682	* 1.6821	* 1.3664	* 1.6280	* 1.6682	* 1.0325	*	
	* 1.5746	* 1.2834	* 1.5768	* 1.3259	* 1.2956	* 2.0875	*	
13	* 1.1744	* 1.3119	* 1.6212	* 1.5886	* 1.0342	*		
	* 1.8341	* 1.6455	* 1.3341	* 1.3610	* 2.0842	*		
14	* 1.4639	* 1.4480	* 1.0517	* 0.8464	*			
	* 1.4772	* 1.4933	* 2.0523	* 2.5463	*			
15	* 0.8565	* 0.7835	* F-SUB-Q					
	* 2.5181	* 2.7520	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5566	* 1.2307	* 1.2230	* 1.5451	* 1.3276	* 1.1396	* 1.4014	* 0.8194
	* 1.3479	* 1.7018	* 1.7126	* 1.3587	* 1.5841	* 1.8462	* 1.5060	* 2.5718
9	* 1.2307	* 1.3535	* 1.5504	* 1.3010	* 1.6188	* 1.2756	* 1.3837	* 0.7690
	* 1.7018	* 1.5484	* 1.3520	* 1.6124	* 1.3015	* 1.6522	* 1.5252	* 2.7400
10	* 1.2230	* 1.5515	* 1.2444	* 1.5530	* 1.3267	* 1.5506	* 1.0139	*
	* 1.7126	* 1.3511	* 1.6832	* 1.3522	* 1.5851	* 1.3603	* 2.0791	*
11	* 1.5451	* 1.3006	* 1.5540	* 1.2505	* 1.5546	* 1.5115	* 0.8180	*
	* 1.3587	* 1.6128	* 1.3514	* 1.6805	* 1.3541	* 1.3951	* 2.5742	*
12	* 1.3276	* 1.6155	* 1.3260	* 1.5558	* 1.5870	* 0.9919	*	
	* 1.5841	* 1.3035	* 1.5860	* 1.3530	* 1.3279	* 2.1215	*	
13	* 1.1396	* 1.2720	* 1.5515	* 1.5133	* 0.9932	*		
	* 1.8462	* 1.6568	* 1.3595	* 1.3935	* 2.1186	*		
14	* 1.4014	* 1.3822	* 1.0130	* 0.8168	*			
	* 1.5060	* 1.5268	* 2.0809	* 2.5779	*			
15	* 0.8194	* 0.7539	* F-SUB-Q					
	* 2.5718	* 2.7949	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 145 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 75% POWER, 475 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3182	* 1.0859	* 1.0614	* 1.3105	* 1.1656	* 0.9927	* 1.1902	* 0.6958 *
	* 1.5640	* 1.8972	* 1.9406	* 1.5740	* 1.7735	* 2.0847	* 1.7426	* 2.9807 *
9	* 1.0859	* 1.1849	* 1.3066	* 1.1355	* 1.3714	* 1.1160	* 1.1765	* 0.6587 *
	* 1.8973	* 1.7389	* 1.5765	* 1.8161	* 1.5080	* 1.8562	* 1.7631	* 3.1490 *
10	* 1.0614	* 1.3075	* 1.0789	* 1.3164	* 1.1565	* 1.3140	* 0.8724	*
	* 1.9406	* 1.5753	* 1.9088	* 1.5673	* 1.7874	* 1.5773	* 2.3760	*
11	* 1.3105	* 1.1352	* 1.3171	* 1.0790	* 1.3072	* 1.2776	* 0.7102	*
	* 1.5740	* 1.8165	* 1.5665	* 1.9118	* 1.5812	* 1.6215	* 2.9170	*
12	* 1.1656	* 1.3703	* 1.1558	* 1.3081	* 1.3258	* 0.8526	*	
	* 1.7735	* 1.5091	* 1.7884	* 1.5801	* 1.5611	* 2.4275	*	
13	* 0.9927	* 1.1126	* 1.3142	* 1.2789	* 0.8532	*		
	* 2.0847	* 1.8617	* 1.5769	* 1.6199	* 2.4256	*		
14	* 1.1903	* 1.1753	* 0.8716	* 0.7090	*			
	* 1.7426	* 1.7649	* 2.3779	* 2.9220	*			
15	* 0.6958	* 0.6487	* F-SUB-Q					
	* 2.9807	* 3.1966	* M-SUB-Q					

AT 75% POWER, 475 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6377	* 0.5728	* 0.5828	* 0.6665	* 0.6115	* 0.5435	* 0.5627	* 0.3572 *
	* 3.1875	* 3.5485	* 3.4881	* 3.0527	* 3.3334	* 3.7583	* 3.6363	* 5.7348 *
9	* 0.5728	* 0.6136	* 0.6636	* 0.6034	* 0.6673	* 0.5827	* 0.5545	* 0.3349 *
	* 3.5485	* 3.3119	* 3.0633	* 3.3717	* 3.0546	* 3.5055	* 3.6902	* 6.1177 *
10	* 0.5828	* 0.6638	* 0.5920	* 0.6695	* 0.6088	* 0.6306	* 0.4537	*
	* 3.4881	* 3.0622	* 3.4348	* 3.0418	* 3.3479	* 3.2396	* 4.5098	*
11	* 0.6665	* 0.6032	* 0.6694	* 0.5914	* 0.6574	* 0.6025	* 0.3633	*
	* 3.0527	* 3.3724	* 3.0416	* 3.4421	* 3.1010	* 3.3904	* 5.6324	*
12	* 0.6115	* 0.6664	* 0.6084	* 0.6577	* 0.6238	* 0.4422	*	
	* 3.3334	* 3.0590	* 3.3501	* 3.0997	* 3.2710	* 4.6200	*	
13	* 0.5435	* 0.5812	* 0.6304	* 0.6028	* 0.4423	*		
	* 3.7583	* 3.5148	* 3.2408	* 3.3883	* 4.6189	*		
14	* 0.5627	* 0.5538	* 0.4533	* 0.3626	*			
	* 3.6363	* 3.6952	* 4.5139	* 5.6423	*			
15	* 0.3572	* 0.3336	* F-SUB-Q					
	* 5.7348	* 6.1410	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 146 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6480	* 0.5920	* 0.5385	* 0.6126	* 0.5694	* 0.4774	* 0.3318	* 0.1672 *
	* 3.4012	* 3.7258	* 4.0969	* 3.5674	* 3.8337	* 4.5620	* 4.8598	* 7.9639 *
9	* 0.5920	* 0.5674	* 0.5747	* 0.5578	* 0.6004	* 0.5113	* 0.3802	* 0.1783 *
	* 3.7258	* 3.8774	* 3.6749	* 3.9167	* 3.6309	* 4.2556	* 5.0036	* 8.4906 *
10	* 0.5385	* 0.5751	* 0.4553	* 0.5600	* 0.5334	* 0.5237	* 0.3687	*
	* 4.0969	* 3.6731	* 4.0233	* 3.7962	* 4.0789	* 4.1509	* 5.8168	*
11	* 0.6126	* 0.5540	* 0.5584	* 0.4913	* 0.5353	* 0.4750	* 0.2874	*
	* 3.5674	* 3.9441	* 3.7994	* 4.3302	* 4.0624	* 4.5829	* 7.5231	*
12	* 0.5694	* 0.5957	* 0.5311	* 0.5343	* 0.4762	* 0.3517	*	*
	* 3.8337	* 3.6596	* 4.0967	* 4.0698	* 4.6091	* 6.2022	*	*
13	* 0.4774	* 0.5079	* 0.5210	* 0.4732	* 0.3500	*	*	*
	* 4.5620	* 4.2845	* 4.1726	* 4.6001	* 6.2329	*	*	*
14	* 0.3318	* 0.3779	* 0.3664	* 0.2856	*	*	*	*
	* 4.8598	* 5.0237	* 5.8493	* 7.5690	*	*	*	*
15	* 0.1672	* 0.1766	* F-SUB-Q					
	* 7.9639	* 8.5440	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3982	* 1.2148	* 1.0676	* 1.2734	* 1.1892	* 0.9650	* 0.7714	* 0.3557 *
	* 1.6439	* 1.8907	* 2.1301	* 1.7863	* 1.9143	* 2.2781	* 2.1543	* 3.9191 *
9	* 1.2148	* 1.1824	* 1.1786	* 1.1322	* 1.3094	* 1.0671	* 0.8855	* 0.3694 *
	* 1.8907	* 1.9058	* 1.8545	* 2.0094	* 1.7375	* 2.1258	* 2.2110	* 4.2532 *
10	* 1.0676	* 1.1795	* 0.8895	* 1.1667	* 1.1124	* 1.1831	* 0.7620	*
	* 2.1301	* 1.8533	* 2.1016	* 1.8862	* 2.0401	* 1.9181	* 2.8988	*
11	* 1.2734	* 1.1275	* 1.1633	* 0.9875	* 1.1225	* 1.0813	* 0.5886	*
	* 1.7863	* 2.0179	* 1.8879	* 2.2287	* 2.0163	* 2.0998	* 3.8346	*
12	* 1.1892	* 1.2980	* 1.1075	* 1.1203	* 1.0652	* 0.6884	*	*
	* 1.9143	* 1.7530	* 2.0491	* 2.0203	* 2.1317	* 3.2880	*	*
13	* 0.9650	* 1.0592	* 1.1768	* 1.0772	* 0.6858	*	*	*
	* 2.2781	* 2.1419	* 1.9284	* 2.1077	* 3.3003	*	*	*
14	* 0.7714	* 0.8798	* 0.7570	* 0.5849	*	*	*	*
	* 2.1543	* 2.2201	* 2.9161	* 3.8593	*	*	*	*
15	* 0.3557	* 0.3625	* F-SUB-Q					
	* 3.9191	* 4.3164	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 147 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4672	* 1.3951	* 1.2358	* 1.3783	* 1.3590	* 1.1512	* 0.9523	* 0.4443
	* 1.6338	* 1.7148	* 1.9145	* 1.7232	* 1.7487	* 1.9786	* 1.9272	* 3.3721
9	* 1.3951	* 1.3703	* 1.2651	* 1.3006	* 1.3899	* 1.2414	* 1.0472	* 0.4507
	* 1.7148	* 1.7432	* 1.8489	* 1.8299	* 1.7118	* 1.9049	* 1.9513	* 3.6470
10	* 1.2358	* 1.2677	* 1.0140	* 1.2520	* 1.2782	* 1.3153	* 0.9263	*
	* 1.9145	* 1.8458	* 1.9172	* 1.8161	* 1.8534	* 1.8018	* 2.4754	*
11	* 1.3783	* 1.2898	* 1.2476	* 1.1475	* 1.2115	* 1.2638	* 0.7038	*
	* 1.7232	* 1.8456	* 1.8195	* 2.0033	* 1.9508	* 1.8719	* 3.3487	*
12	* 1.3590	* 1.3759	* 1.2720	* 1.2078	* 1.2172	* 0.7953	*	*
	* 1.7487	* 1.7295	* 1.8625	* 1.9568	* 1.9385	* 2.9578	*	*
13	* 1.1512	* 1.2326	* 1.3086	* 1.2587	* 0.7928	*	*	*
	* 1.9786	* 1.9217	* 1.8112	* 1.8795	* 2.9667	*	*	*
14	* 0.9523	* 1.0395	* 0.9198	* 0.6992	*	*	*	*
	* 1.9272	* 1.9595	* 2.4912	* 3.3708	*	*	*	*
15	* 0.4443	* 0.4439	* F-SUB-Q					
	* 3.3721	* 3.6929	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6373	* 1.5327	* 1.3571	* 1.5422	* 1.5054	* 1.2905	* 1.1147	* 0.5089
	* 1.5499	* 1.6514	* 1.8425	* 1.6353	* 1.6699	* 1.8614	* 1.7517	* 3.1732
9	* 1.5327	* 1.5140	* 1.4224	* 1.4168	* 1.5632	* 1.3886	* 1.2221	* 0.5093
	* 1.6514	* 1.6703	* 1.7397	* 1.7766	* 1.6159	* 1.7936	* 1.7719	* 3.4932
10	* 1.3571	* 1.4253	* 1.0874	* 1.4076	* 1.4158	* 1.5000	* 1.0323	*
	* 1.8425	* 1.7360	* 1.8948	* 1.7167	* 1.7755	* 1.6738	* 2.3488	*
11	* 1.5422	* 1.4097	* 1.4023	* 1.2456	* 1.3674	* 1.4357	* 0.7613	*
	* 1.6353	* 1.7851	* 1.7203	* 1.9563	* 1.8307	* 1.7441	* 3.2815	*
12	* 1.5054	* 1.5470	* 1.4081	* 1.3628	* 1.3676	* 0.8485	*	*
	* 1.6699	* 1.6332	* 1.7853	* 1.8369	* 1.8256	* 2.9302	*	*
13	* 1.2905	* 1.3760	* 1.4916	* 1.4295	* 0.8464	*	*	*
	* 1.8614	* 1.8116	* 1.6833	* 1.7519	* 2.9376	*	*	*
14	* 1.1147	* 1.2126	* 1.0243	* 0.7558	*	*	*	*
	* 1.7517	* 1.7799	* 2.3656	* 3.3054	*	*	*	*
15	* 0.5089	* 0.5013	* F-SUB-Q					
	* 3.1732	* 3.5488	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 148 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7041	* 1.5780	* 1.4042	* 1.6191	* 1.5724	* 1.3556	* 1.2055	* 0.5610 *
	* 1.6102	* 1.7362	* 1.9151	* 1.6831	* 1.7067	* 1.9088	* 1.7705	* 3.2191 *
9	* 1.5780	* 1.5601	* 1.4827	* 1.4721	* 1.6402	* 1.4596	* 1.3150	* 0.5558 *
	* 1.7362	* 1.7404	* 1.7962	* 1.8342	* 1.6608	* 1.8364	* 1.7913	* 3.5400 *
10	* 1.4042	* 1.4859	* 1.1481	* 1.4842	* 1.4785	* 1.5860	* 1.1026	*
	* 1.9151	* 1.7921	* 1.9535	* 1.7561	* 1.8324	* 1.7032	* 2.3682	*
11	* 1.6191	* 1.4641	* 1.4781	* 1.3140	* 1.4405	* 1.5163	* 0.8046	*
	* 1.6831	* 1.8439	* 1.7604	* 2.0029	* 1.8746	* 1.7761	* 3.3333	*
12	* 1.5724	* 1.6222	* 1.4698	* 1.4354	* 1.4397	* 0.8913	*	
	* 1.7067	* 1.6793	* 1.8421	* 1.8815	* 1.8701	* 3.0014	*	
13	* 1.3556	* 1.4454	* 1.5761	* 1.5092	* 0.8891	*		
	* 1.9088	* 1.8549	* 1.7138	* 1.7846	* 3.0088	*		
14	* 1.2055	* 1.3048	* 1.0937	* 0.7988	*			
	* 1.7705	* 1.8002	* 2.3860	* 3.3579	*			
15	* 0.5610	* 0.5478	* F-SUB-Q					
	* 3.2191	* 3.5895	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7585	* 1.6210	* 1.4541	* 1.6893	* 1.6441	* 1.4246	* 1.3204	* 0.6359 *
	* 1.6825	* 1.8145	* 1.9949	* 1.7294	* 1.7547	* 1.9748	* 1.8230	* 3.3278 *
9	* 1.6210	* 1.6062	* 1.5423	* 1.5380	* 1.7115	* 1.5293	* 1.4161	* 0.6184 *
	* 1.8145	* 1.8170	* 1.8682	* 1.8978	* 1.7065	* 1.8837	* 1.8415	* 3.6455 *
10	* 1.4541	* 1.5461	* 1.2340	* 1.5627	* 1.5418	* 1.6623	* 1.1708	*
	* 1.9949	* 1.8635	* 2.0355	* 1.8143	* 1.8837	* 1.7598	* 2.4164	*
11	* 1.6893	* 1.5224	* 1.5559	* 1.3818	* 1.5057	* 1.5846	* 0.8434	*
	* 1.7294	* 1.9087	* 1.8192	* 2.0683	* 1.9567	* 1.8502	* 3.4733	*
12	* 1.6441	* 1.6920	* 1.5321	* 1.5000	* 1.5037	* 0.9296	*	
	* 1.7547	* 1.7264	* 1.8946	* 1.9643	* 1.9482	* 3.1154	*	
13	* 1.4246	* 1.5136	* 1.6511	* 1.5768	* 0.9273	*		
	* 1.9748	* 1.9031	* 1.7722	* 1.8596	* 3.1233	*		
14	* 1.3204	* 1.4049	* 1.1610	* 0.8370	*			
	* 1.8230	* 1.8514	* 2.4361	* 3.5000	*			
15	* 0.6359	* 0.6102	* F-SUB-Q					
	* 3.3278	* 3.6942	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 149 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8394	* 1.6877	* 1.5275	* 1.7857	* 1.7410	* 1.5206	* 1.5311	* 0.7647 *
	* 1.7468	* 1.8900	* 2.0746	* 1.7791	* 1.8050	* 2.0286	* 1.8604	* 3.4478 *
9	* 1.6877	* 1.6802	* 1.6367	* 1.6112	* 1.8139	* 1.6224	* 1.5617	* 0.7218 *
	* 1.8900	* 1.8811	* 1.9271	* 1.9650	* 1.7509	* 1.9333	* 1.8753	* 3.7868 *
10	* 1.5275	* 1.6407	* 1.3938	* 1.6755	* 1.6285	* 1.7634	* 1.2432	*
	* 2.0746	* 1.9223	* 2.1280	* 1.8562	* 1.9421	* 1.7968	* 2.4903	*
11	* 1.7857	* 1.6015	* 1.6695	* 1.4537	* 1.5939	* 1.6753	* 0.8746	*
	* 1.7791	* 1.9768	* 1.8616	* 2.1443	* 2.0052	* 1.9141	* 3.6512	*
12	* 1.7410	* 1.7929	* 1.6184	* 1.5876	* 1.5899	* 0.9625	*	
	* 1.8050	* 1.7717	* 1.9541	* 2.0122	* 2.0208	* 3.3032	*	
13	* 1.5206	* 1.6047	* 1.7509	* 1.6667	* 0.9603	*		
	* 2.0286	* 1.9542	* 1.8101	* 1.9238	* 3.3109	*		
14	* 1.5311	* 1.5493	* 1.2325	* 0.8675	*			
	* 1.8604	* 1.8858	* 2.5113	* 3.6804	*			
15	* 0.7647	* 0.7102	* F-SUB-Q					
	* 3.4478	* 3.8457	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8890	* 1.7349	* 1.5809	* 1.8511	* 1.8126	* 1.5976	* 1.6921	* 0.8928 *
	* 1.8625	* 2.0190	* 2.2145	* 1.8850	* 1.9115	* 2.1539	* 1.9550	* 3.6169 *
9	* 1.7349	* 1.7319	* 1.7009	* 1.6697	* 1.8826	* 1.6915	* 1.6943	* 0.8195 *
	* 2.0190	* 2.0072	* 2.0542	* 2.0891	* 1.8530	* 2.0425	* 1.9728	* 3.9737 *
10	* 1.5809	* 1.7053	* 1.5168	* 1.7609	* 1.6925	* 1.8331	* 1.3066	*
	* 2.2145	* 2.0488	* 2.2732	* 1.9665	* 2.0548	* 1.8896	* 2.6319	*
11	* 1.8511	* 1.6594	* 1.7545	* 1.5155	* 1.6525	* 1.7343	* 0.9039	*
	* 1.8850	* 2.1024	* 1.9737	* 2.2754	* 2.1074	* 2.0080	* 3.8424	*
12	* 1.8126	* 1.8603	* 1.6815	* 1.6457	* 1.6461	* 0.9910	*	
	* 1.9115	* 1.8757	* 2.0683	* 2.1160	* 2.1191	* 3.5271	*	
13	* 1.5976	* 1.6726	* 1.8191	* 1.7250	* 0.9888	*		
	* 2.1539	* 2.0657	* 1.9043	* 2.0188	* 3.5348	*		
14	* 1.6921	* 1.6842	* 1.2950	* 0.8962	*			
	* 1.9550	* 1.9843	* 2.6552	* 3.8750	*			
15	* 0.8928	* 0.8068	* F-SUB-Q					
	* 3.6169	* 4.0346	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 150 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9613	* 1.7990	* 1.6415	* 1.9358	* 1.8949	* 1.6757	* 1.8328	* 0.9675 *
	* 1.9641	* 2.1367	* 2.3419	* 1.9738	* 2.0035	* 2.2577	* 2.0334	* 3.8213 *
9	* 1.7990	* 1.8118	* 1.7819	* 1.7358	* 1.9730	* 1.7698	* 1.8239	* 0.8790 *
	* 2.1367	* 2.1131	* 2.1549	* 2.2032	* 1.9356	* 2.1376	* 2.0498	* 4.2145 *
10	* 1.6415	* 1.7863	* 1.5871	* 1.8544	* 1.7640	* 1.9218	* 1.3579	*
	* 2.3419	* 2.1493	* 2.3985	* 2.0530	* 2.1596	* 1.9691	* 2.7781	*
11	* 1.9358	* 1.7247	* 1.8484	* 1.5846	* 1.7287	* 1.8126	* 0.9231	*
	* 1.9738	* 2.2176	* 2.0608	* 2.4092	* 2.2001	* 2.0951	* 4.1030	*
12	* 1.8949	* 1.9494	* 1.7521	* 1.7214	* 1.7200	* 1.0136	*	
	* 2.0035	* 1.9594	* 2.1744	* 2.2093	* 2.2126	* 3.7544	*	
13	* 1.6757	* 1.7493	* 1.9064	* 1.8026	* 1.0115	*		
	* 2.2577	* 2.1628	* 1.9849	* 2.1067	* 3.7619	*		
14	* 1.8328	* 1.8130	* 1.3452	* 0.9159	*			
	* 2.0334	* 2.0621	* 2.8039	* 4.1346	*			
15	* 0.9675	* 0.8621	* F-SUB-Q					
	* 3.8213	* 4.2958	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9248	* 1.7790	* 1.6261	* 1.9095	* 1.8848	* 1.6712	* 1.8309	* 0.9925 *
	* 2.2067	* 2.3862	* 2.6111	* 2.2052	* 2.2204	* 2.4984	* 2.2543	* 4.1340 *
9	* 1.7790	* 1.7985	* 1.7490	* 1.7339	* 1.9424	* 1.7603	* 1.8164	* 0.9126 *
	* 2.3862	* 2.3548	* 2.4245	* 2.4354	* 2.1595	* 2.3670	* 2.2764	* 4.4997 *
10	* 1.6261	* 1.7539	* 1.6112	* 1.8351	* 1.7526	* 1.9001	* 1.3826	*
	* 2.6111	* 2.4175	* 2.6328	* 2.2894	* 2.3944	* 2.1892	* 3.0053	*
11	* 1.9095	* 1.7149	* 1.8288	* 1.6111	* 1.7034	* 1.7855	* 0.9466	*
	* 2.2052	* 2.4626	* 2.2982	* 2.6199	* 2.4532	* 2.3348	* 4.3892	*
12	* 1.8848	* 1.9180	* 1.7403	* 1.6973	* 1.6937	* 1.0339	*	
	* 2.2204	* 2.1939	* 2.4113	* 2.4638	* 2.4665	* 4.0326	*	
13	* 1.6712	* 1.7393	* 1.8844	* 1.7752	* 1.0313	*		
	* 2.4984	* 2.3954	* 2.2072	* 2.3480	* 4.0423	*		
14	* 1.8309	* 1.8050	* 1.3696	* 0.9383	*			
	* 2.2543	* 2.2906	* 3.0332	* 4.4269	*			
15	* 0.9925	* 0.8980	* F-SUB-Q					
	* 4.1340	* 4.5718	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 151 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9874	* 1.8246	* 1.6670	* 1.9812	* 1.9471	* 1.7228	* 1.9186	* 1.0163
	* 2.3326	* 2.5400	* 2.7805	* 2.3379	* 2.3675	* 2.6721	* 2.3813	* 4.4739
9	* 1.8246	* 1.8510	* 1.8161	* 1.7688	* 2.0230	* 1.8204	* 1.9044	* 0.9234
	* 2.5400	* 2.5055	* 2.5521	* 2.6219	* 2.2858	* 2.5164	* 2.4006	* 4.9235
10	* 1.6670	* 1.8210	* 1.6287	* 1.9059	* 1.8049	* 1.9787	* 1.4002	*
	* 2.7805	* 2.5454	* 2.8502	* 2.4189	* 2.5516	* 2.3051	* 3.2618	*
11	* 1.9812	* 1.7567	* 1.8991	* 1.6293	* 1.7723	* 1.8594	* 0.9438	*
	* 2.3379	* 2.6403	* 2.4285	* 2.8470	* 2.5765	* 2.4482	* 4.7997	*
12	* 1.9471	* 1.9977	* 1.7917	* 1.7643	* 1.7620	* 1.0352	*	*
	* 2.3675	* 2.3157	* 2.5701	* 2.5877	* 2.5832	* 4.3730	*	*
13	* 1.7228	* 1.7977	* 1.9618	* 1.8483	* 1.0330	*	*	*
	* 2.6721	* 2.5477	* 2.3244	* 2.4622	* 4.3813	*	*	*
14	* 1.9186	* 1.8922	* 1.3864	* 0.9359	*	*	*	*
	* 2.3813	* 2.4157	* 3.2932	* 4.8378	*	*	*	*
15	* 1.0163	* 0.9056	* F-SUB-Q					
	* 4.4739	* 5.0188	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9762	* 1.8138	* 1.6582	* 1.9800	* 1.9475	* 1.7215	* 1.9270	* 1.0203
	* 2.3507	* 2.5602	* 2.7998	* 2.3458	* 2.3897	* 2.7060	* 2.4295	* 4.6005
9	* 1.8138	* 1.8446	* 1.8083	* 1.7631	* 2.0217	* 1.8219	* 1.9115	* 0.9284
	* 2.5602	* 2.5200	* 2.5680	* 2.6354	* 2.2992	* 2.5566	* 2.4466	* 5.0534
10	* 1.6582	* 1.8132	* 1.6240	* 1.9060	* 1.8031	* 1.9829	* 1.4037	*
	* 2.7998	* 2.5611	* 2.8667	* 2.4376	* 2.5778	* 2.3485	* 3.3275	*
11	* 1.9800	* 1.7505	* 1.8986	* 1.6304	* 1.7745	* 1.8622	* 0.9462	*
	* 2.3458	* 2.6545	* 2.4481	* 2.8537	* 2.6182	* 2.4982	* 4.9282	*
12	* 1.9475	* 1.9959	* 1.7892	* 1.7661	* 1.7640	* 1.0376	*	*
	* 2.3897	* 2.3291	* 2.5982	* 2.6310	* 2.6341	* 4.4858	*	*
13	* 1.7215	* 1.7982	* 1.9652	* 1.8506	* 1.0354	*	*	*
	* 2.7060	* 2.5906	* 2.3700	* 2.5141	* 4.4956	*	*	*
14	* 1.9270	* 1.8988	* 1.3896	* 0.9378	*	*	*	*
	* 2.4295	* 2.4631	* 3.3618	* 4.9733	*	*	*	*
15	* 1.0203	* 0.9124	* F-SUB-Q					
	* 4.6005	* 5.1407	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 152 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9102	* 1.7605	* 1.6112	* 1.9211	* 1.9006	* 1.6805	* 1.8760	* 1.0070 *
	* 2.4163	* 2.6208	* 2.8620	* 2.4023	* 2.4353	* 2.7574	* 2.4875	* 4.6474 *
9	* 1.7605	* 1.7924	* 1.7460	* 1.7246	* 1.9612	* 1.7782	* 1.8596	* 0.9259 *
	* 2.6208	* 2.5772	* 2.6420	* 2.6790	* 2.3570	* 2.6038	* 2.5057	* 5.0501 *
10	* 1.6112	* 1.7511	* 1.5958	* 1.8513	* 1.7585	* 1.9309	* 1.3899	*
	* 2.8620	* 2.6343	* 2.8942	* 2.4908	* 2.6238	* 2.3955	* 3.3401	*
11	* 1.9211	* 1.7043	* 1.8431	* 1.6088	* 1.7245	* 1.8106	* 0.9437	*
	* 2.4023	* 2.7095	* 2.5021	* 2.8687	* 2.6702	* 2.5467	* 4.8931	*
12	* 1.9006	* 1.9336	* 1.7444	* 1.7160	* 1.7147	* 1.0337	*	
	* 2.4353	* 2.3887	* 2.6452	* 2.6833	* 2.6823	* 4.4497	*	
13	* 1.6805	* 1.7544	* 1.9130	* 1.7990	* 1.0313	*		
	* 2.7574	* 2.6395	* 2.4182	* 2.5636	* 4.4607	*		
14	* 1.8760	* 1.8467	* 1.3754	* 0.9344	*			
	* 2.4875	* 2.5235	* 3.3757	* 4.9430	*			
15	* 1.0070	* 0.9105	* F-SUB-Q					
	* 4.6474	* 5.1342	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9210	* 1.7569	* 1.6072	* 1.9375	* 1.9101	* 1.6847	* 1.9060	* 0.9984 *
	* 2.3305	* 2.5474	* 2.7768	* 2.3075	* 2.3497	* 2.6577	* 2.3564	* 4.4565 *
9	* 1.7569	* 1.7931	* 1.7623	* 1.7149	* 1.9849	* 1.7902	* 1.8917	* 0.9079 *
	* 2.5474	* 2.4968	* 2.5344	* 2.6044	* 2.2531	* 2.5016	* 2.3720	* 4.8962 *
10	* 1.6072	* 1.7672	* 1.5792	* 1.8695	* 1.7627	* 1.9579	* 1.3695	*
	* 2.7768	* 2.5276	* 2.8195	* 2.3837	* 2.5317	* 2.2851	* 3.2552	*
11	* 1.9375	* 1.7017	* 1.8609	* 1.5815	* 1.7475	* 1.8378	* 0.9170	*
	* 2.3075	* 2.6239	* 2.3943	* 2.8092	* 2.5397	* 2.4165	* 4.8061	*
12	* 1.9101	* 1.9583	* 1.7479	* 1.7385	* 1.7386	* 1.0122	*	
	* 2.3497	* 2.2824	* 2.5523	* 2.5522	* 2.5408	* 4.3352	*	
13	* 1.6847	* 1.7651	* 1.9391	* 1.8255	* 1.0101	*		
	* 2.6577	* 2.5360	* 2.3064	* 2.4321	* 4.3436	*		
14	* 1.9060	* 1.8782	* 1.3544	* 0.9087	*			
	* 2.3564	* 2.3883	* 3.2901	* 4.8488	*			
15	* 0.9984	* 0.8893	* F-SUB-Q					
	* 4.4565	* 4.9949	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 153 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8871	* 1.7197	* 1.5738	* 1.9082	* 1.8810	* 1.6565	* 1.8868	* 0.9801 *
	* 2.1550	* 2.3629	* 2.5735	* 2.1300	* 2.1700	* 2.4578	* 2.1650	* 4.1310 *
9	* 1.7197	* 1.7588	* 1.7324	* 1.6821	* 1.9582	* 1.7652	* 1.8732	* 0.8898 *
	* 2.3629	* 2.3100	* 2.3403	* 2.4130	* 2.0770	* 2.3086	* 2.1794	* 4.5473 *
10	* 1.5738	* 1.7372	* 1.5490	* 1.8435	* 1.7334	* 1.9368	* 1.3423	*
	* 2.5735	* 2.3340	* 2.6082	* 2.1981	* 2.3419	* 2.1032	* 3.0229	*
11	* 1.9082	* 1.6686	* 1.8346	* 1.5542	* 1.7273	* 1.8187	* 0.8952	*
	* 2.1300	* 2.4318	* 2.2084	* 2.5975	* 2.3379	* 2.2225	* 4.4820	*
12	* 1.8810	* 1.9314	* 1.7183	* 1.7181	* 1.7195	* 0.9916	*	
	* 2.1700	* 2.1047	* 2.3618	* 2.3499	* 2.3362	* 4.0222	*	
13	* 1.6565	* 1.7394	* 1.9175	* 1.8061	* 0.9891	*		
	* 2.4578	* 2.3417	* 2.1236	* 2.2374	* 4.0317	*		
14	* 1.8868	* 1.8594	* 1.3271	* 0.8870	*			
	* 2.1650	* 2.1950	* 3.0566	* 4.5227	*			
15	* 0.9801	* 0.8705	* F-SUB-Q					
	* 4.1310	* 4.6445	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8312	* 1.6699	* 1.5281	* 1.8579	* 1.8339	* 1.6127	* 1.8404	* 0.9568 *
	* 2.0055	* 2.1971	* 2.3935	* 1.9788	* 2.0151	* 2.2866	* 2.0143	* 3.8437 *
9	* 1.6699	* 1.7099	* 1.6824	* 1.6351	* 1.9066	* 1.7207	* 1.8268	* 0.8713 *
	* 2.1971	* 2.1463	* 2.1768	* 2.2450	* 1.9304	* 2.1452	* 2.0275	* 4.2175 *
10	* 1.5281	* 1.6872	* 1.5054	* 1.7965	* 1.6888	* 1.8904	* 1.3124	*
	* 2.3935	* 2.1708	* 2.4257	* 2.0402	* 2.1747	* 1.9517	* 2.8021	*
11	* 1.8579	* 1.6216	* 1.7876	* 1.5132	* 1.6845	* 1.7741	* 0.8774	*
	* 1.9788	* 2.2629	* 2.0500	* 2.4119	* 2.1723	* 2.0658	* 4.1477	*
12	* 1.8339	* 1.8801	* 1.6735	* 1.6753	* 1.6772	* 0.9725	*	
	* 2.0151	* 1.9566	* 2.1938	* 2.1838	* 2.1730	* 3.7190	*	
13	* 1.6127	* 1.6949	* 1.8710	* 1.7614	* 0.9705	*		
	* 2.2866	* 2.1768	* 1.9713	* 2.0801	* 3.7264	*		
14	* 1.8404	* 1.8129	* 1.2971	* 0.8690	*			
	* 2.0143	* 2.0425	* 2.8343	* 4.1869	*			
15	* 0.9568	* 0.8531	* F-SUB-Q					
	* 3.8437	* 4.3044	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 154 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7387	* 1.5964	* 1.4623	* 1.7723	* 1.7576	* 1.5457	* 1.7549	* 0.9275 *
	* 1.9115	* 2.0790	* 2.2635	* 1.8788	* 1.9062	* 2.1652	* 1.9233	* 3.6200 *
9	* 1.5964	* 1.6360	* 1.5972	* 1.5721	* 1.8178	* 1.6481	* 1.7400	* 0.8542 *
	* 2.0790	* 2.0311	* 2.0751	* 2.1167	* 1.8382	* 2.0310	* 1.9369	* 3.9258 *
10	* 1.4623	* 1.6022	* 1.4546	* 1.7149	* 1.6192	* 1.8054	* 1.2795	*
	* 2.2634	* 2.0692	* 2.2746	* 1.9361	* 2.0541	* 1.8521	* 2.6094	*
11	* 1.7723	* 1.5528	* 1.7061	* 1.4720	* 1.6074	* 1.6924	* 0.8653	*
	* 1.8788	* 2.1405	* 1.9457	* 2.2474	* 2.0560	* 1.9540	* 3.8005	*
12	* 1.7576	* 1.7882	* 1.6043	* 1.5983	* 1.6006	* 0.9549	*	
	* 1.9062	* 1.8640	* 2.0726	* 2.0672	* 2.0510	* 3.4085	*	
13	* 1.5457	* 1.6229	* 1.7863	* 1.6800	* 0.9526	*		
	* 2.1652	* 2.0616	* 1.8712	* 1.9680	* 3.4164	*		
14	* 1.7549	* 1.7263	* 1.2645	* 0.8557	*			
	* 1.9233	* 1.9519	* 2.6397	* 3.8424	*			
15	* 0.9275	* 0.8395	* F-SUB-Q					
	* 3.6200	* 3.9919	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7466	* 1.5829	* 1.4483	* 1.7757	* 1.7490	* 1.5319	* 1.7645	* 0.9050 *
	* 1.7148	* 1.8896	* 2.0603	* 1.6931	* 1.7296	* 1.9735	* 1.7321	* 3.3644 *
9	* 1.5829	* 1.6266	* 1.6056	* 1.5516	* 1.8255	* 1.6413	* 1.7520	* 0.8230 *
	* 1.8896	* 1.8429	* 1.8625	* 1.9340	* 1.6501	* 1.8421	* 1.7412	* 3.6950 *
10	* 1.4483	* 1.6103	* 1.4283	* 1.7191	* 1.6074	* 1.8133	* 1.2408	*
	* 2.0603	* 1.8573	* 2.0923	* 1.7441	* 1.8676	* 1.6655	* 2.4323	*
11	* 1.7757	* 1.5381	* 1.7100	* 1.4395	* 1.6153	* 1.7025	* 0.8258	*
	* 1.6931	* 1.9503	* 1.7530	* 2.0723	* 1.8508	* 1.7590	* 3.6053	*
12	* 1.7490	* 1.7993	* 1.5920	* 1.6060	* 1.6094	* 0.9202	*	
	* 1.7296	* 1.6732	* 1.8850	* 1.8612	* 1.8489	* 3.2142	*	
13	* 1.5319	* 1.6152	* 1.7936	* 1.6898	* 0.9179	*		
	* 1.9735	* 1.8709	* 1.6832	* 1.7718	* 3.2222	*		
14	* 1.7645	* 1.7380	* 1.2255	* 0.8176	*			
	* 1.7321	* 1.7549	* 2.4620	* 3.6407	*			
15	* 0.9050	* 0.8044	* F-SUB-Q					
	* 3.3644	* 3.7773	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 155 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6912	* 1.5317	* 1.4006	* 1.7162	* 1.6920	* 1.4793	* 1.7041	* 0.8711 *
	* 1.6248	* 1.7904	* 1.9536	* 1.6082	* 1.6400	* 1.8729	* 1.6380	* 3.1873 *
9	* 1.5317	* 1.5748	* 1.5539	* 1.4994	* 1.7659	* 1.5866	* 1.6928	* 0.7931 *
	* 1.7904	* 1.7436	* 1.7647	* 1.8370	* 1.5663	* 1.7491	* 1.6475	* 3.4989 *
10	* 1.4006	* 1.5584	* 1.3796	* 1.6611	* 1.5538	* 1.7532	* 1.1961	*
	* 1.9536	* 1.7598	* 1.9850	* 1.6577	* 1.7752	* 1.5836	* 2.3157	*
11	* 1.7162	* 1.4861	* 1.6522	* 1.3907	* 1.5611	* 1.6459	* 0.7953	*
	* 1.6082	* 1.8529	* 1.6662	* 1.9698	* 1.7635	* 1.6763	* 3.4503	*
12	* 1.6920	* 1.7402	* 1.5387	* 1.5520	* 1.5555	* 0.8886	*	
	* 1.6400	* 1.5887	* 1.7921	* 1.7735	* 1.7639	* 3.0750	*	
13	* 1.4793	* 1.5610	* 1.7337	* 1.6333	* 0.8863	*		
	* 1.8729	* 1.7770	* 1.6007	* 1.6887	* 3.0826	*		
14	* 1.7041	* 1.6788	* 1.1810	* 0.7873	*			
	* 1.6380	* 1.6608	* 2.3446	* 3.4848	*			
15	* 0.8711	* 0.7745	* F-SUB-Q					
	* 3.1873	* 3.5797	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6375	* 1.4791	* 1.3509	* 1.6449	* 1.6243	* 1.4191	* 1.6242	* 0.8306 *
	* 1.5679	* 1.7318	* 1.8928	* 1.5679	* 1.5956	* 1.8242	* 1.6035	* 3.1196 *
9	* 1.4791	* 1.5177	* 1.5035	* 1.4434	* 1.7025	* 1.5200	* 1.6215	* 0.7749 *
	* 1.7318	* 1.6893	* 1.7039	* 1.7840	* 1.5186	* 1.7068	* 1.6054	* 3.3432 *
10	* 1.3509	* 1.5079	* 1.3268	* 1.5900	* 1.4932	* 1.6833	* 1.1464	*
	* 1.8928	* 1.6991	* 1.9293	* 1.6194	* 1.7277	* 1.5417	* 2.2598	*
11	* 1.6449	* 1.4306	* 1.5816	* 1.3351	* 1.4929	* 1.5792	* 0.7627	*
	* 1.5679	* 1.7995	* 1.6278	* 1.9194	* 1.7265	* 1.6363	* 3.3732	*
12	* 1.6243	* 1.6776	* 1.4787	* 1.4844	* 1.4928	* 0.8710	*	
	* 1.5956	* 1.5405	* 1.7441	* 1.7334	* 1.7225	* 2.9444	*	
13	* 1.4191	* 1.4953	* 1.6624	* 1.5671	* 0.8687	*		
	* 1.8242	* 1.7341	* 1.5604	* 1.6485	* 2.9519	*		
14	* 1.6242	* 1.6084	* 1.1319	* 0.7548	*			
	* 1.6035	* 1.6182	* 2.2879	* 3.4075	*			
15	* 0.8306	* 0.7412	* F-SUB-Q					
	* 3.1196	* 3.4927	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 156 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5696 *	* 1.4140 *	* 1.2905 *	* 1.5515 *	* 1.5358 *	* 1.3415 *	* 1.5244 *	* 0.7771 *
	* 1.5533 *	* 1.7203 *	* 1.8819 *	* 1.5797 *	* 1.6020 *	* 1.8326 *	* 1.6213 *	* 3.1685 *
9	* 1.4140 *	* 1.4464 *	* 1.4409 *	* 1.3769 *	* 1.6225 *	* 1.4324 *	* 1.5237 *	* 0.7237 *
	* 1.7203 *	* 1.6827 *	* 1.6881 *	* 1.7761 *	* 1.5127 *	* 1.7201 *	* 1.6218 *	* 3.4006 *
10	* 1.2905 *	* 1.4451 *	* 1.2642 *	* 1.4928 *	* 1.4182 *	* 1.5932 *	* 1.0828 *	
	* 1.8819 *	* 1.6833 *	* 1.9236 *	* 1.6382 *	* 1.7279 *	* 1.5467 *	* 2.2736 *	
11	* 1.5515 *	* 1.3650 *	* 1.4850 *	* 1.2716 *	* 1.4164 *	* 1.4912 *	* 0.7234 *	
	* 1.5797 *	* 1.7911 *	* 1.6466 *	* 1.9144 *	* 1.7263 *	* 1.6471 *	* 3.3844 *	
12	* 1.5358 *	* 1.5994 *	* 1.4048 *	* 1.4107 *	* 1.4115 *	* 0.8250 *		
	* 1.6019 *	* 1.5341 *	* 1.7439 *	* 1.7331 *	* 1.7319 *	* 2.9580 *		
13	* 1.3415 *	* 1.4097 *	* 1.5738 *	* 1.4799 *	* 0.8227 *			
	* 1.8326 *	* 1.7471 *	* 1.5652 *	* 1.6593 *	* 2.9659 *			
14	* 1.5244 *	* 1.5111 *	* 1.0692 *	* 0.7158 *				
	* 1.6213 *	* 1.6350 *	* 2.3019 *	* 3.4194 *				
15	* 0.7771 *	* 0.6979 *	F-SUB-Q					
	* 3.1685 *	* 3.5247 *	M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4521 *	* 1.3223 *	* 1.2100 *	* 1.4414 *	* 1.4244 *	* 1.2337 *	* 1.3669 *	* 0.7023 *
	* 1.6156 *	* 1.7699 *	* 1.9316 *	* 1.6331 *	* 1.6608 *	* 1.9176 *	* 1.7394 *	* 3.3771 *
9	* 1.3223 *	* 1.3634 *	* 1.3372 *	* 1.2977 *	* 1.5054 *	* 1.3214 *	* 1.3663 *	* 0.6577 *
	* 1.7699 *	* 1.7167 *	* 1.7501 *	* 1.8124 *	* 1.5675 *	* 1.7930 *	* 1.7400 *	* 3.6049 *
10	* 1.2100 *	* 1.3411 *	* 1.1894 *	* 1.3880 *	* 1.3280 *	* 1.4568 *	* 0.9881 *	
	* 1.9316 *	* 1.7452 *	* 1.9669 *	* 1.6923 *	* 1.7746 *	* 1.6267 *	* 2.3992 *	
11	* 1.4414 *	* 1.2871 *	* 1.3819 *	* 1.1919 *	* 1.3056 *	* 1.3631 *	* 0.6702 *	
	* 1.6331 *	* 1.8270 *	* 1.6996 *	* 1.9652 *	* 1.8018 *	* 1.7335 *	* 3.5205 *	
12	* 1.4244 *	* 1.4845 *	* 1.3160 *	* 1.3004 *	* 1.3018 *	* 0.7712 *		
	* 1.6608 *	* 1.5891 *	* 1.7903 *	* 1.8087 *	* 1.8069 *	* 3.0482 *		
13	* 1.2337 *	* 1.3012 *	* 1.4397 *	* 1.3531 *	* 0.7690 *			
	* 1.9176 *	* 1.8202 *	* 1.6455 *	* 1.7460 *	* 3.0567 *			
14	* 1.3669 *	* 1.3555 *	* 0.9761 *	* 0.6631 *				
	* 1.7394 *	* 1.7537 *	* 2.4281 *	* 3.5575 *				
15	* 0.7023 *	* 0.6365 *	F-SUB-Q					
	* 3.3771 *	* 3.7235 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 157 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2881	* 1.0967	* 1.0210	* 1.2669	* 1.1770	* 0.9933	* 1.0982	* 0.5625 *
	* 1.7702	* 2.0757	* 2.2293	* 1.8041	* 1.9502	* 2.3166	* 2.1053	* 4.1056 *
9	* 1.0967	* 1.1569	* 1.1932	* 1.1000	* 1.3196	* 1.0923	* 1.0798	* 0.5298 *
	* 2.0757	* 1.9658	* 1.9053	* 2.0813	* 1.7390	* 2.1082	* 2.1410	* 4.3590 *
10	* 1.0210	* 1.1938	* 1.0209	* 1.2295	* 1.1153	* 1.2177	* 0.7942	*
	* 2.2293	* 1.9042	* 2.2261	* 1.8576	* 2.0522	* 1.8914	* 2.9052	*
11	* 1.2669	* 1.0885	* 1.2228	* 1.0052	* 1.1266	* 1.0999	* 0.5581	*
	* 1.8041	* 2.0996	* 1.8675	* 2.2658	* 2.0299	* 2.0884	* 4.1189	*
12	* 1.1770	* 1.3004	* 1.1061	* 1.1222	* 1.0743	* 0.6489	*	
	* 1.9502	* 1.7644	* 2.0690	* 2.0378	* 2.1290	* 3.5279	*	
13	* 0.9933	* 1.0767	* 1.2051	* 1.0921	* 0.6468	*		
	* 2.3166	* 2.1382	* 1.9108	* 2.1029	* 3.5389	*		
14	* 1.0982	* 1.0708	* 0.7851	* 0.5521	*			
	* 2.1053	* 2.1587	* 2.9382	* 4.1623	*			
15	* 0.5625	* 0.5193	* F-SUB-Q					
	* 4.1056	* 4.4455	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5401	* 0.4832	* 0.4728	* 0.5493	* 0.5122	* 0.4464	* 0.4243	* 0.2499 *
	* 4.1088	* 4.5962	* 4.6952	* 4.0490	* 4.3609	* 5.0285	* 5.3077	* 9.0220 *
9	* 0.4832	* 0.5013	* 0.5301	* 0.4929	* 0.5448	* 0.4719	* 0.4153	* 0.2329 *
	* 4.5962	* 4.4239	* 4.1801	* 4.5233	* 4.1026	* 4.7543	* 5.4229	* 9.6809 *
10	* 0.4728	* 0.5303	* 0.4723	* 0.5307	* 0.4865	* 0.4826	* 0.3517	*
	* 4.6952	* 4.1791	* 4.6952	* 4.1885	* 4.5909	* 4.6463	* 6.3990	*
11	* 0.5493	* 0.4893	* 0.5289	* 0.4564	* 0.4817	* 0.4192	* 0.2487	*
	* 4.0490	* 4.5545	* 4.2024	* 4.8716	* 4.6297	* 5.3369	* 9.0233	*
12	* 0.5122	* 0.5386	* 0.4826	* 0.4798	* 0.4178	* 0.2996	*	
	* 4.3609	* 4.1494	* 4.6276	* 4.6472	* 5.3389	* 7.4580	*	
13	* 0.4464	* 0.4660	* 0.4779	* 0.4166	* 0.2986	*		
	* 5.0285	* 4.8133	* 4.6920	* 5.3702	* 7.4846	*		
14	* 0.4243	* 0.4120	* 0.3480	* 0.2462	*			
	* 5.3077	* 5.4652	* 6.4660	* 9.1135	*			
15	* 0.2499	* 0.2319	* F-SUB-Q					
	* 9.0220	* 9.7196	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 158 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5688	* 0.5168	* 0.4847	* 0.5656	* 0.5241	* 0.4401	* 0.3125	* 0.1609
	* 3.7435	* 4.1213	* 4.4427	* 3.7271	* 4.0161	* 4.7681	* 4.9081	* 7.9504
9	* 0.5168	* 0.4973	* 0.5210	* 0.5065	* 0.5597	* 0.4752	* 0.3634	* 0.1720
	* 4.1213	* 4.2303	* 3.9519	* 4.1566	* 3.7557	* 4.4090	* 5.0579	* 8.4754
10	* 0.4847	* 0.5208	* 0.4013	* 0.5272	* 0.5002	* 0.5014	* 0.3485	*
	* 4.4427	* 3.9500	* 4.3937	* 3.9698	* 4.1944	* 4.1778	* 5.9738	*
11	* 0.5656	* 0.5045	* 0.5258	* 0.4599	* 0.5163	* 0.4621	* 0.2795	*
	* 3.7271	* 4.1737	* 3.9804	* 4.5575	* 4.0641	* 4.5397	* 7.4598	*
12	* 0.5241	* 0.5556	* 0.4982	* 0.5155	* 0.4674	* 0.3433	*	*
	* 4.0161	* 3.7834	* 4.2111	* 4.0710	* 4.5671	* 6.1366	*	*
13	* 0.4401	* 0.4725	* 0.4990	* 0.4606	* 0.3417	*	*	*
	* 4.7681	* 4.4369	* 4.1982	* 4.5546	* 6.1655	*	*	*
14	* 0.3125	* 0.3613	* 0.3465	* 0.2779	*	*	*	*
	* 4.9081	* 5.0768	* 6.0043	* 7.5020	*	*	*	*
15	* 0.1609	* 0.1703	* F-SUB-Q					
	* 7.9504	* 8.5329	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2137	* 1.0492	* 0.9531	* 1.1639	* 1.0840	* 0.8834	* 0.7216	* 0.3407
	* 1.8303	* 2.1163	* 2.3157	* 1.8870	* 2.0266	* 2.4090	* 2.1884	* 3.9289
9	* 1.0492	* 1.0240	* 1.0544	* 1.0306	* 1.2055	* 0.9908	* 0.8412	* 0.3547
	* 2.1163	* 2.1035	* 2.0114	* 2.1313	* 1.8207	* 2.2071	* 2.2359	* 4.2547
10	* 0.9531	* 1.0540	* 0.7834	* 1.0867	* 1.0365	* 1.1182	* 0.7164	*
	* 2.3157	* 2.0103	* 2.3063	* 1.9981	* 2.1134	* 1.9571	* 2.9895	*
11	* 1.1639	* 1.0264	* 1.0837	* 0.9165	* 1.0727	* 1.0456	* 0.5704	*
	* 1.8870	* 2.1404	* 2.0026	* 2.3859	* 2.0375	* 2.0914	* 3.8179	*
12	* 1.0840	* 1.1959	* 1.0322	* 1.0708	* 1.0282	* 0.6714	*	*
	* 2.0266	* 1.8355	* 2.1223	* 2.0413	* 2.1339	* 3.2566	*	*
13	* 0.8834	* 0.9839	* 1.1127	* 1.0421	* 0.6690	*	*	*
	* 2.4090	* 2.2226	* 1.9668	* 2.0984	* 3.2683	*	*	*
14	* 0.7216	* 0.8362	* 0.7121	* 0.5670	*	*	*	*
	* 2.1884	* 2.2443	* 3.0058	* 3.8410	*	*	*	*
15	* 0.3407	* 0.3484	* F-SUB-Q					
	* 3.9289	* 4.3171	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 159 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3055 *	* 1.2080 *	* 1.0951 *	* 1.2857 *	* 1.2523 *	* 1.0585 *	* 0.8980 *	* 0.4297 *
	* 1.7754 *	* 1.9161 *	* 2.0985 *	* 1.7841 *	* 1.8324 *	* 2.0858 *	* 1.9349 *	* 3.3315 *
9	* 1.2080 *	* 1.1873 *	* 1.1427 *	* 1.1896 *	* 1.3008 *	* 1.1637 *	* 1.0087 *	* 0.4388 *
	* 1.9161 *	* 1.9099 *	* 1.9655 *	* 1.9289 *	* 1.7643 *	* 1.9636 *	* 1.9639 *	* 3.5957 *
10	* 1.0951 *	* 1.1416 *	* 0.9100 *	* 1.2014 *	* 1.2057 *	* 1.2718 *	* 0.8774 *	
	* 2.0985 *	* 1.9631 *	* 2.0891 *	* 1.8822 *	* 1.8979 *	* 1.7972 *	* 2.5309 *	
11	* 1.2857 *	* 1.1843 *	* 1.1974 *	* 1.0784 *	* 1.1856 *	* 1.2407 *	* 0.6917 *	
	* 1.7841 *	* 1.9377 *	* 1.8854 *	* 2.1174 *	* 1.9232 *	* 1.8404 *	* 3.2882 *	
12	* 1.2523 *	* 1.2881 *	* 1.2001 *	* 1.1825 *	* 1.1963 *	* 0.7906 *		
	* 1.8324 *	* 1.7819 *	* 1.9067 *	* 1.9281 *	* 1.9056 *	* 2.8752 *		
13	* 1.0585 *	* 1.1547 *	* 1.2658 *	* 1.2361 *	* 0.7883 *			
	* 2.0858 *	* 1.9790 *	* 1.8059 *	* 1.8472 *	* 2.8835 *			
14	* 0.8980 *	* 1.0022 *	* 0.8718 *	* 0.6875 *				
	* 1.9349 *	* 1.9713 *	* 2.5456 *	* 3.3083 *				
15	* 0.4297 *	* 0.4321 *	F-SUB-Q					
	* 3.3315 *	* 3.6383 *	M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4714 *	* 1.3322 *	* 1.2076 *	* 1.4588 *	* 1.4002 *	* 1.1888 *	* 1.0587 *	* 0.4957 *
	* 1.6680 *	* 1.8391 *	* 2.0142 *	* 1.6688 *	* 1.7385 *	* 1.9503 *	* 1.7342 *	* 3.0943 *
9	* 1.3322 *	* 1.3159 *	* 1.2916 *	* 1.3172 *	* 1.4798 *	* 1.3130 *	* 1.1926 *	* 0.5004 *
	* 1.8391 *	* 1.8200 *	* 1.8463 *	* 1.8487 *	* 1.6460 *	* 1.8423 *	* 1.7567 *	* 3.3938 *
10	* 1.2076 *	* 1.2902 *	* 0.9882 *	* 1.3681 *	* 1.3460 *	* 1.4694 *	* 0.9849 *	
	* 2.0142 *	* 1.8439 *	* 2.0011 *	* 1.7534 *	* 1.8021 *	* 1.6469 *	* 2.3802 *	
11	* 1.4588 *	* 1.3104 *	* 1.3631 *	* 1.1840 *	* 1.3567 *	* 1.4309 *	* 0.7574 *	
	* 1.6688 *	* 1.8585 *	* 1.7568 *	* 2.0378 *	* 1.7782 *	* 1.6881 *	* 3.1816 *	
12	* 1.4002 *	* 1.4640 *	* 1.3390 *	* 1.3529 *	* 1.3643 *	* 0.8584 *		
	* 1.7385 *	* 1.6651 *	* 1.8116 *	* 1.7832 *	* 1.7664 *	* 2.7980 *		
13	* 1.1888 *	* 1.3017 *	* 1.4618 *	* 1.4252 *	* 0.8563 *			
	* 1.9503 *	* 1.8585 *	* 1.6555 *	* 1.6950 *	* 2.8047 *			
14	* 1.0587 *	* 1.1844 *	* 0.9779 *	* 0.7526 *				
	* 1.7342 *	* 1.7649 *	* 2.3956 *	* 3.2020 *				
15	* 0.4957 *	* 0.4928 *	F-SUB-Q					
	* 3.0943 *	* 3.4462 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 160 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5382	* 1.3778	* 1.2595	* 1.5419	* 1.4699	* 1.2551	* 1.1501	* 0.5480 *
	* 1.7262	* 1.9257	* 2.0772	* 1.7092	* 1.7799	* 1.9880	* 1.7384	* 3.1065 *
9	* 1.3778	* 1.3614	* 1.3612	* 1.3771	* 1.5712	* 1.3890	* 1.2910	* 0.5488 *
	* 1.9257	* 1.8776	* 1.8906	* 1.9144	* 1.6705	* 1.8752	* 1.7498	* 3.4027 *
10	* 1.2595	* 1.3597	* 1.0518	* 1.4521	* 1.4149	* 1.5664	* 1.0596	*
	* 2.0772	* 1.8881	* 2.0610	* 1.7765	* 1.8474	* 1.6565	* 2.3792	*
11	* 1.5419	* 1.3691	* 1.4464	* 1.2531	* 1.4439	* 1.5267	* 0.8090	*
	* 1.7092	* 1.9259	* 1.7829	* 2.0841	* 1.7955	* 1.6962	* 3.1893	*
12	* 1.4699	* 1.5510	* 1.4070	* 1.4396	* 1.4509	* 0.9124	*	
	* 1.7799	* 1.6945	* 1.8581	* 1.8010	* 1.7870	* 2.8259	*	
13	* 1.2551	* 1.3765	* 1.5578	* 1.5202	* 0.9103	*		
	* 1.9880	* 1.8924	* 1.6660	* 1.7036	* 2.8325	*		
14	* 1.1501	* 1.2816	* 1.0520	* 0.8032	*			
	* 1.7384	* 1.7587	* 2.3952	* 3.2126	*			
15	* 0.5480	* 0.5411	* F-SUB-Q					
	* 3.1065	* 3.4472	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5934	* 1.4206	* 1.3132	* 1.6169	* 1.5399	* 1.3244	* 1.2572	* 0.6178 *
	* 1.8165	* 2.0165	* 2.1514	* 1.7638	* 1.8228	* 2.0489	* 1.7809	* 3.1923 *
9	* 1.4206	* 1.4065	* 1.4293	* 1.4384	* 1.6541	* 1.4638	* 1.3908	* 0.6099 *
	* 2.0165	* 1.9549	* 1.9612	* 1.9713	* 1.7139	* 1.9126	* 1.7812	* 3.4807 *
10	* 1.3132	* 1.4279	* 1.1295	* 1.5345	* 1.4827	* 1.6509	* 1.1320	*
	* 2.1514	* 1.9585	* 2.1430	* 1.8127	* 1.9158	* 1.7201	* 2.4163	*
11	* 1.6169	* 1.4296	* 1.5281	* 1.3234	* 1.5197	* 1.6079	* 0.8551	*
	* 1.7638	* 1.9832	* 1.8198	* 2.1442	* 1.8585	* 1.7542	* 3.2993	*
12	* 1.5399	* 1.6303	* 1.4739	* 1.5149	* 1.5264	* 0.9601	*	
	* 1.8228	* 1.7392	* 1.9263	* 1.8653	* 1.8450	* 2.9066	*	
13	* 1.3244	* 1.4501	* 1.6413	* 1.6008	* 0.9579	*		
	* 2.0489	* 1.9306	* 1.7305	* 1.7623	* 2.9134	*		
14	* 1.2572	* 1.3803	* 1.1235	* 0.8487	*			
	* 1.7809	* 1.7909	* 2.4338	* 3.3244	*			
15	* 0.6178	* 0.6025	* F-SUB-Q					
	* 3.1923	* 3.5292	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 161 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6750	* 1.4845	* 1.3882	* 1.7196	* 1.6388	* 1.4204	* 1.4628	* 0.7405 *
	* 1.8791	* 2.0945	* 2.2261	* 1.8065	* 1.8691	* 2.1003	* 1.8088	* 3.2925 *
9	* 1.4845	* 1.4863	* 1.5288	* 1.5215	* 1.7659	* 1.5629	* 1.5447	* 0.7058 *
	* 2.0945	* 2.0182	* 2.0092	* 2.0341	* 1.7485	* 1.9543	* 1.7997	* 3.6021 *
10	* 1.3882	* 1.5273	* 1.2681	* 1.6516	* 1.5723	* 1.7647	* 1.2100	*
	* 2.2261	* 2.0104	* 2.2097	* 1.8482	* 1.9692	* 1.7535	* 2.4787	*
11	* 1.7196	* 1.5118	* 1.6446	* 1.3965	* 1.6181	* 1.7110	* 0.8931	*
	* 1.8065	* 2.0470	* 1.8558	* 2.2011	* 1.9301	* 1.8255	* 3.4953	*
12	* 1.6388	* 1.7397	* 1.5626	* 1.6128	* 1.6230	* 1.0012	*	*
	* 1.8691	* 1.7752	* 1.9807	* 1.9357	* 1.9181	* 3.0669	*	*
13	* 1.4204	* 1.5475	* 1.7529	* 1.7031	* 0.9991	*	*	*
	* 2.1003	* 1.9736	* 1.7653	* 1.8343	* 3.0735	*	*	*
14	* 1.4628	* 1.5335	* 1.2007	* 0.8863	*	*	*	*
	* 1.8088	* 1.8100	* 2.4973	* 3.5222	*	*	*	*
15	* 0.7405	* 0.6949	* F-SUB-Q					
	* 3.2925	* 3.6553	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7287	* 1.5395	* 1.4480	* 1.7931	* 1.7173	* 1.5060	* 1.6641	* 0.8904 *
	* 1.9879	* 2.2201	* 2.3519	* 1.8965	* 1.9626	* 2.2121	* 1.8915	* 3.4378 *
9	* 1.5395	* 1.5742	* 1.6048	* 1.5868	* 1.8480	* 1.6418	* 1.7070	* 0.8257 *
	* 2.2201	* 2.1356	* 2.1163	* 2.1417	* 1.8315	* 2.0455	* 1.8811	* 3.7615 *
10	* 1.4480	* 1.6033	* 1.4072	* 1.7435	* 1.6429	* 1.8478	* 1.2841	*
	* 2.3519	* 2.1183	* 2.3334	* 1.9353	* 2.0631	* 1.8254	* 2.5941	*
11	* 1.7931	* 1.5763	* 1.7359	* 1.4645	* 1.6885	* 1.7833	* 0.9303	*
	* 1.8965	* 2.1560	* 1.9436	* 2.3092	* 2.0126	* 1.9069	* 3.6447	*
12	* 1.7173	* 1.8198	* 1.6329	* 1.6835	* 1.6905	* 1.0381	*	*
	* 1.9626	* 1.8604	* 2.0758	* 2.0186	* 2.0178	* 3.2926	*	*
13	* 1.5060	* 1.6250	* 1.8350	* 1.7748	* 1.0360	*	*	*
	* 2.2121	* 2.0667	* 1.8383	* 1.9162	* 3.2994	*	*	*
14	* 1.6641	* 1.6966	* 1.2740	* 0.9230	*	*	*	*
	* 1.8915	* 1.8923	* 2.6145	* 3.6733	*	*	*	*
15	* 0.8904	* 0.8141	* F-SUB-Q					
	* 3.4378	* 3.8133	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 162 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8046	* 1.6049	* 1.5138	* 1.8870	* 1.8062	* 1.5928	* 1.8502	* 0.9928 *
	* 2.0961	* 2.3515	* 2.4866	* 1.9860	* 2.0595	* 2.3213	* 1.9532	* 3.6082 *
9	* 1.6049	* 1.6670	* 1.6949	* 1.6594	* 1.9501	* 1.7296	* 1.8719	* 0.9068 *
	* 2.3515	* 2.2501	* 2.2119	* 2.2599	* 1.9126	* 2.1421	* 1.9372	* 3.9632 *
10	* 1.5138	* 1.6932	* 1.5175	* 1.8474	* 1.7217	* 1.9505	* 1.3462	*
	* 2.4866	* 2.2161	* 2.4532	* 2.0220	* 2.1712	* 1.9018	* 2.7389	*
11	* 1.8870	* 1.6482	* 1.8392	* 1.5376	* 1.7780	* 1.8735	* 0.9559	*
	* 1.9860	* 2.2754	* 2.0306	* 2.4290	* 2.1027	* 1.9914	* 3.8924	*
12	* 1.8062	* 1.9199	* 1.7109	* 1.7726	* 1.7751	* 1.0674	*	
	* 2.0595	* 1.9432	* 2.1851	* 2.1092	* 2.1090	* 3.5108	*	
13	* 1.5928	* 1.7114	* 1.9365	* 1.8643	* 1.0654	*		
	* 2.3213	* 2.1651	* 1.9156	* 2.0013	* 3.5172	*		
14	* 1.8502	* 1.8604	* 1.3352	* 0.9492	*			
	* 1.9532	* 1.9492	* 2.7614	* 3.9198	*			
15	* 0.9928	* 0.8903	* F-SUB-Q					
	* 3.6082	* 4.0356	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7764	* 1.5955	* 1.5182	* 1.8686	* 1.8073	* 1.6013	* 1.8709	* 1.0341 *
	* 2.3604	* 2.6271	* 2.7594	* 2.2256	* 2.2859	* 2.5711	* 2.1670	* 3.9014 *
9	* 1.5955	* 1.6655	* 1.6822	* 1.6566	* 1.9367	* 1.7317	* 1.8849	* 0.9554 *
	* 2.6271	* 2.5098	* 2.4772	* 2.5138	* 2.1364	* 2.3752	* 2.1520	* 4.2295 *
10	* 1.5182	* 1.6795	* 1.5337	* 1.8361	* 1.7208	* 1.9381	* 1.3835	*
	* 2.7594	* 2.4819	* 2.7192	* 2.2606	* 2.4103	* 2.1197	* 2.9623	*
11	* 1.8686	* 1.6452	* 1.8277	* 1.5529	* 1.7627	* 1.8581	* 0.9880	*
	* 2.2256	* 2.5299	* 2.2709	* 2.6792	* 2.3483	* 2.2199	* 4.1626	*
12	* 1.8073	* 1.9058	* 1.7096	* 1.7572	* 1.7590	* 1.0961	*	
	* 2.2859	* 2.1715	* 2.4260	* 2.3556	* 2.3524	* 3.7712	*	
13	* 1.6013	* 1.7131	* 1.9238	* 1.8486	* 1.0935	*		
	* 2.5711	* 2.4011	* 2.1354	* 2.2311	* 3.7796	*		
14	* 1.8709	* 1.8731	* 1.3721	* 0.9798	*			
	* 2.1670	* 2.1655	* 2.9864	* 4.1964	*			
15	* 1.0341	* 0.9407	* F-SUB-Q					
	* 3.9014	* 4.2944	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 163 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8424	* 1.6408	* 1.5541	* 1.9494	* 1.8740	* 1.6568	* 1.9789	* 1.0683 *
	* 2.5121	* 2.8210	* 2.9756	* 2.3599	* 2.4440	* 2.7602	* 2.2930	* 4.2341 *
9	* 1.6408	* 1.7202	* 1.7567	* 1.7078	* 2.0243	* 1.7988	* 1.9965	* 0.9752 *
	* 2.8210	* 2.6902	* 2.6256	* 2.6959	* 2.2625	* 2.5318	* 2.2695	* 4.6403 *
10	* 1.5541	* 1.7530	* 1.5758	* 1.9173	* 1.7779	* 2.0303	* 1.4081	*
	* 2.9756	* 2.6309	* 2.9244	* 2.3909	* 2.5747	* 2.2342	* 3.2260	*
11	* 1.9494	* 1.6959	* 1.9082	* 1.5922	* 1.8413	* 1.9427	* 0.9895	*
	* 2.3599	* 2.7123	* 2.4008	* 2.8804	* 2.4715	* 2.3333	* 4.5621	*
12	* 1.8740	* 1.9914	* 1.7658	* 1.8353	* 1.8366	* 1.1022	*	
	* 2.4440	* 2.3000	* 2.5921	* 2.4793	* 2.4687	* 4.0967	*	
13	* 1.6568	* 1.7786	* 2.0148	* 1.9325	* 1.1001	*		
	* 2.7602	* 2.5602	* 2.2510	* 2.3452	* 4.1037	*		
14	* 1.9789	* 1.9835	* 1.3960	* 0.9821	*			
	* 2.2930	* 2.2841	* 3.2534	* 4.5950	*			
15	* 1.0683	* 0.9579	* F-SUB-Q					
	* 4.2341	* 4.7230	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8361	* 1.6353	* 1.5521	* 1.9538	* 1.8806	* 1.6619	* 1.9992	* 1.0799 *
	* 2.5339	* 2.8422	* 2.9908	* 2.3760	* 2.4707	* 2.7969	* 2.3375	* 4.3359 *
9	* 1.6353	* 1.7187	* 1.7598	* 1.7081	* 2.0319	* 1.8072	* 2.0175	* 0.9874 *
	* 2.8422	* 2.7060	* 2.6416	* 2.7178	* 2.2871	* 2.5719	* 2.3126	* 4.7399 *
10	* 1.5521	* 1.7559	* 1.5762	* 1.9234	* 1.7819	* 2.0423	* 1.4188	*
	* 2.9908	* 2.6477	* 2.9503	* 2.4134	* 2.6044	* 2.2758	* 3.2842	*
11	* 1.9538	* 1.6963	* 1.9143	* 1.5953	* 1.8494	* 1.9540	* 0.9972	*
	* 2.3760	* 2.7371	* 2.4248	* 2.9076	* 2.5079	* 2.3769	* 4.6660	*
12	* 1.8806	* 1.9983	* 1.7693	* 1.8431	* 1.8458	* 1.1097	*	
	* 2.4707	* 2.3258	* 2.6233	* 2.5166	* 2.5136	* 4.1864	*	
13	* 1.6619	* 1.7863	* 2.0262	* 1.9433	* 1.1076	*		
	* 2.7969	* 2.6025	* 2.2944	* 2.3903	* 4.1946	*		
14	* 1.9992	* 2.0039	* 1.4065	* 0.9893	*			
	* 2.3375	* 2.3285	* 3.3136	* 4.7041	*			
15	* 1.0799	* 0.9717	* F-SUB-Q					
	* 4.3359	* 4.8161	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 164 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7764	* 1.5909	* 1.5192	* 1.8992	* 1.8406	* 1.6285	* 1.9555	* 1.0722
	* 2.6037	* 2.9041	* 3.0398	* 2.4314	* 2.5138	* 2.8437	* 2.3885	* 4.3662
9	* 1.5909	* 1.6739	* 1.7096	* 1.6683	* 1.9798	* 1.7703	* 1.9719	* 0.9909
	* 2.9041	* 2.7630	* 2.7023	* 2.7666	* 2.3365	* 2.6137	* 2.3639	* 4.7206
10	* 1.5192	* 1.7056	* 1.5442	* 1.8729	* 1.7440	* 1.9949	* 1.4121	*
	* 3.0398	* 2.7087	* 2.9891	* 2.4627	* 2.6438	* 2.3175	* 3.2860	*
11	* 1.8992	* 1.6566	* 1.8633	* 1.5682	* 1.8036	* 1.9088	* 0.9998	*
	* 2.4314	* 2.7854	* 2.4749	* 2.9354	* 2.5508	* 2.4144	* 4.6149	*
12	* 1.8406	* 1.9460	* 1.7312	* 1.7973	* 1.8022	* 1.1115	*	*
	* 2.5138	* 2.3771	* 2.6635	* 2.5600	* 2.5502	* 4.1345	*	*
13	* 1.6285	* 1.7492	* 1.9785	* 1.8980	* 1.1089	*	*	*
	* 2.8437	* 2.6456	* 2.3370	* 2.4285	* 4.1446	*	*	*
14	* 1.9555	* 1.9583	* 1.3995	* 0.9908	*	*	*	*
	* 2.3885	* 2.3806	* 3.3164	* 4.6574	*	*	*	*
15	* 1.0722	* 0.9749	* F-SUB-Q					
	* 4.3662	* 4.7976	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7885	* 1.5884	* 1.5120	* 1.9224	* 1.8530	* 1.6344	* 1.9980	* 1.0680
	* 2.5076	* 2.8195	* 2.9554	* 2.3336	* 2.4296	* 2.7531	* 2.2694	* 4.2079
9	* 1.5884	* 1.6766	* 1.7292	* 1.6703	* 2.0079	* 1.7867	* 2.0192	* 0.9759
	* 2.8195	* 2.6754	* 2.5890	* 2.6814	* 2.2403	* 2.5183	* 2.2429	* 4.6011
10	* 1.5120	* 1.7249	* 1.5397	* 1.8978	* 1.7507	* 2.0316	* 1.3955	*
	* 2.9554	* 2.5955	* 2.9030	* 2.3595	* 2.5568	* 2.2129	* 3.2222	*
11	* 1.9224	* 1.6584	* 1.8881	* 1.5656	* 1.8320	* 1.9435	* 0.9749	*
	* 2.3336	* 2.6991	* 2.3696	* 2.8474	* 2.4346	* 2.3005	* 4.5605	*
12	* 1.8530	* 1.9727	* 1.7373	* 1.8254	* 1.8323	* 1.0916	*	*
	* 2.4296	* 2.2793	* 2.5763	* 2.4434	* 2.4274	* 4.0567	*	*
13	* 1.6344	* 1.7643	* 2.0142	* 1.9321	* 1.0897	*	*	*
	* 2.7531	* 2.5498	* 2.2317	* 2.3139	* 4.0636	*	*	*
14	* 1.9980	* 2.0047	* 1.3822	* 0.9670	*	*	*	*
	* 2.2694	* 2.2590	* 3.2521	* 4.5967	*	*	*	*
15	* 1.0680	* 0.9574	* F-SUB-Q					
	* 4.2079	* 4.6878	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 165 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7556 *	* 1.5555 *	* 1.4830 *	* 1.8966 *	* 1.8271 *	* 1.6091 *	* 1.9853 *	* 1.0525 *
	* 2.3206 *	* 2.6146 *	* 2.7365 *	* 2.1536 *	* 2.2448 *	* 2.5429 *	* 2.0752 *	* 3.8810 *
9	* 1.5555 *	* 1.6460 *	* 1.7049 *	* 1.6411 *	* 1.9842 *	* 1.7650 *	* 2.0083 *	* 0.9601 *
	* 2.6146 *	* 2.4738 *	* 2.3841 *	* 2.4843 *	* 2.0654 *	* 2.3230 *	* 2.0503 *	* 4.2517 *
10	* 1.4830 *	* 1.7004 *	* 1.5122 *	* 1.8743 *	* 1.7239 *	* 2.0149 *	* 1.3717 *	
	* 2.7365 *	* 2.3904 *	* 2.6832 *	* 2.1757 *	* 2.3675 *	* 2.0361 *	* 2.9808 *	
11	* 1.8966 *	* 1.6290 *	* 1.8651 *	* 1.5412 *	* 1.8154 *	* 1.9284 *	* 0.9551 *	
	* 2.1536 *	* 2.5008 *	* 2.1850 *	* 2.6319 *	* 2.2379 *	* 2.1122 *	* 4.2324 *	
12	* 1.8271 *	* 1.9483 *	* 1.7101 *	* 1.8066 *	* 1.8165 *	* 1.0724 *		
	* 2.2448 *	* 2.1020 *	* 2.3858 *	* 2.2471 *	* 2.2262 *	* 3.7470 *		
13	* 1.6091 *	* 1.7420 *	* 1.9970 *	* 1.9168 *	* 1.0700 *			
	* 2.5429 *	* 2.3525 *	* 2.0536 *	* 2.1245 *	* 3.7547 *			
14	* 1.9853 *	* 1.9933 *	* 1.3582 *	* 0.9472 *				
	* 2.0752 *	* 2.0652 *	* 3.0094 *	* 4.2665 *				
15	* 1.0525 *	* 0.9409 *	F-SUB-Q					
	* 3.8810 *	* 4.3363 *	M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7036 *	* 1.5105 *	* 1.4405 *	* 1.8460 *	* 1.7818 *	* 1.5676 *	* 1.9384 *	* 1.0290 *
	* 2.1572 *	* 2.4284 *	* 2.5415 *	* 1.9980 *	* 2.0807 *	* 2.3606 *	* 1.9264 *	* 3.6011 *
9	* 1.5105 *	* 1.5999 *	* 1.6584 *	* 1.5960 *	* 1.9339 *	* 1.7215 *	* 1.9604 *	* 0.9415 *
	* 2.4284 *	* 2.2962 *	* 2.2124 *	* 2.3059 *	* 1.9155 *	* 2.1540 *	* 1.9033 *	* 3.9330 *
10	* 1.4405 *	* 1.6538 *	* 1.4697 *	* 1.8265 *	* 1.6802 *	* 1.9673 *	* 1.3429 *	
	* 2.5415 *	* 2.2185 *	* 2.4907 *	* 2.0157 *	* 2.1937 *	* 1.8856 *	* 2.7555 *	
11	* 1.8460 *	* 1.5842 *	* 1.8171 *	* 1.5009 *	* 1.7718 *	* 1.8830 *	* 0.9371 *	
	* 1.9980 *	* 2.3217 *	* 2.0246 *	* 2.4391 *	* 2.0767 *	* 1.9589 *	* 3.9072 *	
12	* 1.7818 *	* 1.8984 *	* 1.6663 *	* 1.7624 *	* 1.7733 *	* 1.0529 *		
	* 2.0807 *	* 1.9500 *	* 2.2112 *	* 2.0850 *	* 2.0648 *	* 3.4521 *		
13	* 1.5676 *	* 1.6985 *	* 1.9493 *	* 1.8712 *	* 1.0510 *			
	* 2.3606 *	* 2.1821 *	* 1.9023 *	* 1.9708 *	* 3.4582 *			
14	* 1.9384 *	* 1.9454 *	* 1.3294 *	* 0.9290 *				
	* 1.9264 *	* 1.9175 *	* 2.7827 *	* 3.9402 *				
15	* 1.0290 *	* 0.9236 *	F-SUB-Q					
	* 3.6011 *	* 4.0071 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 166 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6173	* 1.4433	* 1.3829	* 1.7567	* 1.7066	* 1.5029	* 1.8464	* 0.9978 *
	* 2.0517	* 2.2956	* 2.3957	* 1.8981	* 1.9665	* 2.2314	* 1.8388	* 3.3856 *
9	* 1.4433	* 1.5291	* 1.5772	* 1.5285	* 1.8419	* 1.6483	* 1.8647	* 0.9243 *
	* 2.2956	* 2.1719	* 2.1045	* 2.1771	* 1.8201	* 2.0363	* 1.8177	* 3.6501 *
10	* 1.3829	* 1.5727	* 1.4137	* 1.7398	* 1.6108	* 1.8757	* 1.3103	*
	* 2.3957	* 2.1104	* 2.3428	* 1.9127	* 2.0682	* 1.7883	* 2.5593	*
11	* 1.7567	* 1.5167	* 1.7306	* 1.4466	* 1.6890	* 1.7966	* 0.9244	*
	* 1.8981	* 2.1927	* 1.9214	* 2.2891	* 1.9599	* 1.8474	* 3.5717	*
12	* 1.7066	* 1.8080	* 1.5973	* 1.6800	* 1.6922	* 1.0346	*	
	* 1.9665	* 1.8537	* 2.0851	* 1.9685	* 1.9442	* 3.1558	*	
13	* 1.5029	* 1.6260	* 1.8582	* 1.7851	* 1.0321	*		
	* 2.2314	* 2.0633	* 1.8046	* 1.8589	* 3.1632	*		
14	* 1.8464	* 1.8500	* 1.2970	* 0.9152	*			
	* 1.8388	* 1.8318	* 2.5848	* 3.6069	*			
15	* 0.9978	* 0.9082	* F-SUB-Q					
	* 3.3856	* 3.7130	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6156	* 1.4265	* 1.3607	* 1.7581	* 1.6935	* 1.4843	* 1.8555	* 0.9719 *
	* 1.8500	* 2.0917	* 2.1909	* 1.7104	* 1.7883	* 2.0398	* 1.6559	* 3.1506 *
9	* 1.4265	* 1.5156	* 1.5786	* 1.5092	* 1.8438	* 1.6371	* 1.8775	* 0.8880 *
	* 2.0917	* 1.9748	* 1.8973	* 1.9878	* 1.6410	* 1.8504	* 1.6328	* 3.4438 *
10	* 1.3607	* 1.5739	* 1.3894	* 1.7410	* 1.5934	* 1.8820	* 1.2673	*
	* 2.1909	* 1.9029	* 2.1494	* 1.7228	* 1.8850	* 1.6078	* 2.3901	*
11	* 1.7581	* 1.4977	* 1.7324	* 1.4224	* 1.6942	* 1.8021	* 0.8802	*
	* 1.7104	* 2.0023	* 1.7309	* 2.0962	* 1.7674	* 1.6658	* 3.3908	*
12	* 1.6935	* 1.8097	* 1.5796	* 1.6847	* 1.6961	* 0.9934	*	
	* 1.7883	* 1.6720	* 1.9009	* 1.7753	* 1.7569	* 2.9839	*	
13	* 1.4843	* 1.6146	* 1.8639	* 1.7903	* 0.9912	*		
	* 2.0398	* 1.8760	* 1.6229	* 1.6764	* 2.9904	*		
14	* 1.8555	* 1.8621	* 1.2538	* 0.8724	*			
	* 1.6559	* 1.6461	* 2.4153	* 3.4205	*			
15	* 0.9719	* 0.8696	* F-SUB-Q					
	* 3.1506	* 3.5148	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 167 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5564	* 1.3746	* 1.3096	* 1.6921	* 1.6315	* 1.4275	* 1.7855	* 0.9323 *
	* 1.7612	* 1.9896	* 2.0874	* 1.6300	* 1.7011	* 1.9413	* 1.5677	* 2.9882 *
9	* 1.3746	* 1.4612	* 1.5196	* 1.4524	* 1.7746	* 1.5763	* 1.8061	* 0.8527 *
	* 1.9896	* 1.8757	* 1.8057	* 1.8956	* 1.5638	* 1.7622	* 1.5484	* 3.2654 *
10	* 1.3096	* 1.5149	* 1.3361	* 1.6754	* 1.5337	* 1.8124	* 1.2176	*
	* 2.0874	* 1.8111	* 2.0474	* 1.6435	* 1.7985	* 1.5332	* 2.2796	*
11	* 1.6921	* 1.4408	* 1.6667	* 1.3683	* 1.6303	* 1.7357	* 0.8447	*
	* 1.6300	* 1.9096	* 1.6513	* 2.0007	* 1.6911	* 1.5920	* 3.2542	*
12	* 1.6315	* 1.7407	* 1.5202	* 1.6210	* 1.6326	* 0.9555	*	
	* 1.7011	* 1.5940	* 1.8140	* 1.6988	* 1.6822	* 2.8642	*	
13	* 1.4275	* 1.5540	* 1.7946	* 1.7241	* 0.9534	*		
	* 1.9413	* 1.7871	* 1.5479	* 1.6023	* 2.8705	*		
14	* 1.7855	* 1.7906	* 1.2043	* 0.8370	*			
	* 1.5677	* 1.5615	* 2.3043	* 3.2832	*			
15	* 0.9323	* 0.8343	* F-SUB-Q					
	* 2.9882	* 3.3355	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4895	* 1.3196	* 1.2536	* 1.6103	* 1.5560	* 1.3616	* 1.6847	* 0.8821 *
	* 1.7193	* 1.9359	* 2.0380	* 1.6001	* 1.6655	* 1.9008	* 1.5482	* 2.9435 *
9	* 1.3196	* 1.3990	* 1.4559	* 1.3881	* 1.6876	* 1.4994	* 1.6991	* 0.8252 *
	* 1.9359	* 1.8293	* 1.7609	* 1.8543	* 1.5359	* 1.7305	* 1.5341	* 3.1462 *
10	* 1.2536	* 1.4515	* 1.2766	* 1.5914	* 1.4632	* 1.7145	* 1.1590	*
	* 2.0380	* 1.7661	* 2.0030	* 1.6172	* 1.7627	* 1.5148	* 2.2379	*
11	* 1.6103	* 1.3767	* 1.5837	* 1.3051	* 1.5434	* 1.6517	* 0.8036	*
	* 1.6001	* 1.8680	* 1.6249	* 1.9624	* 1.6707	* 1.5658	* 3.2050	*
12	* 1.5560	* 1.6604	* 1.4504	* 1.5353	* 1.5543	* 0.9262	*	
	* 1.6655	* 1.5625	* 1.7778	* 1.6792	* 1.6556	* 2.7722	*	
13	* 1.3616	* 1.4778	* 1.6976	* 1.6406	* 0.9241	*		
	* 1.9008	* 1.7551	* 1.5295	* 1.5761	* 2.7783	*		
14	* 1.6847	* 1.6840	* 1.1463	* 0.7962	*			
	* 1.5482	* 1.5476	* 2.2621	* 3.2341	*			
15	* 0.8822	* 0.7918	* F-SUB-Q					
	* 2.9435	* 3.2773	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 168 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4051 *	* 1.2524 *	* 1.1861 *	* 1.5001 *	* 1.4567 *	* 1.2774 *	* 1.5457 *	* 0.8150 *
	* 1.7298 *	* 1.9372 *	* 2.0470 *	* 1.6310 *	* 1.6884 *	* 1.9246 *	* 1.5995 *	* 3.0250 *
9	* 1.2524 *	* 1.3204 *	* 1.3765 *	* 1.3099 *	* 1.5726 *	* 1.3984 *	* 1.5505 *	* 0.7611 *
	* 1.9372 *	* 1.8401 *	* 1.7684 *	* 1.8663 *	* 1.5641 *	* 1.7612 *	* 1.5948 *	* 3.2379 *
10	* 1.1861 *	* 1.3726 *	* 1.2053 *	* 1.4784 *	* 1.3753 *	* 1.5863 *	* 1.0838 *	
	* 2.0470 *	* 1.7734 *	* 2.0164 *	* 1.6537 *	* 1.7814 *	* 1.5536 *	* 2.2732 *	
11	* 1.5001 *	* 1.2993 *	* 1.4713 *	* 1.2266 *	* 1.4285 *	* 1.5393 *	* 0.7528 *	
	* 1.6310 *	* 1.8802 *	* 1.6614 *	* 1.9849 *	* 1.7150 *	* 1.5962 *	* 3.2546 *	
12	* 1.4567 *	* 1.5553 *	* 1.3635 *	* 1.4212 *	* 1.4522 *	* 0.8655 *		
	* 1.6884 *	* 1.5835 *	* 1.7963 *	* 1.7236 *	* 1.6851 *	* 2.8224 *		
13	* 1.2774 *	* 1.3787 *	* 1.5692 *	* 1.5290 *	* 0.8634 *			
	* 1.9246 *	* 1.7857 *	* 1.5701 *	* 1.6066 *	* 2.8289 *			
14	* 1.5457 *	* 1.5393 *	* 1.0719 *	* 0.7456 *				
	* 1.5995 *	* 1.6062 *	* 2.2978 *	* 3.2853 *				
15	* 0.8150 *	* 0.7362 *	F-SUB-Q					
	* 3.0250 *	* 3.3467 *	M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2878 *	* 1.1645 *	* 1.1033 *	* 1.3740 *	* 1.3339 *	* 1.1632 *	* 1.3643 *	* 0.7243 *
	* 1.8173 *	* 2.0067 *	* 2.1174 *	* 1.7120 *	* 1.7728 *	* 2.0337 *	* 1.7430 *	* 3.2777 *
9	* 1.1645 *	* 1.2288 *	* 1.2637 *	* 1.2164 *	* 1.4310 *	* 1.2737 *	* 1.3679 *	* 0.6793 *
	* 2.0067 *	* 1.9021 *	* 1.8531 *	* 1.9332 *	* 1.6476 *	* 1.8604 *	* 1.7386 *	* 3.4933 *
10	* 1.1033 *	* 1.2604 *	* 1.1177 *	* 1.3494 *	* 1.2696 *	* 1.4285 *	* 0.9752 *	
	* 2.1174 *	* 1.8578 *	* 2.0921 *	* 1.7422 *	* 1.8560 *	* 1.6593 *	* 2.4321 *	
11	* 1.3740 *	* 1.2073 *	* 1.3433 *	* 1.1312 *	* 1.2915 *	* 1.3800 *	* 0.6854 *	
	* 1.7120 *	* 1.9465 *	* 1.7499 *	* 2.0709 *	* 1.8249 *	* 1.7127 *	* 3.4446 *	
12	* 1.3339 *	* 1.4138 *	* 1.2593 *	* 1.2851 *	* 1.3149 *	* 0.7925 *		
	* 1.7728 *	* 1.6673 *	* 1.8707 *	* 1.8316 *	* 1.7907 *	* 2.9689 *		
13	* 1.1632 *	* 1.2565 *	* 1.4137 *	* 1.3711 *	* 0.7905 *			
	* 2.0337 *	* 1.8854 *	* 1.6762 *	* 1.7235 *	* 2.9761 *			
14	* 1.3643 *	* 1.3584 *	* 0.9649 *	* 0.6789 *				
	* 1.7430 *	* 1.7505 *	* 2.4575 *	* 3.4767 *				
15	* 0.7243 *	* 0.6592 *	F-SUB-Q					
	* 3.2777 *	* 3.5994 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 169 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 75 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1327	* 0.9628	* 0.9213	* 1.1788	* 1.0947	* 0.9332	* 1.0897	* 0.5707 *
	* 2.0093	* 2.3619	* 2.4677	* 1.9384	* 2.0998	* 2.4657	* 2.1223	* 4.0496 *
9	* 0.9628	* 1.0345	* 1.1004	* 1.0159	* 1.2422	* 1.0407	* 1.0782	* 0.5381 *
	* 2.3619	* 2.1970	* 2.0665	* 2.2503	* 1.8468	* 2.2138	* 2.1445	* 4.2953 *
10	* 0.9213	* 1.0992	* 0.9295	* 1.1627	* 1.0481	* 1.1816	* 0.7752	*
	* 2.4677	* 2.0686	* 2.4471	* 1.9646	* 2.1851	* 1.9492	* 2.9776	*
11	* 1.1788	* 1.0089	* 1.1570	* 0.9339	* 1.1006	* 1.0880	* 0.5615	*
	* 1.9384	* 2.2651	* 1.9741	* 2.4400	* 2.0786	* 2.1120	* 4.0956	*
12	* 1.0947	* 1.2258	* 1.0403	* 1.0969	* 1.0632	* 0.6546	*	
	* 2.0998	* 1.8712	* 2.2012	* 2.0854	* 2.1527	* 3.4995	*	
13	* 0.9332	* 1.0276	* 1.1711	* 1.0814	* 0.6528	*		
	* 2.4657	* 2.2416	* 1.9664	* 2.1247	* 3.5088	*		
14	* 1.0897	* 1.0703	* 0.7676	* 0.5561	*			
	* 2.1223	* 2.1601	* 3.0066	* 4.1341	*			
15	* 0.5707	* 0.5281	* F-SUB-Q					
	* 4.0496	* 4.3765	* M-SUB-Q					

AT 50% POWER, 75 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4801	* 0.4275	* 0.4336	* 0.5138	* 0.4804	* 0.4254	* 0.4232	* 0.2530 *
	* 4.6182	* 5.1908	* 5.1180	* 4.3290	* 4.6508	* 5.2788	* 5.3253	* 8.9177 *
9	* 0.4275	* 0.4544	* 0.4904	* 0.4613	* 0.5203	* 0.4529	* 0.4139	* 0.2362 *
	* 5.1908	* 4.8773	* 4.5191	* 4.8328	* 4.2961	* 4.9555	* 5.4437	* 9.5532 *
10	* 0.4336	* 0.4903	* 0.4375	* 0.5060	* 0.4647	* 0.4744	* 0.3454	*
	* 5.1180	* 4.5195	* 5.0740	* 4.3997	* 4.8065	* 4.7289	* 6.5187	*
11	* 0.5138	* 0.4582	* 0.5038	* 0.4356	* 0.4747	* 0.4225	* 0.2505	*
	* 4.3290	* 4.8657	* 4.4127	* 5.1075	* 4.7000	* 5.2986	* 8.9663	*
12	* 0.4804	* 0.5149	* 0.4614	* 0.4732	* 0.4214	* 0.3022	*	
	* 4.6508	* 4.3405	* 4.8407	* 4.7153	* 5.2971	* 7.4021	*	
13	* 0.4254	* 0.4480	* 0.4703	* 0.4202	* 0.3012	*		
	* 5.2788	* 5.0094	* 4.7695	* 5.3273	* 7.4249	*		
14	* 0.4232	* 0.4111	* 0.3423	* 0.2482	*			
	* 5.3253	* 5.4804	* 6.5777	* 9.0465	*			
15	* 0.2530	* 0.2351	* F-SUB-Q					
	* 8.9177	* 9.5977	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 170 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5081	* 0.4624	* 0.4423	* 0.5223	* 0.4842	* 0.4076	* 0.2957	* 0.1542 *
	* 3.9933	* 4.3894	* 4.6823	* 3.8457	* 4.1398	* 4.8979	* 4.9647	* 7.9563 *
9	* 0.4624	* 0.4462	* 0.4773	* 0.4681	* 0.5197	* 0.4451	* 0.3471	* 0.1651 *
	* 4.3894	* 4.5441	* 4.2125	* 4.2860	* 3.8520	* 4.4802	* 5.1166	* 8.4841 *
10	* 0.4423	* 0.4771	* 0.3641	* 0.4933	* 0.4686	* 0.4764	* 0.3287	*
	* 4.6823	* 4.2128	* 4.6707	* 4.0441	* 4.2660	* 4.1869	* 6.0346	*
11	* 0.5223	* 0.4663	* 0.4921	* 0.4364	* 0.4928	* 0.4471	* 0.2698	*
	* 3.8457	* 4.3024	* 4.0539	* 4.5867	* 4.0605	* 4.4733	* 7.3563	*
12	* 0.4842	* 0.5163	* 0.4669	* 0.4921	* 0.4535	* 0.3316	*	*
	* 4.1398	* 3.8777	* 4.2815	* 4.0665	* 4.5126	* 6.0595	*	*
13	* 0.4076	* 0.4425	* 0.4743	* 0.4458	* 0.3301	*	*	*
	* 4.8979	* 4.5063	* 4.2053	* 4.4864	* 6.0868	*	*	*
14	* 0.2957	* 0.3453	* 0.3270	* 0.2685	*	*	*	*
	* 4.9647	* 5.1342	* 6.0656	* 7.3941	*	*	*	*
15	* 0.1542	* 0.1635	* F-SUB-Q					
	* 7.9563	* 8.5454	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0762	* 0.9267	* 0.8620	* 1.0645	* 0.9934	* 0.8118	* 0.6725	* 0.3240 *
	* 1.9690	* 2.2858	* 2.4416	* 1.9670	* 2.1075	* 2.5386	* 2.2359	* 3.9556 *
9	* 0.9267	* 0.9063	* 0.9601	* 0.9433	* 1.1100	* 0.9207	* 0.7943	* 0.3385 *
	* 2.2858	* 2.2879	* 2.1565	* 2.2199	* 1.8842	* 2.2612	* 2.2756	* 4.2745 *
10	* 0.8620	* 0.9597	* 0.7104	* 1.0068	* 0.9609	* 1.0479	* 0.6715	*
	* 2.4416	* 2.1566	* 2.4677	* 2.0673	* 2.1739	* 1.9886	* 3.0851	*
11	* 1.0645	* 0.9394	* 1.0042	* 0.8622	* 1.0139	* 1.0085	* 0.5480	*
	* 1.9670	* 2.2291	* 2.0726	* 2.4189	* 2.0563	* 2.0674	* 3.7853	*
12	* 0.9934	* 1.1018	* 0.9572	* 1.0122	* 0.9885	* 0.6479	*	*
	* 2.1075	* 1.8982	* 2.1822	* 2.0597	* 2.1176	* 3.2205	*	*
13	* 0.8118	* 0.9147	* 1.0433	* 1.0055	* 0.6457	*	*	*
	* 2.5386	* 2.2760	* 1.9974	* 2.0735	* 3.2315	*	*	*
14	* 0.6725	* 0.7900	* 0.6679	* 0.5450	*	*	*	*
	* 2.2359	* 2.2835	* 3.1019	* 3.8064	*	*	*	*
15	* 0.3240	* 0.3326	* F-SUB-Q					
	* 3.9556	* 4.3394	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 171 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1867	* 1.0726	* 1.0025	* 1.2007	* 1.1586	* 0.9771	* 0.8419	* 0.4111
	* 1.8625	* 2.0585	* 2.1856	* 1.8207	* 1.8869	* 2.1908	* 1.9463	* 3.3107
9	* 1.0726	* 1.0545	* 1.0606	* 1.1030	* 1.2323	* 1.0883	* 0.9724	* 0.4226
	* 2.0585	* 2.0525	* 2.0453	* 1.9827	* 1.7745	* 1.9978	* 1.9336	* 3.5678
10	* 1.0025	* 1.0596	* 0.8412	* 1.1424	* 1.1326	* 1.2164	* 0.8265	*
	* 2.1856	* 2.0460	* 2.2055	* 1.9036	* 1.9253	* 1.7889	* 2.5978	*
11	* 1.2007	* 1.0979	* 1.1388	* 1.0120	* 1.1488	* 1.2002	* 0.6729	*
	* 1.8207	* 1.9920	* 1.9095	* 2.1460	* 1.8915	* 1.8089	* 3.2175	*
12	* 1.1586	* 1.2212	* 1.1277	* 1.1460	* 1.1599	* 0.7768	*	*
	* 1.8869	* 1.7908	* 1.9337	* 1.8958	* 1.8748	* 2.7908	*	*
13	* 0.9771	* 1.0805	* 1.2112	* 1.1964	* 0.7748	*	*	*
	* 2.1908	* 2.0123	* 1.7966	* 1.8147	* 2.7980	*	*	*
14	* 0.8419	* 0.9667	* 0.8218	* 0.6691	*	*	*	*
	* 1.9463	* 1.9410	* 2.6113	* 3.2358	*	*	*	*
15	* 0.4111	* 0.4164	* F-SUB-Q					
	* 3.3107	* 3.6110	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3536	* 1.1910	* 1.1171	* 1.3839	* 1.3076	* 1.0974	* 0.9939	* 0.4746
	* 1.7285	* 1.9618	* 2.0780	* 1.6742	* 1.7711	* 2.0374	* 1.7157	* 3.0428
9	* 1.1910	* 1.1754	* 1.2131	* 1.2330	* 1.4240	* 1.2371	* 1.1536	* 0.4837
	* 1.9618	* 1.9343	* 1.8856	* 1.8794	* 1.6274	* 1.8511	* 1.7040	* 3.3308
10	* 1.1171	* 1.2118	* 0.9259	* 1.3199	* 1.2762	* 1.4205	* 0.9325	*
	* 2.0780	* 1.8864	* 2.0833	* 1.7458	* 1.8081	* 1.6169	* 2.4243	*
11	* 1.3839	* 1.2266	* 1.3154	* 1.1393	* 1.3400	* 1.4170	* 0.7431	*
	* 1.6742	* 1.8892	* 1.7518	* 2.0120	* 1.7127	* 1.6158	* 3.0744	*
12	* 1.3076	* 1.4099	* 1.2700	* 1.3359	* 1.3405	* 0.8554	*	*
	* 1.7711	* 1.6428	* 1.8170	* 1.7179	* 1.7125	* 2.6733	*	*
13	* 1.0974	* 1.2273	* 1.4140	* 1.4123	* 0.8536	*	*	*
	* 2.0374	* 1.8658	* 1.6246	* 1.6213	* 2.6791	*	*	*
14	* 0.9939	* 1.1465	* 0.9266	* 0.7388	*	*	*	*
	* 1.7157	* 1.7109	* 2.4382	* 3.0925	*	*	*	*
15	* 0.4746	* 0.4765	* F-SUB-Q					
	* 3.0428	* 3.3835	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 172 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4241	* 1.2385	* 1.1741	* 1.4743	* 1.3821	* 1.1620	* 1.0787	* 0.5233
	* 1.7770	* 2.0421	* 2.1462	* 1.6919	* 1.7990	* 2.0679	* 1.7017	* 3.0361
9	* 1.2385	* 1.2246	* 1.2888	* 1.2996	* 1.5222	* 1.3151	* 1.2478	* 0.5297
	* 2.0421	* 1.9787	* 1.9048	* 1.9203	* 1.6343	* 1.8721	* 1.6957	* 3.3194
10	* 1.1741	* 1.2874	* 0.9926	* 1.4107	* 1.3492	* 1.5231	* 1.0056	*
	* 2.1462	* 1.9059	* 2.1265	* 1.7570	* 1.8335	* 1.6110	* 2.4126	*
11	* 1.4743	* 1.2924	* 1.4055	* 1.2072	* 1.4387	* 1.5247	* 0.7985	*
	* 1.6919	* 1.9313	* 1.7637	* 2.0357	* 1.7041	* 1.6013	* 3.0574	*
12	* 1.3821	* 1.5061	* 1.3422	* 1.4341	* 1.4371	* 0.9170	*	*
	* 1.7990	* 1.6465	* 1.8433	* 1.7097	* 1.7105	* 2.6651	*	*
13	* 1.1620	* 1.3043	* 1.5154	* 1.5194	* 0.9151	*	*	*
	* 2.0679	* 1.8880	* 1.6196	* 1.6070	* 2.6706	*	*	*
14	* 1.0787	* 1.2398	* 0.9992	* 0.7934	*	*	*	*
	* 1.7017	* 1.7030	* 2.4269	* 3.0776	*	*	*	*
15	* 0.5233	* 0.5218	* F-SUB-Q					
	* 3.0361	* 3.3630	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4833	* 1.2835	* 1.2308	* 1.5550	* 1.4518	* 1.2324	* 1.1721	* 0.5838
	* 1.8806	* 2.1664	* 2.2342	* 1.7624	* 1.8837	* 2.1260	* 1.7365	* 3.1177
9	* 1.2835	* 1.2814	* 1.3625	* 1.3641	* 1.6096	* 1.3894	* 1.3411	* 0.5846
	* 2.1664	* 2.0472	* 1.9543	* 2.0129	* 1.6974	* 1.9520	* 1.7275	* 3.3889
10	* 1.2308	* 1.3614	* 1.0642	* 1.4960	* 1.4191	* 1.6128	* 1.0752	*
	* 2.2342	* 1.9557	* 2.1961	* 1.8090	* 1.9132	* 1.6646	* 2.4464	*
11	* 1.5550	* 1.3562	* 1.4902	* 1.2705	* 1.5217	* 1.6133	* 0.8472	*
	* 1.7624	* 2.0250	* 1.8156	* 2.1086	* 1.7526	* 1.6434	* 3.1489	*
12	* 1.4518	* 1.5919	* 1.4112	* 1.5166	* 1.5194	* 0.9710	*	*
	* 1.8837	* 1.7090	* 1.9242	* 1.7587	* 1.7550	* 2.7227	*	*
13	* 1.2324	* 1.3775	* 1.6041	* 1.6075	* 0.9692	*	*	*
	* 2.1260	* 1.9687	* 1.6740	* 1.6495	* 2.7278	*	*	*
14	* 1.1721	* 1.3323	* 1.0681	* 0.8415	*	*	*	*
	* 1.7365	* 1.7355	* 2.4616	* 3.1704	*	*	*	*
15	* 0.5838	* 0.5771	* F-SUB-Q					
	* 3.1177	* 3.4399	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 173 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5698 *	* 1.3531 *	* 1.3079 *	* 1.6643 *	* 1.5433 *	* 1.3192 *	* 1.3512 *	* 0.6898 *
	* 1.9365 *	* 2.2215 *	* 2.2825 *	* 1.7985 *	* 1.9175 *	* 2.1761 *	* 1.7553 *	* 3.2125 *
9	* 1.3531 *	* 1.3691 *	* 1.4753 *	* 1.4498 *	* 1.7272 *	* 1.4873 *	* 1.4791 *	* 0.6692 *
	* 2.2215 *	* 2.1012 *	* 1.9847 *	* 2.0584 *	* 1.7259 *	* 1.9767 *	* 1.7466 *	* 3.5092 *
10	* 1.3079 *	* 1.4742 *	* 1.1808 *	* 1.6168 *	* 1.5098 *	* 1.7302 *	* 1.1518 *	
	* 2.2825 *	* 1.9863 *	* 2.2512 *	* 1.8190 *	* 1.9747 *	* 1.7235 *	* 2.5048 *	
11	* 1.6643 *	* 1.4410 *	* 1.6103 *	* 1.3504 *	* 1.6276 *	* 1.7260 *	* 0.8878 *	
	* 1.7985 *	* 2.0702 *	* 1.8261 *	* 2.1977 *	* 1.8157 *	* 1.6985 *	* 3.3439 *	
12	* 1.5433 *	* 1.7074 *	* 1.5011 *	* 1.6220 *	* 1.6220 *	* 1.0157 *		
	* 1.9175 *	* 1.7457 *	* 1.9855 *	* 1.8222 *	* 1.8178 *	* 2.8668 *		
13	* 1.3192 *	* 1.4738 *	* 1.7205 *	* 1.7197 *	* 1.0139 *			
	* 2.1761 *	* 1.9949 *	* 1.7335 *	* 1.7051 *	* 2.8720 *			
14	* 1.3512 *	* 1.4693 *	* 1.1441 *	* 0.8818 *				
	* 1.7553 *	* 1.7550 *	* 2.5210 *	* 3.3671 *				
15	* 0.6898 *	* 0.6608 *	F-SUB-Q					
	* 3.2125 *	* 3.5550 *	M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6315 *	* 1.4127 *	* 1.3742 *	* 1.7476 *	* 1.6222 *	* 1.4065 *	* 1.5864 *	* 0.8459 *
	* 2.0363 *	* 2.3344 *	* 2.3868 *	* 1.8734 *	* 1.9943 *	* 2.2602 *	* 1.8155 *	* 3.3448 *
9	* 1.4127 *	* 1.4738 *	* 1.5739 *	* 1.5215 *	* 1.8174 *	* 1.5700 *	* 1.6700 *	* 0.7946 *
	* 2.3344 *	* 2.1847 *	* 2.0534 *	* 2.1468 *	* 1.7921 *	* 2.0509 *	* 1.8060 *	* 3.6510 *
10	* 1.3742 *	* 1.5728 *	* 1.3226 *	* 1.7184 *	* 1.5852 *	* 1.8180 *	* 1.2296 *	
	* 2.3868 *	* 2.0553 *	* 2.3352 *	* 1.8859 *	* 2.0582 *	* 1.7877 *	* 2.5854 *	
11	* 1.7476 *	* 1.5121 *	* 1.7115 *	* 1.4234 *	* 1.7045 *	* 1.8066 *	* 0.9289 *	
	* 1.8734 *	* 2.1586 *	* 1.8936 *	* 2.2879 *	* 1.9236 *	* 1.8112 *	* 3.5141 *	
12	* 1.6222 *	* 1.7959 *	* 1.5760 *	* 1.6985 *	* 1.6975 *	* 1.0580 *		
	* 1.9943 *	* 1.8112 *	* 2.0700 *	* 1.9306 *	* 1.9408 *	* 3.0719 *		
13	* 1.4065 *	* 1.5554 *	* 1.8074 *	* 1.7998 *	* 1.0563 *			
	* 2.2602 *	* 2.0703 *	* 1.7989 *	* 1.8183 *	* 3.0772 *			
14	* 1.5864 *	* 1.6614 *	* 1.2213 *	* 0.9225 *				
	* 1.8155 *	* 1.8151 *	* 2.6028 *	* 3.5385 *				
15	* 0.8459 *	* 0.7839 *	F-SUB-Q					
	* 3.3448 *	* 3.6992 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 174 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7156	* 1.4825	* 1.4472	* 1.8518	* 1.7156	* 1.4991	* 1.8460	* 0.9784 *
	* 2.1442	* 2.4729	* 2.5230	* 1.9600	* 2.0950	* 2.3751	* 1.8609	* 3.4745 *
9	* 1.4825	* 1.5786	* 1.6868	* 1.6015	* 1.9297	* 1.6620	* 1.8588	* 0.8960 *
	* 2.4729	* 2.3010	* 2.1431	* 2.2640	* 1.8698	* 2.1513	* 1.8617	* 3.8121 *
10	* 1.4472	* 1.6851	* 1.4633	* 1.8355	* 1.6697	* 1.9279	* 1.2974	*
	* 2.5230	* 2.1452	* 2.4565	* 1.9693	* 2.1681	* 1.8627	* 2.7340	*
11	* 1.8518	* 1.5925	* 1.8279	* 1.5031	* 1.8009	* 1.9083	* 0.9586	*
	* 1.9600	* 2.2768	* 1.9775	* 2.4114	* 2.0081	* 1.8884	* 3.7560	*
12	* 1.7156	* 1.9075	* 1.6600	* 1.7944	* 1.7892	* 1.0914	*	*
	* 2.0950	* 1.8883	* 2.1809	* 2.0156	* 2.0306	* 3.3329	*	*
13	* 1.4991	* 1.6461	* 1.9164	* 1.9010	* 1.0898	*	*	*
	* 2.3751	* 2.1724	* 1.8746	* 1.8959	* 3.3378	*	*	*
14	* 1.8460	* 1.8496	* 1.2883	* 0.9528	*	*	*	*
	* 1.8609	* 1.8710	* 2.7533	* 3.7792	*	*	*	*
15	* 0.9784	* 0.8804	* F-SUB-Q					
	* 3.4745	* 3.8786	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6987	* 1.4857	* 1.4604	* 1.8455	* 1.7278	* 1.5186	* 1.8881	* 1.0348 *
	* 2.4196	* 2.7646	* 2.8065	* 2.2010	* 2.3311	* 2.6304	* 2.0734	* 3.7656 *
9	* 1.4857	* 1.5922	* 1.6935	* 1.6124	* 1.9250	* 1.6748	* 1.8924	* 0.9582 *
	* 2.7646	* 2.5697	* 2.4076	* 2.5215	* 2.0963	* 2.3915	* 2.0739	* 4.0752 *
10	* 1.4604	* 1.6917	* 1.4871	* 1.8350	* 1.6798	* 1.9208	* 1.3433	*
	* 2.8065	* 2.4101	* 2.7363	* 2.2094	* 2.4117	* 2.0846	* 2.9645	*
11	* 1.8455	* 1.6032	* 1.8273	* 1.5177	* 1.7914	* 1.8956	* 0.9961	*
	* 2.2010	* 2.5362	* 2.2188	* 2.6793	* 2.2503	* 2.1165	* 4.0274	*
12	* 1.7278	* 1.9038	* 1.6699	* 1.7847	* 1.7836	* 1.1301	*	*
	* 2.3311	* 2.1149	* 2.4263	* 2.2587	* 2.2678	* 3.5671	*	*
13	* 1.5186	* 1.6586	* 1.9090	* 1.8881	* 1.1278	*	*	*
	* 2.6304	* 2.4151	* 2.0982	* 2.1250	* 3.5742	*	*	*
14	* 1.8881	* 1.8830	* 1.3340	* 0.9891	*	*	*	*
	* 2.0734	* 2.0844	* 2.9850	* 4.0559	*	*	*	*
15	* 1.0348	* 0.9440	* F-SUB-Q					
	* 3.7656	* 4.1360	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 175 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7740	* 1.5347	* 1.5054	* 1.9381	* 1.7988	* 1.5777	* 2.0195	* 1.0777 *
	* 2.5724	* 2.9754	* 3.0277	* 2.3352	* 2.5008	* 2.8375	* 2.1964	* 4.1084 *
9	* 1.5347	* 1.6547	* 1.7814	* 1.6712	* 2.0262	* 1.7455	* 2.0124	* 0.9853 *
	* 2.9754	* 2.7565	* 2.5529	* 2.7082	* 2.2173	* 2.5607	* 2.2029	* 4.4960 *
10	* 1.5054	* 1.7795	* 1.5442	* 1.9295	* 1.7430	* 2.0243	* 1.3727	*
	* 3.0277	* 2.5556	* 2.9392	* 2.3377	* 2.5832	* 2.2008	* 3.2448	*
11	* 1.9381	* 1.6614	* 1.9210	* 1.5688	* 1.8840	* 1.9963	* 1.0016	*
	* 2.3352	* 2.7241	* 2.3479	* 2.8689	* 2.3661	* 2.2217	* 4.4287	*
12	* 1.7988	* 2.0047	* 1.7323	* 1.8769	* 1.8692	* 1.1374	*	
	* 2.5008	* 2.2365	* 2.5991	* 2.3750	* 2.3885	* 3.9086	*	
13	* 1.5777	* 1.7278	* 2.0115	* 1.9885	* 1.1358	*		
	* 2.8375	* 2.5868	* 2.2147	* 2.2303	* 3.9137	*		
14	* 2.0195	* 2.0021	* 1.3627	* 0.9953	*			
	* 2.1964	* 2.2141	* 3.2681	* 4.4562	*			
15	* 1.0777	* 0.9701	* F-SUB-Q					
	* 4.1084	* 4.5654	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7762	* 1.5370	* 1.5112	* 1.9520	* 1.8124	* 1.5890	* 2.0522	* 1.0958 *
	* 2.6107	* 3.0125	* 3.0589	* 2.3674	* 2.5515	* 2.9117	* 2.2668	* 4.2533 *
9	* 1.5370	* 1.6618	* 1.7929	* 1.6798	* 2.0435	* 1.7600	* 2.0411	* 1.0033 *
	* 3.0125	* 2.7873	* 2.5818	* 2.7506	* 2.2634	* 2.6284	* 2.2757	* 4.6436 *
10	* 1.5112	* 1.7909	* 1.5524	* 1.9449	* 1.7545	* 2.0444	* 1.3888	*
	* 3.0589	* 2.5849	* 2.9819	* 2.3754	* 2.6323	* 2.2617	* 3.3398	*
11	* 1.9520	* 1.6696	* 1.9361	* 1.5789	* 1.9020	* 2.0163	* 1.0140	*
	* 2.3674	* 2.7678	* 2.3865	* 2.9223	* 2.4278	* 2.2923	* 4.5682	*
12	* 1.8124	* 2.0225	* 1.7434	* 1.8946	* 1.8868	* 1.1501	*	
	* 2.5515	* 2.2872	* 2.6496	* 2.4377	* 2.4482	* 4.0215	*	
13	* 1.5890	* 1.7417	* 2.0312	* 2.0082	* 1.1485	*		
	* 2.9117	* 2.6564	* 2.2769	* 2.3019	* 4.0274	*		
14	* 2.0522	* 2.0305	* 1.3788	* 1.0065	*			
	* 2.2668	* 2.2879	* 3.3645	* 4.6028	*			
15	* 1.0958	* 0.9887	* F-SUB-Q					
	* 4.2533	* 4.7114	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 176 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7252	* 1.5032	* 1.4855	* 1.9063	* 1.7814	* 1.5663	* 2.0149	* 1.0939 *
	* 2.6741	* 3.0638	* 3.0980	* 2.4139	* 2.5881	* 2.9527	* 2.3139	* 4.2727 *
9	* 1.5032	* 1.6264	* 1.7480	* 1.6492	* 1.9981	* 1.7317	* 2.0048	* 1.0127 *
	* 3.0638	* 2.8340	* 2.6348	* 2.7872	* 2.3062	* 2.6628	* 2.3204	* 4.6115 *
10	* 1.4855	* 1.7458	* 1.5231	* 1.9013	* 1.7252	* 2.0033	* 1.3885	*
	* 3.0980	* 2.6381	* 3.0199	* 2.4165	* 2.6619	* 2.2982	* 3.3326	*
11	* 1.9063	* 1.6388	* 1.8924	* 1.5540	* 1.8634	* 1.9765	* 1.0210	*
	* 2.4139	* 2.8051	* 2.4282	* 2.9492	* 2.4604	* 2.3224	* 4.5045	*
12	* 1.7814	* 1.9793	* 1.7139	* 1.8558	* 1.8520	* 1.1606	*	*
	* 2.5881	* 2.3278	* 2.6799	* 2.4707	* 2.4729	* 3.9459	*	*
13	* 1.5663	* 1.7133	* 1.9892	* 1.9683	* 1.1586	*	*	*
	* 2.9527	* 2.6917	* 2.3141	* 2.3324	* 3.9533	*	*	*
14	* 2.0149	* 1.9941	* 1.3783	* 1.0134	*	*	*	*
	* 2.3139	* 2.3332	* 3.3579	* 4.5394	*	*	*	*
15	* 1.0939	* 0.9971	* F-SUB-Q					
	* 4.2727	* 4.6830	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7458	* 1.5045	* 1.4856	* 1.9407	* 1.7986	* 1.5810	* 2.0740	* 1.0946 *
	* 2.5706	* 2.9769	* 3.0107	* 2.3156	* 2.5070	* 2.8648	* 2.1967	* 4.1488 *
9	* 1.5045	* 1.6356	* 1.7767	* 1.6580	* 2.0417	* 1.7517	* 2.0575	* 1.0011 *
	* 2.9769	* 2.7439	* 2.5249	* 2.7037	* 2.2067	* 2.5743	* 2.2118	* 4.5327 *
10	* 1.4856	* 1.7744	* 1.5300	* 1.9380	* 1.7388	* 2.0515	* 1.3760	*
	* 3.0107	* 2.5282	* 2.9243	* 2.3142	* 2.5776	* 2.1940	* 3.2832	*
11	* 1.9407	* 1.6471	* 1.9285	* 1.5644	* 1.9080	* 2.0284	* 1.0001	*
	* 2.3156	* 2.7214	* 2.3255	* 2.8498	* 2.3446	* 2.2100	* 4.4677	*
12	* 1.7986	* 2.0221	* 1.7269	* 1.9000	* 1.8910	* 1.1422	*	*
	* 2.5070	* 2.2278	* 2.5952	* 2.3544	* 2.3586	* 3.8924	*	*
13	* 1.5810	* 1.7322	* 2.0372	* 2.0197	* 1.1408	*	*	*
	* 2.8648	* 2.6029	* 2.2092	* 2.2194	* 3.8973	*	*	*
14	* 2.0740	* 2.0462	* 1.3653	* 0.9934	*	*	*	*
	* 2.1967	* 2.2240	* 3.3088	* 4.4975	*	*	*	*
15	* 1.0946	* 0.9846	* F-SUB-Q					
	* 4.1488	* 4.6073	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 177 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7203	* 1.4776	* 1.4625	* 1.9231	* 1.7786	* 1.5651	* 2.0717	* 1.0836 *
	* 2.3786	* 2.7647	* 2.7919	* 2.1403	* 2.3226	* 2.6447	* 2.0118	* 3.8137 *
9	* 1.4776	* 1.6115	* 1.7573	* 1.6353	* 2.0293	* 1.7354	* 2.0530	* 0.9892 *
	* 2.7647	* 2.5403	* 2.3304	* 2.5105	* 2.0373	* 2.3824	* 2.0287	* 4.1748 *
10	* 1.4625	* 1.7549	* 1.5082	* 1.9227	* 1.7186	* 2.0436	* 1.3570	*
	* 2.7919	* 2.3335	* 2.7090	* 2.1380	* 2.3911	* 2.0233	* 3.0435	*
11	* 1.9231	* 1.6241	* 1.9129	* 1.5467	* 1.9007	* 2.0246	* 0.9839	*
	* 2.1403	* 2.5271	* 2.1485	* 2.6374	* 2.1575	* 2.0312	* 4.1488	*
12	* 1.7786	* 2.0090	* 1.7063	* 1.8925	* 1.8828	* 1.1269	*	
	* 2.3226	* 2.0570	* 2.4076	* 2.1664	* 2.1678	* 3.6010	*	
13	* 1.5651	* 1.7154	* 2.0289	* 2.0157	* 1.1252	*		
	* 2.6447	* 2.4091	* 2.0372	* 2.0396	* 3.6061	*		
14	* 2.0717	* 2.0414	* 1.3462	* 0.9773	*			
	* 2.0118	* 2.0398	* 3.0671	* 4.1758	*			
15	* 1.0836	* 0.9706	* F-SUB-Q					
	* 3.8137	* 4.2529	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6718	* 1.4380	* 1.4233	* 1.8754	* 1.7382	* 1.5297	* 2.0283	* 1.0629 *
	* 2.2083	* 2.5613	* 2.5868	* 1.9806	* 2.1464	* 2.4472	* 1.8607	* 3.5239 *
9	* 1.4380	* 1.5692	* 1.7109	* 1.5940	* 1.9831	* 1.6965	* 2.0105	* 0.9734 *
	* 2.5613	* 2.3528	* 2.1594	* 2.3238	* 1.8829	* 2.2017	* 1.8753	* 3.8455 *
10	* 1.4233	* 1.7084	* 1.4690	* 1.8768	* 1.6787	* 1.9999	* 1.3325	*
	* 2.5868	* 2.1624	* 2.5076	* 1.9762	* 2.2102	* 1.8682	* 2.8021	*
11	* 1.8754	* 1.5828	* 1.8669	* 1.5100	* 1.8591	* 1.9818	* 0.9684	*
	* 1.9806	* 2.3396	* 1.9862	* 2.4413	* 1.9956	* 1.8769	* 3.8150	*
12	* 1.7382	* 1.9628	* 1.6663	* 1.8509	* 1.8428	* 1.1101	*	
	* 2.1464	* 1.9015	* 2.2260	* 2.0041	* 2.0022	* 3.3013	*	
13	* 1.5297	* 1.6765	* 1.9844	* 1.9729	* 1.1085	*		
	* 2.4472	* 2.2269	* 1.8815	* 1.8850	* 3.3057	*		
14	* 2.0283	* 1.9988	* 1.3216	* 0.9616	*			
	* 1.8607	* 1.8859	* 2.8244	* 3.8409	*			
15	* 1.0629	* 0.9574	* F-SUB-Q					
	* 3.5239	* 3.9077	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 178 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5864	* 1.3769	* 1.3682	* 1.7853	* 1.6682	* 1.4712	* 1.9335	* 1.0341 *
	* 2.1011	* 2.4162	* 2.4357	* 1.8803	* 2.0238	* 2.3099	* 1.7738	* 3.3002 *
9	* 1.3769	* 1.5012	* 1.6257	* 1.5288	* 1.8897	* 1.6288	* 1.9205	* 0.9594 *
	* 2.4162	* 2.2228	* 2.0548	* 2.1897	* 1.7865	* 2.0748	* 1.7826	* 3.5531 *
10	* 1.3682	* 1.6233	* 1.4092	* 1.7879	* 1.6121	* 1.9089	* 1.3045	*
	* 2.4357	* 2.0579	* 2.3643	* 1.8740	* 2.0791	* 1.7692	* 2.5924	*
11	* 1.7853	* 1.5178	* 1.7782	* 1.4513	* 1.7737	* 1.8920	* 0.9579	*
	* 1.8803	* 2.2049	* 1.8837	* 2.2935	* 1.8796	* 1.7657	* 3.4749	*
12	* 1.6682	* 1.8700	* 1.6000	* 1.7657	* 1.7630	* 1.0960	*	
	* 2.0238	* 1.8046	* 2.0941	* 1.8878	* 1.8802	* 3.0023	*	
13	* 1.4712	* 1.6093	* 1.8938	* 1.8833	* 1.0939	*		
	* 2.3099	* 2.0989	* 1.7820	* 1.7735	* 3.0079	*		
14	* 1.9335	* 1.9091	* 1.2938	* 0.9499	*			
	* 1.7738	* 1.7929	* 2.6131	* 3.5032	*			
15	* 1.0341	* 0.9436	* F-SUB-Q					
	* 3.3001	* 3.6105	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5860	* 1.3577	* 1.3449	* 1.7881	* 1.6545	* 1.4562	* 1.9524	* 1.0096 *
	* 1.8942	* 2.2086	* 2.2301	* 1.6938	* 1.8422	* 2.1109	* 1.5903	* 3.0607 *
9	* 1.3577	* 1.4864	* 1.6261	* 1.5091	* 1.8972	* 1.6168	* 1.9355	* 0.9231 *
	* 2.2086	* 2.0250	* 1.8544	* 2.0011	* 1.6063	* 1.8870	* 1.6003	* 3.3461 *
10	* 1.3449	* 1.6235	* 1.3895	* 1.7917	* 1.5946	* 1.9204	* 1.2623	*
	* 2.2301	* 1.8572	* 2.1624	* 1.6871	* 1.8956	* 1.5857	* 2.4207	*
11	* 1.7881	* 1.4979	* 1.7817	* 1.4338	* 1.7833	* 1.9069	* 0.9138	*
	* 1.6938	* 2.0155	* 1.6961	* 2.0915	* 1.6917	* 1.5858	* 3.2928	*
12	* 1.6545	* 1.8767	* 1.5822	* 1.7750	* 1.7671	* 1.0509	*	
	* 1.8422	* 1.6232	* 1.9098	* 1.6993	* 1.6999	* 2.8437	*	
13	* 1.4562	* 1.5969	* 1.9048	* 1.8979	* 1.0492	*		
	* 2.1109	* 1.9098	* 1.5977	* 1.5930	* 2.8479	*		
14	* 1.9524	* 1.9236	* 1.2514	* 0.9072	*			
	* 1.5903	* 1.6099	* 2.4412	* 3.3159	*			
15	* 1.0096	* 0.9052	* F-SUB-Q					
	* 3.0607	* 3.4108	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 179 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5240	* 1.3048	* 1.2913	* 1.7179	* 1.5923	* 1.4012	* 1.8805	* 0.9704 *
	* 1.8097	* 2.1087	* 2.1318	* 1.6183	* 1.7552	* 2.0018	* 1.5026	* 2.8985 *
9	* 1.3048	* 1.4292	* 1.5596	* 1.4494	* 1.8238	* 1.5563	* 1.8672	* 0.8882 *
	* 2.1087	* 1.9304	* 1.7729	* 1.9135	* 1.5346	* 1.7983	* 1.5121	* 3.1651 *
10	* 1.2913	* 1.5571	* 1.3337	* 1.7212	* 1.5331	* 1.8496	* 1.2141	*
	* 2.1318	* 1.7757	* 2.0660	* 1.6130	* 1.8124	* 1.5141	* 2.3063	*
11	* 1.7179	* 1.4384	* 1.7114	* 1.3772	* 1.7152	* 1.8381	* 0.8775	*
	* 1.6183	* 1.9274	* 1.6218	* 2.0035	* 1.6203	* 1.5157	* 3.1590	*
12	* 1.5923	* 1.8036	* 1.5210	* 1.7070	* 1.7001	* 1.0108	*	
	* 1.7552	* 1.5510	* 1.8262	* 1.6277	* 1.6298	* 2.7312	*	
13	* 1.4012	* 1.5367	* 1.8342	* 1.8292	* 1.0093	*		
	* 2.0018	* 1.8205	* 1.5257	* 1.5228	* 2.7352	*		
14	* 1.8805	* 1.8552	* 1.2033	* 0.8711	*			
	* 1.5026	* 1.5216	* 2.3264	* 3.1816	*			
15	* 0.9704	* 0.8702	* F-SUB-Q					
	* 2.8985	* 3.2289	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4495	* 1.2463	* 1.2284	* 1.6233	* 1.5134	* 1.3300	* 1.7659	* 0.9172
	* 1.7793	* 2.0645	* 2.0966	* 1.6012	* 1.7259	* 1.9679	* 1.4904	* 2.8576
9	* 1.2463	* 1.3602	* 1.4720	* 1.3773	* 1.7192	* 1.4772	* 1.7599	* 0.8573
	* 2.0645	* 1.8962	* 1.7562	* 1.8840	* 1.5220	* 1.7712	* 1.4951	* 3.0572
10	* 1.2284	* 1.4697	* 1.2669	* 1.6246	* 1.4552	* 1.7435	* 1.1546	*
	* 2.0966	* 1.7590	* 2.0351	* 1.5987	* 1.7871	* 1.5015	* 2.2669	*
11	* 1.6233	* 1.3669	* 1.6154	* 1.3061	* 1.6139	* 1.7293	* 0.8330	*
	* 1.6012	* 1.8977	* 1.6075	* 1.9796	* 1.6132	* 1.5089	* 3.1201	*
12	* 1.5134	* 1.7001	* 1.4437	* 1.6062	* 1.6105	* 0.9735	*	
	* 1.7259	* 1.5387	* 1.8007	* 1.6207	* 1.6130	* 2.6625	*	
13	* 1.3300	* 1.4584	* 1.7288	* 1.7206	* 0.9720	*		
	* 1.9679	* 1.7933	* 1.5132	* 1.5161	* 2.6664	*		
14	* 1.7659	* 1.7480	* 1.1442	* 0.8267	*			
	* 1.4904	* 1.5049	* 2.2867	* 3.1433	*			
15	* 0.9172	* 0.8250	* F-SUB-Q					
	* 2.8576	* 3.1753	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 180 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3499	* 1.1738	* 1.1509	* 1.4930	* 1.4081	* 1.2338	* 1.5928	* 0.8429 *
	* 1.8165	* 2.0838	* 2.1284	* 1.6538	* 1.7621	* 2.0154	* 1.5674	* 2.9528 *
9	* 1.1738	* 1.2719	* 1.3689	* 1.2869	* 1.5805	* 1.3705	* 1.5985	* 0.7872 *
	* 2.0838	* 1.9273	* 1.7947	* 1.9169	* 1.5705	* 1.8133	* 1.5615	* 3.1611 *
10	* 1.1509	* 1.3652	* 1.1842	* 1.4911	* 1.3550	* 1.5927	* 1.0749	*
	* 2.1284	* 1.7994	* 2.0712	* 1.6553	* 1.8247	* 1.5610	* 2.3138	*
11	* 1.4930	* 1.2776	* 1.4829	* 1.2155	* 1.4701	* 1.5701	* 0.7749	*
	* 1.6538	* 1.9303	* 1.6642	* 2.0244	* 1.6841	* 1.5797	* 3.1927	*
12	* 1.4081	* 1.5588	* 1.3447	* 1.4632	* 1.4897	* 0.9014	*	
	* 1.7621	* 1.5915	* 1.8383	* 1.6918	* 1.6581	* 2.7376	*	
13	* 1.2338	* 1.3536	* 1.5801	* 1.5621	* 0.8999	*		
	* 2.0154	* 1.8354	* 1.5730	* 1.5875	* 2.7420	*		
14	* 1.5928	* 1.5877	* 1.0652	* 0.7688	*			
	* 1.5674	* 1.5719	* 2.3343	* 3.2174	*			
15	* 0.8429	* 0.7629	* F-SUB-Q					
	* 2.9528	* 3.2616	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2257	* 1.0802	* 1.0541	* 1.3405	* 1.2744	* 1.1100	* 1.3755	* 0.7402 *
	* 1.9271	* 2.1821	* 2.2381	* 1.7715	* 1.8737	* 2.1513	* 1.7462	* 3.2393 *
9	* 1.0802	* 1.1658	* 1.2338	* 1.1759	* 1.4150	* 1.2344	* 1.3920	* 0.6945 *
	* 2.1821	* 2.0246	* 1.9169	* 2.0196	* 1.6877	* 1.9375	* 1.7250	* 3.4519 *
10	* 1.0541	* 1.2309	* 1.0812	* 1.3357	* 1.2324	* 1.4076	* 0.9589	*
	* 2.2381	* 1.9213	* 2.1846	* 1.7783	* 1.9311	* 1.6989	* 2.4982	*
11	* 1.3405	* 1.1679	* 1.3289	* 1.1022	* 1.3010	* 1.3825	* 0.6973	*
	* 1.7715	* 2.0327	* 1.7871	* 2.1498	* 1.8310	* 1.7271	* 3.4212	*
12	* 1.2744	* 1.3942	* 1.2236	* 1.2951	* 1.3257	* 0.8124	*	
	* 1.8737	* 1.7120	* 1.9445	* 1.8368	* 1.7940	* 2.9279	*	
13	* 1.1100	* 1.2199	* 1.3976	* 1.3754	* 0.8109	*		
	* 2.1513	* 1.9600	* 1.7107	* 1.7357	* 2.9331	*		
14	* 1.3755	* 1.3827	* 0.9505	* 0.6917	*			
	* 1.7462	* 1.7364	* 2.5196	* 3.4480	*			
15	* 0.7402	* 0.6756	* F-SUB-Q					
	* 3.2393	* 3.5482	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 181 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 150 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0480	* 0.8902	* 0.8688	* 1.1201	* 1.0353	* 0.8878	* 1.0757	* 0.5750 *
	* 2.1931	* 2.5802	* 2.6439	* 2.0610	* 2.2429	* 2.6176	* 2.1717	* 4.0614 *
9	* 0.8902	* 0.9677	* 1.0524	* 0.9674	* 1.1877	* 0.9977	* 1.0669	* 0.5429 *
	* 2.5802	* 2.3729	* 2.1836	* 2.3878	* 1.9513	* 2.3323	* 2.1894	* 4.3016 *
10	* 0.8688	* 1.0514	* 0.8869	* 1.1157	* 1.0042	* 1.1464	* 0.7558 *	
	* 2.6439	* 2.1855	* 2.5915	* 2.0688	* 2.3046	* 2.0297	* 3.0853 *	
11	* 1.1201	* 0.9615	* 1.1110	* 0.8977	* 1.0773	* 1.0781	* 0.5631 *	
	* 2.0610	* 2.4020	* 2.0773	* 2.5652	* 2.1461	* 2.1540	* 4.1276 *	
12	* 1.0353	* 1.1740	* 0.9978	* 1.0744	* 1.0507	* 0.6590 *		
	* 2.2429	* 1.9735	* 2.3191	* 2.1518	* 2.2024	* 3.5155 *		
13	* 0.8878	* 0.9867	* 1.1378	* 1.0732	* 0.6576 *			
	* 2.6176	* 2.3577	* 2.0445	* 2.1635	* 3.5226 *			
14	* 1.0757	* 1.0604	* 0.7497	* 0.5586 *				
	* 2.1717	* 2.2025	* 3.1099	* 4.1601 *				
15	* 0.5750	* 0.5330	* F-SUB-Q					
	* 4.0614	* 4.3809	* M-SUB-Q					

AT 50% POWER, 150 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4488	* 0.4004	* 0.4126	* 0.4933	* 0.4601	* 0.4109	* 0.4210	* 0.2551 *
	* 4.9927	* 5.5974	* 5.4353	* 4.5648	* 4.9093	* 5.5215	* 5.4084	* 8.9374 *
9	* 0.4004	* 0.4305	* 0.4703	* 0.4429	* 0.5032	* 0.4399	* 0.4121	* 0.2385 *
	* 5.5974	* 5.2035	* 4.7676	* 5.0865	* 4.4916	* 5.1579	* 5.5248	* 9.5602 *
10	* 0.4126	* 0.4699	* 0.4210	* 0.4907	* 0.4503	* 0.4668	* 0.3393 *	
	* 5.4353	* 4.7716	* 5.3323	* 4.5890	* 5.0146	* 4.8572	* 6.7053 *	
11	* 0.4933	* 0.4405	* 0.4887	* 0.4230	* 0.4694	* 0.4250	* 0.2516 *	
	* 4.5648	* 5.1141	* 4.6064	* 5.3163	* 4.8057	* 5.3252	* 9.0199 *	
12	* 0.4601	* 0.4986	* 0.4475	* 0.4681	* 0.4248	* 0.3039 *		
	* 4.9093	* 4.5321	* 5.0450	* 4.8183	* 5.3134	* 7.4416 *		
13	* 0.4109	* 0.4357	* 0.4634	* 0.4232	* 0.3032 *			
	* 5.5215	* 5.2063	* 4.8917	* 5.3479	* 7.4598 *			
14	* 0.4210	* 0.4097	* 0.3368	* 0.2497 *				
	* 5.4084	* 5.5563	* 6.7552	* 9.0873 *				
15	* 0.2551	* 0.2373	* F-SUB-Q					
	* 8.9374	* 9.6063	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 182 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5141	* 0.4703	* 0.4572	* 0.5368	* 0.4967	* 0.4142	* 0.3034	* 0.1583
	* 3.9501	* 4.3205	* 4.4591	* 3.7595	* 4.0574	* 4.8441	* 5.1408	* 8.2187
9	* 0.4703	* 0.4555	* 0.4933	* 0.4828	* 0.5339	* 0.4571	* 0.3600	* 0.1703
	* 4.3205	* 4.4573	* 4.1085	* 4.1757	* 3.7705	* 4.3886	* 5.3041	* 8.7706
10	* 0.4572	* 0.4931	* 0.3724	* 0.5120	* 0.4860	* 0.4954	* 0.3362	*
	* 4.4591	* 4.1096	* 4.7979	* 3.9184	* 4.1405	* 4.0551	* 5.9284	*
11	* 0.5368	* 0.4811	* 0.5110	* 0.4614	* 0.5184	* 0.4754	* 0.2845	*
	* 3.7595	* 4.1898	* 3.9262	* 4.3828	* 3.8920	* 4.2465	* 7.0301	*
12	* 0.4967	* 0.5311	* 0.4845	* 0.5178	* 0.4852	* 0.3528	*	*
	* 4.0574	* 3.7899	* 4.1530	* 3.8964	* 4.2022	* 5.7541	*	*
13	* 0.4142	* 0.4548	* 0.4936	* 0.4743	* 0.3512	*	*	*
	* 4.8441	* 4.4107	* 4.0697	* 4.2564	* 5.7791	*	*	*
14	* 0.3034	* 0.3584	* 0.3348	* 0.2831	*	*	*	*
	* 5.1408	* 5.3199	* 5.9532	* 7.0632	*	*	*	*
15	* 0.1583	* 0.1687	* F-SUB-Q					
	* 8.2187	* 8.8358	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0676	* 0.9163	* 0.8743	* 1.0778	* 0.9954	* 0.8040	* 0.6656	* 0.3233
	* 1.9784	* 2.3050	* 2.4055	* 1.9444	* 2.1075	* 2.5909	* 2.3647	* 4.1564
9	* 0.9163	* 0.9025	* 0.9819	* 0.9527	* 1.1191	* 0.9207	* 0.7946	* 0.3403
	* 2.3050	* 2.3293	* 2.1300	* 2.2016	* 1.8723	* 2.2683	* 2.4234	* 4.4921
10	* 0.8743	* 0.9816	* 0.7208	* 1.0290	* 0.9738	* 1.0612	* 0.6698	*
	* 2.4055	* 2.1306	* 2.5714	* 2.0263	* 2.1516	* 1.9712	* 3.0985	*
11	* 1.0778	* 0.9491	* 1.0268	* 0.8929	* 1.0489	* 1.0461	* 0.5663	*
	* 1.9444	* 2.2096	* 2.0306	* 2.3484	* 1.9973	* 2.0049	* 3.6787	*
12	* 0.9954	* 1.1127	* 0.9706	* 1.0475	* 1.0389	* 0.6811	*	*
	* 2.1075	* 1.8829	* 2.1585	* 1.9999	* 2.0282	* 3.0857	*	*
13	* 0.8040	* 0.9154	* 1.0572	* 1.0436	* 0.6791	*	*	*
	* 2.5909	* 2.2811	* 1.9784	* 2.0095	* 3.0949	*	*	*
14	* 0.6656	* 0.7910	* 0.6668	* 0.5636	*	*	*	*
	* 2.3647	* 2.4304	* 3.1123	* 3.6956	*	*	*	*
15	* 0.3233	* 0.3347	* F-SUB-Q					
	* 4.1564	* 4.5618	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 183 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2179	* 1.0648	* 1.0339	* 1.2581	* 1.1716	* 0.9673	* 0.8204	* 0.4035 *
	* 1.8011	* 2.0587	* 2.1056	* 1.7294	* 1.8590	* 2.2439	* 2.0025	* 3.4714 *
9	* 1.0648	* 1.0572	* 1.1348	* 1.1266	* 1.2894	* 1.0883	* 0.9663	* 0.4187 *
	* 2.0587	* 2.0628	* 1.9135	* 1.9331	* 1.6887	* 1.9918	* 2.0484	* 3.7457 *
10	* 1.0339	* 1.1345	* 0.8712	* 1.2081	* 1.1585	* 1.2574	* 0.8193	*
	* 2.1056	* 1.9141	* 2.2386	* 1.7932	* 1.8777	* 1.7275	* 2.6303	*
11	* 1.2581	* 1.1220	* 1.2049	* 1.0622	* 1.2241	* 1.2672	* 0.6956	*
	* 1.7294	* 1.9409	* 1.7978	* 2.0440	* 1.7754	* 1.7141	* 3.1077	*
12	* 1.1716	* 1.2805	* 1.1542	* 1.2214	* 1.2311	* 0.8307	*	
	* 1.8590	* 1.7006	* 1.8845	* 1.7792	* 1.7688	* 2.6157	*	
13	* 0.9673	* 1.0819	* 1.2530	* 1.2641	* 0.8289	*		
	* 2.2439	* 2.0041	* 1.7336	* 1.7181	* 2.6215	*		
14	* 0.8204	* 0.9617	* 0.8155	* 0.6923	*			
	* 2.0025	* 2.0547	* 2.6424	* 3.1222	*			
15	* 0.4035	* 0.4131	* F-SUB-Q					
	* 3.4714	* 3.7926	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4087	* 1.1831	* 1.1637	* 1.4759	* 1.3225	* 1.0687	* 0.9424	* 0.4514 *
	* 1.6356	* 1.9462	* 1.9657	* 1.5475	* 1.7280	* 2.1286	* 1.7892	* 3.2161 *
9	* 1.1831	* 1.1885	* 1.3346	* 1.2693	* 1.5100	* 1.2266	* 1.1184	* 0.4663 *
	* 1.9462	* 1.9282	* 1.7101	* 1.8012	* 1.5127	* 1.8528	* 1.8374	* 3.5299 *
10	* 1.1637	* 1.3342	* 0.9701	* 1.4128	* 1.3069	* 1.4643	* 0.9104	*
	* 1.9657	* 1.7106	* 2.0701	* 1.6092	* 1.7453	* 1.5537	* 2.4779	*
11	* 1.4759	* 1.2636	* 1.4088	* 1.2039	* 1.4406	* 1.4840	* 0.7619	*
	* 1.5475	* 1.8093	* 1.6137	* 1.8892	* 1.5791	* 1.5308	* 2.9730	*
12	* 1.3225	* 1.4986	* 1.3016	* 1.4372	* 1.4345	* 0.9167	*	
	* 1.7280	* 1.5243	* 1.7523	* 1.5827	* 1.5892	* 2.4801	*	
13	* 1.0687	* 1.2181	* 1.4591	* 1.4804	* 0.9152	*		
	* 2.1286	* 1.8655	* 1.5591	* 1.5344	* 2.4841	*		
14	* 0.9424	* 1.1129	* 0.9058	* 0.7581	*			
	* 1.7892	* 1.8432	* 2.4905	* 2.9879	*			
15	* 0.4514	* 0.4598	* F-SUB-Q					
	* 3.2161	* 3.5788	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 184 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4832	* 1.2283	* 1.2242	* 1.5717	* 1.3867	* 1.1253	* 0.9889	* 0.4772
	* 1.6635	* 2.0046	* 2.0038	* 1.5512	* 1.7543	* 2.1519	* 1.8103	* 3.2576
9	* 1.2283	* 1.2432	* 1.4260	* 1.3316	* 1.6081	* 1.2830	* 1.1741	* 0.4910
	* 2.0046	* 1.9408	* 1.7148	* 1.8324	* 1.5118	* 1.8788	* 1.8578	* 3.5581
10	* 1.2242	* 1.4256	* 1.0364	* 1.5081	* 1.3733	* 1.5542	* 0.9600	*
	* 2.0038	* 1.7155	* 2.0768	* 1.6071	* 1.7665	* 1.5508	* 2.4980	*
11	* 1.5717	* 1.3254	* 1.5038	* 1.2727	* 1.5428	* 1.5760	* 0.8072	*
	* 1.5512	* 1.8412	* 1.6118	* 1.9031	* 1.5654	* 1.5286	* 2.9733	*
12	* 1.3867	* 1.5952	* 1.3677	* 1.5393	* 1.5345	* 0.9782	*	
	* 1.7543	* 1.5214	* 1.7740	* 1.5691	* 1.5798	* 2.4706	*	
13	* 1.1253	* 1.2738	* 1.5488	* 1.5723	* 0.9768	*		
	* 2.1519	* 1.8925	* 1.5562	* 1.5322	* 2.4740	*		
14	* 0.9889	* 1.1682	* 0.9552	* 0.8035	*			
	* 1.8103	* 1.8637	* 2.5105	* 2.9870	*			
15	* 0.4772	* 0.4841	* F-SUB-Q					
	* 3.2576	* 3.6049	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5374	* 1.2682	* 1.2730	* 1.6439	* 1.4353	* 1.1683	* 1.0246	* 0.4993
	* 1.7527	* 2.1212	* 2.0971	* 1.6066	* 1.8370	* 2.2538	* 1.8914	* 3.4142
9	* 1.2682	* 1.2941	* 1.4966	* 1.3803	* 1.6807	* 1.3337	* 1.2144	* 0.5120
	* 2.1212	* 1.9804	* 1.7597	* 1.9164	* 1.5658	* 1.9646	* 1.9305	* 3.7079
10	* 1.2730	* 1.4961	* 1.0907	* 1.5816	* 1.4252	* 1.6205	* 0.9963	*
	* 2.0971	* 1.7603	* 2.1207	* 1.6607	* 1.8414	* 1.6018	* 2.6182	*
11	* 1.6439	* 1.3736	* 1.5769	* 1.3256	* 1.6168	* 1.6383	* 0.8404	*
	* 1.6066	* 1.9260	* 1.6659	* 1.9660	* 1.6056	* 1.5786	* 3.0791	*
12	* 1.4353	* 1.6681	* 1.4193	* 1.6140	* 1.6082	* 1.0285	*	
	* 1.8370	* 1.5749	* 1.8492	* 1.6094	* 1.6162	* 2.5176	*	
13	* 1.1683	* 1.3251	* 1.6148	* 1.6345	* 1.0270	*		
	* 2.2538	* 1.9775	* 1.6075	* 1.5823	* 2.5214	*		
14	* 1.0246	* 1.2083	* 0.9913	* 0.8366	*			
	* 1.8914	* 1.9369	* 2.6315	* 3.0933	*			
15	* 0.4993	* 0.5049	* F-SUB-Q					
	* 3.4142	* 3.7596	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 185 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6191	* 1.3241	* 1.3344	* 1.7410	* 1.4989	* 1.2100	* 1.0845	* 0.5317 *
	* 1.8445	* 2.2393	* 2.2102	* 1.6821	* 1.9499	* 2.3905	* 1.9543	* 3.5843 *
9	* 1.3241	* 1.3666	* 1.5978	* 1.4439	* 1.7814	* 1.3823	* 1.2797	* 0.5411 *
	* 2.2393	* 2.0151	* 1.7648	* 2.0331	* 1.6342	* 2.0974	* 1.9874	* 3.9092 *
10	* 1.3344	* 1.5973	* 1.1453	* 1.6840	* 1.4915	* 1.7088	* 1.0316	*
	* 2.2102	* 1.7655	* 2.1599	* 1.7168	* 1.9470	* 1.6694	* 2.7574	*
11	* 1.7410	* 1.4368	* 1.6790	* 1.3888	* 1.7151	* 1.7191	* 0.8626	*
	* 1.6821	* 2.0436	* 1.7216	* 2.0639	* 1.6635	* 1.6477	* 3.2991	*
12	* 1.4989	* 1.7691	* 1.4851	* 1.7121	* 1.7007	* 1.0587	*	
	* 1.9499	* 1.6441	* 1.9555	* 1.6675	* 1.6653	* 2.6721	*	
13	* 1.2100	* 1.3722	* 1.7029	* 1.7153	* 1.0577	*		
	* 2.3905	* 2.1130	* 1.6754	* 1.6515	* 2.6748	*		
14	* 1.0845	* 1.2734	* 1.0265	* 0.8589	*			
	* 1.9543	* 1.9940	* 2.7702	* 3.3137	*			
15	* 0.5317	* 0.5337	* F-SUB-Q					
	* 3.5843	* 3.9573	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6787	* 1.3741	* 1.3912	* 1.8126	* 1.5503	* 1.2576	* 1.1767	* 0.5967 *
	* 1.9542	* 2.3503	* 2.3097	* 1.7875	* 2.0900	* 2.5123	* 2.0658	* 3.7868 *
9	* 1.3741	* 1.4477	* 1.6894	* 1.4986	* 1.8562	* 1.4311	* 1.3467	* 0.5923 *
	* 2.3503	* 2.1061	* 1.8316	* 2.1336	* 1.7373	* 2.2286	* 2.1016	* 4.1206 *
10	* 1.3912	* 1.6890	* 1.2353	* 1.7706	* 1.5475	* 1.7679	* 1.0739	*
	* 2.3097	* 1.8323	* 2.2569	* 1.7803	* 2.0858	* 1.8088	* 2.8913	*
11	* 1.8126	* 1.4912	* 1.7655	* 1.4399	* 1.7866	* 1.7712	* 0.8876	*
	* 1.7875	* 2.1379	* 1.7851	* 2.2374	* 1.7931	* 1.7848	* 3.5936	*
12	* 1.5503	* 1.8451	* 1.5410	* 1.7836	* 1.7655	* 1.0926	*	
	* 2.0900	* 1.7475	* 2.0945	* 1.7974	* 1.7870	* 2.8806	*	
13	* 1.2576	* 1.4213	* 1.7618	* 1.7674	* 1.0918	*		
	* 2.5123	* 2.2457	* 1.8153	* 1.7888	* 2.8828	*		
14	* 1.1767	* 1.3402	* 1.0687	* 0.8839	*			
	* 2.0658	* 2.1086	* 2.9048	* 3.6094	*			
15	* 0.5967	* 0.5854	* F-SUB-Q					
	* 3.7868	* 4.1718	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 186 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7713	* 1.4440	* 1.4637	* 1.9160	* 1.6195	* 1.3080	* 1.3608	* 0.7151 *
	* 2.0525	* 2.4933	* 2.4478	* 1.8747	* 2.2153	* 2.6748	* 2.1690	* 4.0329 *
9	* 1.4440	* 1.5677	* 1.8251	* 1.5704	* 1.9677	* 1.4980	* 1.4585	* 0.6799 *
	* 2.4933	* 2.2221	* 1.9096	* 2.2570	* 1.8149	* 2.3615	* 2.2018	* 4.4194 *
10	* 1.4637	* 1.8248	* 1.3860	* 1.8980	* 1.6212	* 1.8546	* 1.1201	*
	* 2.4478	* 1.9103	* 2.3817	* 1.8628	* 2.2034	* 1.9214	* 3.0957	*
11	* 1.9160	* 1.5630	* 1.8928	* 1.5035	* 1.8865	* 1.8464	* 0.9056	*
	* 1.8747	* 2.2617	* 1.8678	* 2.3738	* 1.8949	* 1.9335	* 3.9336	*
12	* 1.6195	* 1.9563	* 1.6144	* 1.8836	* 1.8550	* 1.1155	*	
	* 2.2153	* 1.8258	* 2.2128	* 1.8979	* 1.9231	* 3.1841	*	
13	* 1.3080	* 1.4863	* 1.8484	* 1.8427	* 1.1150	*		
	* 2.6748	* 2.3799	* 1.9280	* 1.9375	* 3.1858	*		
14	* 1.3608	* 1.4532	* 1.1145	* 0.9013	*			
	* 2.1690	* 2.2091	* 3.1107	* 3.9524	*			
15	* 0.7151	* 0.6712	* F-SUB-Q					
	* 4.0329	* 4.4747	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7627	* 1.4800	* 1.4958	* 1.9123	* 1.6290	* 1.3569	* 1.5313	* 0.8248 *
	* 2.3043	* 2.7363	* 2.6979	* 2.0967	* 2.4558	* 2.9211	* 2.4362	* 4.4176 *
9	* 1.4800	* 1.6306	* 1.8551	* 1.5953	* 1.9650	* 1.5196	* 1.5304	* 0.7728 *
	* 2.7363	* 2.4484	* 2.1431	* 2.5004	* 2.0285	* 2.6159	* 2.4742	* 4.7566 *
10	* 1.4958	* 1.8544	* 1.5017	* 1.9145	* 1.6366	* 1.8371	* 1.1635	*
	* 2.6979	* 2.1439	* 2.6417	* 2.0787	* 2.4384	* 2.1534	* 3.3572	*
11	* 1.9123	* 1.5920	* 1.9094	* 1.5200	* 1.8760	* 1.8265	* 0.9364	*
	* 2.0967	* 2.5056	* 2.0843	* 2.6222	* 2.1228	* 2.1620	* 4.2190	*
12	* 1.6290	* 1.9535	* 1.6299	* 1.8731	* 1.8369	* 1.1519	*	
	* 2.4558	* 2.0407	* 2.4486	* 2.1261	* 2.1525	* 3.4290	*	
13	* 1.3569	* 1.5096	* 1.8310	* 1.8231	* 1.1509	*		
	* 2.9211	* 2.6333	* 2.1615	* 2.1664	* 3.4323	*		
14	* 1.5313	* 1.5252	* 1.1581	* 0.9325	*			
	* 2.4362	* 2.4823	* 3.3726	* 4.2368	*			
15	* 0.8248	* 0.7626	* F-SUB-Q					
	* 4.4176	* 4.8190	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 187 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8607	* 1.5208	* 1.5469	* 2.0180	* 1.6911	* 1.3832	* 1.6553	* 0.8807 *
	* 2.3559	* 2.8772	* 2.8248	* 2.1673	* 2.5909	* 3.1690	* 2.6103	* 4.8497 *
9	* 1.5208	* 1.7072	* 1.9890	* 1.6698	* 2.0783	* 1.5681	* 1.6393	* 0.8092 *
	* 2.8772	* 2.5537	* 2.1905	* 2.6154	* 2.1081	* 2.7992	* 2.6454	* 5.2923 *
10	* 1.5469	* 1.9883	* 1.5815	* 2.0302	* 1.6984	* 1.9323	* 1.1869	*
	* 2.8248	* 2.1912	* 2.7586	* 2.1542	* 2.5841	* 2.2766	* 3.7023	*
11	* 2.0180	* 1.6664	* 2.0249	* 1.5854	* 1.9774	* 1.9082	* 0.9372	*
	* 2.1673	* 2.6208	* 2.1600	* 2.7632	* 2.2258	* 2.3057	* 4.7051	*
12	* 1.6911	* 2.0668	* 1.6914	* 1.9747	* 1.9332	* 1.1538	*	
	* 2.5909	* 2.1201	* 2.5951	* 2.2291	* 2.2785	* 3.8158	*	
13	* 1.3832	* 1.5559	* 1.9252	* 1.9049	* 1.1536	*		
	* 3.1690	* 2.8215	* 2.2873	* 2.3099	* 3.8167	*		
14	* 1.6553	* 1.6340	* 1.1816	* 0.9336	*			
	* 2.6103	* 2.6539	* 3.7194	* 4.7234	*			
15	* 0.8807	* 0.7996	* F-SUB-Q					
	* 4.8497	* 5.3552	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8779	* 1.5375	* 1.5625	* 2.0392	* 1.7032	* 1.3974	* 1.6832	* 0.9009 *
	* 2.3846	* 2.9095	* 2.8586	* 2.1912	* 2.6283	* 3.2132	* 2.6762	* 5.0075 *
9	* 1.5375	* 1.7364	* 2.0201	* 1.6882	* 2.1001	* 1.5786	* 1.6628	* 0.8301 *
	* 2.9095	* 2.5749	* 2.2107	* 2.6470	* 2.1315	* 2.8441	* 2.7074	* 5.4359 *
10	* 1.5625	* 2.0194	* 1.6033	* 2.0548	* 1.7110	* 1.9485	* 1.1991	*
	* 2.8586	* 2.2115	* 2.7904	* 2.1751	* 2.6165	* 2.3046	* 3.7593	*
11	* 2.0392	* 1.6848	* 2.0496	* 1.6019	* 1.9966	* 1.9191	* 0.9446	*
	* 2.1912	* 2.6524	* 2.1808	* 2.7915	* 2.2432	* 2.3427	* 4.7801	*
12	* 1.7032	* 2.0885	* 1.7040	* 1.9939	* 1.9512	* 1.1643	*	
	* 2.6283	* 2.1436	* 2.6275	* 2.2464	* 2.3015	* 3.8702	*	
13	* 1.3974	* 1.5664	* 1.9403	* 1.9159	* 1.1642	*		
	* 3.2132	* 2.8668	* 2.3153	* 2.3468	* 3.8709	*		
14	* 1.6832	* 1.6575	* 1.1938	* 0.9411	*			
	* 2.6762	* 2.7164	* 3.7765	* 4.7986	*			
15	* 0.9009	* 0.8207	* F-SUB-Q					
	* 5.0075	* 5.4976	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 188 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8346	* 1.5382	* 1.5516	* 1.9965	* 1.6760	* 1.3960	* 1.6521	* 0.8992
	* 2.4728	* 2.9465	* 2.9180	* 2.2670	* 2.7050	* 3.2624	* 2.7879	* 5.1456
9	* 1.5382	* 1.7299	* 1.9806	* 1.6655	* 2.0571	* 1.5598	* 1.6310	* 0.8379
	* 2.9466	* 2.6208	* 2.2859	* 2.7170	* 2.2033	* 2.9151	* 2.8178	* 5.5176
10	* 1.5516	* 1.9800	* 1.5827	* 2.0133	* 1.6857	* 1.9062	* 1.1982	*
	* 2.9180	* 2.2867	* 2.8625	* 2.2466	* 2.6845	* 2.3827	* 3.8179	*
11	* 1.9965	* 1.6621	* 2.0082	* 1.5815	* 1.9550	* 1.8791	* 0.9506	*
	* 2.2670	* 2.7227	* 2.2524	* 2.8580	* 2.3104	* 2.4116	* 4.7887	*
12	* 1.6760	* 2.0451	* 1.6789	* 1.9525	* 1.9109	* 1.1752	*	*
	* 2.7050	* 2.2163	* 2.6957	* 2.3136	* 2.3650	* 3.8533	*	*
13	* 1.3960	* 1.5496	* 1.8984	* 1.8762	* 1.1746	*	*	*
	* 3.2624	* 2.9347	* 2.3902	* 2.4155	* 3.8555	*	*	*
14	* 1.6521	* 1.6258	* 1.1929	* 0.9469	*	*	*	*
	* 2.7879	* 2.8270	* 3.8352	* 4.8079	*	*	*	*
15	* 0.8992	* 0.8269	* F-SUB-Q					
	* 5.1456	* 5.5909	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8738	* 1.5215	* 1.5510	* 2.0397	* 1.6878	* 1.3733	* 1.6794	* 0.8936
	* 2.3942	* 2.9437	* 2.8843	* 2.2027	* 2.6614	* 3.2782	* 2.7090	* 5.0829
9	* 1.5215	* 1.7304	* 2.0286	* 1.6758	* 2.1040	* 1.5633	* 1.6589	* 0.8206
	* 2.9437	* 2.5954	* 2.2145	* 2.6750	* 2.1386	* 2.8789	* 2.7385	* 5.5316
10	* 1.5510	* 2.0279	* 1.5936	* 2.0587	* 1.6964	* 1.9499	* 1.1799	*
	* 2.8843	* 2.2152	* 2.8120	* 2.1807	* 2.6417	* 2.3041	* 3.8248	*
11	* 2.0397	* 1.6726	* 2.0539	* 1.5916	* 2.0027	* 1.9189	* 0.9288	*
	* 2.2027	* 2.6800	* 2.1857	* 2.8070	* 2.2340	* 2.3371	* 4.8160	*
12	* 1.6878	* 2.0925	* 1.6895	* 2.0002	* 1.9661	* 1.1542	*	*
	* 2.6614	* 2.1500	* 2.6521	* 2.2363	* 2.2732	* 3.8615	*	*
13	* 1.3733	* 1.5510	* 1.9443	* 1.9162	* 1.1541	*	*	*
	* 3.2782	* 2.9014	* 2.3106	* 2.3403	* 3.8618	*	*	*
14	* 1.6794	* 1.6537	* 1.1746	* 0.9255	*	*	*	*
	* 2.7090	* 2.7470	* 3.8418	* 4.8327	*	*	*	*
15	* 0.8936	* 0.8108	* F-SUB-Q					
	* 5.0829	* 5.5979	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 189 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8611	* 1.5006	* 1.5351	* 2.0298	* 1.6696	* 1.3484	* 1.6656	* 0.8807 *
	* 2.2135	* 2.7381	* 2.6792	* 2.0433	* 2.4806	* 3.0644	* 2.5001	* 4.6918 *
9	* 1.5006	* 1.7136	* 2.0216	* 1.6581	* 2.0955	* 1.5464	* 1.6460	* 0.8072 *
	* 2.7381	* 2.4078	* 2.0464	* 2.4898	* 1.9847	* 2.6807	* 2.5284	* 5.1169 *
10	* 1.5351	* 2.0210	* 1.5777	* 2.0501	* 1.6787	* 1.9444	* 1.1605	*
	* 2.6792	* 2.0470	* 2.6110	* 2.0237	* 2.4656	* 2.1350	* 3.5654	*
11	* 2.0298	* 1.6550	* 2.0454	* 1.5766	* 1.9981	* 1.9123	* 0.9132	*
	* 2.0433	* 2.4940	* 2.0279	* 2.6142	* 2.0702	* 2.1669	* 4.4919	*
12	* 1.6696	* 2.0841	* 1.6719	* 1.9957	* 1.9677	* 1.1395	*	*
	* 2.4806	* 1.9947	* 2.4748	* 2.0720	* 2.0985	* 3.5964	*	*
13	* 1.3484	* 1.5340	* 1.9389	* 1.9099	* 1.1397	*	*	*
	* 3.0644	* 2.7010	* 2.1404	* 2.1693	* 3.5955	*	*	*
14	* 1.6656	* 1.6409	* 1.1553	* 0.9092	*	*	*	*
	* 2.5001	* 2.5357	* 3.5804	* 4.5101	*	*	*	*
15	* 0.8807	* 0.7955	* F-SUB-Q					
	* 4.6918	* 5.1896	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8212	* 1.4769	* 1.5042	* 1.9896	* 1.6361	* 1.3283	* 1.6321	* 0.8647 *
	* 2.0341	* 2.5018	* 2.4575	* 1.8741	* 2.2770	* 2.8025	* 2.3025	* 4.3177 *
9	* 1.4769	* 1.6864	* 1.9812	* 1.6252	* 2.0548	* 1.5146	* 1.6129	* 0.7953 *
	* 2.5018	* 2.1993	* 1.8767	* 2.2832	* 1.8204	* 2.4632	* 2.3275	* 4.6916 *
10	* 1.5042	* 1.9805	* 1.5456	* 2.0101	* 1.6459	* 1.9072	* 1.1420	*
	* 2.4575	* 1.8772	* 2.3950	* 1.8549	* 2.2610	* 1.9605	* 3.2637	*
11	* 1.9896	* 1.6222	* 2.0054	* 1.5458	* 1.9600	* 1.8768	* 0.9011	*
	* 1.8741	* 2.2871	* 1.8589	* 2.3953	* 1.9001	* 1.9882	* 4.1052	*
12	* 1.6361	* 2.0435	* 1.6392	* 1.9578	* 1.9316	* 1.1267	*	*
	* 2.2770	* 1.8298	* 2.2696	* 1.9018	* 1.9233	* 3.2710	*	*
13	* 1.3283	* 1.5024	* 1.9019	* 1.8745	* 1.1268	*	*	*
	* 2.8025	* 2.4821	* 1.9655	* 1.9903	* 3.2704	*	*	*
14	* 1.6321	* 1.6080	* 1.1369	* 0.8981	*	*	*	*
	* 2.3025	* 2.3343	* 3.2776	* 4.1184	*	*	*	*
15	* 0.8647	* 0.7857	* F-SUB-Q					
	* 4.3177	* 4.7470	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 190 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7386	* 1.4518	* 1.4653	* 1.9073	* 1.5805	* 1.3093	* 1.5684	* 0.8461 *
	* 1.9224	* 2.2971	* 2.2811	* 1.7623	* 2.1256	* 2.5674	* 2.1708	* 4.0079 *
9	* 1.4518	* 1.6468	* 1.8967	* 1.5719	* 1.9696	* 1.4737	* 1.5495	* 0.7904 *
	* 2.2971	* 2.0331	* 1.7687	* 2.1297	* 1.7118	* 2.2845	* 2.1931	* 4.2852 *
10	* 1.4653	* 1.8960	* 1.4943	* 1.9273	* 1.5923	* 1.8284	* 1.1252	*
	* 2.2811	* 1.7693	* 2.2357	* 1.7435	* 2.1061	* 1.8359	* 2.9909	*
11	* 1.9073	* 1.5688	* 1.9224	* 1.4976	* 1.8794	* 1.8039	* 0.8955	*
	* 1.7623	* 2.1336	* 1.7476	* 2.2305	* 1.7783	* 1.8531	* 3.7060	*
12	* 1.5805	* 1.9583	* 1.5857	* 1.8773	* 1.8504	* 1.1202	*	
	* 2.1256	* 1.7210	* 2.1143	* 1.7798	* 1.7980	* 2.9466	*	
13	* 1.3093	* 1.4637	* 1.8232	* 1.8016	* 1.1200	*		
	* 2.5674	* 2.2992	* 1.8407	* 1.8552	* 2.9468	*		
14	* 1.5684	* 1.5447	* 1.1203	* 0.8923	*			
	* 2.1708	* 2.1997	* 3.0033	* 3.7187	*			
15	* 0.8461	* 0.7795	* F-SUB-Q					
	* 4.0079	* 4.3434	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7537	* 1.4127	* 1.4431	* 1.9260	* 1.5722	* 1.2666	* 1.5827	* 0.8298 *
	* 1.7192	* 2.1301	* 2.0832	* 1.5729	* 1.9258	* 2.3932	* 1.9433	* 3.6953 *
9	* 1.4127	* 1.6208	* 1.9176	* 1.5595	* 1.9911	* 1.4563	* 1.5642	* 0.7618 *
	* 2.1301	* 1.8638	* 1.5779	* 1.9355	* 1.5262	* 2.0827	* 1.9613	* 4.0203 *
10	* 1.4431	* 1.9168	* 1.4830	* 1.9469	* 1.5815	* 1.8525	* 1.0913	*
	* 2.0832	* 1.5785	* 2.0320	* 1.5554	* 1.9102	* 1.6356	* 2.7807	*
11	* 1.9260	* 1.5564	* 1.9421	* 1.4853	* 1.9019	* 1.8238	* 0.8596	*
	* 1.5729	* 1.9392	* 1.5591	* 2.0242	* 1.5857	* 1.6579	* 3.4896	*
12	* 1.5722	* 1.9793	* 1.5747	* 1.8998	* 1.8793	* 1.0787	*	
	* 1.9258	* 1.5346	* 1.9180	* 1.5872	* 1.6028	* 2.7749	*	
13	* 1.2666	* 1.4440	* 1.8471	* 1.8215	* 1.0790	*		
	* 2.3932	* 2.0996	* 1.6400	* 1.6597	* 2.7739	*		
14	* 1.5827	* 1.5593	* 1.0862	* 0.8561	*			
	* 1.9433	* 1.9673	* 2.7931	* 3.5036	*			
15	* 0.8298	* 0.7506	* F-SUB-Q					
	* 3.6953	* 4.0788	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 191 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6935	* 1.3656	* 1.3956	* 1.8656	* 1.5234	* 1.2269	* 1.5437	* 0.8081
	* 1.6335	* 2.0209	* 1.9762	* 1.4897	* 1.8247	* 2.2661	* 1.8149	* 3.4504
9	* 1.3656	* 1.5690	* 1.8549	* 1.5087	* 1.9301	* 1.4129	* 1.5251	* 0.7426
	* 2.0209	* 1.7633	* 1.4940	* 1.8347	* 1.4451	* 1.9703	* 1.8356	* 3.7542
10	* 1.3956	* 1.8541	* 1.4339	* 1.8861	* 1.5322	* 1.7986	* 1.0594	*
	* 1.9762	* 1.4947	* 1.9253	* 1.4733	* 1.8120	* 1.5494	* 2.6268	*
11	* 1.8656	* 1.5055	* 1.8808	* 1.4371	* 1.8431	* 1.7737	* 0.8331	*
	* 1.4897	* 1.8384	* 1.4771	* 1.9216	* 1.5061	* 1.5700	* 3.3177	*
12	* 1.5234	* 1.9181	* 1.5253	* 1.8408	* 1.8217	* 1.0463	*	*
	* 1.8247	* 1.4537	* 1.8197	* 1.5076	* 1.5244	* 2.6409	*	*
13	* 1.2269	* 1.4006	* 1.7932	* 1.7713	* 1.0467	*	*	*
	* 2.2661	* 1.9868	* 1.5538	* 1.5719	* 2.6400	*	*	*
14	* 1.5437	* 1.5200	* 1.0544	* 0.8296	*	*	*	*
	* 1.8149	* 1.8415	* 2.6389	* 3.3311	*	*	*	*
15	* 0.8081	* 0.7307	* F-SUB-Q					
	* 3.4504	* 3.8133	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6058	* 1.3094	* 1.3322	* 1.7707	* 1.4576	* 1.1804	* 1.4860	* 0.7813
	* 1.6105	* 1.9710	* 1.9370	* 1.4675	* 1.7839	* 2.2033	* 1.7583	* 3.3290
9	* 1.3094	* 1.4973	* 1.7525	* 1.4404	* 1.8293	* 1.3549	* 1.4664	* 0.7315
	* 1.9710	* 1.7275	* 1.4780	* 1.7983	* 1.4257	* 1.9225	* 1.7815	* 3.5558
10	* 1.3322	* 1.7516	* 1.3679	* 1.7886	* 1.4649	* 1.7071	* 1.0206	*
	* 1.9370	* 1.4788	* 1.8885	* 1.4532	* 1.7742	* 1.5287	* 2.5513	*
11	* 1.7707	* 1.4369	* 1.7833	* 1.3709	* 1.7450	* 1.6888	* 0.7994	*
	* 1.4675	* 1.8023	* 1.4572	* 1.8865	* 1.4896	* 1.5445	* 3.2431	*
12	* 1.4576	* 1.8165	* 1.4581	* 1.7426	* 1.7169	* 1.0104	*	*
	* 1.7839	* 1.4353	* 1.7821	* 1.4916	* 1.5164	* 2.5671	*	*
13	* 1.1804	* 1.3428	* 1.7015	* 1.6864	* 1.0107	*	*	*
	* 2.2033	* 1.9392	* 1.5335	* 1.5466	* 2.5662	*	*	*
14	* 1.4860	* 1.4612	* 1.0156	* 0.7960	*	*	*	*
	* 1.7583	* 1.7877	* 2.5634	* 3.2565	*	*	*	*
15	* 0.7813	* 0.7074	* F-SUB-Q					
	* 3.3290	* 3.6756	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 192 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4754	* 1.2343	* 1.2426	* 1.6223	* 1.3625	* 1.1158	* 1.3899	* 0.7390 *
	* 1.6663	* 1.9881	* 1.9754	* 1.5220	* 1.8143	* 2.2175	* 1.7860	* 3.3468 *
9	* 1.2343	* 1.3972	* 1.5918	* 1.3435	* 1.6684	* 1.2703	* 1.3695	* 0.6891 *
	* 1.9881	* 1.7592	* 1.5461	* 1.8333	* 1.4853	* 1.9505	* 1.8125	* 3.5886 *
10	* 1.2426	* 1.5908	* 1.2740	* 1.6350	* 1.3673	* 1.5616	* 0.9642	*
	* 1.9754	* 1.5470	* 1.9285	* 1.5106	* 1.8082	* 1.5898	* 2.5696	*
11	* 1.6223	* 1.3401	* 1.6295	* 1.2753	* 1.5865	* 1.5526	* 0.7511	*
	* 1.5220	* 1.8377	* 1.5153	* 1.9299	* 1.5585	* 1.5978	* 3.2885	*
12	* 1.3625	* 1.6562	* 1.3608	* 1.5839	* 1.5791	* 0.9387	*	
	* 1.8143	* 1.4959	* 1.8165	* 1.5609	* 1.5676	* 2.6311	*	
13	* 1.1158	* 1.2590	* 1.5536	* 1.5500	* 0.9388	*		
	* 2.2175	* 1.9675	* 1.5975	* 1.6003	* 2.6309	*		
14	* 1.3899	* 1.3643	* 0.9592	* 0.7477	*			
	* 1.7860	* 1.8190	* 2.5824	* 3.3030	*			
15	* 0.7390	* 0.6710	* F-SUB-Q					
	* 3.3468	* 3.6851	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3165	* 1.1176	* 1.1174	* 1.4241	* 1.2306	* 1.0108	* 1.2446	* 0.6641
	* 1.7994	* 2.1165	* 2.1161	* 1.6693	* 1.9349	* 2.3556	* 1.9214	* 3.5926
9	* 1.1176	* 1.2501	* 1.3920	* 1.2092	* 1.4643	* 1.1498	* 1.2238	* 0.6224
	* 2.1165	* 1.8934	* 1.7017	* 1.9617	* 1.6289	* 2.0764	* 1.9540	* 3.8340
10	* 1.1174	* 1.3917	* 1.1426	* 1.4311	* 1.2309	* 1.3728	* 0.8706	*
	* 2.1161	* 1.7021	* 2.0711	* 1.6615	* 1.9345	* 1.7416	* 2.7444	*
11	* 1.4241	* 1.2064	* 1.4263	* 1.1414	* 1.3800	* 1.3665	* 0.6780	*
	* 1.6693	* 1.9662	* 1.6669	* 2.0774	* 1.7255	* 1.7479	* 3.5159	*
12	* 1.2306	* 1.4541	* 1.2253	* 1.3777	* 1.3840	* 0.8376	*	
	* 1.9349	* 1.6401	* 1.9431	* 1.7283	* 1.7223	* 2.8437	*	
13	* 1.0108	* 1.1399	* 1.3658	* 1.3640	* 0.8374	*		
	* 2.3556	* 2.0940	* 1.7500	* 1.7509	* 2.8444	*		
14	* 1.2446	* 1.2192	* 0.8661	* 0.6747	*			
	* 1.9214	* 1.9611	* 2.7581	* 3.5327	*			
15	* 0.6641	* 0.6071	* F-SUB-Q					
	* 3.5926	* 3.9302	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 193 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 275 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0830	* 0.9120	* 0.8988	* 1.1259	* 0.9981	* 0.8192	* 0.9668	* 0.5224 *
	* 2.1276	* 2.5238	* 2.5608	* 2.0532	* 2.3215	* 2.8351	* 2.4084	* 4.4538 *
9	* 0.9120	* 1.0089	* 1.1118	* 0.9746	* 1.1714	* 0.9298	* 0.9545	* 0.4943 *
	* 2.5238	* 2.2827	* 2.0720	* 2.3680	* 1.9794	* 2.4996	* 2.4397	* 4.7082 *
10	* 0.8988	* 1.1114	* 0.9168	* 1.1299	* 0.9886	* 1.0896	* 0.6940	*
	* 2.5608	* 2.0727	* 2.5122	* 2.0459	* 2.3435	* 2.1345	* 3.3531	*
11	* 1.1259	* 0.9726	* 1.1270	* 0.9130	* 1.0890	* 1.0586	* 0.5478	*
	* 2.0532	* 2.3728	* 2.0510	* 2.5277	* 2.1263	* 2.1952	* 4.2420	*
12	* 0.9981	* 1.1651	* 0.9845	* 1.0876	* 1.0682	* 0.6708	*	
	* 2.3215	* 1.9898	* 2.3529	* 2.1289	* 2.1707	* 3.4597	*	
13	* 0.8192	* 0.9225	* 1.0850	* 1.0566	* 0.6704	*		
	* 2.8351	* 2.5189	* 2.1433	* 2.1990	* 3.4619	*		
14	* 0.9668	* 0.9509	* 0.6907	* 0.5451	*			
	* 2.4084	* 2.4486	* 3.3688	* 4.2628	*			
15	* 0.5224	* 0.4855	* F-SUB-Q					
	* 4.4538	* 4.7924	* M-SUB-Q					

AT 50% POWER, 275 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4693	* 0.4210	* 0.4328	* 0.5030	* 0.4567	* 0.3917	* 0.3925	* 0.2378 *
	* 4.7882	* 5.3379	* 5.1939	* 4.4800	* 4.9488	* 5.7861	* 5.7895	* 9.5596 *
9	* 0.4210	* 0.4560	* 0.4967	* 0.4516	* 0.4989	* 0.4236	* 0.3862	* 0.2231 *
	* 5.3379	* 4.9273	* 4.5273	* 4.9863	* 4.5314	* 5.3532	* 5.8843	* 10.1939 *
10	* 0.4328	* 0.4966	* 0.4410	* 0.5035	* 0.4524	* 0.4566	* 0.3206	*
	* 5.1939	* 4.5258	* 5.0996	* 4.4763	* 4.9955	* 4.9679	* 7.0890	*
11	* 0.5030	* 0.4508	* 0.5028	* 0.4373	* 0.4804	* 0.4304	* 0.2495	*
	* 4.4800	* 4.9948	* 4.4823	* 5.1535	* 4.7053	* 5.2668	* 9.1004	*
12	* 0.4567	* 0.4964	* 0.4507	* 0.4798	* 0.4419	* 0.3116	*	
	* 4.9488	* 4.5537	* 5.0136	* 4.7112	* 5.1199	* 7.2741	*	
13	* 0.3917	* 0.4208	* 0.4546	* 0.4295	* 0.3112	*		
	* 5.7861	* 5.3887	* 4.9887	* 5.2772	* 7.2823	*		
14	* 0.3925	* 0.3847	* 0.3192	* 0.2482	*			
	* 5.7895	* 5.9075	* 7.1206	* 9.1460	*			
15	* 0.2378	* 0.2221	* F-SUB-Q					
	* 9.5596	* 10.2389	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 194 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7444	* 0.6771	* 0.6075	* 0.8054	* 0.7549	* 0.6341	* 0.4696	* 0.2489
	* 3.6235	* 3.9412	* 3.9787	* 3.4059	* 3.6870	* 4.4246	* 5.1053	* 8.1770
9	* 0.6771	* 0.6576	* 0.7041	* 0.7314	* 0.8151	* 0.7028	* 0.5607	* 0.2689
	* 3.9412	* 4.0447	* 3.6755	* 3.7731	* 3.4221	* 3.9946	* 4.9948	* 8.6960
10	* 0.6075	* 0.7038	* 0.5680	* 0.7896	* 0.7492	* 0.7643	* 0.5186	*
	* 3.9787	* 3.6761	* 4.5545	* 3.5181	* 3.7264	* 3.6662	* 5.4055	*
11	* 0.8054	* 0.7292	* 0.7883	* 0.7041	* 0.7909	* 0.7277	* 0.4439	*
	* 3.4059	* 3.7841	* 3.5235	* 3.8656	* 3.4622	* 3.7737	* 6.2648	*
12	* 0.7549	* 0.8125	* 0.7474	* 0.7902	* 0.6762	* 0.4969	*	*
	* 3.6870	* 3.4379	* 3.7353	* 3.4648	* 3.6600	* 5.0521	*	*
13	* 0.6341	* 0.6998	* 0.7620	* 0.7264	* 0.4948	*	*	*
	* 4.4246	* 4.0112	* 3.6762	* 3.7797	* 5.0727	*	*	*
14	* 0.4696	* 0.5587	* 0.5169	* 0.4422	*	*	*	*
	* 5.1053	* 5.0119	* 5.4224	* 6.2879	*	*	*	*
15	* 0.2489	* 0.2666	* F-SUB-Q					
	* 8.1770	* 8.7596	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4919	* 1.2688	* 1.1828	* 1.5639	* 1.4396	* 1.1637	* 0.9620	* 0.4778
	* 1.8772	* 2.2002	* 2.2450	* 1.8170	* 1.9926	* 2.4741	* 2.4844	* 4.3234
9	* 1.2688	* 1.2596	* 1.4063	* 1.3787	* 1.6373	* 1.3385	* 1.1543	* 0.5066
	* 2.2002	* 2.1992	* 1.9678	* 2.0687	* 1.7532	* 2.1527	* 2.4866	* 4.6566
10	* 1.1828	* 1.4059	* 1.0581	* 1.5233	* 1.4259	* 1.5565	* 0.9767	*
	* 2.2450	* 1.9681	* 2.5285	* 1.8754	* 2.0140	* 1.8427	* 2.9440	*
11	* 1.5639	* 1.3743	* 1.5207	* 1.3119	* 1.5533	* 1.5283	* 0.8417	*
	* 1.8170	* 2.0751	* 1.8783	* 2.1457	* 1.8276	* 1.8614	* 3.4001	*
12	* 1.4396	* 1.6318	* 1.4221	* 1.5518	* 1.4597	* 0.9796	*	*
	* 1.9926	* 1.7600	* 2.0188	* 1.8291	* 1.8314	* 2.8003	*	*
13	* 1.1637	* 1.3321	* 1.5531	* 1.5258	* 0.9770	*	*	*
	* 2.4741	* 2.1627	* 1.8464	* 1.8641	* 2.8074	*	*	*
14	* 0.9620	* 1.1503	* 0.9733	* 0.8386	*	*	*	*
	* 2.4844	* 2.4949	* 2.9538	* 3.4121	*	*	*	*
15	* 0.4778	* 0.4987	* F-SUB-Q					
	* 4.3234	* 4.7260	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 195 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7285	* 1.4493	* 1.4526	* 1.8455	* 1.6522	* 1.3621	* 1.1358	* 0.5702
	* 1.6745	* 1.9959	* 1.9907	* 1.5845	* 1.7794	* 2.1645	* 2.1503	* 3.6914
9	* 1.4493	* 1.4592	* 1.6766	* 1.5966	* 1.9043	* 1.5436	* 1.3501	* 0.5966
	* 1.9959	* 1.9768	* 1.7235	* 1.8355	* 1.5439	* 1.9104	* 2.1694	* 3.9590
10	* 1.4526	* 1.6761	* 1.2628	* 1.7911	* 1.6530	* 1.8206	* 1.1566	*
	* 1.9907	* 1.7238	* 2.2165	* 1.6344	* 1.7786	* 1.6133	* 2.5415	*
11	* 1.8455	* 1.5912	* 1.7878	* 1.5499	* 1.8389	* 1.8151	* 1.0064	*
	* 1.5845	* 1.8416	* 1.6372	* 1.8811	* 1.5898	* 1.6121	* 2.9145	*
12	* 1.6522	* 1.8971	* 1.6485	* 1.8370	* 1.8088	* 1.2165	*	*
	* 1.7794	* 1.5495	* 1.7830	* 1.5913	* 1.6023	* 2.3854	*	*
13	* 1.3621	* 1.5371	* 1.8164	* 1.8123	* 1.2145	*	*	*
	* 2.1645	* 1.9182	* 1.6168	* 1.6143	* 2.3892	*	*	*
14	* 1.1358	* 1.3454	* 1.1527	* 1.0028	*	*	*	*
	* 2.1503	* 2.1769	* 2.5498	* 2.9246	*	*	*	*
15	* 0.5702	* 0.5886	* F-SUB-Q					
	* 3.6914	* 4.0075	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9350	* 1.5578	* 1.5774	* 2.0609	* 1.7882	* 1.4426	* 1.2378	* 0.6057
	* 1.5484	* 1.9219	* 1.9016	* 1.4616	* 1.6899	* 2.0936	* 1.9745	* 3.4857
9	* 1.5578	* 1.5872	* 1.8893	* 1.7269	* 2.1446	* 1.6615	* 1.4863	* 0.6325
	* 1.9219	* 1.8826	* 1.5843	* 1.7470	* 1.4079	* 1.8155	* 2.0034	* 3.8033
10	* 1.5774	* 1.8889	* 1.3462	* 2.0087	* 1.7948	* 2.0681	* 1.2323	*
	* 1.9016	* 1.5846	* 2.0771	* 1.4978	* 1.6824	* 1.4584	* 2.4385	*
11	* 2.0609	* 1.7210	* 2.0066	* 1.7053	* 2.0995	* 2.0480	* 1.0611	*
	* 1.4616	* 1.7530	* 1.4992	* 1.7649	* 1.4320	* 1.4704	* 2.8416	*
12	* 1.7882	* 2.1370	* 1.7901	* 2.0987	* 2.1045	* 1.3111	*	*
	* 1.6899	* 1.4128	* 1.6867	* 1.4325	* 1.4260	* 2.2932	*	*
13	* 1.4426	* 1.6527	* 2.0639	* 2.0453	* 1.3098	*	*	*
	* 2.0936	* 1.8251	* 1.4612	* 1.4722	* 2.2953	*	*	*
14	* 1.2378	* 1.4813	* 1.2278	* 1.0579	*	*	*	*
	* 1.9745	* 2.0079	* 2.4472	* 2.8499	*	*	*	*
15	* 0.6057	* 0.6232	* F-SUB-Q					
	* 3.4857	* 3.8477	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 196 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9379	* 1.5387	* 1.5665	* 2.0540	* 1.7713	* 1.4403	* 1.2282	* 0.6026 *
	* 1.6089	* 2.0273	* 1.9924	* 1.5153	* 1.7564	* 2.1569	* 1.9816	* 3.5294 *
9	* 1.5387	* 1.5757	* 1.8859	* 1.7107	* 2.1490	* 1.6552	* 1.4852	* 0.6275 *
	* 2.0273	* 1.9347	* 1.6507	* 1.8214	* 1.4457	* 1.8777	* 2.0036	* 3.8198 *
10	* 1.5665	* 1.8857	* 1.3542	* 2.0138	* 1.7846	* 2.0869	* 1.2334	*
	* 1.9924	* 1.6509	* 2.0533	* 1.5423	* 1.7432	* 1.4860	* 2.5065	*
11	* 2.0540	* 1.7048	* 2.0120	* 1.7132	* 2.1367	* 2.0667	* 1.0732	*
	* 1.5153	* 1.8276	* 1.5436	* 1.8175	* 1.4558	* 1.5019	* 2.8875	*
12	* 1.7713	* 2.1420	* 1.7815	* 2.1361	* 2.1565	* 1.3420	*	
	* 1.7564	* 1.4503	* 1.7462	* 1.4562	* 1.4421	* 2.3217	*	
13	* 1.4403	* 1.6480	* 2.0832	* 2.0645	* 1.3408	*		
	* 2.1569	* 1.8858	* 1.4885	* 1.5035	* 2.3236	*		
14	* 1.2282	* 1.4807	* 1.2295	* 1.0700	*			
	* 1.9816	* 2.0082	* 2.5145	* 2.8960	*			
15	* 0.6026	* 0.6182	* F-SUB-Q					
	* 3.5294	* 3.8689	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8784	* 1.4823	* 1.5115	* 1.9852	* 1.7075	* 1.3976	* 1.1862	* 0.5824 *
	* 1.7350	* 2.1972	* 2.1461	* 1.6257	* 1.8903	* 2.3095	* 2.0470	* 3.6200 *
9	* 1.4823	* 1.5207	* 1.8237	* 1.6483	* 2.0831	* 1.6120	* 1.4425	* 0.6067 *
	* 2.1972	* 2.0008	* 1.7320	* 1.9609	* 1.5461	* 1.9994	* 2.0725	* 3.9105 *
10	* 1.5115	* 1.8236	* 1.3185	* 1.9543	* 1.7297	* 2.0351	* 1.1996	*
	* 2.1461	* 1.7319	* 2.1333	* 1.6473	* 1.8624	* 1.5769	* 2.6783	*
11	* 1.9852	* 1.6428	* 1.9529	* 1.6714	* 2.0947	* 2.0176	* 1.0522	*
	* 1.6257	* 1.9675	* 1.6485	* 1.9279	* 1.5333	* 1.5897	* 3.0509	*
12	* 1.7075	* 2.0768	* 1.7268	* 2.0944	* 2.1235	* 1.3258	*	
	* 1.8903	* 1.5508	* 1.8654	* 1.5335	* 1.5117	* 2.4262	*	
13	* 1.3976	* 1.6053	* 2.0323	* 2.0159	* 1.3250	*		
	* 2.3095	* 2.0076	* 1.5790	* 1.5910	* 2.4276	*		
14	* 1.1862	* 1.4383	* 1.1960	* 1.0492	*			
	* 2.0470	* 2.0770	* 2.6864	* 3.0594	*			
15	* 0.5824	* 0.5979	* F-SUB-Q					
	* 3.6200	* 3.9575	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 197 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8229	* 1.4238	* 1.4507	* 1.9203	* 1.6426	* 1.3331	* 1.1415	* 0.5552 *
	* 1.8745	* 2.3450	* 2.3011	* 1.7627	* 2.0608	* 2.5055	* 2.1387	* 3.8327 *
9	* 1.4238	* 1.4629	* 1.7634	* 1.5834	* 2.0208	* 1.5444	* 1.3968	* 0.5792 *
	* 2.3450	* 2.1009	* 1.8010	* 2.1263	* 1.6701	* 2.1871	* 2.1580	* 4.1572 *
10	* 1.4507	* 1.7635	* 1.2559	* 1.8960	* 1.6694	* 1.9835	* 1.1474	*
	* 2.3011	* 1.8008	* 2.2318	* 1.7619	* 2.0197	* 1.6922	* 2.8785	*
11	* 1.9203	* 1.5782	* 1.8949	* 1.6162	* 2.0488	* 1.9708	* 1.0071	*
	* 1.7627	* 2.1284	* 1.7635	* 2.0833	* 1.6372	* 1.7004	* 3.3364	*
12	* 1.6426	* 2.0152	* 1.6668	* 2.0487	* 2.0883	* 1.2760	*	
	* 2.0608	* 1.6748	* 2.0228	* 1.6373	* 1.6046	* 2.6324	*	
13	* 1.3331	* 1.5382	* 1.9812	* 1.9696	* 1.2756	*		
	* 2.5055	* 2.1961	* 1.6941	* 1.7014	* 2.6331	*		
14	* 1.1415	* 1.3932	* 1.1445	* 1.0046	*			
	* 2.1387	* 2.1625	* 2.8859	* 3.3446	*			
15	* 0.5552	* 0.5709	* F-SUB-Q					
	* 3.8327	* 4.2042	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7352	* 1.3492	* 1.3750	* 1.8229	* 1.5569	* 1.2658	* 1.0828	* 0.5266 *
	* 2.0004	* 2.4995	* 2.4568	* 1.9055	* 2.2405	* 2.6722	* 2.2772	* 4.0688 *
9	* 1.3492	* 1.3872	* 1.6736	* 1.4996	* 1.9214	* 1.4704	* 1.3315	* 0.5501 *
	* 2.4995	* 2.2328	* 1.9186	* 2.2732	* 1.8119	* 2.3733	* 2.3006	* 4.4035 *
10	* 1.3750	* 1.6738	* 1.1923	* 1.8032	* 1.5868	* 1.8934	* 1.0927	*
	* 2.4568	* 1.9184	* 2.3898	* 1.8773	* 2.2111	* 1.8765	* 3.0588	*
11	* 1.8229	* 1.4948	* 1.8024	* 1.5409	* 1.9604	* 1.8846	* 0.9626	*
	* 1.9055	* 2.2753	* 1.8789	* 2.3124	* 1.8092	* 1.8803	* 3.6962	*
12	* 1.5569	* 1.9164	* 1.5846	* 1.9604	* 2.0040	* 1.2247	*	
	* 2.2405	* 1.8164	* 2.2156	* 1.8092	* 1.7669	* 2.8990	*	
13	* 1.2658	* 1.4647	* 1.8917	* 1.8839	* 1.2246	*		
	* 2.6722	* 2.3848	* 1.8781	* 1.8811	* 2.8991	*		
14	* 1.0828	* 1.3283	* 1.0906	* 0.9604	*			
	* 2.2772	* 2.3053	* 3.0663	* 3.7045	*			
15	* 0.5266	* 0.5424	* F-SUB-Q					
	* 4.0688	* 4.4580	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 198 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6772	* 1.2934	* 1.3151	* 1.7565	* 1.4928	* 1.1982	* 1.0383	* 0.4991
	* 2.0939	* 2.6401	* 2.5922	* 1.9991	* 2.3662	* 2.8555	* 2.3940	* 4.3448
9	* 1.2934	* 1.3304	* 1.6131	* 1.4344	* 1.8536	* 1.3960	* 1.2823	* 0.5232
	* 2.6401	* 2.3619	* 2.0107	* 2.3994	* 1.9037	* 2.5151	* 2.4132	* 4.7473
10	* 1.3151	* 1.6135	* 1.1259	* 1.7393	* 1.5217	* 1.8323	* 1.0421	*
	* 2.5922	* 2.0103	* 2.5212	* 1.9708	* 2.3424	* 2.0164	* 3.2820	*
11	* 1.7565	* 1.4298	* 1.7387	* 1.4785	* 1.8988	* 1.8265	* 0.9117	*
	* 1.9991	* 2.4016	* 1.9722	* 2.4816	* 1.9726	* 2.0643	* 4.1006	*
12	* 1.4928	* 1.8493	* 1.5197	* 1.8990	* 1.9459	* 1.1640	*	*
	* 2.3662	* 1.9081	* 2.3470	* 1.9724	* 1.9465	* 3.2630	*	*
13	* 1.1982	* 1.3907	* 1.8311	* 1.8262	* 1.1644	*	*	*
	* 2.8555	* 2.5272	* 2.0176	* 2.0646	* 3.2619	*	*	*
14	* 1.0383	* 1.2795	* 1.0405	* 0.9098	*	*	*	*
	* 2.3940	* 2.4179	* 3.2903	* 4.1091	*	*	*	*
15	* 0.4991	* 0.5159	* F-SUB-Q					
	* 4.3448	* 4.7973	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5637	* 1.2134	* 1.2388	* 1.6307	* 1.3932	* 1.1503	* 0.9730	* 0.4781
	* 2.2701	* 2.7987	* 2.7740	* 2.1739	* 2.5598	* 3.0066	* 2.6096	* 4.6276
9	* 1.2134	* 1.2461	* 1.4979	* 1.3411	* 1.7202	* 1.3385	* 1.2004	* 0.5005
	* 2.7987	* 2.5079	* 2.1853	* 2.5871	* 2.0712	* 2.6982	* 2.6310	* 4.9593
10	* 1.2388	* 1.4983	* 1.0829	* 1.6145	* 1.4240	* 1.7016	* 0.9948	*
	* 2.7740	* 2.1849	* 2.7192	* 2.1425	* 2.5263	* 2.1922	* 3.4546	*
11	* 1.6307	* 1.3369	* 1.6141	* 1.4088	* 1.7648	* 1.6961	* 0.8856	*
	* 2.1739	* 2.5893	* 2.1438	* 2.6720	* 2.1411	* 2.2437	* 4.2605	*
12	* 1.3932	* 1.7162	* 1.4222	* 1.7650	* 1.8075	* 1.1315	*	*
	* 2.5598	* 2.0760	* 2.5309	* 2.1408	* 2.1192	* 3.4356	*	*
13	* 1.1503	* 1.3338	* 1.7009	* 1.6961	* 1.1316	*	*	*
	* 3.0066	* 2.7076	* 2.1932	* 2.2437	* 3.4351	*	*	*
14	* 0.9730	* 1.1980	* 0.9926	* 0.8839	*	*	*	*
	* 2.6096	* 2.6359	* 3.4620	* 4.2688	*	*	*	*
15	* 0.4781	* 0.4935	* F-SUB-Q					
	* 4.6276	* 5.0150	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 199 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5493	* 1.1859	* 1.2030	* 1.6087	* 1.3631	* 1.0990	* 0.9528	* 0.4597
	* 2.3345	* 2.9604	* 2.9100	* 2.2413	* 2.6602	* 3.2025	* 2.6942	* 4.8888
9	* 1.1859	* 1.2209	* 1.4803	* 1.3078	* 1.6983	* 1.2814	* 1.1804	* 0.4827
	* 2.9604	* 2.6403	* 2.2509	* 2.6965	* 2.1327	* 2.8260	* 2.7124	* 5.3104
10	* 1.2030	* 1.4808	* 1.0287	* 1.5918	* 1.3890	* 1.6831	* 0.9564	*
	* 2.9100	* 2.2504	* 2.8324	* 2.2073	* 2.6289	* 2.2494	* 3.6748	*
11	* 1.6087	* 1.3037	* 1.5917	* 1.3516	* 1.7445	* 1.6793	* 0.8404	*
	* 2.2413	* 2.6988	* 2.2083	* 2.7729	* 2.1949	* 2.2972	* 4.5525	*
12	* 1.3631	* 1.6949	* 1.3873	* 1.7448	* 1.7922	* 1.0753	*	*
	* 2.6602	* 2.1371	* 2.6335	* 2.1945	* 2.1643	* 3.6576	*	*
13	* 1.0990	* 1.2768	* 1.6827	* 1.6796	* 1.0761	*	*	*
	* 3.2025	* 2.8392	* 2.2498	* 2.2967	* 3.6547	*	*	*
14	* 0.9528	* 1.1783	* 0.9553	* 0.8392	*	*	*	*
	* 2.6942	* 2.7172	* 3.6820	* 4.5595	*	*	*	*
15	* 0.4597	* 0.4760	* F-SUB-Q					
	* 4.8888	* 5.3662	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5109	* 1.1554	* 1.1709	* 1.5634	* 1.3225	* 1.0705	* 0.9312	* 0.4534
	* 2.4697	* 3.1346	* 3.0841	* 2.3761	* 2.8247	* 3.3873	* 2.8428	* 5.1467
9	* 1.1554	* 1.1912	* 1.4427	* 1.2688	* 1.6488	* 1.2482	* 1.1513	* 0.4748
	* 3.1346	* 2.7852	* 2.3814	* 2.8606	* 2.2625	* 3.0005	* 2.8644	* 5.5744
10	* 1.1709	* 1.4432	* 1.0017	* 1.5452	* 1.3457	* 1.6327	* 0.9306	*
	* 3.0841	* 2.3808	* 3.0048	* 2.3418	* 2.7934	* 2.3884	* 3.8859	*
11	* 1.5634	* 1.2650	* 1.5452	* 1.3096	* 1.6913	* 1.6280	* 0.8185	*
	* 2.3761	* 2.8629	* 2.3427	* 2.9490	* 2.3320	* 2.4407	* 4.8178	*
12	* 1.3225	* 1.6458	* 1.3443	* 1.6918	* 1.7383	* 1.0471	*	*
	* 2.8247	* 2.2669	* 2.7981	* 2.3314	* 2.2985	* 3.8670	*	*
13	* 1.0705	* 1.2439	* 1.6327	* 1.6286	* 1.0478	*	*	*
	* 3.3873	* 3.0143	* 2.3885	* 2.4399	* 3.8644	*	*	*
14	* 0.9312	* 1.1495	* 0.9297	* 0.8175	*	*	*	*
	* 2.8428	* 2.8693	* 3.8931	* 4.8245	*	*	*	*
15	* 0.4534	* 0.4682	* F-SUB-Q					
	* 5.1467	* 5.6267	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 200 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4708	* 1.1336	* 1.1480	* 1.5145	* 1.2837	* 1.0606	* 0.9226	* 0.4625
	* 2.6667	* 3.3175	* 3.3060	* 2.5769	* 3.0515	* 3.5891	* 3.0853	* 5.4825
9	* 1.1336	* 1.1699	* 1.4056	* 1.2345	* 1.5947	* 1.2310	* 1.1247	* 0.4803
	* 3.3175	* 2.9715	* 2.5842	* 3.0859	* 2.4544	* 3.2119	* 3.1053	* 5.8607
10	* 1.1480	* 1.4063	* 0.9999	* 1.4962	* 1.3046	* 1.5728	* 0.9205	*
	* 3.3060	* 2.5834	* 3.2446	* 2.5390	* 3.0099	* 2.5822	* 4.1077	*
11	* 1.5145	* 1.2309	* 1.4964	* 1.2866	* 1.6273	* 1.5651	* 0.8118	*
	* 2.5769	* 3.0882	* 2.5396	* 3.1677	* 2.5185	* 2.6357	* 5.0295	*
12	* 1.2837	* 1.5919	* 1.3034	* 1.6278	* 1.6700	* 1.0360	*	*
	* 3.0515	* 2.4588	* 3.0144	* 2.5177	* 2.4815	* 4.0395	*	*
13	* 1.0606	* 1.2271	* 1.5731	* 1.5660	* 1.0366	*	*	*
	* 3.5891	* 3.2220	* 2.5817	* 2.6342	* 4.0371	*	*	*
14	* 0.9226	* 1.1231	* 0.9190	* 0.8107	*	*	*	*
	* 3.0853	* 3.1102	* 4.1144	* 5.0364	*	*	*	*
15	* 0.4625	* 0.4736	* F-SUB-Q					
	* 5.4825	* 5.9271	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5108	* 1.1518	* 1.1653	* 1.5498	* 1.3022	* 1.0548	* 0.9789	* 0.4982
	* 2.5233	* 3.2159	* 3.1929	* 2.4849	* 2.9458	* 3.4967	* 2.8006	* 4.9324
9	* 1.1518	* 1.2126	* 1.4590	* 1.2512	* 1.6321	* 1.2214	* 1.1591	* 0.5065
	* 3.2159	* 2.8826	* 2.4753	* 2.9904	* 2.3764	* 3.0982	* 2.8385	* 5.3615
10	* 1.1653	* 1.4598	* 1.0127	* 1.5373	* 1.3161	* 1.6021	* 0.9205	*
	* 3.1929	* 2.4745	* 3.1231	* 2.4669	* 2.9444	* 2.5006	* 3.9410	*
11	* 1.5498	* 1.2476	* 1.5377	* 1.2771	* 1.6532	* 1.5918	* 0.7940	*
	* 2.4849	* 2.9919	* 2.4669	* 3.1279	* 2.4812	* 2.5649	* 4.9306	*
12	* 1.3022	* 1.6297	* 1.3148	* 1.6538	* 1.6992	* 1.0104	*	*
	* 2.9458	* 2.3793	* 2.9479	* 2.4802	* 2.4393	* 4.0662	*	*
13	* 1.0548	* 1.2164	* 1.6029	* 1.5930	* 1.0115	*	*	*
	* 3.4967	* 3.1097	* 2.4991	* 2.5628	* 4.0616	*	*	*
14	* 0.9789	* 1.1571	* 0.9188	* 0.7934	*	*	*	*
	* 2.8007	* 2.8419	* 3.9470	* 4.9339	*	*	*	*
15	* 0.4982	* 0.5004	* F-SUB-Q					
	* 4.9325	* 5.4200	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 201 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5441 *	* 1.1801 *	* 1.1950 *	* 1.5807 *	* 1.3221 *	* 1.0728 *	* 1.1113 *	* 0.5898 *
	* 2.2741 *	* 2.9172 *	* 2.8966 *	* 2.2456 *	* 2.6731 *	* 3.1741 *	* 2.5376 *	* 4.5013 *
9	* 1.1801 *	* 1.2787 *	* 1.5204 *	* 1.2748 *	* 1.6641 *	* 1.2440 *	* 1.2177 *	* 0.5672 *
	* 2.9172 *	* 2.6197 *	* 2.2366 *	* 2.7181 *	* 2.1478 *	* 2.8101 *	* 2.5676 *	* 4.9144 *
10	* 1.1950 *	* 1.5214 *	* 1.1107 *	* 1.5829 *	* 1.3346 *	* 1.6202 *	* 0.9408 *	
	* 2.8966 *	* 2.2359 *	* 2.8391 *	* 2.2314 *	* 2.6724 *	* 2.2541 *	* 3.5973 *	
11	* 1.5807 *	* 1.2727 *	* 1.5835 *	* 1.2900 *	* 1.6681 *	* 1.6047 *	* 0.7932 *	
	* 2.2455 *	* 2.7195 *	* 2.2310 *	* 2.8322 *	* 2.2359 *	* 2.3080 *	* 4.5024 *	
12	* 1.3221 *	* 1.6619 *	* 1.3329 *	* 1.6688 *	* 1.7129 *	* 1.0063 *		
	* 2.6731 *	* 2.1501 *	* 2.6753 *	* 2.2347 *	* 2.1913 *	* 3.6936 *		
13	* 1.0728 *	* 1.2390 *	* 1.6214 *	* 1.6062 *	* 1.0076 *			
	* 3.1741 *	* 2.8204 *	* 2.2523 *	* 2.3056 *	* 3.6888 *			
14	* 1.1113 *	* 1.2159 *	* 0.9394 *	* 0.7920 *				
	* 2.5375 *	* 2.5704 *	* 3.6017 *	* 4.5080 *				
15	* 0.5898 *	* 0.5614 *	F-SUB-Q					
	* 4.5014 *	* 4.9637 *	M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5791 *	* 1.2133 *	* 1.2282 *	* 1.6120 *	* 1.3457 *	* 1.1092 *	* 1.2866 *	* 0.6927 *
	* 2.0908 *	* 2.6900 *	* 2.6733 *	* 2.0715 *	* 2.4675 *	* 2.9327 *	* 2.3437 *	* 4.1551 *
9	* 1.2133 *	* 1.3456 *	* 1.5814 *	* 1.3077 *	* 1.6957 *	* 1.2691 *	* 1.2999 *	* 0.6464 *
	* 2.6900 *	* 2.4042 *	* 2.0617 *	* 2.5078 *	* 1.9789 *	* 2.5932 *	* 2.3715 *	* 4.5050 *
10	* 1.2282 *	* 1.5820 *	* 1.2268 *	* 1.6272 *	* 1.3601 *	* 1.6353 *	* 0.9738 *	
	* 2.6733 *	* 2.0609 *	* 2.6192 *	* 2.0565 *	* 2.4659 *	* 2.0746 *	* 3.3005 *	
11	* 1.6120 *	* 1.3060 *	* 1.6280 *	* 1.3047 *	* 1.6792 *	* 1.6133 *	* 0.8072 *	
	* 2.0715 *	* 2.5089 *	* 2.0561 *	* 2.6097 *	* 2.0562 *	* 2.1239 *	* 4.1114 *	
12	* 1.3457 *	* 1.6938 *	* 1.3584 *	* 1.6800 *	* 1.7203 *	* 1.0167 *		
	* 2.4675 *	* 1.9807 *	* 2.4684 *	* 2.0551 *	* 2.0152 *	* 3.3700 *		
13	* 1.1092 *	* 1.2641 *	* 1.6368 *	* 1.6151 *	* 1.0183 *			
	* 2.9327 *	* 2.6024 *	* 2.0725 *	* 2.1214 *	* 3.3641 *			
14	* 1.2866 *	* 1.2981 *	* 0.9727 *	* 0.8068 *				
	* 2.3437 *	* 2.3740 *	* 3.3035 *	* 4.1129 *				
15	* 0.6927 *	* 0.6390 *	F-SUB-Q					
	* 4.1551 *	* 4.5549 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 202 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5895	* 1.2574	* 1.2551	* 1.6207	* 1.3570	* 1.1498	* 1.3467	* 0.7496 *
	* 1.9488	* 2.4447	* 2.4631	* 1.9262	* 2.3000	* 2.6920	* 2.2182	* 3.8654 *
9	* 1.2574	* 1.4049	* 1.6171	* 1.3369	* 1.7016	* 1.2932	* 1.3414	* 0.7044 *
	* 2.4447	* 2.1920	* 1.9150	* 2.3154	* 1.8471	* 2.4238	* 2.2438	* 4.1297 *
10	* 1.2551	* 1.6178	* 1.2704	* 1.6402	* 1.3732	* 1.6287	* 1.0091	*
	* 2.4631	* 1.9143	* 2.4202	* 1.9087	* 2.2802	* 1.9454	* 3.0400	*
11	* 1.6207	* 1.3362	* 1.6410	* 1.3113	* 1.6701	* 1.6009	* 0.8315	*
	* 1.9262	* 2.3165	* 1.9077	* 2.4008	* 1.9017	* 1.9852	* 3.7539	*
12	* 1.3570	* 1.6996	* 1.3716	* 1.6710	* 1.7051	* 1.0425	*	
	* 2.3000	* 1.8490	* 2.2825	* 1.9007	* 1.8669	* 3.0278	*	
13	* 1.1498	* 1.2897	* 1.6303	* 1.6029	* 1.0437	*		
	* 2.6920	* 2.4297	* 1.9433	* 1.9828	* 3.0243	*		
14	* 1.3467	* 1.3397	* 1.0080	* 0.8310	*			
	* 2.2182	* 2.2460	* 3.0426	* 3.7558	*			
15	* 0.7496	* 0.6961	* F-SUB-Q					
	* 3.8654	* 4.1774	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6690	* 1.2795	* 1.2957	* 1.6984	* 1.4073	* 1.1577	* 1.4354	* 0.7821 *
	* 1.7135	* 2.2206	* 2.1988	* 1.6954	* 2.0443	* 2.4783	* 2.0060	* 3.6105 *
9	* 1.2795	* 1.4459	* 1.7064	* 1.3872	* 1.7832	* 1.3285	* 1.4254	* 0.7192 *
	* 2.2206	* 1.9768	* 1.6818	* 2.0645	* 1.6239	* 2.1731	* 2.0238	* 3.9315 *
10	* 1.2957	* 1.7072	* 1.3244	* 1.7192	* 1.4183	* 1.7029	* 1.0201	*
	* 2.1988	* 1.6811	* 2.1555	* 1.6790	* 2.0319	* 1.7074	* 2.8261	*
11	* 1.6984	* 1.3865	* 1.7197	* 1.3505	* 1.7423	* 1.6730	* 0.8264	*
	* 1.6954	* 2.0655	* 1.6784	* 2.1335	* 1.6670	* 1.7386	* 3.4796	*
12	* 1.4073	* 1.7814	* 1.4167	* 1.7433	* 1.7829	* 1.0365	*	
	* 2.0443	* 1.6253	* 2.0338	* 1.6660	* 1.6320	* 2.7865	*	
13	* 1.1577	* 1.3235	* 1.7049	* 1.6753	* 1.0382	*		
	* 2.4783	* 2.1809	* 1.7053	* 1.7363	* 2.7820	*		
14	* 1.4354	* 1.4237	* 1.0189	* 0.8255	*			
	* 2.0060	* 2.0259	* 2.8292	* 3.4829	*			
15	* 0.7821	* 0.7116	* F-SUB-Q					
	* 3.6105	* 3.9722	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 203 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6972	* 1.2980	* 1.3154	* 1.7256	* 1.4269	* 1.1730	* 1.4659	* 0.7996 *
	* 1.5687	* 2.0388	* 2.0165	* 1.5520	* 1.8763	* 2.2773	* 1.8366	* 3.3437 *
9	* 1.2980	* 1.4723	* 1.7373	* 1.4081	* 1.8106	* 1.3466	* 1.4539	* 0.7356 *
	* 2.0388	* 1.8063	* 1.5361	* 1.8923	* 1.4872	* 1.9955	* 1.8524	* 3.6348 *
10	* 1.3154	* 1.7381	* 1.3458	* 1.7456	* 1.4362	* 1.7256	* 1.0342	*
	* 2.0165	* 1.5354	* 1.9727	* 1.5373	* 1.8667	* 1.5668	* 2.5962	*
11	* 1.7256	* 1.4074	* 1.7462	* 1.3648	* 1.7642	* 1.6938	* 0.8345	*
	* 1.5520	* 1.8932	* 1.5367	* 1.9638	* 1.5301	* 1.5968	* 3.2105	*
12	* 1.4269	* 1.8088	* 1.4347	* 1.7653	* 1.8049	* 1.0471	*	
	* 1.8763	* 1.4884	* 1.8685	* 1.5292	* 1.4984	* 2.5675	*	
13	* 1.1730	* 1.3415	* 1.7277	* 1.6962	* 1.0488	*		
	* 2.2773	* 2.0027	* 1.5648	* 1.5946	* 2.5632	*		
14	* 1.4659	* 1.4521	* 1.0329	* 0.8335	*			
	* 1.8366	* 1.8545	* 2.5993	* 3.2142	*			
15	* 0.7996	* 0.7271	* F-SUB-Q					
	* 3.3437	* 3.6761	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7086	* 1.3118	* 1.3259	* 1.7362	* 1.4374	* 1.1844	* 1.4737	* 0.8073 *
	* 1.4734	* 1.9115	* 1.8927	* 1.4554	* 1.7612	* 2.1383	* 1.7277	* 3.1371 *
9	* 1.3118	* 1.4874	* 1.7487	* 1.4201	* 1.8187	* 1.3550	* 1.4603	* 0.7572 *
	* 1.9115	* 1.6912	* 1.4421	* 1.7743	* 1.3986	* 1.8754	* 1.7441	* 3.3447 *
10	* 1.3259	* 1.7495	* 1.3569	* 1.7542	* 1.4461	* 1.7273	* 1.0426	*
	* 1.8927	* 1.4414	* 1.8506	* 1.4431	* 1.7526	* 1.4785	* 2.4369	*
11	* 1.7362	* 1.4194	* 1.7551	* 1.3693	* 1.7651	* 1.6928	* 0.8380	*
	* 1.4554	* 1.7752	* 1.4424	* 1.8501	* 1.4437	* 1.5090	* 3.0261	*
12	* 1.4374	* 1.8167	* 1.4445	* 1.7661	* 1.8022	* 1.0586	*	
	* 1.7612	* 1.3999	* 1.7543	* 1.4429	* 1.4168	* 2.4009	*	
13	* 1.1844	* 1.3497	* 1.7292	* 1.6950	* 1.0605	*		
	* 2.1383	* 1.8825	* 1.4768	* 1.5070	* 2.3967	*		
14	* 1.4737	* 1.4582	* 1.0412	* 0.8368	*			
	* 1.7277	* 1.7463	* 2.4399	* 3.0303	*			
15	* 0.8073	* 0.7352	* F-SUB-Q					
	* 3.1371	* 3.4441	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 204 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6784	* 1.3062	* 1.3110	* 1.7123	* 1.4212	* 1.1770	* 1.4406	* 0.7966 *
	* 1.4383	* 1.8420	* 1.8368	* 1.4138	* 1.7081	* 2.0653	* 1.6947	* 3.0538 *
9	* 1.3062	* 1.4760	* 1.7190	* 1.4054	* 1.7794	* 1.3376	* 1.4258	* 0.7444 *
	* 1.8420	* 1.6345	* 1.4045	* 1.7196	* 1.3692	* 1.8217	* 1.7126	* 3.2668 *
10	* 1.3110	* 1.7205	* 1.3416	* 1.7282	* 1.4287	* 1.6820	* 1.0316	*
	* 1.8368	* 1.4033	* 1.7957	* 1.4030	* 1.7008	* 1.4540	* 2.3630	*
11	* 1.7123	* 1.4046	* 1.7290	* 1.3462	* 1.7182	* 1.6432	* 0.8256	*
	* 1.4138	* 1.7205	* 1.4024	* 1.8020	* 1.4192	* 1.4884	* 2.9477	*
12	* 1.4212	* 1.7770	* 1.4270	* 1.7196	* 1.7431	* 1.0380	*	*
	* 1.7081	* 1.3709	* 1.7027	* 1.4180	* 1.4020	* 2.3465	*	*
13	* 1.1770	* 1.3322	* 1.6835	* 1.6451	* 1.0396	*	*	*
	* 2.0653	* 1.8291	* 1.4526	* 1.4867	* 2.3429	*	*	*
14	* 1.4406	* 1.4236	* 1.0299	* 0.8241	*	*	*	*
	* 1.6947	* 1.7151	* 2.3667	* 2.9531	*	*	*	*
15	* 0.7966	* 0.7269	* F-SUB-Q					
	* 3.0538	* 3.3455	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5638	* 1.2430	* 1.2433	* 1.6069	* 1.3499	* 1.1173	* 1.3503	* 0.7475 *
	* 1.4964	* 1.8780	* 1.8784	* 1.4597	* 1.7433	* 2.1106	* 1.7529	* 3.1603 *
9	* 1.2430	* 1.3935	* 1.6079	* 1.3350	* 1.6669	* 1.2687	* 1.3338	* 0.7015 *
	* 1.8780	* 1.6774	* 1.4546	* 1.7551	* 1.4154	* 1.8621	* 1.7751	* 3.3671 *
10	* 1.2433	* 1.6093	* 1.2711	* 1.6194	* 1.3561	* 1.5628	* 0.9723	*
	* 1.8784	* 1.4533	* 1.8376	* 1.4499	* 1.7366	* 1.5150	* 2.4325	*
11	* 1.6069	* 1.3342	* 1.6199	* 1.2694	* 1.5933	* 1.5237	* 0.7784	*
	* 1.4597	* 1.7561	* 1.4494	* 1.8477	* 1.4805	* 1.5539	* 3.0345	*
12	* 1.3499	* 1.6636	* 1.3543	* 1.5942	* 1.5997	* 0.9706	*	*
	* 1.7433	* 1.4181	* 1.7388	* 1.4797	* 1.4782	* 2.4327	*	*
13	* 1.1173	* 1.2630	* 1.5632	* 1.5249	* 0.9717	*	*	*
	* 2.1106	* 1.8703	* 1.5146	* 1.5526	* 2.4298	*	*	*
14	* 1.3503	* 1.3315	* 0.9705	* 0.7767	*	*	*	*
	* 1.7529	* 1.7780	* 2.4369	* 3.0412	*	*	*	*
15	* 0.7475	* 0.6862	* F-SUB-Q					
	* 3.1603	* 3.4425	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 205 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 375 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2749	* 1.0556	* 1.0413	* 1.3007	* 1.1417	* 0.9413	* 1.1032	* 0.6145 *
	* 1.7925	* 2.1623	* 2.1928	* 1.7616	* 2.0143	* 2.4496	* 2.0974	* 3.7642 *
9	* 1.0556	* 1.1674	* 1.2987	* 1.1222	* 1.3548	* 1.0695	* 1.0916	* 0.5818 *
	* 2.1623	* 1.9567	* 1.7603	* 2.0404	* 1.6995	* 2.1590	* 2.1202	* 3.9764 *
10	* 1.0413	* 1.2991	* 1.0629	* 1.3086	* 1.1368	* 1.2639	* 0.8077	*
	* 2.1928	* 1.7598	* 2.1482	* 1.7523	* 2.0240	* 1.8290	* 2.8634	*
11	* 1.3007	* 1.1216	* 1.3087	* 1.0599	* 1.2816	* 1.2341	* 0.6529	*
	* 1.7616	* 2.0415	* 1.7522	* 2.1630	* 1.7963	* 1.8731	* 3.5402	*
12	* 1.1417	* 1.3516	* 1.1351	* 1.2820	* 1.2773	* 0.8051	*	
	* 2.0143	* 1.7033	* 2.0269	* 1.7957	* 1.8072	* 2.8680	*	
13	* 0.9413	* 1.0647	* 1.2625	* 1.2347	* 0.8056	*		
	* 2.4496	* 2.1685	* 1.8308	* 1.8721	* 2.8663	*		
14	* 1.1032	* 1.0895	* 0.8062	* 0.6514	*			
	* 2.0974	* 2.1240	* 2.8686	* 3.5487	*			
15	* 0.6145	* 0.5723	* F-SUB-Q					
	* 3.7642	* 4.0416	* M-SUB-Q					

AT 50% POWER, 375 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5765	* 0.5176	* 0.5308	* 0.6113	* 0.5553	* 0.4780	* 0.4813	* 0.2958 *
	* 3.8782	* 4.3188	* 4.2143	* 3.6698	* 4.0519	* 4.7234	* 4.7072	* 7.6670 *
9	* 0.5176	* 0.5596	* 0.6096	* 0.5524	* 0.6084	* 0.5174	* 0.4746	* 0.2777 *
	* 4.3188	* 3.9952	* 3.6725	* 4.0588	* 3.7007	* 4.3680	* 4.7742	* 8.1708 *
10	* 0.5308	* 0.6097	* 0.5412	* 0.6144	* 0.5535	* 0.5613	* 0.3937	*
	* 4.2143	* 3.6716	* 4.1361	* 3.6537	* 4.0677	* 4.0284	* 5.7557	*
11	* 0.6113	* 0.5521	* 0.6143	* 0.5385	* 0.5955	* 0.5362	* 0.3130	*
	* 3.6698	* 4.0612	* 3.6542	* 4.1701	* 3.7841	* 4.2176	* 7.2382	*
12	* 0.5553	* 0.6069	* 0.5527	* 0.5956	* 0.5572	* 0.3916	*	
	* 4.0519	* 3.7099	* 4.0735	* 3.7834	* 4.0524	* 5.7766	*	
13	* 0.4780	* 0.5154	* 0.5604	* 0.5362	* 0.3916	*		
	* 4.7234	* 4.3849	* 4.0341	* 4.2171	* 5.7765	*		
14	* 0.4813	* 0.4736	* 0.3930	* 0.3123	*			
	* 4.7072	* 4.7842	* 5.7664	* 7.2559	*			
15	* 0.2958	* 0.2766	* F-SUB-Q					
	* 7.6670	* 8.2021	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 206 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8597	* 0.7831	* 0.6915	* 0.9403	* 0.8885	* 0.7569	* 0.5664	* 0.3102
	* 3.2391	* 3.5178	* 3.5524	* 3.0281	* 3.2592	* 3.8601	* 4.3598	* 6.8314
9	* 0.7831	* 0.7599	* 0.8141	* 0.8564	* 0.9638	* 0.8402	* 0.6842	* 0.3371
	* 3.5178	* 3.6127	* 3.2818	* 3.3473	* 3.0157	* 3.4797	* 4.2642	* 7.2674
10	* 0.6915	* 0.8139	* 0.6568	* 0.9317	* 0.8898	* 0.9204	* 0.6284	*
	* 3.5524	* 3.2819	* 4.0341	* 3.0975	* 3.2643	* 3.1649	* 4.6492	*
11	* 0.9403	* 0.8543	* 0.9308	* 0.8415	* 0.9500	* 0.8825	* 0.5471	*
	* 3.0281	* 3.3552	* 3.0987	* 3.3377	* 2.9941	* 3.2347	* 5.2954	*
12	* 0.8885	* 0.9616	* 0.8883	* 0.9496	* 0.8098	* 0.6026	*	*
	* 3.2592	* 3.0223	* 3.2695	* 2.9950	* 3.1176	* 4.3063	*	*
13	* 0.7569	* 0.8375	* 0.9186	* 0.8816	* 0.6004	*	*	*
	* 3.8601	* 3.4906	* 3.1688	* 3.2376	* 4.3213	*	*	*
14	* 0.5664	* 0.6825	* 0.6271	* 0.5456	*	*	*	*
	* 4.3598	* 4.2744	* 4.6587	* 5.3098	*	*	*	*
15	* 0.3102	* 0.3344	* F-SUB-Q					
	* 6.8314	* 7.3243	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6206	* 1.3678	* 1.2782	* 1.7029	* 1.5744	* 1.2973	* 1.0739	* 0.5565
	* 1.7851	* 2.1060	* 2.1373	* 1.7292	* 1.8901	* 2.3047	* 2.3039	* 3.8617
9	* 1.3678	* 1.3546	* 1.5232	* 1.5042	* 1.8133	* 1.4928	* 1.3037	* 0.5950
	* 2.1060	* 2.1102	* 1.8773	* 1.9654	* 1.6442	* 2.0049	* 2.2880	* 4.1606
10	* 1.2782	* 1.5230	* 1.1558	* 1.6793	* 1.5756	* 1.7600	* 1.1132	*
	* 2.1373	* 1.8774	* 2.4021	* 1.7628	* 1.8914	* 1.6924	* 2.6844	*
11	* 1.7029	* 1.5004	* 1.6785	* 1.4802	* 1.7505	* 1.7236	* 0.9759	*
	* 1.7292	* 1.9702	* 1.7635	* 1.9711	* 1.6775	* 1.7132	* 3.0470	*
12	* 1.5744	* 1.8092	* 1.5729	* 1.7498	* 1.6548	* 1.1288	*	*
	* 1.8901	* 1.6478	* 1.8936	* 1.6777	* 1.6535	* 2.5140	*	*
13	* 1.2973	* 1.4875	* 1.7580	* 1.7221	* 1.1263	*	*	*
	* 2.3047	* 2.0119	* 1.6941	* 1.7144	* 2.5194	*	*	*
14	* 1.0739	* 1.3007	* 1.1106	* 0.9733	*	*	*	*
	* 2.3039	* 2.2932	* 2.6902	* 3.0548	*	*	*	*
15	* 0.5565	* 0.5857	* F-SUB-Q					
	* 3.8617	* 4.2196	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 207 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8414	* 1.5125	* 1.5180	* 1.9393	* 1.7407	* 1.4674	* 1.2243	* 0.6401
	* 1.6208	* 1.9711	* 1.9655	* 1.5589	* 1.7468	* 2.0797	* 2.0744	* 3.4227
9	* 1.5125	* 1.5154	* 1.7578	* 1.6762	* 2.0498	* 1.6611	* 1.4789	* 0.6751
	* 1.9711	* 1.9625	* 1.6972	* 1.8075	* 1.4840	* 1.8381	* 2.0580	* 3.6591
10	* 1.5180	* 1.7576	* 1.3285	* 1.9091	* 1.7577	* 2.0088	* 1.2747	*
	* 1.9655	* 1.6972	* 2.1922	* 1.5856	* 1.7274	* 1.5141	* 2.3895	*
11	* 1.9393	* 1.6719	* 1.9081	* 1.6844	* 2.0208	* 1.9718	* 1.1292	*
	* 1.5589	* 1.8120	* 1.5863	* 1.7906	* 1.4881	* 1.5360	* 2.6910	*
12	* 1.7407	* 2.0452	* 1.7557	* 2.0206	* 2.0471	* 1.3632	*	*
	* 1.7468	* 1.4872	* 1.7291	* 1.4882	* 1.4639	* 2.2013	*	*
13	* 1.4674	* 1.6563	* 2.0068	* 1.9705	* 1.3616	*	*	*
	* 2.0797	* 1.8431	* 1.5154	* 1.5369	* 2.2037	*	*	*
14	* 1.2243	* 1.4758	* 1.2719	* 1.1264	*	*	*	*
	* 2.0744	* 2.0621	* 2.3944	* 2.6975	*	*	*	*
15	* 0.6401	* 0.6662	* F-SUB-Q					
	* 3.4227	* 3.7005	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9644	* 1.5750	* 1.5932	* 2.0648	* 1.8185	* 1.4976	* 1.2878	* 0.6591
	* 1.5689	* 1.9565	* 1.9381	* 1.5038	* 1.7132	* 2.0774	* 1.9589	* 3.3188
9	* 1.5750	* 1.5898	* 1.8847	* 1.7481	* 2.1859	* 1.7219	* 1.5731	* 0.6942
	* 1.9565	* 1.9356	* 1.6362	* 1.7789	* 1.4244	* 1.8054	* 1.9665	* 3.6115
10	* 1.5932	* 1.8846	* 1.3593	* 2.0391	* 1.8446	* 2.1665	* 1.3166	*
	* 1.9381	* 1.6363	* 2.1235	* 1.5219	* 1.6867	* 1.4366	* 2.3564	*
11	* 2.0648	* 1.7437	* 2.0383	* 1.7844	* 2.2049	* 2.1431	* 1.1530	*
	* 1.5038	* 1.7834	* 1.5224	* 1.7395	* 1.4055	* 1.4495	* 2.6910	*
12	* 1.8185	* 2.1815	* 1.8427	* 2.2048	* 2.2553	* 1.4194	*	*
	* 1.7132	* 1.4272	* 1.6884	* 1.4056	* 1.3725	* 2.1840	*	*
13	* 1.4976	* 1.7154	* 2.1648	* 2.1421	* 1.4186	*	*	*
	* 2.0774	* 1.8121	* 1.4376	* 1.4501	* 2.1852	*	*	*
14	* 1.2878	* 1.5702	* 1.3147	* 1.1506	*	*	*	*
	* 1.9589	* 1.9701	* 2.3597	* 2.6975	*	*	*	*
15	* 0.6591	* 0.6847	* F-SUB-Q					
	* 3.3188	* 3.6462	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 208 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9100	* 1.5209	* 1.5441	* 2.0003	* 1.7523	* 1.4564	* 1.2486	* 0.6421 *
	* 1.6752	* 2.1055	* 2.0762	* 1.5968	* 1.8213	* 2.1876	* 1.9948	* 3.4122 *
9	* 1.5209	* 1.5396	* 1.8300	* 1.6841	* 2.1183	* 1.6661	* 1.5348	* 0.6731 *
	* 2.1055	* 2.0299	* 1.7479	* 1.8983	* 1.5053	* 1.9131	* 2.0131	* 3.6864 *
10	* 1.5441	* 1.8300	* 1.3301	* 1.9808	* 1.7865	* 2.1123	* 1.2834	*
	* 2.0762	* 1.7478	* 2.1349	* 1.6104	* 1.7880	* 1.5076	* 2.4736	*
11	* 2.0003	* 1.6799	* 1.9802	* 1.7383	* 2.1608	* 2.0967	* 1.1342	*
	* 1.5968	* 1.9031	* 1.6108	* 1.8408	* 1.4795	* 1.5209	* 2.8069	*
12	* 1.7523	* 2.1142	* 1.7847	* 2.1608	* 2.2213	* 1.4087	*	
	* 1.8213	* 1.5081	* 1.7897	* 1.4795	* 1.4390	* 2.2732	*	
13	* 1.4564	* 1.6612	* 2.1111	* 2.0962	* 1.4082	*		
	* 2.1876	* 1.9186	* 1.5083	* 1.5212	* 2.2740	*		
14	* 1.2486	* 1.5321	* 1.2819	* 1.1319	*			
	* 1.9948	* 2.0162	* 2.4767	* 2.8125	*			
15	* 0.6421	* 0.6646	* F-SUB-Q					
	* 3.4122	* 3.7279	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8199	* 1.4424	* 1.4651	* 1.8975	* 1.6569	* 1.3879	* 1.1865	* 0.6108 *
	* 1.8306	* 2.3078	* 2.2623	* 1.7375	* 1.9894	* 2.3747	* 2.0755	* 3.5206 *
9	* 1.4424	* 1.4614	* 1.7382	* 1.5923	* 2.0102	* 1.5919	* 1.4639	* 0.6403 *
	* 2.3078	* 2.1237	* 1.8544	* 2.0732	* 1.6367	* 2.0669	* 2.1002	* 3.7962 *
10	* 1.4651	* 1.7384	* 1.2704	* 1.8827	* 1.6953	* 2.0112	* 1.2245	*
	* 2.2623	* 1.8541	* 2.2430	* 1.7475	* 1.9413	* 1.6304	* 2.6797	*
11	* 1.8975	* 1.5884	* 1.8823	* 1.6603	* 2.0639	* 2.0014	* 1.0896	*
	* 1.7375	* 2.0784	* 1.7478	* 1.9829	* 1.5907	* 1.6382	* 3.0127	*
12	* 1.6569	* 2.0065	* 1.6936	* 2.0640	* 2.1266	* 1.3599	*	
	* 1.9894	* 1.6397	* 1.9431	* 1.5906	* 1.5434	* 2.4178	*	
13	* 1.3879	* 1.5875	* 2.0104	* 2.0012	* 1.3596	*		
	* 2.3747	* 2.0726	* 1.6309	* 1.6383	* 2.4183	*		
14	* 1.1865	* 1.4616	* 1.2232	* 1.0875	*			
	* 2.0755	* 2.1032	* 2.6825	* 3.0182	*			
15	* 0.6108	* 0.6324	* F-SUB-Q					
	* 3.5206	* 3.8364	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 209 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7450	* 1.3719	* 1.3912	* 1.8117	* 1.5746	* 1.3068	* 1.1263	* 0.5757 *
	* 1.9924	* 2.4686	* 2.4306	* 1.8999	* 2.1858	* 2.5826	* 2.1766	* 3.7355 *
9	* 1.3719	* 1.3910	* 1.6607	* 1.5104	* 1.9216	* 1.5032	* 1.3966	* 0.6045 *
	* 2.4686	* 2.2408	* 1.9390	* 2.2634	* 1.7862	* 2.2840	* 2.1955	* 4.0445 *
10	* 1.3912	* 1.6609	* 1.1941	* 1.7995	* 1.6123	* 1.9291	* 1.1603	*
	* 2.4306	* 1.9387	* 2.3582	* 1.8888	* 2.1264	* 1.7697	* 2.9008	*
11	* 1.8117	* 1.5066	* 1.7992	* 1.5790	* 1.9822	* 1.9252	* 1.0277	*
	* 1.8999	* 2.2648	* 1.8889	* 2.1682	* 1.7211	* 1.7709	* 3.3286	*
12	* 1.5746	* 1.9183	* 1.6108	* 1.9824	* 2.0481	* 1.2868	*	
	* 2.1858	* 1.7892	* 2.1283	* 1.7210	* 1.6642	* 2.6552	*	
13	* 1.3068	* 1.4990	* 1.9288	* 1.9252	* 1.2868	*		
	* 2.5826	* 2.2904	* 1.7700	* 1.7708	* 2.6550	*		
14	* 1.1263	* 1.3947	* 1.1592	* 1.0261	*			
	* 2.1766	* 2.1986	* 2.9054	* 3.3338	*			
15	* 0.5757	* 0.5969	* F-SUB-Q					
	* 3.7355	* 4.0901	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6527	* 1.2944	* 1.3118	* 1.7096	* 1.4833	* 1.2335	* 1.0624	* 0.5432 *
	* 2.0731	* 2.5746	* 2.5368	* 2.0034	* 2.3201	* 2.6978	* 2.2754	* 3.9082 *
9	* 1.2944	* 1.3124	* 1.5677	* 1.4218	* 1.8140	* 1.4214	* 1.3220	* 0.5709 *
	* 2.5746	* 2.3333	* 2.0216	* 2.3671	* 1.8975	* 2.4241	* 2.2932	* 4.2194 *
10	* 1.3118	* 1.5682	* 1.1255	* 1.6987	* 1.5206	* 1.8258	* 1.0976	*
	* 2.5368	* 2.0211	* 2.4700	* 1.9733	* 2.2959	* 1.9695	* 3.0319	*
11	* 1.7096	* 1.4182	* 1.6986	* 1.4923	* 1.8780	* 1.8248	* 0.9745	*
	* 2.0034	* 2.3686	* 1.9732	* 2.3987	* 1.9119	* 1.9671	* 3.7021	*
12	* 1.4833	* 1.8111	* 1.5193	* 1.8782	* 1.9427	* 1.2228	*	
	* 2.3201	* 1.9002	* 2.2988	* 1.9116	* 1.8452	* 2.9399	*	
13	* 1.2335	* 1.4175	* 1.8257	* 1.8252	* 1.2231	*		
	* 2.6978	* 2.4325	* 1.9694	* 1.9667	* 2.9393	*		
14	* 1.0624	* 1.3204	* 1.0967	* 0.9731	*			
	* 2.2754	* 2.2963	* 3.0364	* 3.7074	*			
15	* 0.5432	* 0.5639	* F-SUB-Q					
	* 3.9082	* 4.2665	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 210 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5931	* 1.2391	* 1.2530	* 1.6421	* 1.4183	* 1.1642	* 1.0147	* 0.5127 *
	* 2.1420	* 2.6769	* 2.6389	* 2.0744	* 2.4136	* 2.8224	* 2.3414	* 4.0677 *
9	* 1.2391	* 1.2569	* 1.5070	* 1.3566	* 1.7436	* 1.3475	* 1.2675	* 0.5419 *
	* 2.6769	* 2.4227	* 2.0900	* 2.4662	* 1.9640	* 2.5213	* 2.3602	* 4.4330 *
10	* 1.2530	* 1.5075	* 1.0591	* 1.6313	* 1.4525	* 1.7581	* 1.0425	*
	* 2.6389	* 2.0896	* 2.5722	* 2.0454	* 2.3940	* 2.0396	* 3.1890	*
11	* 1.6421	* 1.3532	* 1.6314	* 1.4260	* 1.8083	* 1.7604	* 0.9192	*
	* 2.0744	* 2.4677	* 2.0451	* 2.5016	* 2.0165	* 2.0815	* 3.9468	*
12	* 1.4183	* 1.7410	* 1.4512	* 1.8086	* 1.8742	* 1.1561	*	
	* 2.4136	* 1.9667	* 2.3970	* 2.0161	* 1.9693	* 3.2366	*	
13	* 1.1642	* 1.3428	* 1.7583	* 1.7609	* 1.1568	*		
	* 2.8224	* 2.5301	* 2.0393	* 2.0807	* 3.2344	*		
14	* 1.0147	* 1.2662	* 1.0418	* 0.9183	*			
	* 2.3414	* 2.3632	* 3.1942	* 3.9509	*			
15	* 0.5127	* 0.5350	* F-SUB-Q					
	* 4.0677	* 4.4780	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4917	* 1.1640	* 1.1822	* 1.5299	* 1.3259	* 1.1209	* 0.9557	* 0.4930 *
	* 2.2954	* 2.8118	* 2.8051	* 2.2305	* 2.5868	* 2.9574	* 2.5262	* 4.2871 *
9	* 1.1640	* 1.1790	* 1.4048	* 1.2709	* 1.6223	* 1.2939	* 1.1919	* 0.5191 *
	* 2.8118	* 2.5522	* 2.2460	* 2.6337	* 2.1147	* 2.6832	* 2.5492	* 4.5869 *
10	* 1.1822	* 1.4054	* 1.0210	* 1.5185	* 1.3608	* 1.6355	* 0.9946	*
	* 2.8051	* 2.2455	* 2.7507	* 2.1988	* 2.5580	* 2.1968	* 3.3237	*
11	* 1.5299	* 1.2678	* 1.5186	* 1.3589	* 1.6834	* 1.6350	* 0.8939	*
	* 2.2305	* 2.6353	* 2.1984	* 2.6751	* 2.1695	* 2.2449	* 4.0665	*
12	* 1.3259	* 1.6201	* 1.3598	* 1.6837	* 1.7418	* 1.1242	*	
	* 2.5868	* 2.1175	* 2.5610	* 2.1691	* 2.1240	* 3.3369	*	
13	* 1.1209	* 1.2907	* 1.6359	* 1.6357	* 1.1245	*		
	* 2.9574	* 2.6899	* 2.1962	* 2.2439	* 3.3358	*		
14	* 0.9557	* 1.1906	* 0.9940	* 0.8928	*			
	* 2.5262	* 2.5523	* 3.3282	* 4.0718	*			
15	* 0.4930	* 0.5128	* F-SUB-Q					
	* 4.2871	* 4.6335	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 211 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4773	* 1.1406	* 1.1500	* 1.5091	* 1.2987	* 1.0714	* 0.9345	* 0.4740 *
	* 2.3509	* 2.9545	* 2.9166	* 2.2891	* 2.6729	* 3.1314	* 2.5933	* 4.5112 *
9	* 1.1406	* 1.1572	* 1.3879	* 1.2407	* 1.6013	* 1.2379	* 1.1695	* 0.5016 *
	* 2.9545	* 2.6720	* 2.3036	* 2.7298	* 2.1674	* 2.7908	* 2.6117	* 4.8933 *
10	* 1.1500	* 1.3885	* 0.9697	* 1.4955	* 1.3272	* 1.6159	* 0.9586	*
	* 2.9166	* 2.3031	* 2.8472	* 2.2547	* 2.6484	* 2.2456	* 3.5191	*
11	* 1.5091	* 1.2377	* 1.4958	* 1.3036	* 1.6603	* 1.6185	* 0.8482	*
	* 2.2891	* 2.7314	* 2.2542	* 2.7610	* 2.2168	* 2.2878	* 4.3268	*
12	* 1.2987	* 1.5993	* 1.3262	* 1.6607	* 1.7228	* 1.0670	*	
	* 2.6729	* 2.1699	* 2.6515	* 2.2162	* 2.1635	* 3.5438	*	
13	* 1.0714	* 1.2347	* 1.6166	* 1.6194	* 1.0680	*		
	* 3.1314	* 2.8003	* 2.2447	* 2.2864	* 3.5406	*		
14	* 0.9345	* 1.1685	* 0.9583	* 0.8474	*			
	* 2.5933	* 2.6148	* 3.5234	* 4.3312	*			
15	* 0.4740	* 0.4951	* F-SUB-Q					
	* 4.5112	* 4.9324	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4443	* 1.1144	* 1.1220	* 1.4706	* 1.2635	* 1.0470	* 0.9165	* 0.4696 *
	* 2.4883	* 3.1302	* 3.0921	* 2.4267	* 2.8378	* 3.3136	* 2.7339	* 4.7382 *
9	* 1.1144	* 1.1317	* 1.3561	* 1.2069	* 1.5583	* 1.2081	* 1.1438	* 0.4949 *
	* 3.1302	* 2.8275	* 2.4383	* 2.8967	* 2.3000	* 2.9625	* 2.7565	* 5.1223 *
10	* 1.1220	* 1.3568	* 0.9466	* 1.4545	* 1.2883	* 1.5701	* 0.9352	*
	* 3.0921	* 2.4376	* 3.0222	* 2.3943	* 2.8153	* 2.3865	* 3.7195	*
11	* 1.4706	* 1.2041	* 1.4548	* 1.2647	* 1.6112	* 1.5710	* 0.8281	*
	* 2.4267	* 2.8984	* 2.3935	* 2.9400	* 2.3588	* 2.4340	* 4.5803	*
12	* 1.2635	* 1.5566	* 1.2874	* 1.6117	* 1.6714	* 1.0397	*	
	* 2.8378	* 2.3025	* 2.8185	* 2.3581	* 2.3006	* 3.7484	*	
13	* 1.0470	* 1.2051	* 1.5710	* 1.5721	* 1.0405	*		
	* 3.3136	* 2.9725	* 2.3853	* 2.4323	* 3.7453	*		
14	* 0.9165	* 1.1430	* 0.9350	* 0.8274	*			
	* 2.7339	* 2.7596	* 3.7238	* 4.5845	*			
15	* 0.4696	* 0.4888	* F-SUB-Q					
	* 4.7382	* 5.1693	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 212 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4106 *	* 1.0944 *	* 1.1026 *	* 1.4294 *	* 1.2300 *	* 1.0414 *	* 0.9141 *	* 0.4817 *
	* 2.6818 *	* 3.3113 *	* 3.3205 *	* 2.6256 *	* 3.0604 *	* 3.5055 *	* 2.9658 *	* 5.0285 *
9	* 1.0944 *	* 1.1134 *	* 1.3256 *	* 1.1772 *	* 1.5116 *	* 1.1972 *	* 1.1243 *	* 0.5026 *
	* 3.3113 *	* 3.0061 *	* 2.6398 *	* 3.1208 *	* 2.4894 *	* 3.1727 *	* 2.9877 *	* 5.3680 *
10	* 1.1026 *	* 1.3264 *	* 0.9472 *	* 1.4123 *	* 1.2514 *	* 1.5161 *	* 0.9243 *	
	* 3.3205 *	* 2.6390 *	* 3.2613 *	* 2.5873 *	* 3.0288 *	* 2.5758 *	* 3.9263 *	
11	* 1.4294 *	* 1.1745 *	* 1.4128 *	* 1.2430 *	* 1.5533 *	* 1.5123 *	* 0.8235 *	
	* 2.6256 *	* 3.1225 *	* 2.5863 *	* 3.1563 *	* 2.5414 *	* 2.6255 *	* 4.7759 *	
12	* 1.2300 *	* 1.5101 *	* 1.2506 *	* 1.5538 *	* 1.6078 *	* 1.0303 *		
	* 3.0604 *	* 2.4917 *	* 3.0318 *	* 2.5406 *	* 2.4823 *	* 3.9165 *		
13	* 1.0414 *	* 1.1945 *	* 1.5172 *	* 1.5136 *	* 1.0310 *			
	* 3.5055 *	* 3.1799 *	* 2.5742 *	* 2.6234 *	* 3.9139 *			
14	* 0.9141 *	* 1.1235 *	* 0.9234 *	* 0.8227 *				
	* 2.9658 *	* 2.9907 *	* 3.9303 *	* 4.7804 *				
15	* 0.4817 *	* 0.4962 *	F-SUB-Q					
	* 5.0285 *	* 5.4241 *	M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4458 *	* 1.1135 *	* 1.1200 *	* 1.4607 *	* 1.2474 *	* 1.0363 *	* 0.9698 *	* 0.5196 *
	* 2.6391 *	* 3.3345 *	* 3.3101 *	* 2.6065 *	* 3.0558 *	* 3.5573 *	* 2.8932 *	* 4.9719 *
9	* 1.1135 *	* 1.1544 *	* 1.3725 *	* 1.1932 *	* 1.5450 *	* 1.1899 *	* 1.1548 *	* 0.5311 *
	* 3.3345 *	* 3.0231 *	* 2.6124 *	* 3.1220 *	* 2.4749 *	* 3.1807 *	* 2.9193 *	* 5.3851 *
10	* 1.1200 *	* 1.3732 *	* 0.9587 *	* 1.4481 *	* 1.2606 *	* 1.5418 *	* 0.9247 *	
	* 3.3101 *	* 2.6116 *	* 3.2513 *	* 2.5785 *	* 3.0406 *	* 2.5611 *	* 3.9841 *	
11	* 1.4607 *	* 1.1904 *	* 1.4487 *	* 1.2329 *	* 1.5726 *	* 1.5362 *	* 0.8050 *	
	* 2.6065 *	* 3.1233 *	* 2.5773 *	* 3.1727 *	* 2.5396 *	* 2.6090 *	* 4.8974 *	
12	* 1.2474 *	* 1.5438 *	* 1.2599 *	* 1.5732 *	* 1.6297 *	* 1.0029 *		
	* 3.0558 *	* 2.4766 *	* 3.0434 *	* 2.5386 *	* 2.4747 *	* 4.0386 *		
13	* 1.0363 *	* 1.1861 *	* 1.5432 *	* 1.5377 *	* 1.0043 *			
	* 3.5573 *	* 3.1906 *	* 2.5589 *	* 2.6065 *	* 4.0332 *			
14	* 0.9698 *	* 1.1539 *	* 0.9240 *	* 0.8046 *				
	* 2.8932 *	* 2.9218 *	* 3.9873 *	* 4.9002 *				
15	* 0.5196 *	* 0.5247 *	F-SUB-Q					
	* 4.9719 *	* 5.4374 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 213 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4750	* 1.1403	* 1.1478	* 1.4882	* 1.2661	* 1.0548	* 1.1084	* 0.6176 *
	* 2.4532	* 3.1027	* 3.0909	* 2.4424	* 2.8686	* 3.3233	* 2.6763	* 4.5662 *
9	* 1.1403	* 1.2171	* 1.4284	* 1.2142	* 1.5735	* 1.2126	* 1.2166	* 0.5962 *
	* 3.1027	* 2.8184	* 2.4384	* 2.9252	* 2.3279	* 2.9875	* 2.7061	* 4.9750 *
10	* 1.1478	* 1.4292	* 1.0561	* 1.4888	* 1.2752	* 1.5569	* 0.9462	*
	* 3.0909	* 2.4376	* 3.0382	* 2.4240	* 2.8655	* 2.4143	* 3.7404	*
11	* 1.4882	* 1.2122	* 1.4896	* 1.2429	* 1.5820	* 1.5460	* 0.8033	*
	* 2.4424	* 2.9264	* 2.4232	* 2.9957	* 2.4015	* 2.4609	* 4.6233	*
12	* 1.2661	* 1.5725	* 1.2744	* 1.5827	* 1.6374	* 0.9957	*	
	* 2.8686	* 2.3290	* 2.8678	* 2.4005	* 2.3397	* 3.8345	*	
13	* 1.0548	* 1.2088	* 1.5585	* 1.5477	* 0.9976	*		
	* 3.3233	* 2.9963	* 2.4119	* 2.4583	* 3.8271	*		
14	* 1.1084	* 1.2158	* 0.9452	* 0.8030	*			
	* 2.6763	* 2.7080	* 3.7438	* 4.6252	*			
15	* 0.6176	* 0.5906	* F-SUB-Q					
	* 4.5662	* 5.0233	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5050	* 1.1695	* 1.1769	* 1.5147	* 1.2866	* 1.0910	* 1.2883	* 0.7273 *
	* 2.2031	* 2.7934	* 2.7854	* 2.2049	* 2.5926	* 3.0078	* 2.4178	* 4.1221 *
9	* 1.1695	* 1.2781	* 1.4816	* 1.2422	* 1.6001	* 1.2359	* 1.3004	* 0.6796 *
	* 2.7934	* 2.5367	* 2.1979	* 2.6393	* 2.1049	* 2.7019	* 2.4447	* 4.4602 *
10	* 1.1769	* 1.4825	* 1.1695	* 1.5271	* 1.2951	* 1.5680	* 0.9796	*
	* 2.7854	* 2.1972	* 2.7392	* 2.1905	* 2.5906	* 2.1852	* 3.3635	*
11	* 1.5147	* 1.2408	* 1.5281	* 1.2534	* 1.5877	* 1.5498	* 0.8171	*
	* 2.2049	* 2.6403	* 2.1896	* 2.7110	* 2.1738	* 2.2280	* 4.1380	*
12	* 1.2866	* 1.5993	* 1.2940	* 1.5885	* 1.6389	* 1.0042	*	
	* 2.5926	* 2.1057	* 2.5924	* 2.1728	* 2.1184	* 3.4345	*	
13	* 1.0910	* 1.2321	* 1.5698	* 1.5517	* 1.0058	*		
	* 3.0078	* 2.7095	* 2.1827	* 2.2254	* 3.4292	*		
14	* 1.2883	* 1.2994	* 0.9790	* 0.8168	*			
	* 2.4178	* 2.4463	* 3.3654	* 4.1393	*			
15	* 0.7273	* 0.6729	* F-SUB-Q					
	* 4.1221	* 4.5030	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 214 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5126	* 1.2072	* 1.1957	* 1.5203	* 1.2977	* 1.1307	* 1.3494	* 0.7883
	* 2.0268	* 2.5149	* 2.5541	* 2.0314	* 2.3799	* 2.7153	* 2.2406	* 3.7588
9	* 1.2072	* 1.3274	* 1.5109	* 1.2640	* 1.6026	* 1.2543	* 1.3418	* 0.7418
	* 2.5149	* 2.2886	* 2.0228	* 2.4189	* 1.9423	* 2.4780	* 2.2672	* 4.0057
10	* 1.1957	* 1.5115	* 1.2075	* 1.5363	* 1.3044	* 1.5587	* 1.0156	*
	* 2.5541	* 2.0220	* 2.5116	* 2.0190	* 2.3762	* 2.0165	* 3.0293	*
11	* 1.5203	* 1.2635	* 1.5373	* 1.2542	* 1.5756	* 1.5333	* 0.8411	*
	* 2.0314	* 2.4198	* 2.0181	* 2.4842	* 1.9988	* 2.0567	* 3.6927	*
12	* 1.2977	* 1.6020	* 1.3035	* 1.5764	* 1.6200	* 1.0268	*	*
	* 2.3799	* 1.9431	* 2.3777	* 1.9979	* 1.9489	* 3.0491	*	*
13	* 1.1307	* 1.2519	* 1.5606	* 1.5352	* 1.0280	*	*	*
	* 2.7153	* 2.4825	* 2.0141	* 2.0540	* 3.0457	*	*	*
14	* 1.3494	* 1.3409	* 1.0149	* 0.8408	*	*	*	*
	* 2.2406	* 2.2686	* 3.0309	* 3.6939	*	*	*	*
15	* 0.7883	* 0.7336	* F-SUB-Q					
	* 3.7588	* 4.0491	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5770	* 1.2248	* 1.2321	* 1.5823	* 1.3361	* 1.1427	* 1.4352	* 0.8211
	* 1.7932	* 2.2909	* 2.2835	* 1.7977	* 2.1275	* 2.4824	* 1.9880	* 3.4342
9	* 1.2248	* 1.3587	* 1.5821	* 1.3049	* 1.6686	* 1.2873	* 1.4231	* 0.7558
	* 2.2909	* 2.0757	* 1.7913	* 2.1671	* 1.7160	* 2.2183	* 2.0082	* 3.7329
10	* 1.2321	* 1.5828	* 1.2531	* 1.5973	* 1.3402	* 1.6204	* 1.0229	*
	* 2.2835	* 1.7906	* 2.2490	* 1.7854	* 2.1244	* 1.7758	* 2.7903	*
11	* 1.5823	* 1.3044	* 1.5985	* 1.2868	* 1.6313	* 1.5942	* 0.8322	*
	* 1.7977	* 2.1678	* 1.7844	* 2.2134	* 1.7608	* 1.8057	* 3.4192	*
12	* 1.3361	* 1.6682	* 1.3394	* 1.6322	* 1.6819	* 1.0158	*	*
	* 2.1275	* 1.7163	* 2.1257	* 1.7599	* 1.7122	* 2.8143	*	*
13	* 1.1427	* 1.2836	* 1.6226	* 1.5965	* 1.0179	*	*	*
	* 2.4824	* 2.2244	* 1.7733	* 1.8032	* 2.8085	*	*	*
14	* 1.4352	* 1.4221	* 1.0221	* 0.8319	*	*	*	*
	* 1.9880	* 2.0094	* 2.7923	* 3.4203	*	*	*	*
15	* 0.8211	* 0.7482	* F-SUB-Q					
	* 3.4342	* 3.7697	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 215 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5994	* 1.2399	* 1.2470	* 1.6025	* 1.3515	* 1.1570	* 1.4654	* 0.8402
	* 1.6426	* 2.1031	* 2.0958	* 1.6475	* 1.9531	* 2.2779	* 1.8168	* 3.1458
9	* 1.2399	* 1.3784	* 1.6052	* 1.3206	* 1.6888	* 1.3030	* 1.4511	* 0.7736
	* 2.1031	* 1.9001	* 1.6384	* 1.9878	* 1.5731	* 2.0355	* 1.8349	* 3.4163
10	* 1.2470	* 1.6058	* 1.2698	* 1.6161	* 1.3535	* 1.6384	* 1.0366	*
	* 2.0958	* 1.6378	* 2.0599	* 1.6366	* 1.9527	* 1.6295	* 2.5590	*
11	* 1.6025	* 1.3201	* 1.6171	* 1.2969	* 1.6470	* 1.6106	* 0.8400	*
	* 1.6475	* 1.9885	* 1.6356	* 2.0380	* 1.6173	* 1.6583	* 3.1493	*
12	* 1.3515	* 1.6885	* 1.3526	* 1.6479	* 1.6984	* 1.0249	*	*
	* 1.9531	* 1.5733	* 1.9538	* 1.6164	* 1.5725	* 2.5904	*	*
13	* 1.1570	* 1.2992	* 1.6409	* 1.6130	* 1.0271	*	*	*
	* 2.2779	* 2.0410	* 1.6272	* 1.6559	* 2.5848	*	*	*
14	* 1.4654	* 1.4501	* 1.0358	* 0.8399	*	*	*	*
	* 1.8168	* 1.8361	* 2.5607	* 3.1496	*	*	*	*
15	* 0.8402	* 0.7653	* F-SUB-Q					
	* 3.1458	* 3.4523	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6148	* 1.2522	* 1.2581	* 1.6134	* 1.3643	* 1.1677	* 1.4774	* 0.8516
	* 1.5356	* 1.9674	* 1.9618	* 1.5436	* 1.8261	* 2.1321	* 1.7009	* 2.9343
9	* 1.2522	* 1.3917	* 1.6210	* 1.3332	* 1.6993	* 1.3149	* 1.4623	* 0.7993
	* 1.9674	* 1.7766	* 1.5307	* 1.8587	* 1.4742	* 1.9038	* 1.7185	* 3.1261
10	* 1.2581	* 1.6217	* 1.2815	* 1.6260	* 1.3650	* 1.6449	* 1.0485	*
	* 1.9618	* 1.5301	* 1.9271	* 1.5339	* 1.8269	* 1.5303	* 2.3893	*
11	* 1.6134	* 1.3328	* 1.6270	* 1.3043	* 1.6532	* 1.6154	* 0.8472	*
	* 1.5436	* 1.8593	* 1.5330	* 1.9117	* 1.5185	* 1.5585	* 2.9496	*
12	* 1.3643	* 1.6990	* 1.3642	* 1.6541	* 1.7026	* 1.0392	*	*
	* 1.8261	* 1.4744	* 1.8278	* 1.5177	* 1.4782	* 2.4106	*	*
13	* 1.1677	* 1.3111	* 1.6474	* 1.6178	* 1.0411	*	*	*
	* 2.1321	* 1.9091	* 1.5281	* 1.5562	* 2.4063	*	*	*
14	* 1.4774	* 1.4611	* 1.0478	* 0.8474	*	*	*	*
	* 1.7009	* 1.7198	* 2.3909	* 2.9491	*	*	*	*
15	* 0.8516	* 0.7769	* F-SUB-Q					
	* 2.9343	* 3.2154	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 216 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6077	* 1.2516	* 1.2535	* 1.6010	* 1.3622	* 1.1668	* 1.4576	* 0.8485 *
	* 1.4768	* 1.8879	* 1.8870	* 1.4868	* 1.7514	* 2.0449	* 1.6505	* 2.8241 *
9	* 1.2516	* 1.3910	* 1.6065	* 1.3319	* 1.6837	* 1.3117	* 1.4435	* 0.7936 *
	* 1.8879	* 1.7046	* 1.4770	* 1.7820	* 1.4248	* 1.8275	* 1.6666	* 3.0182 *
10	* 1.2535	* 1.6077	* 1.2769	* 1.6126	* 1.3630	* 1.6208	* 1.0485	*
	* 1.8870	* 1.4759	* 1.8531	* 1.4781	* 1.7517	* 1.4852	* 2.2887	*
11	* 1.6010	* 1.3315	* 1.6137	* 1.2955	* 1.6294	* 1.5891	* 0.8439	*
	* 1.4868	* 1.7825	* 1.4771	* 1.8424	* 1.4728	* 1.5147	* 2.8373	*
12	* 1.3622	* 1.6803	* 1.3623	* 1.6303	* 1.6727	* 1.0323	*	
	* 1.7514	* 1.4261	* 1.7525	* 1.4721	* 1.4383	* 2.3220	*	
13	* 1.1668	* 1.3079	* 1.6231	* 1.5913	* 1.0340	*		
	* 2.0449	* 1.8325	* 1.4831	* 1.5126	* 2.3182	*		
14	* 1.4576	* 1.4421	* 1.0476	* 0.8430	*			
	* 1.6505	* 1.6680	* 2.2906	* 2.8405	*			
15	* 0.8485	* 0.7760	* F-SUB-Q					
	* 2.8241	* 3.0864	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5436	* 1.2174	* 1.2110	* 1.5351	* 1.3198	* 1.1312	* 1.3937	* 0.8117 *
	* 1.4890	* 1.8808	* 1.8924	* 1.5005	* 1.7506	* 2.0443	* 1.6710	* 2.8625 *
9	* 1.2174	* 1.3420	* 1.5381	* 1.2909	* 1.6139	* 1.2699	* 1.3765	* 0.7616 *
	* 1.8808	* 1.7103	* 1.4929	* 1.7808	* 1.4376	* 1.8281	* 1.6921	* 3.0498 *
10	* 1.2110	* 1.5392	* 1.2327	* 1.5450	* 1.3204	* 1.5473	* 1.0088	*
	* 1.8924	* 1.4919	* 1.8593	* 1.4927	* 1.7509	* 1.5040	* 2.3051	*
11	* 1.5351	* 1.2906	* 1.5460	* 1.2449	* 1.5515	* 1.5098	* 0.8135	*
	* 1.5005	* 1.7813	* 1.4918	* 1.8560	* 1.4951	* 1.5420	* 2.8534	*
12	* 1.3198	* 1.6105	* 1.3196	* 1.5528	* 1.5860	* 0.9891	*	
	* 1.7506	* 1.4395	* 1.7518	* 1.4939	* 1.4663	* 2.3463	*	
13	* 1.1312	* 1.2662	* 1.5488	* 1.5116	* 0.9905	*		
	* 2.0443	* 1.8332	* 1.5032	* 1.5401	* 2.3432	*		
14	* 1.3937	* 1.3750	* 1.0078	* 0.8123	*			
	* 1.6710	* 1.6938	* 2.3071	* 2.8576	*			
15	* 0.8117	* 0.7467	* F-SUB-Q					
	* 2.8625	* 3.1108	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 217 of 306

TABLE A-1 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - NORMAL OPERATION

AT 50% POWER, 475 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3006	* 1.0698	* 1.0463	* 1.2955	* 1.1534	* 0.9814	* 1.1781	* 0.6865 *
	* 1.7238	* 2.0916	* 2.1391	* 1.7346	* 1.9556	* 2.3026	* 1.9291	* 3.3079 *
9	* 1.0698	* 1.1688	* 1.2900	* 1.1217	* 1.3593	* 1.1057	* 1.1648	* 0.6500 *
	* 2.0916	* 1.9163	* 1.7370	* 2.0013	* 1.6621	* 2.0492	* 1.9513	* 3.4946 *
10	* 1.0463	* 1.2907	* 1.0639	* 1.3032	* 1.1454	* 1.3040	* 0.8639	*
	* 2.1391	* 1.7358	* 2.1036	* 1.7268	* 1.9702	* 1.7405	* 2.6281	*
11	* 1.2955	* 1.1214	* 1.3035	* 1.0676	* 1.2962	* 1.2688	* 0.7032	*
	* 1.7346	* 2.0017	* 1.7260	* 2.1069	* 1.7427	* 1.7891	* 3.2260	*
12	* 1.1534	* 1.3583	* 1.1446	* 1.2970	* 1.3170	* 0.8460	*	
	* 1.9556	* 1.6633	* 1.9713	* 1.7416	* 1.7210	* 2.6796	*	
13	* 0.9814	* 1.1024	* 1.3042	* 1.2701	* 0.8466	*		
	* 2.3026	* 2.0553	* 1.7401	* 1.7873	* 2.6775	*		
14	* 1.1781	* 1.1635	* 0.8631	* 0.7020	*			
	* 1.9291	* 1.9534	* 2.6303	* 3.2315	*			
15	* 0.6865	* 0.6400	* F-SUB-Q					
	* 3.3079	* 3.5475	* M-SUB-Q					

AT 50% POWER, 475 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6221	* 0.5584	* 0.5688	* 0.6521	* 0.5984	* 0.5318	* 0.5507	* 0.3489 *
	* 3.5159	* 3.9142	* 3.8470	* 3.3672	* 3.6784	* 4.1537	* 4.0272	* 6.3638 *
9	* 0.5584	* 0.5987	* 0.6483	* 0.5897	* 0.6538	* 0.5710	* 0.5428	* 0.3272 *
	* 3.9142	* 3.6523	* 3.3778	* 3.7182	* 3.3699	* 3.8728	* 4.0864	* 6.7883 *
10	* 0.5688	* 0.6485	* 0.5783	* 0.6555	* 0.5963	* 0.6185	* 0.4445	*
	* 3.8470	* 3.3766	* 3.7875	* 3.3546	* 3.6935	* 3.5781	* 4.9902	*
11	* 0.6521	* 0.5896	* 0.6554	* 0.5787	* 0.6447	* 0.5913	* 0.3559	*
	* 3.3672	* 3.7190	* 3.3543	* 3.7960	* 3.4211	* 3.7439	* 6.2305	*
12	* 0.5984	* 0.6528	* 0.5958	* 0.6449	* 0.6123	* 0.4340	*	
	* 3.6784	* 3.3747	* 3.6960	* 3.4197	* 3.6100	* 5.1028	*	
13	* 0.5318	* 0.5694	* 0.6182	* 0.5916	* 0.4341	*		
	* 4.1537	* 3.8832	* 3.5795	* 3.7416	* 5.1015	*		
14	* 0.5507	* 0.5420	* 0.4441	* 0.3553	*			
	* 4.0272	* 4.0920	* 4.9949	* 6.2415	*			
15	* 0.3489	* 0.3259	* F-SUB-Q					
	* 6.3638	* 6.8142	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 218 of 306

TABLE A-2

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 3.3476	* 3.3961	* 3.5166	* 3.4238	* 3.5012	* 3.9623	* 4.4597	* 6.4938
	* 3.6597	* 3.6784	* 3.7898	* 3.6538	* 3.7087	* 4.1724	* 4.6160	* 6.6165
	* 3.8916	* 3.8958	* 3.9493	* 3.8229	* 3.8707	* 4.2631	* 4.6790	* 6.6568
	* 4.0246	* 3.9443	* 3.9676	* 3.9129	* 3.8880	* 4.2234	* 4.5677	* 6.4316
	* 3.5534	* 3.4521	* 3.4394	* 3.4322	* 3.3975	* 3.7124	* 4.0056	* 5.6147
	* 3.1046	* 3.0094	* 2.9967	* 3.0016	* 2.9471	* 3.1942	* 3.4111	* 4.6947
9	* 3.3961	* 3.3986	* 3.3769	* 3.4985	* 3.5119	* 3.7972	* 4.5833	* 6.6308
	* 3.6784	* 3.6405	* 3.6117	* 3.7509	* 3.7174	* 4.0109	* 4.7426	* 6.7399
	* 3.8958	* 3.8359	* 3.8176	* 3.8829	* 3.8730	* 4.1604	* 4.8028	* 6.7442
	* 3.9443	* 3.8739	* 3.9280	* 3.8806	* 3.9397	* 4.1513	* 4.7023	* 6.5553
	* 3.4521	* 3.3605	* 3.4059	* 3.3501	* 3.4637	* 3.6447	* 4.1336	* 5.7630
	* 3.0094	* 2.9321	* 2.9681	* 2.9009	* 3.0271	* 3.1360	* 3.5287	* 4.8668
10	* 3.5166	* 3.3755	* 3.4386	* 3.4985	* 3.6071	* 4.0547	* 4.8940	*
	* 3.7898	* 3.6102	* 3.7383	* 3.6990	* 3.8551	* 4.2043	* 5.1096	*
	* 3.9493	* 3.8159	* 3.8825	* 3.8575	* 3.9858	* 4.3071	* 5.2330	*
	* 3.9676	* 3.9266	* 3.8859	* 3.9263	* 3.9855	* 4.3173	* 5.2169	*
	* 3.4394	* 3.4051	* 3.3412	* 3.4083	* 3.4576	* 3.8073	* 4.6116	*
	* 2.9967	* 2.9674	* 2.8803	* 2.9663	* 2.9799	* 3.2613	* 3.9592	*
11	* 3.4238	* 3.4996	* 3.4994	* 3.6855	* 3.9274	* 4.5201	* 6.1094	*
	* 3.6538	* 3.7526	* 3.6997	* 3.9474	* 4.0697	* 4.6674	* 6.2381	*
	* 3.8229	* 3.8843	* 3.8585	* 4.0885	* 4.1944	* 4.7665	* 6.3107	*
	* 3.9129	* 3.8830	* 3.9280	* 4.0640	* 4.2439	* 4.7312	* 6.2476	*
	* 3.4322	* 3.3524	* 3.4089	* 3.4950	* 3.6882	* 4.0853	* 5.4785	*
	* 3.0016	* 2.9027	* 2.9663	* 3.0095	* 3.1557	* 3.4908	* 4.6641	*
12	* 3.5012	* 3.5267	* 3.6147	* 3.9303	* 4.4917	* 5.2591	*	*
	* 3.7087	* 3.7314	* 3.8629	* 4.0723	* 4.6044	* 5.4042	*	*
	* 3.8707	* 3.8885	* 3.9916	* 4.1971	* 4.6930	* 5.5180	*	*
	* 3.8880	* 3.9597	* 3.9904	* 4.2464	* 4.6864	* 5.5306	*	*
	* 3.3975	* 3.4786	* 3.4619	* 3.6902	* 3.9893	* 4.7240	*	*
	* 2.9471	* 3.0365	* 2.9828	* 3.1563	* 3.4303	* 4.1404	*	*
13	* 3.9623	* 3.8142	* 4.0658	* 4.5292	* 5.2688	*	*	*
	* 4.1724	* 4.0290	* 4.2143	* 4.6754	* 5.4178	*	*	*
	* 4.2631	* 4.1752	* 4.3175	* 4.7746	* 5.5316	*	*	*
	* 4.2234	* 4.1630	* 4.3275	* 4.7388	* 5.5451	*	*	*
	* 3.7124	* 3.6546	* 3.8155	* 4.0913	* 4.7388	*	*	*
	* 3.1942	* 3.1429	* 3.2663	* 3.4945	* 4.1522	*	*	*
14	* 4.4597	* 4.5948	* 4.9122	* 6.1300	*	*	*	*
	* 4.6160	* 4.7526	* 5.1262	* 6.2571	*	*	*	*
	* 4.6790	* 4.8138	* 5.2489	* 6.3282	*	*	*	*
	* 4.5677	* 4.7131	* 5.2296	* 6.2664	*	*	*	*
	* 4.0056	* 4.1408	* 4.6219	* 5.4933	*	*	*	*
	* 3.4111	* 3.5343	* 3.9655	* 4.6671	*	*	*	*
15	* 6.4938	* 6.6823	* 4 EFPD 118	% POWER				
	* 6.6164	* 6.7961	* 75 EFPD 118	% POWER				
	* 6.6568	* 6.8027	* 150 EFPD 118	% POWER				
	* 6.4316	* 6.6090	* 275 EFPD 118	% POWER				
	* 5.6147	* 5.8075	* 375 EFPD 118	% POWER				
	* 4.6947	* 4.9068	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 219 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6439	* 1.7639	* 1.9001	* 1.7522	* 1.7870	* 2.0426	* 2.0365	* 3.2746 *
	* 1.8189	* 1.9443	* 2.0634	* 1.8861	* 1.9116	* 2.1777	* 2.1255	* 3.3499 *
	* 1.9626	* 2.0989	* 2.1794	* 1.9994	* 2.0178	* 2.2610	* 2.1848	* 3.4067 *
	* 2.0866	* 2.1861	* 2.2430	* 2.0957	* 2.0827	* 2.3205	* 2.1928	* 3.3937 *
	* 1.9304	* 2.0075	* 2.0348	* 1.9161	* 1.9187	* 2.1640	* 2.0578	* 3.1513 *
	* 1.8074	* 1.8849	* 1.8994	* 1.8021	* 1.7957	* 2.0003	* 1.9123	* 2.8248 *
9	* 1.7639	* 1.7284	* 1.7532	* 1.8269	* 1.7088	* 1.9387	* 2.0827	* 3.4109 *
	* 1.9443	* 1.8792	* 1.8978	* 1.9639	* 1.8331	* 2.0479	* 2.1640	* 3.4718 *
	* 2.0989	* 2.0108	* 2.0254	* 2.0574	* 1.9346	* 2.1445	* 2.2165	* 3.4958 *
	* 2.1861	* 2.0847	* 2.1237	* 2.1136	* 2.0280	* 2.1995	* 2.2424	* 3.5078 *
	* 2.0075	* 1.9000	* 1.9128	* 1.9164	* 1.8653	* 2.0422	* 2.1098	* 3.2797 *
	* 1.8849	* 1.7856	* 1.7902	* 1.7888	* 1.7411	* 1.8938	* 1.9599	* 2.9670 *
10	* 1.9001	* 1.7523	* 1.8676	* 1.7891	* 1.8735	* 1.9037	* 2.5095	*
	* 2.0634	* 1.8968	* 2.0394	* 1.9136	* 1.9839	* 2.0026	* 2.6362	*
	* 2.1794	* 2.0244	* 2.1452	* 2.0234	* 2.0771	* 2.0868	* 2.7239	*
	* 2.2430	* 2.1232	* 2.1983	* 2.1117	* 2.1331	* 2.1549	* 2.7924	*
	* 2.0348	* 1.9125	* 1.9815	* 1.9096	* 1.9489	* 1.9919	* 2.6082	*
	* 1.8994	* 1.7898	* 1.8434	* 1.7864	* 1.8108	* 1.8350	* 2.3868	*
11	* 1.7522	* 1.8285	* 1.7895	* 1.9662	* 1.9782	* 2.0987	* 3.1706	*
	* 1.8861	* 1.9651	* 1.9139	* 2.1300	* 2.0722	* 2.1868	* 3.2441	*
	* 1.9994	* 2.0588	* 2.0238	* 2.2254	* 2.1659	* 2.2476	* 3.3005	*
	* 2.0957	* 2.1154	* 2.1123	* 2.2752	* 2.2403	* 2.2934	* 3.3596	*
	* 1.9161	* 1.9180	* 1.9103	* 2.0489	* 2.0206	* 2.0961	* 3.0918	*
	* 1.8021	* 1.7901	* 1.7866	* 1.8914	* 1.8552	* 1.9296	* 2.8040	*
12	* 1.7870	* 1.7184	* 1.8770	* 1.9799	* 2.1023	* 2.8635	*	*
	* 1.9116	* 1.8417	* 1.9877	* 2.0737	* 2.1854	* 2.9356	*	*
	* 2.0178	* 1.9438	* 2.0801	* 2.1674	* 2.2736	* 2.9991	*	*
	* 2.0827	* 2.0361	* 2.1360	* 2.2418	* 2.3348	* 3.0583	*	*
	* 1.9187	* 1.8726	* 1.9515	* 2.0219	* 2.0813	* 2.7166	*	*
	* 1.7957	* 1.7451	* 1.8126	* 1.8558	* 1.8951	* 2.5169	*	*
13	* 2.0426	* 1.9478	* 1.9086	* 2.1027	* 2.8662	*	*	*
	* 2.1777	* 2.0559	* 2.0071	* 2.1903	* 2.9403	*	*	*
	* 2.2610	* 2.1511	* 2.0916	* 2.2511	* 3.0036	*	*	*
	* 2.3205	* 2.2058	* 2.1598	* 2.2968	* 3.0626	*	*	*
	* 2.1640	* 2.0478	* 1.9960	* 2.0988	* 2.7210	*	*	*
	* 2.0003	* 1.8978	* 1.8374	* 1.9313	* 2.5212	*	*	*
14	* 2.0365	* 2.0878	* 2.5193	* 3.1836	*	*	*	*
	* 2.1255	* 2.1684	* 2.6450	* 3.2564	*	*	*	*
	* 2.1848	* 2.2212	* 2.7324	* 3.3119	*	*	*	*
	* 2.1928	* 2.2471	* 2.8003	* 3.3698	*	*	*	*
	* 2.0578	* 2.1134	* 2.6147	* 3.0999	*	*	*	*
	* 1.9123	* 1.9628	* 2.3912	* 2.8056	*	*	*	*
15	* 3.2746	* 3.4676	* 4 EFPD 118	% POWER				
	* 3.3499	* 3.5292	* 75 EFPD 118	% POWER				
	* 3.4067	* 3.5537	* 150 EFPD 118	% POWER				
	* 3.3937	* 3.5654	* 275 EFPD 118	% POWER				
	* 3.1513	* 3.3296	* 375 EFPD 118	% POWER				
	* 2.8248	* 3.0091	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 220 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6124	* 1.5871	* 1.7114	* 1.6694	* 1.6110	* 1.7702	* 1.8158	* 2.8129 *
	* 1.7400	* 1.7396	* 1.8570	* 1.7569	* 1.7052	* 1.8800	* 1.8655	* 2.8340 *
	* 1.8325	* 1.8654	* 1.9389	* 1.8262	* 1.7849	* 1.9472	* 1.8941	* 2.8492 *
	* 1.8768	* 1.9263	* 1.9516	* 1.8425	* 1.8180	* 2.0035	* 1.8565	* 2.8429 *
	* 1.7048	* 1.8020	* 1.7956	* 1.6558	* 1.6982	* 1.9128	* 1.7915	* 2.7184 *
	* 1.6320	* 1.7451	* 1.7369	* 1.6072	* 1.6416	* 1.8290	* 1.7262	* 2.5227 *
9	* 1.5871	* 1.5788	* 1.7461	* 1.6568	* 1.6560	* 1.7138	* 1.8357	* 2.9207 *
	* 1.7396	* 1.6992	* 1.8460	* 1.7603	* 1.7439	* 1.7967	* 1.8881	* 2.9284 *
	* 1.8654	* 1.7989	* 1.9148	* 1.8249	* 1.7913	* 1.8708	* 1.8769	* 2.9175 *
	* 1.9263	* 1.8265	* 1.8905	* 1.8368	* 1.8031	* 1.9101	* 1.8957	* 2.9351 *
	* 1.8020	* 1.6843	* 1.6618	* 1.6866	* 1.6250	* 1.8041	* 1.8379	* 2.8185 *
	* 1.7451	* 1.6390	* 1.6048	* 1.6294	* 1.5549	* 1.7255	* 1.7663	* 2.6315 *
10	* 1.7114	* 1.7438	* 1.6991	* 1.7144	* 1.6800	* 1.7607	* 2.1397	*
	* 1.8570	* 1.8439	* 1.8440	* 1.7916	* 1.7593	* 1.8216	* 2.2265	*
	* 1.9389	* 1.9137	* 1.9119	* 1.8550	* 1.8203	* 1.8653	* 2.2878	*
	* 1.9516	* 1.8903	* 1.9136	* 1.8626	* 1.8432	* 1.8885	* 2.3483	*
	* 1.7956	* 1.6617	* 1.7491	* 1.6543	* 1.7062	* 1.7293	* 2.2351	*
	* 1.7369	* 1.6045	* 1.6882	* 1.5976	* 1.6403	* 1.6329	* 2.1071	*
11	* 1.6694	* 1.6617	* 1.7161	* 1.7619	* 1.8952	* 1.8485	* 2.7412	*
	* 1.7569	* 1.7639	* 1.7931	* 1.8842	* 1.9300	* 1.8865	* 2.7640	*
	* 1.8262	* 1.8272	* 1.8567	* 1.9634	* 1.9693	* 1.9337	* 2.7804	*
	* 1.8425	* 1.8387	* 1.8649	* 1.9702	* 1.9653	* 1.9428	* 2.8188	*
	* 1.6558	* 1.6881	* 1.6551	* 1.7970	* 1.7430	* 1.8005	* 2.6366	*
	* 1.6072	* 1.6307	* 1.5979	* 1.7205	* 1.6433	* 1.7147	* 2.4622	*
12	* 1.6110	* 1.6688	* 1.6843	* 1.8976	* 1.8940	* 2.5582	*	
	* 1.7052	* 1.7547	* 1.7635	* 1.9321	* 1.9313	* 2.5716	*	
	* 1.7849	* 1.8059	* 1.8238	* 1.9714	* 1.9788	* 2.5829	*	
	* 1.8180	* 1.8122	* 1.8465	* 1.9673	* 1.9926	* 2.5806	*	
	* 1.6982	* 1.6323	* 1.7087	* 1.7444	* 1.7979	* 2.2987	*	
	* 1.6416	* 1.5574	* 1.6421	* 1.6438	* 1.6660	* 2.1880	*	
13	* 1.7703	* 1.7233	* 1.7672	* 1.8526	* 2.5588	*		
	* 1.8800	* 1.8053	* 1.8273	* 1.8900	* 2.5739	*		
	* 1.9472	* 1.8780	* 1.8701	* 1.9372	* 2.5847	*		
	* 2.0035	* 1.9166	* 1.8928	* 1.9458	* 2.5823	*		
	* 1.9128	* 1.8097	* 1.7334	* 1.8027	* 2.3003	*		
	* 1.8290	* 1.7293	* 1.6349	* 1.7160	* 2.1896	*		
14	* 1.8158	* 1.8410	* 2.1489	* 2.7530	*			
	* 1.8655	* 1.8925	* 2.2347	* 2.7747	*			
	* 1.8941	* 1.8817	* 2.2955	* 2.7904	*			
	* 1.8565	* 1.9000	* 2.3552	* 2.8276	*			
	* 1.7915	* 1.8411	* 2.2406	* 2.6434	*			
	* 1.7262	* 1.7689	* 2.1107	* 2.4633	*			
15	* 2.8129	* 2.9620	* 4 EFPD 118	* % POWER				
	* 2.8340	* 2.9676	* 75 EFPD 118	* % POWER				
	* 2.8492	* 2.9555	* 150 EFPD 118	* % POWER				
	* 2.8429	* 2.9731	* 275 EFPD 118	* % POWER				
	* 2.7184	* 2.8527	* 375 EFPD 118	* % POWER				
	* 2.5227	* 2.6605	* 475 EFPD 118	* % POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 221 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4983	* 1.4939	* 1.6217	* 1.5484	* 1.4931	* 1.6387	* 1.6249	* 2.6151 *
	* 1.6010	* 1.6323	* 1.7498	* 1.6052	* 1.5676	* 1.7283	* 1.6438	* 2.5969 *
	* 1.6679	* 1.7409	* 1.8075	* 1.6450	* 1.6295	* 1.7818	* 1.6423	* 2.5859 *
	* 1.6673	* 1.7748	* 1.7839	* 1.6109	* 1.6520	* 1.8429	* 1.6348	* 2.6050 *
	* 1.5402	* 1.6910	* 1.6739	* 1.4894	* 1.5727	* 1.7938	* 1.6353	* 2.5610 *
	* 1.5318	* 1.6794	* 1.6622	* 1.5033	* 1.5616	* 1.7548	* 1.6105	* 2.4271 *
9	* 1.4939	* 1.4915	* 1.6251	* 1.5674	* 1.5280	* 1.5878	* 1.6417	* 2.7649 *
	* 1.6323	* 1.5928	* 1.7067	* 1.6492	* 1.5856	* 1.6489	* 1.6614	* 2.7280 *
	* 1.7409	* 1.6695	* 1.7405	* 1.6932	* 1.6045	* 1.7030	* 1.6292	* 2.6910 *
	* 1.7748	* 1.6579	* 1.6505	* 1.6732	* 1.5794	* 1.7376	* 1.6769	* 2.7376 *
	* 1.6910	* 1.5626	* 1.4891	* 1.5660	* 1.4495	* 1.6694	* 1.6723	* 2.7037 *
	* 1.6794	* 1.5641	* 1.5007	* 1.5568	* 1.4472	* 1.6421	* 1.6442	* 2.5789 *
10	* 1.6217	* 1.6222	* 1.6531	* 1.5940	* 1.5750	* 1.5995	* 2.0016	*
	* 1.7498	* 1.7047	* 1.7376	* 1.6399	* 1.6329	* 1.6290	* 2.0618	*
	* 1.8075	* 1.7406	* 1.7801	* 1.6703	* 1.6736	* 1.6513	* 2.1047	*
	* 1.7839	* 1.6505	* 1.7453	* 1.6263	* 1.6746	* 1.6531	* 2.1717	*
	* 1.6739	* 1.4890	* 1.6272	* 1.4830	* 1.5756	* 1.5378	* 2.1074	*
	* 1.6622	* 1.5006	* 1.6152	* 1.4942	* 1.5602	* 1.5115	* 2.0372	*
11	* 1.5484	* 1.5729	* 1.5961	* 1.6935	* 1.7466	* 1.6868	* 2.6374	*
	* 1.6052	* 1.6546	* 1.6418	* 1.7776	* 1.7489	* 1.6929	* 2.6226	*
	* 1.6450	* 1.6975	* 1.6733	* 1.8149	* 1.7580	* 1.7028	* 2.6140	*
	* 1.6109	* 1.6754	* 1.6288	* 1.7915	* 1.7172	* 1.7007	* 2.6480	*
	* 1.4894	* 1.5675	* 1.4837	* 1.6627	* 1.5402	* 1.5882	* 2.5208	*
	* 1.5033	* 1.5581	* 1.4944	* 1.6385	* 1.5216	* 1.5758	* 2.4111	*
12	* 1.4931	* 1.5406	* 1.5799	* 1.7493	* 1.7485	* 2.4731	*	
	* 1.5676	* 1.5995	* 1.6378	* 1.7513	* 1.7531	* 2.4400	*	
	* 1.6295	* 1.6199	* 1.6778	* 1.7603	* 1.7739	* 2.4211	*	
	* 1.6520	* 1.5889	* 1.6782	* 1.7191	* 1.7561	* 2.3916	*	
	* 1.5727	* 1.4546	* 1.5781	* 1.5413	* 1.5503	* 2.1446	*	
	* 1.5616	* 1.4494	* 1.5619	* 1.5220	* 1.5121	* 2.0905	*	
13	* 1.6387	* 1.5988	* 1.6067	* 1.6913	* 2.4728	*		
	* 1.7283	* 1.6584	* 1.6343	* 1.6967	* 2.4412	*		
	* 1.7818	* 1.7109	* 1.6562	* 1.7062	* 2.4219	*		
	* 1.8429	* 1.7448	* 1.6582	* 1.7034	* 2.3919	*		
	* 1.7938	* 1.6751	* 1.5412	* 1.5900	* 2.1447	*		
	* 1.7548	* 1.6461	* 1.5132	* 1.5767	* 2.0909	*		
14	* 1.6249	* 1.6470	* 2.0120	* 2.6508	*			
	* 1.6438	* 1.6664	* 2.0710	* 2.6336	*			
	* 1.6423	* 1.6337	* 2.1131	* 2.6237	*			
	* 1.6348	* 1.6810	* 2.1790	* 2.6572	*			
	* 1.6353	* 1.6753	* 2.1132	* 2.5259	*			
	* 1.6105	* 1.6466	* 2.0405	* 2.4113	*			
15	* 2.6151	* 2.8132	* 4 EFPD 118 % POWER					
	* 2.5969	* 2.7745	* 75 EFPD 118 % POWER					
	* 2.5859	* 2.7362	* 150 EFPD 118 % POWER					
	* 2.6050	* 2.7766	* 275 EFPD 118 % POWER					
	* 2.5610	* 2.7352	* 375 EFPD 118 % POWER					
	* 2.4271	* 2.6039	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 222 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5029	* 1.5166	* 1.6472	* 1.5444	* 1.4905	* 1.6414	* 1.6041	* 2.6007
	* 1.6023	* 1.6523	* 1.7631	* 1.5891	* 1.5548	* 1.7195	* 1.6062	* 2.5516
	* 1.6597	* 1.7489	* 1.8053	* 1.6153	* 1.6083	* 1.7669	* 1.5879	* 2.5265
	* 1.6310	* 1.7580	* 1.7536	* 1.5573	* 1.6222	* 1.8349	* 1.6131	* 2.5850
	* 1.5354	* 1.7082	* 1.6838	* 1.4832	* 1.5764	* 1.8168	* 1.6510	* 2.5949
	* 1.5584	* 1.7225	* 1.6990	* 1.5262	* 1.5937	* 1.8035	* 1.6468	* 2.4894
9	* 1.5166	* 1.5104	* 1.6402	* 1.5822	* 1.5252	* 1.5877	* 1.6222	* 2.7479
	* 1.6523	* 1.6046	* 1.7061	* 1.6531	* 1.5614	* 1.6293	* 1.6143	* 2.6780
	* 1.7489	* 1.6692	* 1.7195	* 1.6824	* 1.5693	* 1.6736	* 1.5804	* 2.6270
	* 1.7580	* 1.6269	* 1.5933	* 1.6399	* 1.5259	* 1.7114	* 1.6544	* 2.7045
	* 1.7082	* 1.5700	* 1.4849	* 1.5717	* 1.4353	* 1.6740	* 1.6846	* 2.7187
	* 1.7225	* 1.5979	* 1.5266	* 1.5911	* 1.4660	* 1.6767	* 1.6786	* 2.6271
10	* 1.6472	* 1.6369	* 1.6641	* 1.5935	* 1.5771	* 1.5808	* 1.9762	*
	* 1.7631	* 1.7041	* 1.7482	* 1.6247	* 1.6219	* 1.5846	* 2.0156	*
	* 1.8053	* 1.7199	* 1.7773	* 1.6369	* 1.6524	* 1.5997	* 2.0497	*
	* 1.7536	* 1.5935	* 1.7145	* 1.5678	* 1.6375	* 1.5989	* 2.1307	*
	* 1.6838	* 1.4848	* 1.6367	* 1.4761	* 1.5720	* 1.5187	* 2.1015	*
	* 1.6990	* 1.5265	* 1.6530	* 1.5162	* 1.5869	* 1.5281	* 2.0635	*
11	* 1.5444	* 1.5886	* 1.5961	* 1.6958	* 1.7242	* 1.6503	* 2.5901	*
	* 1.5891	* 1.6594	* 1.6270	* 1.7746	* 1.7073	* 1.6366	* 2.5461	*
	* 1.6153	* 1.6873	* 1.6405	* 1.7984	* 1.7029	* 1.6257	* 2.5249	*
	* 1.5573	* 1.6424	* 1.5706	* 1.7499	* 1.6385	* 1.6254	* 2.5645	*
	* 1.4832	* 1.5733	* 1.4767	* 1.6602	* 1.5040	* 1.5442	* 2.4573	*
	* 1.5262	* 1.5926	* 1.5168	* 1.6657	* 1.5229	* 1.5600	* 2.4049	*
12	* 1.4905	* 1.5391	* 1.5830	* 1.7274	* 1.7162	* 2.4191	*	*
	* 1.5548	* 1.5790	* 1.6277	* 1.7102	* 1.6980	* 2.3536	*	*
	* 1.6083	* 1.5858	* 1.6574	* 1.7055	* 1.7042	* 2.3123	*	*
	* 1.6222	* 1.5360	* 1.6415	* 1.6405	* 1.6669	* 2.2590	*	*
	* 1.5764	* 1.4392	* 1.5746	* 1.5045	* 1.4905	* 2.0712	*	*
	* 1.5937	* 1.4682	* 1.5887	* 1.5230	* 1.4903	* 2.0549	*	*
13	* 1.6414	* 1.5997	* 1.5878	* 1.6555	* 2.4186	*	*	*
	* 1.7195	* 1.6396	* 1.5907	* 1.6410	* 2.3546	*	*	*
	* 1.7669	* 1.6822	* 1.6052	* 1.6294	* 2.3128	*	*	*
	* 1.8349	* 1.7193	* 1.6042	* 1.6281	* 2.2587	*	*	*
	* 1.8168	* 1.6799	* 1.5219	* 1.5456	* 2.0711	*	*	*
	* 1.8035	* 1.6807	* 1.5296	* 1.5607	* 2.0548	*	*	*
14	* 1.6041	* 1.6283	* 1.9873	* 2.6038	*	*	*	*
	* 1.6062	* 1.6199	* 2.0253	* 2.5594	*	*	*	*
	* 1.5879	* 1.5853	* 2.0584	* 2.5364	*	*	*	*
	* 1.6131	* 1.6586	* 2.1378	* 2.5724	*	*	*	*
	* 1.6510	* 1.6876	* 2.1066	* 2.4625	*	*	*	*
	* 1.6468	* 1.6811	* 2.0668	* 2.4050	*	*	*	*
15	* 2.6007	* 2.7909	* 4 EFPD 118 % POWER					
	* 2.5516	* 2.7175	* 75 EFPD 118 % POWER					
	* 2.5265	* 2.6642	* 150 EFPD 118 % POWER					
	* 2.5850	* 2.7415	* 275 EFPD 118 % POWER					
	* 2.5949	* 2.7529	* 375 EFPD 118 % POWER					
	* 2.4894	* 2.6573	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 223 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5144	* 1.5375	* 1.6713	* 1.5444	* 1.4914	* 1.6523	* 1.6079	* 2.6259 *
	* 1.6118	* 1.6737	* 1.7795	* 1.5812	* 1.5496	* 1.7227	* 1.5996	* 2.5564 *
	* 1.6631	* 1.7665	* 1.8146	* 1.5984	* 1.5997	* 1.7673	* 1.5760	* 2.5299 *
	* 1.6100	* 1.7458	* 1.7357	* 1.5238	* 1.6057	* 1.8465	* 1.6402	* 2.6400 *
	* 1.5466	* 1.7305	* 1.7083	* 1.4953	* 1.5951	* 1.8556	* 1.7047	* 2.6803 *
	* 1.5821	* 1.7587	* 1.7378	* 1.5528	* 1.6276	* 1.8554	* 1.7095	* 2.5874 *
9	* 1.5375	* 1.5337	* 1.6618	* 1.5942	* 1.5255	* 1.5869	* 1.6232	* 2.7646 *
	* 1.6737	* 1.6243	* 1.7196	* 1.6565	* 1.5484	* 1.6167	* 1.5969	* 2.6717 *
	* 1.7665	* 1.6796	* 1.7181	* 1.6770	* 1.5502	* 1.6580	* 1.5658	* 2.6161 *
	* 1.7458	* 1.6133	* 1.5665	* 1.6260	* 1.4944	* 1.7048	* 1.6736	* 2.7469 *
	* 1.7305	* 1.5920	* 1.5060	* 1.5985	* 1.4422	* 1.6969	* 1.7291	* 2.7959 *
	* 1.7587	* 1.6353	* 1.5615	* 1.6319	* 1.4893	* 1.7151	* 1.7330	* 2.7166 *
10	* 1.6713	* 1.6581	* 1.6851	* 1.6029	* 1.5786	* 1.5642	* 1.9690	*
	* 1.7795	* 1.7175	* 1.7693	* 1.6188	* 1.6124	* 1.5562	* 1.9940	*
	* 1.8146	* 1.7187	* 1.7887	* 1.6179	* 1.6349	* 1.5652	* 2.0245	*
	* 1.7357	* 1.5667	* 1.7046	* 1.5340	* 1.6112	* 1.5662	* 2.1248	*
	* 1.7083	* 1.5059	* 1.6703	* 1.4887	* 1.5843	* 1.5182	* 2.1260	*
	* 1.7378	* 1.5613	* 1.7008	* 1.5442	* 1.6147	* 1.5429	* 2.1016	*
11	* 1.5444	* 1.6014	* 1.6060	* 1.7063	* 1.7118	* 1.6336	* 2.5655	*
	* 1.5812	* 1.6641	* 1.6223	* 1.7771	* 1.6805	* 1.6046	* 2.4974	*
	* 1.5984	* 1.6840	* 1.6221	* 1.7877	* 1.6659	* 1.5832	* 2.4661	*
	* 1.5238	* 1.6287	* 1.5371	* 1.7247	* 1.5858	* 1.5781	* 2.5081	*
	* 1.4953	* 1.6003	* 1.4900	* 1.6729	* 1.4946	* 1.5401	* 2.4475	*
	* 1.5528	* 1.6334	* 1.5448	* 1.6838	* 1.5313	* 1.5706	* 2.4089	*
12	* 1.4914	* 1.5404	* 1.5854	* 1.7159	* 1.7023	* 2.4070	*	
	* 1.5496	* 1.5672	* 1.6190	* 1.6837	* 1.6690	* 2.3176	*	
	* 1.5997	* 1.5667	* 1.6406	* 1.6688	* 1.6643	* 2.2599	*	
	* 1.6057	* 1.5035	* 1.6155	* 1.5879	* 1.6067	* 2.1787	*	
	* 1.5951	* 1.4460	* 1.5868	* 1.4950	* 1.4774	* 2.0546	*	
	* 1.6276	* 1.4913	* 1.6165	* 1.5314	* 1.4991	* 2.0608	*	
13	* 1.6523	* 1.5983	* 1.5721	* 1.6393	* 2.4067	*		
	* 1.7227	* 1.6281	* 1.5631	* 1.6094	* 2.3186	*		
	* 1.7673	* 1.6676	* 1.5712	* 1.5870	* 2.2600	*		
	* 1.8465	* 1.7132	* 1.5719	* 1.5808	* 2.1787	*		
	* 1.8556	* 1.7028	* 1.5200	* 1.5412	* 2.0541	*		
	* 1.8554	* 1.7192	* 1.5436	* 1.5711	* 2.0605	*		
14	* 1.6079	* 1.6300	* 1.9812	* 2.5800	*			
	* 1.5996	* 1.6031	* 2.0045	* 2.5113	*			
	* 1.5760	* 1.5712	* 2.0338	* 2.4780	*			
	* 1.6402	* 1.6779	* 2.1322	* 2.5160	*			
	* 1.7047	* 1.7321	* 2.1310	* 2.4525	*			
	* 1.7095	* 1.7355	* 2.1049	* 2.4087	*			
15	* 2.6259	* 2.8063	* 4 EFPD 118 % POWER					
	* 2.5565	* 2.7135	* 75 EFPD 118 % POWER					
	* 2.5299	* 2.6584	* 150 EFPD 118 % POWER					
	* 2.6400	* 2.7859	* 275 EFPD 118 % POWER					
	* 2.6803	* 2.8293	* 375 EFPD 118 % POWER					
	* 2.5873	* 2.7457	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 224 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5203	* 1.5481	* 1.6820	* 1.5368	* 1.4820	* 1.6438	* 1.5890	* 2.6412 *
	* 1.6120	* 1.6809	* 1.7816	* 1.5643	* 1.5336	* 1.7081	* 1.5705	* 2.5545 *
	* 1.6541	* 1.7672	* 1.8078	* 1.5716	* 1.5781	* 1.7507	* 1.5392	* 2.5251 *
	* 1.5711	* 1.7324	* 1.7105	* 1.4770	* 1.5785	* 1.8426	* 1.6389	* 2.6776 *
	* 1.5445	* 1.7434	* 1.7189	* 1.4985	* 1.6078	* 1.8738	* 1.7256	* 2.7492 *
	* 1.5739	* 1.7667	* 1.7454	* 1.5547	* 1.6370	* 1.8755	* 1.7296	* 2.6514 *
9	* 1.5481	* 1.5367	* 1.6594	* 1.5967	* 1.5141	* 1.5735	* 1.6012	* 2.7891 *
	* 1.6809	* 1.6233	* 1.7131	* 1.6516	* 1.5253	* 1.5944	* 1.5596	* 2.6798 *
	* 1.7672	* 1.6712	* 1.6913	* 1.6630	* 1.5187	* 1.6310	* 1.5298	* 2.6249 *
	* 1.7324	* 1.5920	* 1.5210	* 1.6019	* 1.4464	* 1.6815	* 1.6665	* 2.7970 *
	* 1.7434	* 1.6030	* 1.5080	* 1.6089	* 1.4403	* 1.7089	* 1.7439	* 2.8789 *
	* 1.7667	* 1.6474	* 1.5683	* 1.6477	* 1.4931	* 1.7291	* 1.7471	* 2.7915 *
10	* 1.6820	* 1.6556	* 1.7142	* 1.5898	* 1.5742	* 1.5440	* 1.9665	*
	* 1.7816	* 1.7124	* 1.7672	* 1.5938	* 1.6006	* 1.5254	* 1.9806	*
	* 1.8078	* 1.6921	* 1.7778	* 1.5848	* 1.6169	* 1.5279	* 2.0085	*
	* 1.7105	* 1.5214	* 1.6852	* 1.4837	* 1.5780	* 1.5184	* 2.1298	*
	* 1.7189	* 1.5079	* 1.6839	* 1.4916	* 1.5941	* 1.5062	* 2.1601	*
	* 1.7454	* 1.5681	* 1.7183	* 1.5488	* 1.6258	* 1.5415	* 2.1403	*
11	* 1.5368	* 1.6045	* 1.5933	* 1.7161	* 1.6971	* 1.6176	* 2.5982	*
	* 1.5643	* 1.6598	* 1.5976	* 1.7620	* 1.6553	* 1.5779	* 2.5111	*
	* 1.5716	* 1.6694	* 1.5893	* 1.7684	* 1.6321	* 1.5452	* 2.4709	*
	* 1.4770	* 1.6047	* 1.4869	* 1.6896	* 1.5238	* 1.5335	* 2.4985	*
	* 1.4985	* 1.6105	* 1.4927	* 1.6754	* 1.4816	* 1.5294	* 2.4826	*
	* 1.5547	* 1.6491	* 1.5489	* 1.6890	* 1.5331	* 1.5710	* 2.4462	*
12	* 1.4820	* 1.5294	* 1.5817	* 1.7019	* 1.6892	* 2.4353	*	
	* 1.5336	* 1.5448	* 1.6078	* 1.6587	* 1.6452	* 2.3267	*	
	* 1.5781	* 1.5362	* 1.6231	* 1.6351	* 1.6328	* 2.2609	*	
	* 1.5785	* 1.4540	* 1.5826	* 1.5258	* 1.5544	* 2.1673	*	
	* 1.6078	* 1.4439	* 1.5966	* 1.4818	* 1.4608	* 2.0835	*	
	* 1.6370	* 1.4949	* 1.6275	* 1.5331	* 1.5003	* 2.1061	*	
13	* 1.6438	* 1.5861	* 1.5524	* 1.6237	* 2.4344	*		
	* 1.7081	* 1.6067	* 1.5327	* 1.5829	* 2.3273	*		
	* 1.7507	* 1.6413	* 1.5343	* 1.5492	* 2.2609	*		
	* 1.8426	* 1.6905	* 1.5242	* 1.5360	* 2.1662	*		
	* 1.8738	* 1.7149	* 1.5077	* 1.5302	* 2.0823	*		
	* 1.8755	* 1.7331	* 1.5419	* 1.5713	* 2.1053	*		
14	* 1.5890	* 1.6084	* 1.9796	* 2.6144	*			
	* 1.5705	* 1.5662	* 1.9919	* 2.5258	*			
	* 1.5392	* 1.5354	* 2.0183	* 2.4831	*			
	* 1.6389	* 1.6711	* 2.1374	* 2.5059	*			
	* 1.7256	* 1.7469	* 2.1646	* 2.4869	*			
	* 1.7296	* 1.7496	* 2.1433	* 2.4454	*			
15	* 2.6412	* 2.8374	* 4 EFPD 118	% POWER				
	* 2.5545	* 2.7242	* 75 EFPD 118	% POWER				
	* 2.5251	* 2.6623	* 150 EFPD 118	% POWER				
	* 2.6776	* 2.8317	* 275 EFPD 118	% POWER				
	* 2.7492	* 2.9113	* 375 EFPD 118	% POWER				
	* 2.6514	* 2.8237	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 225 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5698	* 1.5989	* 1.7365	* 1.5747	* 1.5131	* 1.6794	* 1.6067	* 2.6772 *
	* 1.6608	* 1.7334	* 1.8318	* 1.5970	* 1.5613	* 1.7399	* 1.5775	* 2.5722 *
	* 1.6974	* 1.8169	* 1.8513	* 1.5968	* 1.6030	* 1.7806	* 1.5376	* 2.5345 *
	* 1.5816	* 1.7487	* 1.7183	* 1.4761	* 1.5872	* 1.8605	* 1.6633	* 2.7381 *
	* 1.5834	* 1.8001	* 1.7729	* 1.5339	* 1.6496	* 1.9286	* 1.7611	* 2.8054 *
	* 1.5896	* 1.7877	* 1.7642	* 1.5690	* 1.6557	* 1.8941	* 1.7519	* 2.6923 *
9	* 1.5989	* 1.5812	* 1.7099	* 1.6414	* 1.5495	* 1.6037	* 1.6210	* 2.8284 *
	* 1.7334	* 1.6665	* 1.7520	* 1.6915	* 1.5514	* 1.6187	* 1.5652	* 2.6991 *
	* 1.8169	* 1.7088	* 1.7208	* 1.6957	* 1.5383	* 1.6526	* 1.5329	* 2.6353 *
	* 1.7487	* 1.5915	* 1.5090	* 1.5998	* 1.4406	* 1.6884	* 1.6862	* 2.8565 *
	* 1.8001	* 1.6477	* 1.5475	* 1.6571	* 1.4710	* 1.7470	* 1.7817	* 2.9292 *
	* 1.7877	* 1.6590	* 1.5770	* 1.6613	* 1.5040	* 1.7420	* 1.7658	* 2.8299 *
10	* 1.7365	* 1.7058	* 1.7644	* 1.6262	* 1.6118	* 1.5702	* 2.0036	*
	* 1.8318	* 1.7536	* 1.8097	* 1.6230	* 1.6330	* 1.5437	* 2.0074	*
	* 1.8513	* 1.7217	* 1.8137	* 1.6071	* 1.6443	* 1.5414	* 2.0315	*
	* 1.7183	* 1.5093	* 1.6856	* 1.4744	* 1.5828	* 1.5170	* 2.1420	*
	* 1.7729	* 1.5472	* 1.7340	* 1.5211	* 1.6329	* 1.5275	* 2.2070	*
	* 1.7642	* 1.5768	* 1.7349	* 1.5581	* 1.6442	* 1.5608	* 2.1513	*
11	* 1.5747	* 1.6500	* 1.6307	* 1.7586	* 1.7310	* 1.6471	* 2.6588	*
	* 1.5970	* 1.6995	* 1.6272	* 1.8001	* 1.6814	* 1.5974	* 2.5549	*
	* 1.5968	* 1.7029	* 1.6120	* 1.8001	* 1.6503	* 1.5575	* 2.5083	*
	* 1.4761	* 1.6028	* 1.4776	* 1.6870	* 1.5175	* 1.5376	* 2.5201	*
	* 1.5339	* 1.6587	* 1.5221	* 1.7026	* 1.5040	* 1.5545	* 2.5257	*
	* 1.5690	* 1.6628	* 1.5582	* 1.7118	* 1.5536	* 1.5936	* 2.4748	*
12	* 1.5131	* 1.5659	* 1.6201	* 1.7364	* 1.7209	* 2.4828	*	
	* 1.5613	* 1.5722	* 1.6409	* 1.6851	* 1.6665	* 2.3567	*	
	* 1.6030	* 1.5566	* 1.6510	* 1.6545	* 1.6517	* 2.2877	*	
	* 1.5872	* 1.4482	* 1.5876	* 1.5195	* 1.5520	* 2.1759	*	
	* 1.6496	* 1.4744	* 1.6353	* 1.5041	* 1.4821	* 2.1231	*	
	* 1.6557	* 1.5058	* 1.6459	* 1.5535	* 1.5231	* 2.1346	*	
13	* 1.6794	* 1.6175	* 1.5795	* 1.6538	* 2.4819	*		
	* 1.7399	* 1.6321	* 1.5516	* 1.6029	* 2.3572	*		
	* 1.7806	* 1.6638	* 1.5486	* 1.5618	* 2.2875	*		
	* 1.8605	* 1.6978	* 1.5229	* 1.5400	* 2.1743	*		
	* 1.9286	* 1.7531	* 1.5288	* 1.5550	* 2.1214	*		
	* 1.8941	* 1.7462	* 1.5610	* 1.5937	* 2.1334	*		
14	* 1.6067	* 1.6287	* 2.0178	* 2.6767	*			
	* 1.5775	* 1.5724	* 2.0195	* 2.5705	*			
	* 1.5376	* 1.5389	* 2.0419	* 2.5212	*			
	* 1.6633	* 1.6909	* 2.1498	* 2.5276	*			
	* 1.7611	* 1.7845	* 2.2116	* 2.5295	*			
	* 1.7519	* 1.7681	* 2.1542	* 2.4737	*			
15	* 2.6772	* 2.8770	* 4 EFPD 118 % POWER					
	* 2.5722	* 2.7413	* 75 EFPD 118 % POWER					
	* 2.5345	* 2.6732	* 150 EFPD 118 % POWER					
	* 2.7381	* 2.8941	* 275 EFPD 118 % POWER					
	* 2.8054	* 2.9656	* 375 EFPD 118 % POWER					
	* 2.6923	* 2.8623	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 226 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5900	* 1.6264	* 1.7678	* 1.5870	* 1.5277	* 1.7009	* 1.6150	* 2.7381 *
	* 1.6810	* 1.7644	* 1.8629	* 1.6063	* 1.5758	* 1.7619	* 1.5804	* 2.6231 *
	* 1.7163	* 1.8507	* 1.8827	* 1.6052	* 1.6214	* 1.8088	* 1.5390	* 2.5863 *
	* 1.5916	* 1.7791	* 1.7448	* 1.4797	* 1.6083	* 1.8901	* 1.6617	* 2.7801 *
	* 1.6007	* 1.8475	* 1.8144	* 1.5489	* 1.6743	* 1.9776	* 1.7838	* 2.8969 *
	* 1.6036	* 1.8155	* 1.7913	* 1.5832	* 1.6785	* 1.9156	* 1.7376	* 2.7032 *
9	* 1.6264	* 1.6058	* 1.7281	* 1.6665	* 1.5583	* 1.6174	* 1.6281	* 2.9047 *
	* 1.7644	* 1.6924	* 1.7660	* 1.7149	* 1.5573	* 1.6304	* 1.5642	* 2.7640 *
	* 1.8507	* 1.7350	* 1.7327	* 1.7188	* 1.5439	* 1.6691	* 1.5389	* 2.7034 *
	* 1.7791	* 1.6091	* 1.5059	* 1.6202	* 1.4390	* 1.7093	* 1.6872	* 2.9221 *
	* 1.8475	* 1.6915	* 1.5736	* 1.6940	* 1.4809	* 1.7726	* 1.8021	* 3.0576 *
	* 1.8155	* 1.6776	* 1.5867	* 1.6858	* 1.5149	* 1.7615	* 1.7550	* 2.8662 *
10	* 1.7678	* 1.7240	* 1.7930	* 1.6360	* 1.6293	* 1.5738	* 2.0459	*
	* 1.8629	* 1.7687	* 1.8369	* 1.6284	* 1.6485	* 1.5425	* 2.0462	*
	* 1.8827	* 1.7338	* 1.8414	* 1.6122	* 1.6619	* 1.5405	* 2.0770	*
	* 1.7448	* 1.5063	* 1.7045	* 1.4744	* 1.6031	* 1.5175	* 2.1931	*
	* 1.8144	* 1.5734	* 1.7841	* 1.5355	* 1.6569	* 1.5419	* 2.2743	*
	* 1.7913	* 1.5865	* 1.7574	* 1.5711	* 1.6699	* 1.5715	* 2.1956	*
11	* 1.5870	* 1.6757	* 1.6409	* 1.7967	* 1.7365	* 1.6511	* 2.7342	*
	* 1.6063	* 1.7227	* 1.6328	* 1.8200	* 1.6822	* 1.5970	* 2.6187	*
	* 1.6052	* 1.7264	* 1.6175	* 1.8189	* 1.6468	* 1.5510	* 2.5718	*
	* 1.4797	* 1.6232	* 1.4776	* 1.7072	* 1.5157	* 1.5441	* 2.5995	*
	* 1.5489	* 1.6958	* 1.5360	* 1.7336	* 1.5216	* 1.5723	* 2.6133	*
	* 1.5832	* 1.6873	* 1.5714	* 1.7407	* 1.5688	* 1.6046	* 2.5516	*
12	* 1.5277	* 1.5751	* 1.6384	* 1.7421	* 1.7278	* 2.5452	*	
	* 1.5758	* 1.5788	* 1.6571	* 1.6865	* 1.6693	* 2.4077	*	
	* 1.6214	* 1.5594	* 1.6691	* 1.6513	* 1.6505	* 2.3323	*	
	* 1.6083	* 1.4468	* 1.6081	* 1.5176	* 1.5490	* 2.2342	*	
	* 1.6743	* 1.4841	* 1.6593	* 1.5216	* 1.4984	* 2.2010	*	
	* 1.6785	* 1.5165	* 1.6717	* 1.5687	* 1.5354	* 2.2021	*	
13	* 1.7009	* 1.6322	* 1.5836	* 1.6581	* 2.5438	*		
	* 1.7619	* 1.6447	* 1.5509	* 1.6027	* 2.4079	*		
	* 1.8088	* 1.6811	* 1.5477	* 1.5554	* 2.3316	*		
	* 1.8901	* 1.7191	* 1.5234	* 1.5465	* 2.2321	*		
	* 1.9776	* 1.7786	* 1.5429	* 1.5725	* 2.1984	*		
	* 1.9156	* 1.7658	* 1.5715	* 1.6046	* 2.1998	*		
14	* 1.6150	* 1.6362	* 2.0617	* 2.7506	*			
	* 1.5804	* 1.5718	* 2.0597	* 2.6328	*			
	* 1.5390	* 1.5451	* 2.0886	* 2.5832	*			
	* 1.6617	* 1.6919	* 2.2016	* 2.6087	*			
	* 1.7838	* 1.8050	* 2.2793	* 2.6170	*			
	* 1.7376	* 1.7572	* 2.1989	* 2.5496	*			
15	* 2.7381	* 2.9664	* 4 EFPD 118	% POWER				
	* 2.6231	* 2.8200	* 75 EFPD 118	% POWER				
	* 2.5863	* 2.7541	* 150 EFPD 118	% POWER				
	* 2.7801	* 2.9611	* 275 EFPD 118	% POWER				
	* 2.8969	* 3.0901	* 375 EFPD 118	% POWER				
	* 2.7032	* 2.8963	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 227 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7071	* 1.7353	* 1.8812	* 1.6944	* 1.6157	* 1.7979	* 1.7098	* 2.8400 *
	* 1.8058	* 1.8808	* 1.9782	* 1.7153	* 1.6647	* 1.8593	* 1.6685	* 2.7105 *
	* 1.8408	* 1.9671	* 1.9967	* 1.7092	* 1.7099	* 1.9004	* 1.6248	* 2.6713 *
	* 1.7152	* 1.8809	* 1.8577	* 1.5868	* 1.7110	* 1.9952	* 1.7741	* 2.9053 *
	* 1.7022	* 1.9347	* 1.9178	* 1.6485	* 1.7733	* 2.0486	* 1.8864	* 3.0053 *
	* 1.6938	* 1.8969	* 1.8920	* 1.6756	* 1.7709	* 2.0004	* 1.8238	* 2.7721 *
9	* 1.7353	* 1.7103	* 1.8594	* 1.7615	* 1.6617	* 1.7096	* 1.7266	* 2.9737 *
	* 1.8808	* 1.8007	* 1.8876	* 1.8176	* 1.6563	* 1.7203	* 1.6533	* 2.8191 *
	* 1.9671	* 1.8410	* 1.8489	* 1.8167	* 1.6400	* 1.7579	* 1.6232	* 2.7526 *
	* 1.8809	* 1.6995	* 1.6165	* 1.7214	* 1.5410	* 1.8173	* 1.8021	* 3.0006 *
	* 1.9347	* 1.7599	* 1.6636	* 1.7828	* 1.5740	* 1.8688	* 1.9027	* 3.1112 *
	* 1.8969	* 1.7517	* 1.6799	* 1.7762	* 1.6021	* 1.8525	* 1.8458	* 2.8884 *
10	* 1.8812	* 1.8544	* 1.8847	* 1.7440	* 1.7258	* 1.6700	* 2.1166	*
	* 1.9782	* 1.8906	* 1.9467	* 1.7358	* 1.7430	* 1.6350	* 2.1092	*
	* 1.9967	* 1.8501	* 1.9488	* 1.7146	* 1.7526	* 1.6326	* 2.1365	*
	* 1.8577	* 1.6169	* 1.8127	* 1.5792	* 1.7022	* 1.6244	* 2.2768	*
	* 1.9178	* 1.6632	* 1.8733	* 1.6302	* 1.7512	* 1.6409	* 2.3234	*
	* 1.8920	* 1.6796	* 1.8555	* 1.6630	* 1.7585	* 1.6607	* 2.2426	*
11	* 1.6944	* 1.7793	* 1.7494	* 1.8729	* 1.8508	* 1.7581	* 2.8028	*
	* 1.7153	* 1.8262	* 1.7408	* 1.9195	* 1.7897	* 1.6943	* 2.6743	*
	* 1.7092	* 1.8254	* 1.7204	* 1.9208	* 1.7477	* 1.6449	* 2.6204	*
	* 1.5868	* 1.7247	* 1.5827	* 1.8132	* 1.6225	* 1.6492	* 2.6718	*
	* 1.6485	* 1.7847	* 1.6310	* 1.8371	* 1.6232	* 1.6768	* 2.6674	*
	* 1.6756	* 1.7778	* 1.6632	* 1.8372	* 1.6604	* 1.6998	* 2.5900	*
12	* 1.6157	* 1.6855	* 1.7358	* 1.8571	* 1.8425	* 2.6197	*	*
	* 1.6647	* 1.6803	* 1.7525	* 1.7944	* 1.7743	* 2.4694	*	*
	* 1.7099	* 1.6543	* 1.7606	* 1.7525	* 1.7482	* 2.3773	*	*
	* 1.7110	* 1.5496	* 1.7075	* 1.6245	* 1.6557	* 2.2890	*	*
	* 1.7733	* 1.5773	* 1.7535	* 1.6231	* 1.6002	* 2.2537	*	*
	* 1.7709	* 1.6037	* 1.7602	* 1.6602	* 1.6269	* 2.2370	*	*
13	* 1.7979	* 1.7259	* 1.6810	* 1.7659	* 2.6194	*	*	*
	* 1.8593	* 1.7359	* 1.6444	* 1.7007	* 2.4707	*	*	*
	* 1.9004	* 1.7709	* 1.6408	* 1.6498	* 2.3780	*	*	*
	* 1.9952	* 1.8277	* 1.6309	* 1.6517	* 2.2879	*	*	*
	* 2.0486	* 1.8748	* 1.6416	* 1.6768	* 2.2516	*	*	*
	* 2.0004	* 1.8568	* 1.6606	* 1.6995	* 2.2356	*	*	*
14	* 1.7098	* 1.7358	* 2.1331	* 2.8224	*	*	*	*
	* 1.6685	* 1.6616	* 2.1231	* 2.6918	*	*	*	*
	* 1.6248	* 1.6299	* 2.1482	* 2.6347	*	*	*	*
	* 1.7741	* 1.8071	* 2.2851	* 2.6798	*	*	*	*
	* 1.8864	* 1.9056	* 2.3278	* 2.6710	*	*	*	*
	* 1.8238	* 1.8481	* 2.2454	* 2.5887	*	*	*	*
15	* 2.8400	* 3.0270	* 4 EFPD 118 % POWER					
	* 2.7105	* 2.8680	* 75 EFPD 118 % POWER					
	* 2.6713	* 2.7974	* 150 EFPD 118 % POWER					
	* 2.9053	* 3.0426	* 275 EFPD 118 % POWER					
	* 3.0053	* 3.1466	* 375 EFPD 118 % POWER					
	* 2.7721	* 2.9188	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 228 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7451	* 1.7866	* 1.9431	* 1.7226	* 1.6474	* 1.8379	* 1.7199	* 2.9313
	* 1.8440	* 1.9391	* 2.0431	* 1.7415	* 1.6992	* 1.9039	* 1.6727	* 2.7942
	* 1.8744	* 2.0285	* 2.0572	* 1.7310	* 1.7461	* 1.9412	* 1.6231	* 2.7521
	* 1.7371	* 1.9571	* 1.9152	* 1.6082	* 1.7602	* 2.0823	* 1.8141	* 3.0442
	* 1.7414	* 2.0231	* 1.9872	* 1.6876	* 1.8287	* 2.1412	* 1.8950	* 3.0959
	* 1.7306	* 1.9794	* 1.9541	* 1.7128	* 1.8214	* 2.0719	* 1.8408	* 2.8639
9	* 1.7866	* 1.7560	* 1.8920	* 1.8184	* 1.6847	* 1.7394	* 1.7356	* 3.1057
	* 1.9391	* 1.8502	* 1.9193	* 1.8676	* 1.6767	* 1.7512	* 1.6548	* 2.9401
	* 2.0285	* 1.8896	* 1.8755	* 1.8651	* 1.6553	* 1.7915	* 1.6279	* 2.8705
	* 1.9571	* 1.7600	* 1.6354	* 1.7736	* 1.5567	* 1.8692	* 1.8417	* 3.1901
	* 2.0231	* 1.8337	* 1.6992	* 1.8455	* 1.6067	* 1.9204	* 1.9141	* 3.2483
	* 1.9794	* 1.8217	* 1.7178	* 1.8366	* 1.6327	* 1.8993	* 1.8619	* 3.0273
10	* 1.9431	* 1.8872	* 1.9581	* 1.7701	* 1.7652	* 1.6857	* 2.2013	*
	* 2.0431	* 1.9227	* 2.0060	* 1.7595	* 1.7848	* 1.6478	* 2.1943	*
	* 2.0572	* 1.8769	* 2.0045	* 1.7344	* 1.7944	* 1.6425	* 2.2244	*
	* 1.9152	* 1.6357	* 1.8680	* 1.5975	* 1.7496	* 1.6413	* 2.3965	*
	* 1.9872	* 1.6988	* 1.9376	* 1.6679	* 1.8113	* 1.6706	* 2.4353	*
	* 1.9541	* 1.7175	* 1.9169	* 1.7001	* 1.8141	* 1.6862	* 2.3497	*
11	* 1.7226	* 1.8295	* 1.7758	* 1.9531	* 1.8714	* 1.7746	* 2.9577	*
	* 1.7415	* 1.8767	* 1.7648	* 1.9784	* 1.8082	* 1.7102	* 2.8218	*
	* 1.7310	* 1.8744	* 1.7406	* 1.9698	* 1.7601	* 1.6523	* 2.7638	*
	* 1.6082	* 1.7770	* 1.6010	* 1.8635	* 1.6339	* 1.6676	* 2.8236	*
	* 1.6876	* 1.8473	* 1.6685	* 1.9025	* 1.6589	* 1.7074	* 2.8338	*
	* 1.7128	* 1.8382	* 1.7001	* 1.8935	* 1.6924	* 1.7229	* 2.7413	*
12	* 1.6474	* 1.7060	* 1.7760	* 1.8780	* 1.8626	* 2.7460	*	*
	* 1.6993	* 1.7015	* 1.7950	* 1.8133	* 1.7943	* 2.5908	*	*
	* 1.7461	* 1.6678	* 1.8030	* 1.7652	* 1.7671	* 2.5011	*	*
	* 1.7602	* 1.5650	* 1.7551	* 1.6357	* 1.6576	* 2.4048	*	*
	* 1.8287	* 1.6099	* 1.8136	* 1.6588	* 1.6292	* 2.3977	*	*
	* 1.8214	* 1.6341	* 1.8159	* 1.6921	* 1.6514	* 2.3687	*	*
13	* 1.8379	* 1.7570	* 1.6972	* 1.7827	* 2.7444	*	*	*
	* 1.9039	* 1.7679	* 1.6577	* 1.7169	* 2.5908	*	*	*
	* 1.9412	* 1.8056	* 1.6509	* 1.6571	* 2.5002	*	*	*
	* 2.0823	* 1.8798	* 1.6476	* 1.6698	* 2.4020	*	*	*
	* 2.1412	* 1.9267	* 1.6710	* 1.7072	* 2.3939	*	*	*
	* 2.0719	* 1.9039	* 1.6859	* 1.7225	* 2.3657	*	*	*
14	* 1.7199	* 1.7450	* 2.2194	* 2.9766	*	*	*	*
	* 1.6727	* 1.6635	* 2.2097	* 2.8379	*	*	*	*
	* 1.6231	* 1.6348	* 2.2375	* 2.7766	*	*	*	*
	* 1.8141	* 1.8468	* 2.4050	* 2.8311	*	*	*	*
	* 1.8950	* 1.9169	* 2.4394	* 2.8366	*	*	*	*
	* 1.8408	* 1.8640	* 2.3524	* 2.7392	*	*	*	*
15	* 2.9313	* 3.1724	* 4 EFPD 118	% POWER				
	* 2.7942	* 2.9990	* 75 EFPD 118	% POWER				
	* 2.7521	* 2.9192	* 150 EFPD 118	% POWER				
	* 3.0442	* 3.2311	* 275 EFPD 118	% POWER				
	* 3.0959	* 3.2842	* 375 EFPD 118	% POWER				
	* 2.8639	* 3.0528	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 229 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7803 *	* 1.8232 *	* 1.9785 *	* 1.7667 *	* 1.7044 *	* 1.9064 *	* 1.7895 *	* 3.0494 *
	* 1.8995 *	* 1.9946 *	* 2.0984 *	* 1.8000 *	* 1.7696 *	* 1.9873 *	* 1.7423 *	* 2.9094 *
	* 1.9419 *	* 2.1022 *	* 2.1334 *	* 1.8097 *	* 1.8270 *	* 2.0326 *	* 1.6925 *	* 2.8695 *
	* 1.8232 *	* 2.0495 *	* 2.0091 *	* 1.6858 *	* 1.8499 *	* 2.1891 *	* 1.8978 *	* 3.1803 *
	* 1.7963 *	* 2.0782 *	* 2.0459 *	* 1.7538 *	* 1.9069 *	* 2.2462 *	* 1.9892 *	* 3.2404 *
	* 1.7564 *	* 2.0077 *	* 1.9816 *	* 1.7426 *	* 1.8593 *	* 2.1333 *	* 1.9201 *	* 2.9983 *
9	* 1.8232 *	* 1.7932 *	* 1.9281 *	* 1.8663 *	* 1.7330 *	* 1.8090 *	* 1.8063 *	* 3.2252 *
	* 1.9946 *	* 1.9049 *	* 1.9763 *	* 1.9308 *	* 1.7437 *	* 1.8275 *	* 1.7223 *	* 3.0552 *
	* 2.1022 *	* 1.9639 *	* 1.9510 *	* 1.9512 *	* 1.7264 *	* 1.8719 *	* 1.6987 *	* 2.9870 *
	* 2.0495 *	* 1.8449 *	* 1.7143 *	* 1.8658 *	* 1.6287 *	* 1.9601 *	* 1.9249 *	* 3.3174 *
	* 2.0782 *	* 1.8865 *	* 1.7574 *	* 1.9118 *	* 1.6815 *	* 2.0251 *	* 2.0110 *	* 3.3927 *
	* 2.0077 *	* 1.8477 *	* 1.7449 *	* 1.8674 *	* 1.6686 *	* 1.9551 *	* 1.9395 *	* 3.1583 *
10	* 1.9785 *	* 1.9233 *	* 2.0082 *	* 1.8199 *	* 1.8205 *	* 1.7515 *	* 2.2882 *	
	* 2.0984 *	* 1.9801 *	* 2.0705 *	* 1.8214 *	* 1.8519 *	* 1.7147 *	* 2.2832 *	
	* 2.1334 *	* 1.9525 *	* 2.0901 *	* 1.8100 *	* 1.8745 *	* 1.7099 *	* 2.3179 *	
	* 2.0091 *	* 1.7146 *	* 1.9661 *	* 1.6730 *	* 1.8378 *	* 1.7143 *	* 2.5049 *	
	* 2.0459 *	* 1.7570 *	* 2.0072 *	* 1.7396 *	* 1.8935 *	* 1.7675 *	* 2.5663 *	
	* 1.9816 *	* 1.7445 *	* 1.9516 *	* 1.7327 *	* 1.8526 *	* 1.7356 *	* 2.4311 *	
11	* 1.7667 *	* 1.8778 *	* 1.8263 *	* 1.9974 *	* 1.9350 *	* 1.8409 *	* 3.0613 *	
	* 1.8000 *	* 1.9405 *	* 1.8271 *	* 2.0421 *	* 1.8786 *	* 1.7759 *	* 2.9213 *	
	* 1.8097 *	* 1.9604 *	* 1.8165 *	* 2.0550 *	* 1.8290 *	* 1.7152 *	* 2.8622 *	
	* 1.6858 *	* 1.8694 *	* 1.6766 *	* 1.9589 *	* 1.7078 *	* 1.7428 *	* 2.9509 *	
	* 1.7538 *	* 1.9135 *	* 1.7401 *	* 1.9946 *	* 1.7494 *	* 1.8071 *	* 2.9905 *	
	* 1.7426 *	* 1.8691 *	* 1.7327 *	* 1.9349 *	* 1.7328 *	* 1.7757 *	* 2.8384 *	
12	* 1.7044 *	* 1.7527 *	* 1.8322 *	* 1.9424 *	* 1.9268 *	* 2.8291 *		
	* 1.7696 *	* 1.7691 *	* 1.8629 *	* 1.8839 *	* 1.8614 *	* 2.6795 *		
	* 1.8270 *	* 1.7397 *	* 1.8836 *	* 1.8342 *	* 1.8336 *	* 2.5861 *		
	* 1.8499 *	* 1.6374 *	* 1.8436 *	* 1.7096 *	* 1.7278 *	* 2.5092 *		
	* 1.9069 *	* 1.6848 *	* 1.8958 *	* 1.7492 *	* 1.7252 *	* 2.5257 *		
	* 1.8593 *	* 1.6702 *	* 1.8543 *	* 1.7324 *	* 1.6964 *	* 2.4293 *		
13	* 1.9064 *	* 1.8279 *	* 1.7636 *	* 1.8494 *	* 2.8266 *			
	* 1.9873 *	* 1.8453 *	* 1.7252 *	* 1.7829 *	* 2.6794 *			
	* 2.0326 *	* 1.8869 *	* 1.7185 *	* 1.7201 *	* 2.5849 *			
	* 2.1891 *	* 1.9713 *	* 1.7208 *	* 1.7449 *	* 2.5059 *			
	* 2.2462 *	* 2.0316 *	* 1.7676 *	* 1.8066 *	* 2.5221 *			
	* 2.1333 *	* 1.9599 *	* 1.7356 *	* 1.7751 *	* 2.4265 *			
14	* 1.7895 *	* 1.8164 *	* 2.3068 *	* 3.0800 *				
	* 1.7423 *	* 1.7316 *	* 2.2989 *	* 2.9387 *				
	* 1.6925 *	* 1.7059 *	* 2.3309 *	* 2.8779 *				
	* 1.8978 *	* 1.9301 *	* 2.5137 *	* 2.9585 *				
	* 1.9892 *	* 2.0138 *	* 2.5704 *	* 2.9930 *				
	* 1.9201 *	* 1.9418 *	* 2.4339 *	* 2.8361 *				
15	* 3.0494 *	* 3.2872 *	* 4 EFPD 118 % POWER					
	* 2.9094 *	* 3.1101 *	* 75 EFPD 118 % POWER					
	* 2.8695 *	* 3.0345 *	* 150 EFPD 118 % POWER					
	* 3.1803 *	* 3.3580 *	* 275 EFPD 118 % POWER					
	* 3.2404 *	* 3.4265 *	* 375 EFPD 118 % POWER					
	* 2.9983 *	* 3.1889 *	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 230 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7895	* 1.8249	* 1.9721	* 1.7690	* 1.6957	* 1.8972	* 1.7977	* 3.0476
	* 1.9059	* 1.9903	* 2.0882	* 1.7976	* 1.7535	* 1.9681	* 1.7525	* 2.8945
	* 1.9515	* 2.0934	* 2.1158	* 1.7979	* 1.8169	* 2.0386	* 1.7236	* 2.8828
	* 1.8165	* 2.0011	* 1.9828	* 1.6906	* 1.8520	* 2.1862	* 1.9854	* 3.3039
	* 1.8077	* 2.0633	* 2.0564	* 1.7700	* 1.9201	* 2.2260	* 2.0345	* 3.2878
	* 1.7687	* 1.9981	* 1.9969	* 1.7574	* 1.8734	* 2.1282	* 1.9331	* 2.9987
9	* 1.8249	* 1.7932	* 1.9405	* 1.8561	* 1.7371	* 1.7998	* 1.8124	* 3.1882
	* 1.9903	* 1.8991	* 1.9745	* 1.9177	* 1.7364	* 1.8137	* 1.7320	* 3.0045
	* 2.0934	* 1.9493	* 1.9429	* 1.9279	* 1.7285	* 1.8730	* 1.7277	* 2.9647
	* 2.0011	* 1.8023	* 1.7073	* 1.8463	* 1.6460	* 1.9933	* 2.0103	* 3.4010
	* 2.0633	* 1.8723	* 1.7722	* 1.9204	* 1.6975	* 2.0370	* 2.0554	* 3.3968
	* 1.9981	* 1.8393	* 1.7593	* 1.8789	* 1.6822	* 1.9677	* 1.9551	* 3.1194
10	* 1.9721	* 1.9352	* 1.9830	* 1.8188	* 1.8118	* 1.7497	* 2.2505	*
	* 2.0882	* 1.9784	* 2.0528	* 1.8142	* 1.8345	* 1.7143	* 2.2412	*
	* 2.1158	* 1.9446	* 2.0676	* 1.8015	* 1.8577	* 1.7241	* 2.2959	*
	* 1.9828	* 1.7077	* 1.9413	* 1.6815	* 1.8397	* 1.7590	* 2.5360	*
	* 2.0564	* 1.7717	* 2.0162	* 1.7551	* 1.9028	* 1.7857	* 2.5471	*
	* 1.9969	* 1.7589	* 1.9653	* 1.7472	* 1.8633	* 1.7500	* 2.4032	*
11	* 1.7690	* 1.8746	* 1.8255	* 1.9652	* 1.9302	* 1.8367	* 2.9921	*
	* 1.7976	* 1.9278	* 1.8202	* 2.0184	* 1.8667	* 1.7688	* 2.8435	*
	* 1.7979	* 1.9381	* 1.8084	* 2.0324	* 1.8380	* 1.7347	* 2.8186	*
	* 1.6906	* 1.8495	* 1.6850	* 1.9449	* 1.7304	* 1.7902	* 2.9575	*
	* 1.7700	* 1.9221	* 1.7555	* 2.0034	* 1.7633	* 1.8297	* 2.9488	*
	* 1.7574	* 1.8806	* 1.7470	* 1.9477	* 1.7458	* 1.7918	* 2.7909	*
12	* 1.6957	* 1.7578	* 1.8240	* 1.9380	* 1.9201	* 2.7701	*	*
	* 1.7535	* 1.7630	* 1.8458	* 1.8719	* 1.8468	* 2.5981	*	*
	* 1.8169	* 1.7444	* 1.8673	* 1.8437	* 1.8354	* 2.5301	*	*
	* 1.8520	* 1.6549	* 1.8453	* 1.7322	* 1.7645	* 2.4832	*	*
	* 1.9201	* 1.7007	* 1.9049	* 1.7630	* 1.7400	* 2.4758	*	*
	* 1.8734	* 1.6837	* 1.8650	* 1.7455	* 1.7105	* 2.3836	*	*
13	* 1.8972	* 1.8197	* 1.7630	* 1.8462	* 2.7697	*	*	*
	* 1.9681	* 1.8323	* 1.7257	* 1.7765	* 2.5997	*	*	*
	* 2.0386	* 1.8885	* 1.7334	* 1.7402	* 2.5303	*	*	*
	* 2.1862	* 2.0050	* 1.7657	* 1.7923	* 2.4811	*	*	*
	* 2.2260	* 2.0433	* 1.7857	* 1.8289	* 2.4725	*	*	*
	* 2.1282	* 1.9724	* 1.7493	* 1.7911	* 2.3812	*	*	*
14	* 1.7977	* 1.8233	* 2.2707	* 3.0172	*	*	*	*
	* 1.7525	* 1.7420	* 2.2582	* 2.8647	*	*	*	*
	* 1.7236	* 1.7354	* 2.3098	* 2.8356	*	*	*	*
	* 1.9854	* 2.0158	* 2.5451	* 2.9659	*	*	*	*
	* 2.0345	* 2.0582	* 2.5511	* 2.9515	*	*	*	*
	* 1.9331	* 1.9574	* 2.4058	* 2.7888	*	*	*	*
15	* 3.0476	* 3.2477	* 4 EFPD 118	% POWER				
	* 2.8945	* 3.0598	* 75 EFPD 118	% POWER				
	* 2.8828	* 3.0149	* 150 EFPD 118	% POWER				
	* 3.3039	* 3.4494	* 275 EFPD 118	% POWER				
	* 3.2878	* 3.4374	* 375 EFPD 118	% POWER				
	* 2.9987	* 3.1541	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 231 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7054	* 1.7557	* 1.8971	* 1.6838	* 1.6177	* 1.8133	* 1.6954	* 2.9450 *
	* 1.8169	* 1.9121	* 2.0055	* 1.7010	* 1.6675	* 1.8760	* 1.6411	* 2.7804 *
	* 1.8707	* 2.0293	* 2.0522	* 1.7151	* 1.7453	* 1.9560	* 1.6181	* 2.7925 *
	* 1.7340	* 1.9684	* 1.9188	* 1.6085	* 1.7881	* 2.1536	* 1.8986	* 3.2414 *
	* 1.7514	* 2.0391	* 2.0126	* 1.7293	* 1.8891	* 2.2231	* 1.9763	* 3.2476 *
	* 1.7301	* 1.9910	* 1.9682	* 1.7287	* 1.8537	* 2.1259	* 1.8864	* 2.9870 *
9	* 1.7557	* 1.7194	* 1.8385	* 1.7891	* 1.6463	* 1.7131	* 1.7078	* 3.1158 *
	* 1.9121	* 1.8175	* 1.8707	* 1.8345	* 1.6395	* 1.7195	* 1.6193	* 2.9197 *
	* 2.0293	* 1.8853	* 1.8585	* 1.8623	* 1.6422	* 1.7947	* 1.6284	* 2.9084 *
	* 1.9684	* 1.7537	* 1.6209	* 1.7842	* 1.5631	* 1.9242	* 1.9224	* 3.3878 *
	* 2.0391	* 1.8543	* 1.7250	* 1.8894	* 1.6553	* 2.0045	* 1.9969	* 3.4036 *
	* 1.9910	* 1.8306	* 1.7253	* 1.8603	* 1.6517	* 1.9464	* 1.9078	* 3.1516 *
10	* 1.8971	* 1.8344	* 1.9191	* 1.7293	* 1.7345	* 1.6546	* 2.1902	* 2.1902 *
	* 2.0055	* 1.8748	* 1.9676	* 1.7142	* 1.7498	* 1.6103	* 2.1697	* 2.1697 *
	* 2.0522	* 1.8603	* 1.9984	* 1.7158	* 1.7886	* 1.6310	* 2.2471	* 2.2471 *
	* 1.9188	* 1.6212	* 1.8737	* 1.5973	* 1.7761	* 1.6702	* 2.5069	* 2.5069 *
	* 2.0126	* 1.7245	* 1.9744	* 1.7143	* 1.8789	* 1.7364	* 2.5620	* 2.5620 *
	* 1.9682	* 1.7249	* 1.9361	* 1.7187	* 1.8510	* 1.7130	* 2.4331	* 2.4331 *
11	* 1.6838	* 1.8013	* 1.7360	* 1.9122	* 1.8304	* 1.7385	* 2.9610	* 2.9610 *
	* 1.7010	* 1.8447	* 1.7202	* 1.9324	* 1.7592	* 1.6642	* 2.7978	* 2.7978 *
	* 1.7151	* 1.8726	* 1.7229	* 1.9590	* 1.7412	* 1.6385	* 2.7964	* 2.7964 *
	* 1.6085	* 1.7874	* 1.6004	* 1.8771	* 1.6397	* 1.7013	* 2.9473	* 2.9473 *
	* 1.7293	* 1.8910	* 1.7145	* 1.9753	* 1.7165	* 1.7769	* 2.9843	* 2.9843 *
	* 1.7287	* 1.8618	* 1.7184	* 1.9311	* 1.7125	* 1.7504	* 2.8426	* 2.8426 *
12	* 1.6177	* 1.6662	* 1.7470	* 1.8381	* 1.8217	* 2.7240	* 2.7240	* 2.7240 *
	* 1.6675	* 1.6653	* 1.7614	* 1.7650	* 1.7426	* 2.5419	* 2.5419	* 2.5419 *
	* 1.7453	* 1.6562	* 1.7986	* 1.7470	* 1.7454	* 2.4987	* 2.4987	* 2.4987 *
	* 1.7881	* 1.5712	* 1.7816	* 1.6412	* 1.6641	* 2.4585	* 2.4585	* 2.4585 *
	* 1.8891	* 1.6581	* 1.8809	* 1.7160	* 1.6868	* 2.5059	* 2.5059	* 2.5059 *
	* 1.8537	* 1.6528	* 1.8526	* 1.7120	* 1.6715	* 2.4275	* 2.4275	* 2.4275 *
13	* 1.8133	* 1.7332	* 1.6679	* 1.7480	* 2.7227	* 2.7227	* 2.7227	* 2.7227 *
	* 1.8760	* 1.7381	* 1.6214	* 1.6719	* 2.5421	* 2.5421	* 2.5421	* 2.5421 *
	* 1.9560	* 1.8108	* 1.6403	* 1.6439	* 2.4977	* 2.4977	* 2.4977	* 2.4977 *
	* 2.1536	* 1.9361	* 1.6752	* 1.7031	* 2.4554	* 2.4554	* 2.4554	* 2.4554 *
	* 2.2231	* 2.0108	* 1.7360	* 1.7759	* 2.5013	* 2.5013	* 2.5013	* 2.5013 *
	* 2.1259	* 1.9512	* 1.7120	* 1.7494	* 2.4235	* 2.4235	* 2.4235	* 2.4235 *
14	* 1.6954	* 1.7184	* 2.2112	* 2.9831	* 2.9831	* 2.9831	* 2.9831	* 2.9831 *
	* 1.6411	* 1.6291	* 2.1872	* 2.8164	* 2.8164	* 2.8164	* 2.8164	* 2.8164 *
	* 1.6181	* 1.6360	* 2.2619	* 2.8108	* 2.8108	* 2.8108	* 2.8108	* 2.8108 *
	* 1.8986	* 1.9276	* 2.5165	* 2.9547	* 2.9547	* 2.9547	* 2.9547	* 2.9547 *
	* 1.9763	* 1.9994	* 2.5664	* 2.9856	* 2.9856	* 2.9856	* 2.9856	* 2.9856 *
	* 1.8864	* 1.9099	* 2.4354	* 2.8396	* 2.8396	* 2.8396	* 2.8396	* 2.8396 *
15	* 2.9450	* 3.1859	* 4 EFPD 118 % POWER					
	* 2.7804	* 2.9817	* 75 EFPD 118 % POWER					
	* 2.7925	* 2.9612	* 150 EFPD 118 % POWER					
	* 3.2414	* 3.4323	* 275 EFPD 118 % POWER					
	* 3.2476	* 3.4428	* 375 EFPD 118 % POWER					
	* 2.9870	* 3.1843	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 232 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6621	* 1.7171	* 1.8557	* 1.6387	* 1.5725	* 1.7649	* 1.6363	* 2.8670
	* 1.7816	* 1.8792	* 1.9681	* 1.6569	* 1.6228	* 1.8283	* 1.5791	* 2.7043
	* 1.8241	* 1.9858	* 2.0035	* 1.6694	* 1.7016	* 1.9034	* 1.5595	* 2.7167
	* 1.6922	* 1.9321	* 1.8787	* 1.5654	* 1.7503	* 2.1154	* 1.8511	* 3.1809
	* 1.7128	* 2.0050	* 1.9782	* 1.6941	* 1.8558	* 2.1861	* 1.9327	* 3.1825
	* 1.7127	* 1.9765	* 1.9551	* 1.7140	* 1.8419	* 2.1088	* 1.8654	* 2.9484
9	* 1.7171	* 1.6776	* 1.7902	* 1.7481	* 1.5993	* 1.6629	* 1.6485	* 3.0392
	* 1.8792	* 1.7808	* 1.8250	* 1.7950	* 1.5931	* 1.6699	* 1.5581	* 2.8456
	* 1.9858	* 1.8398	* 1.8123	* 1.8211	* 1.5929	* 1.7461	* 1.5714	* 2.8352
	* 1.9321	* 1.7159	* 1.5754	* 1.7464	* 1.5192	* 1.8825	* 1.8737	* 3.3316
	* 2.0050	* 1.8203	* 1.6872	* 1.8583	* 1.6280	* 1.9703	* 1.9535	* 3.3513
	* 1.9765	* 1.8169	* 1.7096	* 1.8504	* 1.6429	* 1.9329	* 1.8865	* 3.1273
10	* 1.8557	* 1.7877	* 1.8736	* 1.6808	* 1.6900	* 1.6011	* 2.1389	*
	* 1.9681	* 1.8294	* 1.9266	* 1.6673	* 1.7074	* 1.5574	* 2.1184	*
	* 2.0035	* 1.8140	* 1.9548	* 1.6676	* 1.7449	* 1.5778	* 2.1958	*
	* 1.8787	* 1.5757	* 1.8326	* 1.5527	* 1.7372	* 1.6206	* 2.4658	*
	* 1.9782	* 1.6866	* 1.9399	* 1.6839	* 1.8493	* 1.7106	* 2.5260	*
	* 1.9551	* 1.7091	* 1.9233	* 1.7073	* 1.8413	* 1.7062	* 2.4215	*
11	* 1.6387	* 1.7607	* 1.6876	* 1.8642	* 1.7749	* 1.6833	* 2.9090	*
	* 1.6569	* 1.8056	* 1.6735	* 1.8878	* 1.7061	* 1.6108	* 2.7477	*
	* 1.6694	* 1.8316	* 1.6748	* 1.9104	* 1.6846	* 1.5815	* 2.7396	*
	* 1.5654	* 1.7495	* 1.5556	* 1.8342	* 1.5899	* 1.6509	* 2.8993	*
	* 1.6941	* 1.8598	* 1.6838	* 1.9434	* 1.6928	* 1.7492	* 2.9487	*
	* 1.7140	* 1.8519	* 1.7069	* 1.9207	* 1.7083	* 1.7441	* 2.8343	*
12	* 1.5725	* 1.6192	* 1.7028	* 1.7827	* 1.7662	* 2.6698	*	*
	* 1.6228	* 1.6182	* 1.7193	* 1.7121	* 1.6905	* 2.4916	*	*
	* 1.7016	* 1.6072	* 1.7551	* 1.6904	* 1.6896	* 2.4413	*	*
	* 1.7503	* 1.5270	* 1.7426	* 1.5912	* 1.6080	* 2.4088	*	*
	* 1.8558	* 1.6303	* 1.8510	* 1.6922	* 1.6600	* 2.4783	*	*
	* 1.8419	* 1.6440	* 1.8427	* 1.7078	* 1.6678	* 2.4259	*	*
13	* 1.7649	* 1.6834	* 1.6146	* 1.6930	* 2.6697	*	*	*
	* 1.8283	* 1.6889	* 1.5687	* 1.6187	* 2.4927	*	*	*
	* 1.9034	* 1.7623	* 1.5872	* 1.5870	* 2.4409	*	*	*
	* 2.1154	* 1.8943	* 1.6246	* 1.6525	* 2.4052	*	*	*
	* 2.1861	* 1.9760	* 1.7098	* 1.7478	* 2.4733	*	*	*
	* 2.1088	* 1.9374	* 1.7059	* 1.7430	* 2.4205	*	*	*
14	* 1.6363	* 1.6591	* 2.1602	* 2.9314	*	*	*	*
	* 1.5791	* 1.5680	* 2.1363	* 2.7663	*	*	*	*
	* 1.5595	* 1.5790	* 2.2107	* 2.7538	*	*	*	*
	* 1.8511	* 1.8788	* 2.4751	* 2.9089	*	*	*	*
	* 1.9327	* 1.9556	* 2.5296	* 2.9518	*	*	*	*
	* 1.8654	* 1.8883	* 2.4241	* 2.8309	*	*	*	*
15	* 2.8670	* 3.1117	* 4 EFPD 118	% POWER				
	* 2.7043	* 2.9092	* 75 EFPD 118	% POWER				
	* 2.7167	* 2.8934	* 150 EFPD 118	% POWER				
	* 3.1809	* 3.3833	* 275 EFPD 118	% POWER				
	* 3.1825	* 3.3870	* 375 EFPD 118	% POWER				
	* 2.9484	* 3.1599	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 233 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6470	* 1.6999	* 1.8391	* 1.6188	* 1.5488	* 1.7415	* 1.6086	* 2.8225 *
	* 1.7757	* 1.8721	* 1.9604	* 1.6436	* 1.6045	* 1.8097	* 1.5546	* 2.6659 *
	* 1.8067	* 1.9653	* 1.9822	* 1.6509	* 1.6775	* 1.8739	* 1.5287	* 2.6661 *
	* 1.6741	* 1.9062	* 1.8563	* 1.5420	* 1.7261	* 2.0893	* 1.8216	* 3.1311 *
	* 1.6793	* 1.9741	* 1.9477	* 1.6632	* 1.8254	* 2.1524	* 1.8929	* 3.1160 *
	* 1.6807	* 1.9477	* 1.9268	* 1.6847	* 1.8131	* 2.0762	* 1.8263	* 2.8815 *
9	* 1.6999	* 1.6585	* 1.7720	* 1.7307	* 1.5786	* 1.6381	* 1.6215	* 2.9837 *
	* 1.8721	* 1.7714	* 1.8142	* 1.7829	* 1.5764	* 1.6494	* 1.5347	* 2.7976 *
	* 1.9653	* 1.8180	* 1.7903	* 1.8030	* 1.5695	* 1.7197	* 1.5405	* 2.7748 *
	* 1.9062	* 1.6868	* 1.5530	* 1.7229	* 1.4946	* 1.8563	* 1.8440	* 3.2687 *
	* 1.9741	* 1.7841	* 1.6559	* 1.8279	* 1.5966	* 1.9365	* 1.9131	* 3.2612 *
	* 1.9477	* 1.7873	* 1.6802	* 1.8221	* 1.6135	* 1.9003	* 1.8479	* 3.0362 *
10	* 1.8391	* 1.7710	* 1.8549	* 1.6592	* 1.6682	* 1.5749	* 2.1029	*
	* 1.9604	* 1.8187	* 1.9166	* 1.6521	* 1.6911	* 1.5363	* 2.0865	*
	* 1.9822	* 1.7922	* 1.9345	* 1.6472	* 1.7226	* 1.5517	* 2.1537	*
	* 1.8563	* 1.5533	* 1.8095	* 1.5281	* 1.7116	* 1.5927	* 2.4214	*
	* 1.9477	* 1.6553	* 1.9096	* 1.6527	* 1.8178	* 1.6709	* 2.4682	*
	* 1.9268	* 1.6798	* 1.8952	* 1.6780	* 1.8118	* 1.6733	* 2.3639	*
11	* 1.6188	* 1.7437	* 1.6663	* 1.8437	* 1.7508	* 1.6594	* 2.8596	*
	* 1.6436	* 1.7939	* 1.6585	* 1.8731	* 1.6875	* 1.5909	* 2.7062	*
	* 1.6509	* 1.8141	* 1.6546	* 1.8885	* 1.6587	* 1.5542	* 2.6862	*
	* 1.5420	* 1.7260	* 1.5312	* 1.8083	* 1.5633	* 1.6212	* 2.8418	*
	* 1.6632	* 1.8293	* 1.6525	* 1.9117	* 1.6537	* 1.7085	* 2.8748	*
	* 1.6847	* 1.8236	* 1.6775	* 1.8913	* 1.6761	* 1.7087	* 2.7602	*
12	* 1.5488	* 1.6002	* 1.6815	* 1.7589	* 1.7432	* 2.6245	*	
	* 1.6045	* 1.5997	* 1.7034	* 1.6938	* 1.6723	* 2.4536	*	
	* 1.6775	* 1.5841	* 1.7331	* 1.6647	* 1.6643	* 2.3921	*	
	* 1.7261	* 1.5026	* 1.7171	* 1.5646	* 1.5792	* 2.3544	*	
	* 1.8254	* 1.5987	* 1.8193	* 1.6531	* 1.6206	* 2.4110	*	
	* 1.8131	* 1.6144	* 1.8132	* 1.6756	* 1.6332	* 2.3634	*	
13	* 1.7415	* 1.6592	* 1.5888	* 1.6693	* 2.6234	*		
	* 1.8097	* 1.6676	* 1.5480	* 1.5990	* 2.4540	*		
	* 1.8739	* 1.7363	* 1.5614	* 1.5598	* 2.3916	*		
	* 2.0893	* 1.8682	* 1.5967	* 1.6227	* 2.3510	*		
	* 2.1524	* 1.9420	* 1.6699	* 1.7069	* 2.4053	*		
	* 2.0762	* 1.9046	* 1.6719	* 1.7074	* 2.3590	*		
14	* 1.6086	* 1.6324	* 2.1247	* 2.8828	*			
	* 1.5546	* 1.5448	* 2.1048	* 2.7255	*			
	* 1.5287	* 1.5483	* 2.1688	* 2.7009	*			
	* 1.8216	* 1.8490	* 2.4307	* 2.8487	*			
	* 1.8929	* 1.9152	* 2.4708	* 2.8752	*			
	* 1.8263	* 1.8496	* 2.3657	* 2.7567	*			
15	* 2.8225	* 3.0528	* 4 EFPD 118 % POWER					
	* 2.6659	* 2.8575	* 75 EFPD 118 % POWER					
	* 2.6661	* 2.8250	* 150 EFPD 118 % POWER					
	* 3.1311	* 3.3118	* 275 EFPD 118 % POWER					
	* 3.1160	* 3.2996	* 375 EFPD 118 % POWER					
	* 2.8815	* 3.0677	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016

Appendix A, Rev. 2

Page 234 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6736	* 1.7143	* 1.8528	* 1.6387	* 1.5580	* 1.7530	* 1.6242	* 2.8105 *
	* 1.7976	* 1.8863	* 1.9728	* 1.6740	* 1.6214	* 1.8256	* 1.5750	* 2.6608 *
	* 1.8356	* 1.9808	* 1.9959	* 1.6765	* 1.6882	* 1.8801	* 1.5429	* 2.6451 *
	* 1.6935	* 1.8755	* 1.8591	* 1.5582	* 1.7324	* 2.0602	* 1.8325	* 3.1020 *
	* 1.6794	* 1.9391	* 1.9413	* 1.6616	* 1.8204	* 2.1107	* 1.8839	* 3.0612 *
	* 1.6837	* 1.9198	* 1.9275	* 1.6875	* 1.8118	* 2.0537	* 1.8208	* 2.8299 *
9	* 1.7143	* 1.6708	* 1.7990	* 1.7407	* 1.5984	* 1.6486	* 1.6395	* 2.9385 *
	* 1.8863	* 1.7866	* 1.8432	* 1.8057	* 1.6025	* 1.6625	* 1.5572	* 2.7585 *
	* 1.9808	* 1.8318	* 1.8153	* 1.8188	* 1.5894	* 1.7287	* 1.5519	* 2.7180 *
	* 1.8755	* 1.6733	* 1.5725	* 1.7287	* 1.5088	* 1.8622	* 1.8559	* 3.1879 *
	* 1.9391	* 1.7526	* 1.6560	* 1.8195	* 1.5908	* 1.9244	* 1.9053	* 3.1571 *
	* 1.9198	* 1.7627	* 1.6840	* 1.8193	* 1.6146	* 1.8955	* 1.8443	* 2.9382 *
10	* 1.8528	* 1.7993	* 1.8514	* 1.6785	* 1.6795	* 1.5889	* 2.0812	*
	* 1.9728	* 1.8477	* 1.9339	* 1.6809	* 1.7091	* 1.5573	* 2.0696	*
	* 1.9959	* 1.8173	* 1.9450	* 1.6711	* 1.7339	* 1.5674	* 2.1236	*
	* 1.8591	* 1.5729	* 1.8169	* 1.5429	* 1.7147	* 1.6062	* 2.3814	*
	* 1.9413	* 1.6554	* 1.9029	* 1.6488	* 1.8065	* 1.6628	* 2.4033	*
	* 1.9275	* 1.6835	* 1.8956	* 1.6804	* 1.8071	* 1.6684	* 2.3054	*
11	* 1.6387	* 1.7594	* 1.6860	* 1.8302	* 1.7713	* 1.6782	* 2.8036	*
	* 1.6740	* 1.8175	* 1.6877	* 1.8912	* 1.7137	* 1.6130	* 2.6602	*
	* 1.6765	* 1.8292	* 1.6790	* 1.9023	* 1.6779	* 1.5691	* 2.6265	*
	* 1.5582	* 1.7321	* 1.5463	* 1.8128	* 1.5772	* 1.6300	* 2.7737	*
	* 1.6616	* 1.8209	* 1.6485	* 1.8968	* 1.6442	* 1.7007	* 2.7825	*
	* 1.6875	* 1.8208	* 1.6798	* 1.8871	* 1.6699	* 1.7060	* 2.6754	*
12	* 1.5580	* 1.6247	* 1.6934	* 1.7798	* 1.7645	* 2.5854	*	
	* 1.6214	* 1.6248	* 1.7220	* 1.7207	* 1.6978	* 2.4222	*	
	* 1.6882	* 1.6048	* 1.7449	* 1.6843	* 1.6805	* 2.3434	*	
	* 1.7324	* 1.5174	* 1.7205	* 1.5786	* 1.5938	* 2.2947	*	
	* 1.8204	* 1.5931	* 1.8080	* 1.6436	* 1.6130	* 2.3225	*	
	* 1.8118	* 1.6152	* 1.8082	* 1.6693	* 1.6294	* 2.2851	*	
13	* 1.7530	* 1.6705	* 1.6035	* 1.6887	* 2.5851	*		
	* 1.8256	* 1.6827	* 1.5697	* 1.6216	* 2.4239	*		
	* 1.8801	* 1.7459	* 1.5781	* 1.5750	* 2.3441	*		
	* 2.0602	* 1.8729	* 1.6104	* 1.6316	* 2.2920	*		
	* 2.1107	* 1.9300	* 1.6615	* 1.6990	* 2.3182	*		
	* 2.0537	* 1.8997	* 1.6669	* 1.7045	* 2.2819	*		
14	* 1.6242	* 1.6512	* 2.1030	* 2.8307	*			
	* 1.5750	* 1.5680	* 2.0879	* 2.6829	*			
	* 1.5429	* 1.5600	* 2.1386	* 2.6445	*			
	* 1.8325	* 1.8611	* 2.3902	* 2.7811	*			
	* 1.8839	* 1.9074	* 2.4059	* 2.7833	*			
	* 1.8208	* 1.8460	* 2.3071	* 2.6721	*			
15	* 2.8105	* 2.9954	* 4 EFPD 118	% POWER				
	* 2.6608	* 2.8132	* 75 EFPD 118	% POWER				
	* 2.6451	* 2.7674	* 150 EFPD 118	% POWER				
	* 3.1020	* 3.2358	* 275 EFPD 118	% POWER				
	* 3.0612	* 3.1960	* 375 EFPD 118	% POWER				
	* 2.8299	* 2.9724	* 475 EFPD 118	% POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 235 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5912	* 1.6510	* 1.7901	* 1.5668	* 1.5000	* 1.6963	* 1.5510	* 2.7816 *
	* 1.7188	* 1.8217	* 1.9093	* 1.6011	* 1.5656	* 1.7696	* 1.5019	* 2.6315 *
	* 1.7588	* 1.9231	* 1.9363	* 1.5987	* 1.6269	* 1.8155	* 1.4583	* 2.5966 *
	* 1.6072	* 1.8439	* 1.7924	* 1.4765	* 1.6686	* 2.0350	* 1.7486	* 3.0591 *
	* 1.5923	* 1.8935	* 1.8643	* 1.5739	* 1.7438	* 2.0744	* 1.7887	* 2.9998 *
	* 1.6194	* 1.8955	* 1.8732	* 1.6223	* 1.7579	* 2.0182	* 1.7359	* 2.7822 *
9	* 1.6510	* 1.6061	* 1.7138	* 1.6860	* 1.5244	* 1.5881	* 1.5633	* 2.9466 *
	* 1.8217	* 1.7205	* 1.7587	* 1.7499	* 1.5348	* 1.6030	* 1.4821	* 2.7670 *
	* 1.9231	* 1.7702	* 1.7361	* 1.7595	* 1.5131	* 1.6617	* 1.4700	* 2.7081 *
	* 1.8439	* 1.6246	* 1.4877	* 1.6677	* 1.4286	* 1.7954	* 1.7700	* 3.2006 *
	* 1.8935	* 1.7021	* 1.5668	* 1.7488	* 1.5046	* 1.8470	* 1.8075	* 3.1555 *
	* 1.8955	* 1.7311	* 1.6182	* 1.7709	* 1.5467	* 1.8334	* 1.7565	* 2.9480 *
10	* 1.7901	* 1.7128	* 1.8060	* 1.6074	* 1.6230	* 1.5185	* 2.0642	*
	* 1.9093	* 1.7633	* 1.8737	* 1.6110	* 1.6571	* 1.4880	* 2.0547	*
	* 1.9363	* 1.7382	* 1.8845	* 1.5949	* 1.6761	* 1.4883	* 2.0993	*
	* 1.7924	* 1.4881	* 1.7496	* 1.4611	* 1.6533	* 1.5196	* 2.3640	*
	* 1.8643	* 1.5661	* 1.8263	* 1.5602	* 1.7335	* 1.5736	* 2.3790	*
	* 1.8732	* 1.6177	* 1.8417	* 1.6133	* 1.7556	* 1.5942	* 2.2941	*
11	* 1.5668	* 1.6989	* 1.6149	* 1.7928	* 1.6948	* 1.6044	* 2.8384	*
	* 1.6011	* 1.7610	* 1.6180	* 1.8360	* 1.6405	* 1.5436	* 2.6934	*
	* 1.5987	* 1.7698	* 1.6029	* 1.8418	* 1.5958	* 1.4877	* 2.6411	*
	* 1.4765	* 1.6709	* 1.4644	* 1.7484	* 1.4919	* 1.5457	* 2.7846	*
	* 1.5739	* 1.7501	* 1.5598	* 1.8177	* 1.5536	* 1.6072	* 2.7826	*
	* 1.6223	* 1.7723	* 1.6126	* 1.8279	* 1.5984	* 1.6262	* 2.6938	*
12	* 1.5000	* 1.5482	* 1.6373	* 1.7036	* 1.6902	* 2.5889	*	
	* 1.5656	* 1.5570	* 1.6704	* 1.6485	* 1.6287	* 2.4315	*	
	* 1.6269	* 1.5286	* 1.6874	* 1.6022	* 1.6046	* 2.3432	*	
	* 1.6686	* 1.4371	* 1.6593	* 1.4932	* 1.5030	* 2.2889	*	
	* 1.7438	* 1.5065	* 1.7348	* 1.5530	* 1.5194	* 2.3059	*	
	* 1.7579	* 1.5472	* 1.7567	* 1.5977	* 1.5535	* 2.2888	*	
13	* 1.6963	* 1.6107	* 1.5335	* 1.6152	* 2.5889	*		
	* 1.7696	* 1.6240	* 1.5008	* 1.5524	* 2.4332	*		
	* 1.8155	* 1.6788	* 1.4991	* 1.4937	* 2.3432	*		
	* 2.0350	* 1.8074	* 1.5237	* 1.5472	* 2.2854	*		
	* 2.0744	* 1.8525	* 1.5721	* 1.6053	* 2.3005	*		
	* 2.0182	* 1.8376	* 1.5925	* 1.6246	* 2.2834	*		
14	* 1.5510	* 1.5749	* 2.0878	* 2.8635	*			
	* 1.5019	* 1.4932	* 2.0747	* 2.7144	*			
	* 1.4583	* 1.4782	* 2.1156	* 2.6568	*			
	* 1.7486	* 1.7753	* 2.3738	* 2.7939	*			
	* 1.7887	* 1.8094	* 2.3820	* 2.7844	*			
	* 1.7359	* 1.7581	* 2.2962	* 2.6903	*			
15	* 2.7816	* 3.0206	* 4 EFPD 118 % POWER					
	* 2.6315	* 2.8321	* 75 EFPD 118 % POWER					
	* 2.5966	* 2.7664	* 150 EFPD 118 % POWER					
	* 3.0591	* 3.2521	* 275 EFPD 118 % POWER					
	* 2.9998	* 3.1915	* 375 EFPD 118 % POWER					
	* 2.7822	* 2.9800	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 236 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5577	* 1.6166	* 1.7556	* 1.5338	* 1.4641	* 1.6600	* 1.5168	* 2.7393
	* 1.6964	* 1.7974	* 1.8869	* 1.5789	* 1.5378	* 1.7416	* 1.4751	* 2.6020
	* 1.7446	* 1.9081	* 1.9226	* 1.5819	* 1.6032	* 1.7882	* 1.4318	* 2.5645
	* 1.5865	* 1.8209	* 1.7672	* 1.4470	* 1.6362	* 1.9982	* 1.7013	* 2.9898
	* 1.5257	* 1.8231	* 1.7917	* 1.5006	* 1.6672	* 1.9922	* 1.7113	* 2.8951
	* 1.5612	* 1.8334	* 1.8129	* 1.5621	* 1.6957	* 1.9520	* 1.6727	* 2.6968
9	* 1.6166	* 1.5721	* 1.6817	* 1.6534	* 1.4897	* 1.5517	* 1.5284	* 2.8991
	* 1.7974	* 1.6961	* 1.7370	* 1.7271	* 1.5099	* 1.5738	* 1.4560	* 2.7337
	* 1.9081	* 1.7542	* 1.7242	* 1.7432	* 1.4920	* 1.6332	* 1.4412	* 2.6724
	* 1.8209	* 1.5990	* 1.4610	* 1.6390	* 1.3981	* 1.7574	* 1.7231	* 3.1261
	* 1.8231	* 1.6309	* 1.4941	* 1.6750	* 1.4331	* 1.7653	* 1.7290	* 3.0424
	* 1.8334	* 1.6716	* 1.5607	* 1.7135	* 1.4875	* 1.7670	* 1.6927	* 2.8554
10	* 1.7556	* 1.6785	* 1.7741	* 1.5734	* 1.5874	* 1.4833	* 2.0262	*
	* 1.8869	* 1.7417	* 1.8521	* 1.5864	* 1.6307	* 1.4613	* 2.0258	*
	* 1.9226	* 1.7264	* 1.8704	* 1.5757	* 1.6546	* 1.4633	* 2.0705	*
	* 1.7672	* 1.4615	* 1.7243	* 1.4311	* 1.6211	* 1.4842	* 2.3155	*
	* 1.7917	* 1.4934	* 1.7537	* 1.4868	* 1.6568	* 1.4973	* 2.2798	*
	* 1.8129	* 1.5601	* 1.7821	* 1.5528	* 1.6934	* 1.5312	* 2.2167	*
11	* 1.5338	* 1.6665	* 1.5811	* 1.7602	* 1.6590	* 1.5697	* 2.7953	*
	* 1.5789	* 1.7385	* 1.5935	* 1.8134	* 1.6144	* 1.5170	* 2.6650	*
	* 1.5819	* 1.7539	* 1.5839	* 1.8215	* 1.5730	* 1.4618	* 2.6142	*
	* 1.4470	* 1.6427	* 1.4348	* 1.7176	* 1.4604	* 1.5069	* 2.7349	*
	* 1.5006	* 1.6763	* 1.4864	* 1.7367	* 1.4767	* 1.5287	* 2.6694	*
	* 1.5621	* 1.7148	* 1.5520	* 1.7621	* 1.5338	* 1.5616	* 2.6062	*
12	* 1.4641	* 1.5145	* 1.6019	* 1.6678	* 1.6558	* 2.5466	*	*
	* 1.5378	* 1.5306	* 1.6442	* 1.6227	* 1.6038	* 2.4002	*	*
	* 1.6032	* 1.5080	* 1.6662	* 1.5796	* 1.5829	* 2.3152	*	*
	* 1.6362	* 1.4071	* 1.6273	* 1.4621	* 1.4708	* 2.2437	*	*
	* 1.6672	* 1.4349	* 1.6581	* 1.4760	* 1.4434	* 2.2006	*	*
	* 1.6957	* 1.4878	* 1.6944	* 1.5331	* 1.4894	* 2.2021	*	*
13	* 1.6600	* 1.5746	* 1.4985	* 1.5806	* 2.5473	*	*	*
	* 1.7416	* 1.5949	* 1.4743	* 1.5260	* 2.4020	*	*	*
	* 1.7882	* 1.6506	* 1.4744	* 1.4680	* 2.3152	*	*	*
	* 1.9982	* 1.7698	* 1.4885	* 1.5086	* 2.2402	*	*	*
	* 1.9922	* 1.7707	* 1.4958	* 1.5268	* 2.1953	*	*	*
	* 1.9520	* 1.7711	* 1.5294	* 1.5599	* 2.1966	*	*	*
14	* 1.5168	* 1.5403	* 2.0503	* 2.8208	*	*	*	*
	* 1.4751	* 1.4676	* 2.0464	* 2.6864	*	*	*	*
	* 1.4318	* 1.4499	* 2.0872	* 2.6304	*	*	*	*
	* 1.7013	* 1.7286	* 2.3255	* 2.7442	*	*	*	*
	* 1.7113	* 1.7310	* 2.2828	* 2.6716	*	*	*	*
	* 1.6727	* 1.6943	* 2.2188	* 2.6022	*	*	*	*
15	* 2.7393	* 2.9746	* 4 EFPD 118	* % POWER				
	* 2.6020	* 2.8007	* 75 EFPD 118	* % POWER				
	* 2.5645	* 2.7325	* 150 EFPD 118	* % POWER				
	* 2.9898	* 3.1803	* 275 EFPD 118	* % POWER				
	* 2.8951	* 3.0803	* 375 EFPD 118	* % POWER				
	* 2.6968	* 2.8885	* 475 EFPD 118	* % POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 237 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5351	* 1.5972	* 1.7386	* 1.5216	* 1.4486	* 1.6456	* 1.5140	* 2.7387
	* 1.6959	* 1.7914	* 1.8876	* 1.5816	* 1.5351	* 1.7457	* 1.4890	* 2.6241
	* 1.7578	* 1.9154	* 1.9381	* 1.5978	* 1.6087	* 1.7969	* 1.4506	* 2.5898
	* 1.6032	* 1.8208	* 1.7754	* 1.4559	* 1.6347	* 1.9885	* 1.6866	* 2.9594
	* 1.4721	* 1.7598	* 1.7299	* 1.4470	* 1.6068	* 1.9223	* 1.6536	* 2.7960
	* 1.4879	* 1.7514	* 1.7321	* 1.4985	* 1.6261	* 1.8808	* 1.6197	* 2.6061
9	* 1.5972	* 1.5558	* 1.6605	* 1.6343	* 1.4707	* 1.5390	* 1.5161	* 2.8291
	* 1.7914	* 1.6942	* 1.7340	* 1.7248	* 1.5118	* 1.5779	* 1.4719	* 2.6963
	* 1.9154	* 1.7660	* 1.7486	* 1.7526	* 1.5084	* 1.6413	* 1.4545	* 2.6438
	* 1.8208	* 1.6051	* 1.4778	* 1.6422	* 1.4078	* 1.7511	* 1.7102	* 3.0370
	* 1.7598	* 1.5708	* 1.4411	* 1.6141	* 1.3818	* 1.7016	* 1.6712	* 2.8812
	* 1.7514	* 1.5949	* 1.4885	* 1.6358	* 1.4332	* 1.7072	* 1.6387	* 2.7064
10	* 1.7386	* 1.6560	* 1.7620	* 1.5633	* 1.5708	* 1.4747	* 2.0121	*
	* 1.8876	* 1.7387	* 1.8552	* 1.5914	* 1.6286	* 1.4694	* 2.0280	*
	* 1.9381	* 1.7509	* 1.8867	* 1.5929	* 1.6635	* 1.4781	* 2.0764	*
	* 1.7754	* 1.4786	* 1.7301	* 1.4407	* 1.6203	* 1.4919	* 2.2978	*
	* 1.7299	* 1.4405	* 1.6923	* 1.4335	* 1.5955	* 1.4454	* 2.1954	*
	* 1.7321	* 1.4880	* 1.7018	* 1.4930	* 1.6270	* 1.4822	* 2.1386	*
11	* 1.5216	* 1.6484	* 1.5711	* 1.7483	* 1.6501	* 1.5557	* 2.7802	*
	* 1.5816	* 1.7371	* 1.5986	* 1.8164	* 1.6266	* 1.5177	* 2.6751	*
	* 1.5978	* 1.7651	* 1.6013	* 1.8353	* 1.5934	* 1.4792	* 2.6318	*
	* 1.4559	* 1.6463	* 1.4448	* 1.7222	* 1.4718	* 1.5084	* 2.7274	*
	* 1.4470	* 1.6154	* 1.4330	* 1.6757	* 1.4245	* 1.4764	* 2.5771	*
	* 1.4985	* 1.6371	* 1.4922	* 1.7002	* 1.4840	* 1.5111	* 2.5179	*
12	* 1.4486	* 1.4940	* 1.5852	* 1.6591	* 1.6422	* 2.4778	*	*
	* 1.5351	* 1.5275	* 1.6422	* 1.6335	* 1.6060	* 2.3641	*	*
	* 1.6087	* 1.5250	* 1.6752	* 1.6002	* 1.5933	* 2.2963	*	*
	* 1.6347	* 1.4181	* 1.6269	* 1.4737	* 1.4886	* 2.2205	*	*
	* 1.6068	* 1.3837	* 1.5968	* 1.4238	* 1.3941	* 2.1040	*	*
	* 1.6261	* 1.4337	* 1.6279	* 1.4833	* 1.4412	* 2.1107	*	*
13	* 1.6456	* 1.5620	* 1.4920	* 1.5667	* 2.4788	*	*	*
	* 1.7457	* 1.5996	* 1.4828	* 1.5269	* 2.3661	*	*	*
	* 1.7969	* 1.6592	* 1.4896	* 1.4858	* 2.2965	*	*	*
	* 1.9885	* 1.7640	* 1.4967	* 1.5104	* 2.2171	*	*	*
	* 1.9223	* 1.7071	* 1.4440	* 1.4746	* 2.0987	*	*	*
	* 1.8808	* 1.7110	* 1.4804	* 1.5094	* 2.1063	*	*	*
14	* 1.5140	* 1.5278	* 2.0362	* 2.8063	*	*	*	*
	* 1.4890	* 1.4842	* 2.0489	* 2.6973	*	*	*	*
	* 1.4506	* 1.4638	* 2.0936	* 2.6491	*	*	*	*
	* 1.6866	* 1.7161	* 2.3083	* 2.7369	*	*	*	*
	* 1.6536	* 1.6735	* 2.1985	* 2.5799	*	*	*	*
	* 1.6197	* 1.6405	* 2.1405	* 2.5133	*	*	*	*
15	* 2.7387	* 2.9642	* 4 EFPD 118 % POWER					
	* 2.6241	* 2.8171	* 75 EFPD 118 % POWER					
	* 2.5898	* 2.7524	* 150 EFPD 118 % POWER					
	* 2.9594	* 3.1445	* 275 EFPD 118 % POWER					
	* 2.7960	* 2.9703	* 375 EFPD 118 % POWER					
	* 2.6061	* 2.7869	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 238 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5374	* 1.6042	* 1.7486	* 1.5426	* 1.4639	* 1.6652	* 1.5417	* 2.8075
	* 1.7290	* 1.8162	* 1.9219	* 1.6278	* 1.5699	* 1.7855	* 1.5561	* 2.7270
	* 1.8179	* 1.9589	* 1.9942	* 1.6665	* 1.6579	* 1.8592	* 1.5395	* 2.7059
	* 1.6791	* 1.8602	* 1.8338	* 1.5262	* 1.6803	* 2.0257	* 1.7301	* 3.0098
	* 1.4525	* 1.7181	* 1.6984	* 1.4246	* 1.5792	* 1.8877	* 1.6418	* 2.7587
	* 1.4400	* 1.6942	* 1.6785	* 1.4514	* 1.5697	* 1.8200	* 1.5887	* 2.5365
9	* 1.6042	* 1.5666	* 1.6637	* 1.6392	* 1.4769	* 1.5610	* 1.5420	* 2.9037
	* 1.8162	* 1.7262	* 1.7633	* 1.7529	* 1.5448	* 1.6231	* 1.5505	* 2.8057
	* 1.9589	* 1.8183	* 1.8096	* 1.8007	* 1.5747	* 1.6993	* 1.5324	* 2.7641
	* 1.8602	* 1.6540	* 1.5634	* 1.6929	* 1.4807	* 1.7939	* 1.7564	* 3.0999
	* 1.7181	* 1.5358	* 1.4232	* 1.5865	* 1.3684	* 1.6735	* 1.6606	* 2.8516
	* 1.6942	* 1.5438	* 1.4438	* 1.5788	* 1.3915	* 1.6489	* 1.6061	* 2.6403
10	* 1.7486	* 1.6591	* 1.7766	* 1.5923	* 1.5816	* 1.4885	* 2.0387	
	* 1.9219	* 1.7679	* 1.8921	* 1.6424	* 1.6604	* 1.5272	* 2.0787	
	* 1.9942	* 1.8138	* 1.9443	* 1.6645	* 1.7137	* 1.5490	* 2.1385	
	* 1.8338	* 1.5643	* 1.7878	* 1.5129	* 1.6676	* 1.5665	* 2.3366	
	* 1.6984	* 1.4220	* 1.6615	* 1.4116	* 1.5680	* 1.4360	* 2.1545	
	* 1.6785	* 1.4429	* 1.6482	* 1.4457	* 1.5690	* 1.4509	* 2.0649	
11	* 1.5426	* 1.6531	* 1.6002	* 1.7641	* 1.6703	* 1.5752	* 2.8107	
	* 1.6278	* 1.7651	* 1.6497	* 1.8560	* 1.6833	* 1.5590	* 2.7419	
	* 1.6665	* 1.8132	* 1.6731	* 1.8948	* 1.6761	* 1.5595	* 2.7175	
	* 1.5262	* 1.6973	* 1.5179	* 1.7806	* 1.5533	* 1.5715	* 2.7910	
	* 1.4246	* 1.5878	* 1.4109	* 1.6533	* 1.4144	* 1.4703	* 2.5393	
	* 1.4514	* 1.5800	* 1.4451	* 1.6467	* 1.4470	* 1.4827	* 2.4390	
12	* 1.4639	* 1.4979	* 1.5959	* 1.6766	* 1.6616	* 2.5066		
	* 1.5699	* 1.5608	* 1.6740	* 1.6922	* 1.6479	* 2.4277		
	* 1.6579	* 1.5934	* 1.7255	* 1.6833	* 1.6498	* 2.3801		
	* 1.6803	* 1.4921	* 1.6747	* 1.5557	* 1.5572	* 2.2935		
	* 1.5792	* 1.3715	* 1.5695	* 1.4134	* 1.3926	* 2.0768		
	* 1.5697	* 1.3933	* 1.5698	* 1.4459	* 1.4135	* 2.0480		
13	* 1.6652	* 1.5840	* 1.5058	* 1.5864	* 2.5080			
	* 1.7855	* 1.6451	* 1.5427	* 1.5686	* 2.4299			
	* 1.8592	* 1.7181	* 1.5605	* 1.5666	* 2.3807			
	* 2.0257	* 1.8073	* 1.5721	* 1.5738	* 2.2905			
	* 1.8877	* 1.6791	* 1.4350	* 1.4688	* 2.0720			
	* 1.8200	* 1.6526	* 1.4493	* 1.4812	* 2.0441			
14	* 1.5417	* 1.5543	* 2.0634	* 2.8378				
	* 1.5561	* 1.5611	* 2.1002	* 2.7658				
	* 1.5395	* 1.5424	* 2.1566	* 2.7363				
	* 1.7301	* 1.7628	* 2.3478	* 2.8015				
	* 1.6418	* 1.6631	* 2.1582	* 2.5430				
	* 1.5887	* 1.6079	* 2.0669	* 2.4377				
15	* 2.8075	* 3.0188	* 4 EFPD 118 % POWER					
	* 2.7270	* 2.9086	* 75 EFPD 118 % POWER					
	* 2.7059	* 2.8583	* 150 EFPD 118 % POWER					
	* 3.0098	* 3.1886	* 275 EFPD 118 % POWER					
	* 2.7587	* 2.9242	* 375 EFPD 118 % POWER					
	* 2.5365	* 2.7037	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 239 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5999	* 1.6500	* 1.7982	* 1.5947	* 1.5156	* 1.7411	* 1.6525	* 2.9949
	* 1.8221	* 1.8877	* 1.9948	* 1.7105	* 1.6495	* 1.8889	* 1.6971	* 2.9624
	* 1.9335	* 2.0573	* 2.1025	* 1.7868	* 1.7640	* 2.0050	* 1.7156	* 2.9745
	* 1.8139	* 1.9783	* 1.9640	* 1.6756	* 1.7935	* 2.1497	* 1.8606	* 3.2327
	* 1.5094	* 1.7511	* 1.7352	* 1.4707	* 1.6145	* 1.9283	* 1.6983	* 2.8589
	* 1.4443	* 1.6819	* 1.6759	* 1.4564	* 1.5611	* 1.8097	* 1.5976	* 2.5603
9	* 1.6500	* 1.5981	* 1.7235	* 1.6715	* 1.5287	* 1.6259	* 1.6529	* 3.0811
	* 1.8877	* 1.7893	* 1.8534	* 1.8175	* 1.6449	* 1.7155	* 1.6915	* 3.0347
	* 2.0573	* 1.9143	* 1.9364	* 1.8992	* 1.6926	* 1.8156	* 1.6930	* 3.0244
	* 1.9783	* 1.7792	* 1.7239	* 1.8141	* 1.6241	* 1.9106	* 1.8927	* 3.3133
	* 1.7511	* 1.5727	* 1.4706	* 1.6177	* 1.4164	* 1.7131	* 1.7212	* 2.9438
	* 1.6819	* 1.5385	* 1.4510	* 1.5702	* 1.3949	* 1.6388	* 1.6202	* 2.6574
10	* 1.7982	* 1.7232	* 1.8162	* 1.6475	* 1.6224	* 1.5631	* 2.1508	*
	* 1.9948	* 1.8578	* 1.9688	* 1.7317	* 1.7310	* 1.6315	* 2.2268	*
	* 2.1025	* 1.9402	* 2.0547	* 1.7891	* 1.8144	* 1.6857	* 2.3106	*
	* 1.9640	* 1.7242	* 1.9235	* 1.6653	* 1.7849	* 1.7148	* 2.4958	*
	* 1.7352	* 1.4694	* 1.6981	* 1.4603	* 1.6031	* 1.4950	* 2.2190	*
	* 1.6759	* 1.4500	* 1.6460	* 1.4509	* 1.5599	* 1.4560	* 2.0673	*
11	* 1.5947	* 1.6850	* 1.6554	* 1.8127	* 1.7415	* 1.6555	* 2.9238	*
	* 1.7105	* 1.8295	* 1.7391	* 1.9390	* 1.7928	* 1.6731	* 2.9065	*
	* 1.7868	* 1.9116	* 1.7977	* 2.0143	* 1.8224	* 1.7089	* 2.9147	*
	* 1.6756	* 1.8187	* 1.6708	* 1.9188	* 1.7194	* 1.7161	* 2.9840	*
	* 1.4707	* 1.6190	* 1.4600	* 1.7043	* 1.4755	* 1.5331	* 2.6155	*
	* 1.4564	* 1.5713	* 1.4503	* 1.6485	* 1.4571	* 1.4963	* 2.4393	*
12	* 1.5156	* 1.5500	* 1.6364	* 1.7479	* 1.7315	* 2.5817	*	*
	* 1.6495	* 1.6645	* 1.7445	* 1.8010	* 1.7519	* 2.5566	*	*
	* 1.7640	* 1.7142	* 1.8261	* 1.8299	* 1.7844	* 2.5470	*	*
	* 1.7935	* 1.6362	* 1.7922	* 1.7222	* 1.7089	* 2.4773	*	*
	* 1.6145	* 1.4198	* 1.6048	* 1.4748	* 1.4663	* 2.1523	*	*
	* 1.5611	* 1.3974	* 1.5608	* 1.4560	* 1.4290	* 2.0534	*	*
13	* 1.7411	* 1.6488	* 1.5809	* 1.6670	* 2.5834	*	*	*
	* 1.8889	* 1.7380	* 1.6475	* 1.6831	* 2.5593	*	*	*
	* 2.0050	* 1.8348	* 1.6970	* 1.7166	* 2.5481	*	*	*
	* 2.1497	* 1.9248	* 1.7225	* 1.7190	* 2.4748	*	*	*
	* 1.9283	* 1.7192	* 1.4949	* 1.5320	* 2.1481	*	*	*
	* 1.8097	* 1.6426	* 1.4555	* 1.4950	* 2.0500	*	*	*
14	* 1.6525	* 1.6656	* 2.1760	* 2.9526	*	*	*	*
	* 1.6971	* 1.7027	* 2.2491	* 2.9317	*	*	*	*
	* 1.7156	* 1.7041	* 2.3296	* 2.9354	*	*	*	*
	* 1.8606	* 1.8998	* 2.5077	* 2.9964	*	*	*	*
	* 1.6983	* 1.7241	* 2.2233	* 2.6203	*	*	*	*
	* 1.5976	* 1.6223	* 2.0695	* 2.4387	*	*	*	*
15	* 2.9949	* 3.1924	* 4 EFPD 118 % POWER					
	* 2.9624	* 3.1368	* 75 EFPD 118 % POWER					
	* 2.9745	* 3.1163	* 150 EFPD 118 % POWER					
	* 3.2327	* 3.4012	* 275 EFPD 118 % POWER					
	* 2.8589	* 3.0134	* 375 EFPD 118 % POWER					
	* 2.5603	* 2.7139	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 240 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7435	* 1.9240	* 2.0583	* 1.7536	* 1.7743	* 2.0967	* 1.9855	* 3.6333
	* 2.0034	* 2.2087	* 2.3132	* 1.9303	* 1.9473	* 2.2836	* 2.0531	* 3.6557
	* 2.1868	* 2.4184	* 2.4691	* 2.0688	* 2.1032	* 2.4311	* 2.1242	* 3.7217
	* 2.1158	* 2.3283	* 2.3471	* 2.0404	* 2.1322	* 2.5558	* 2.3113	* 3.9490
	* 1.7839	* 1.9899	* 2.0019	* 1.7513	* 1.8465	* 2.2112	* 2.0149	* 3.3712
	* 1.6454	* 1.8446	* 1.8665	* 1.6563	* 1.7155	* 2.0040	* 1.8102	* 2.9122
9	* 1.9240	* 1.8198	* 1.8661	* 1.9132	* 1.6820	* 1.9048	* 2.0180	* 3.7198
	* 2.2087	* 2.0547	* 2.0562	* 2.1081	* 1.8315	* 2.0376	* 2.0713	* 3.7294
	* 2.4184	* 2.2285	* 2.1899	* 2.2360	* 1.9506	* 2.1797	* 2.1404	* 3.7633
	* 2.3283	* 2.1166	* 2.0719	* 2.1658	* 1.9597	* 2.2821	* 2.3435	* 4.0104
	* 1.9899	* 1.8091	* 1.7560	* 1.8573	* 1.6866	* 1.9710	* 2.0383	* 3.4420
	* 1.8446	* 1.6980	* 1.6611	* 1.7383	* 1.5846	* 1.8050	* 1.8338	* 2.9996
10	* 2.0583	* 1.8650	* 2.0557	* 1.7994	* 1.8792	* 1.8007	* 2.5969	*
	* 2.3132	* 2.0580	* 2.2902	* 1.9483	* 2.0312	* 1.9007	* 2.7210	*
	* 2.4691	* 2.1913	* 2.4210	* 2.0727	* 2.1566	* 2.0035	* 2.8453	*
	* 2.3471	* 2.0724	* 2.3034	* 2.0349	* 2.1471	* 2.0861	* 3.0181	*
	* 2.0019	* 1.7554	* 1.9612	* 1.7440	* 1.8534	* 1.7909	* 2.5916	*
	* 1.8665	* 1.6600	* 1.8343	* 1.6508	* 1.7260	* 1.6521	* 2.3152	*
11	* 1.7536	* 1.9280	* 1.8088	* 2.0804	* 1.9436	* 1.9870	* 3.4132	*
	* 1.9303	* 2.1222	* 1.9575	* 2.2780	* 2.0376	* 2.0576	* 3.4513	*
	* 2.0688	* 2.2482	* 2.0811	* 2.3979	* 2.1350	* 2.1154	* 3.5085	*
	* 2.0404	* 2.1702	* 2.0394	* 2.3121	* 2.1028	* 2.1397	* 3.5616	*
	* 1.7513	* 1.8589	* 1.7440	* 1.9758	* 1.7806	* 1.8304	* 3.0296	*
	* 1.6563	* 1.7394	* 1.6502	* 1.8398	* 1.6663	* 1.7010	* 2.7126	*
12	* 1.7743	* 1.7068	* 1.8944	* 1.9508	* 2.0322	* 2.9800	*	*
	* 1.9473	* 1.8557	* 2.0460	* 2.0440	* 2.1003	* 3.0084	*	*
	* 2.1032	* 1.9709	* 2.1693	* 2.1404	* 2.1827	* 3.0499	*	*
	* 2.1322	* 1.9703	* 2.1542	* 2.1054	* 2.1314	* 2.9961	*	*
	* 1.8465	* 1.6910	* 1.8556	* 1.7801	* 1.7755	* 2.5176	*	*
	* 1.7155	* 1.5864	* 1.7271	* 1.6653	* 1.6421	* 2.3031	*	*
13	* 2.0967	* 1.9304	* 1.8187	* 2.0004	* 2.9830	*	*	*
	* 2.2836	* 2.0627	* 1.9169	* 2.0692	* 3.0124	*	*	*
	* 2.4311	* 2.2013	* 2.0177	* 2.1242	* 3.0520	*	*	*
	* 2.5558	* 2.2965	* 2.0948	* 2.1434	* 2.9939	*	*	*
	* 2.2112	* 1.9785	* 1.7929	* 1.8296	* 2.5141	*	*	*
	* 2.0040	* 1.8093	* 1.6519	* 1.6998	* 2.3004	*	*	*
14	* 1.9855	* 2.0343	* 2.6257	* 3.4472	*	*	*	*
	* 2.0531	* 2.0859	* 2.7466	* 3.4816	*	*	*	*
	* 2.1242	* 2.1533	* 2.8672	* 3.5337	*	*	*	*
	* 2.3113	* 2.3514	* 3.0302	* 3.5756	*	*	*	*
	* 2.0149	* 2.0420	* 2.5963	* 3.0358	*	*	*	*
	* 1.8102	* 1.8362	* 2.3174	* 2.7126	*	*	*	*
15	* 3.6333	* 3.8048	* 4 EFPD 118	* % POWER				
	* 3.6557	* 3.8111	* 75 EFPD 118	* % POWER				
	* 3.7217	* 3.8417	* 150 EFPD 118	* % POWER				
	* 3.9490	* 4.0875	* 275 EFPD 118	* % POWER				
	* 3.3712	* 3.5010	* 375 EFPD 118	* % POWER				
	* 2.9122	* 3.0470	* 475 EFPD 118	* % POWER				

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 241 of 306

TABLE A-2 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) NORMAL OPERATION

THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 3.9799	* 4.1965	* 4.2703	* 3.9011	* 3.9589	* 4.5400	* 5.0296	* 7.9431 *
	* 4.5092	* 4.7539	* 4.7072	* 4.2451	* 4.2823	* 4.8379	* 5.1161	* 7.9080 *
	* 4.8931	* 5.1574	* 4.9968	* 4.5068	* 4.5570	* 5.0829	* 5.3001	* 8.1914 *
	* 4.6099	* 4.7741	* 4.6122	* 4.3083	* 4.3994	* 5.0517	* 5.3822	* 8.2437 *
	* 3.7338	* 3.8542	* 3.7303	* 3.5280	* 3.5861	* 4.1172	* 4.3732	* 6.6601 *
	* 3.2338	* 3.3328	* 3.2433	* 3.0956	* 3.1087	* 3.4896	* 3.6414	* 5.4215 *
9	* 4.1965	* 4.0290	* 4.0300	* 4.1077	* 3.9407	* 4.3017	* 5.1402	* 8.2147 *
	* 4.7539	* 4.4683	* 4.4107	* 4.4603	* 4.2088	* 4.5275	* 5.2216	* 8.1436 *
	* 5.1574	* 4.8073	* 4.7076	* 4.6841	* 4.4318	* 4.7922	* 5.4133	* 8.3609 *
	* 4.7741	* 4.4217	* 4.3788	* 4.4128	* 4.3349	* 4.7370	* 5.4784	* 8.4483 *
	* 3.8542	* 3.5797	* 3.5480	* 3.5767	* 3.5398	* 3.8519	* 4.4419	* 6.8635 *
	* 3.3328	* 3.1218	* 3.1162	* 3.1146	* 3.0914	* 3.2871	* 3.7003	* 5.6409 *
10	* 4.2703	* 4.0289	* 4.2716	* 4.0194	* 4.1522	* 4.4322	* 5.7237	*
	* 4.7072	* 4.4103	* 4.6606	* 4.2939	* 4.4104	* 4.5779	* 5.8862	*
	* 4.9968	* 4.7100	* 4.9040	* 4.5283	* 4.6337	* 4.7764	* 6.1652	*
	* 4.6122	* 4.3770	* 4.5272	* 4.3055	* 4.4270	* 4.7045	* 6.1914	*
	* 3.7303	* 3.5471	* 3.6607	* 3.5148	* 3.5942	* 3.8178	* 5.0412	*
	* 3.2433	* 3.1151	* 3.1905	* 3.0866	* 3.1168	* 3.2672	* 4.2447	*
11	* 3.9011	* 4.1355	* 4.0316	* 4.4041	* 4.4127	* 5.0607	* 7.4234	*
	* 4.2451	* 4.4837	* 4.3038	* 4.6723	* 4.5409	* 5.0757	* 7.3996	*
	* 4.5068	* 4.7078	* 4.5411	* 4.8908	* 4.7362	* 5.2216	* 7.6257	*
	* 4.3083	* 4.4205	* 4.3109	* 4.5636	* 4.5079	* 4.9931	* 7.4234	*
	* 3.5280	* 3.5798	* 3.5155	* 3.6845	* 3.6288	* 4.0078	* 6.0035	*
	* 3.0956	* 3.1167	* 3.0866	* 3.2002	* 3.1492	* 3.4270	* 5.0670	*
12	* 3.9589	* 3.9832	* 4.1830	* 4.4276	* 5.0554	* 6.2403	*	
	* 4.2823	* 4.2464	* 4.4368	* 4.5520	* 5.0549	* 6.2214	*	
	* 4.5570	* 4.4717	* 4.6582	* 4.7472	* 5.2092	* 6.4093	*	
	* 4.3994	* 4.3572	* 4.4400	* 4.5127	* 4.8722	* 6.1074	*	
	* 3.5861	* 3.5498	* 3.5983	* 3.6286	* 3.8663	* 4.9256	*	
	* 3.1087	* 3.0962	* 3.1190	* 3.1481	* 3.3120	* 4.2319	*	
13	* 4.5400	* 4.3492	* 4.4722	* 5.0890	* 6.2458	*		
	* 4.8379	* 4.5697	* 4.6094	* 5.0963	* 6.2287	*		
	* 5.0829	* 4.8307	* 4.8078	* 5.2414	* 6.4154	*		
	* 5.0517	* 4.7623	* 4.7224	* 5.0014	* 6.1059	*		
	* 4.1172	* 3.8641	* 3.8234	* 4.0076	* 4.9215	*		
	* 3.4896	* 3.2944	* 3.2689	* 3.4259	* 4.2293	*		
14	* 5.0296	* 5.1797	* 5.7790	* 7.4831	*			
	* 5.1161	* 5.2509	* 5.9295	* 7.4514	*			
	* 5.3001	* 5.4426	* 6.2068	* 7.6742	*			
	* 5.3822	* 5.4979	* 6.2154	* 7.4535	*			
	* 4.3732	* 4.4509	* 5.0505	* 6.0157	*			
	* 3.6414	* 3.7064	* 4.2493	* 5.0674	*			
15	* 7.9431	* 8.2689	* 4 EFPD 118 % POWER					
	* 7.9080	* 8.2004	* 75 EFPD 118 % POWER					
	* 8.1914	* 8.4180	* 150 EFPD 118 % POWER					
	* 8.2438	* 8.4975	* 275 EFPD 118 % POWER					
	* 6.6601	* 6.8971	* 375 EFPD 118 % POWER					
	* 5.4215	* 5.6686	* 475 EFPD 118 % POWER					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 242 of 306

TABLE A-3

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4467 *	* 1.3334 *	* 1.2308 *	* 1.4404 *	* 1.3961 *	* 1.2405 *	* 1.3568 *	* 0.7469 *
	* 1.1578 *	* 1.2449 *	* 1.3516 *	* 1.1682 *	* 1.2016 *	* 1.3475 *	* 1.2419 *	* 2.1781 *
9	* 1.3334 *	* 1.3582 *	* 1.3302 *	* 1.2944 *	* 1.4610 *	* 1.3072 *	* 1.3507 *	* 0.6869 *
	* 1.2449 *	* 1.2249 *	* 1.2650 *	* 1.2897 *	* 1.1540 *	* 1.2750 *	* 1.2500 *	* 2.3720 *
10	* 1.2308 *	* 1.3334 *	* 1.2112 *	* 1.3937 *	* 1.3119 *	* 1.4130 *	* 1.0170 *	
	* 1.3516 *	* 1.2629 *	* 1.3693 *	* 1.2107 *	* 1.2764 *	* 1.1749 *	* 1.6227 *	
11	* 1.4404 *	* 1.2867 *	* 1.3896 *	* 1.2077 *	* 1.2932 *	* 1.3405 *	* 0.7052 *	
	* 1.1682 *	* 1.2964 *	* 1.2143 *	* 1.3900 *	* 1.2862 *	* 1.2287 *	* 2.2756 *	
12	* 1.3961 *	* 1.4447 *	* 1.3037 *	* 1.2893 *	* 1.2891 *	* 0.7837 *		
	* 1.2016 *	* 1.1664 *	* 1.2833 *	* 1.2894 *	* 1.2780 *	* 2.0488 *		
13	* 1.2405 *	* 1.2927 *	* 1.4016 *	* 1.3338 *	* 0.7821 *			
	* 1.3475 *	* 1.2876 *	* 1.1823 *	* 1.2339 *	* 2.0525 *			
14	* 1.3568 *	* 1.3429 *	* 1.0083 *	* 0.6998 *				
	* 1.2419 *	* 1.2563 *	* 1.6353 *	* 2.2908 *				
15	* 0.7469 *	* 0.6740 *	F-DEL-H					
	* 2.1781 *	* 2.4129 *	M-DEL-H					

AT 100% POWER, 75 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3476 *	* 1.2105 *	* 1.1500 *	* 1.4027 *	* 1.3343 *	* 1.1860 *	* 1.3776 *	* 0.7718 *
	* 1.2304 *	* 1.3588 *	* 1.4373 *	* 1.1955 *	* 1.2526 *	* 1.4102 *	* 1.2228 *	* 2.1216 *
9	* 1.2105 *	* 1.2649 *	* 1.2847 *	* 1.2399 *	* 1.4386 *	* 1.2765 *	* 1.3874 *	* 0.7123 *
	* 1.3588 *	* 1.3053 *	* 1.3020 *	* 1.3439 *	* 1.1636 *	* 1.3083 *	* 1.2171 *	* 2.3022 *
10	* 1.1500 *	* 1.2836 *	* 1.1533 *	* 1.3766 *	* 1.2774 *	* 1.4241 *	* 1.0080 *	
	* 1.4373 *	* 1.3031 *	* 1.4294 *	* 1.2227 *	* 1.3070 *	* 1.1657 *	* 1.6416 *	
11	* 1.4027 *	* 1.2324 *	* 1.3724 *	* 1.1625 *	* 1.3180 *	* 1.3715 *	* 0.7245 *	
	* 1.1955 *	* 1.3517 *	* 1.2263 *	* 1.4432 *	* 1.2584 *	* 1.2025 *	* 2.2242 *	
12	* 1.3343 *	* 1.4177 *	* 1.2701 *	* 1.3144 *	* 1.3163 *	* 0.8132 *		
	* 1.2526 *	* 1.1801 *	* 1.3135 *	* 1.2613 *	* 1.2501 *	* 1.9799 *		
13	* 1.1860 *	* 1.2640 *	* 1.4149 *	* 1.3655 *	* 0.8118 *			
	* 1.4102 *	* 1.3203 *	* 1.1724 *	* 1.2071 *	* 1.9831 *			
14	* 1.3776 *	* 1.3794 *	* 1.0005 *	* 0.7196 *				
	* 1.2228 *	* 1.2219 *	* 1.6526 *	* 2.2377 *				
15	* 0.7718 *	* 0.6997 *	F-DEL-H					
	* 2.1216 *	* 2.3392 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 243 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* 1.2977 *	* 1.1383 *	* 1.1111 *	* 1.3821 *	* 1.2815 *	* 1.1334 *	* 1.3981 *	* 0.7789 *
	* 1.2773 *	* 1.4420 *	* 1.4883 *	* 1.2140 *	* 1.2994 *	* 1.4693 *	* 1.2005 *	* 2.0938 *
9	* 1.1383 *	* 1.2160 *	* 1.2907 *	* 1.2062 *	* 1.4305 *	* 1.2379 *	* 1.4001 *	* 0.7197 *
	* 1.4420 *	* 1.3567 *	* 1.3057 *	* 1.3807 *	* 1.1725 *	* 1.3482 *	* 1.2000 *	* 2.2793 *
10	* 1.1111 *	* 1.2896 *	* 1.1248 *	* 1.3727 *	* 1.2469 *	* 1.4123 *	* 0.9823 *	
	* 1.4883 *	* 1.3062 *	* 1.4667 *	* 1.2244 *	* 1.3390 *	* 1.1765 *	* 1.6860 *	
11	* 1.3821 *	* 1.2007 *	* 1.3678 *	* 1.1374 *	* 1.3305 *	* 1.3890 *	* 0.7293 *	
	* 1.2140 *	* 1.3873 *	* 1.2283 *	* 1.4746 *	* 1.2442 *	* 1.1852 *	* 2.2296 *	
12	* 1.2815 *	* 1.4145 *	* 1.2405 *	* 1.3275 *	* 1.3249 *	* 0.8293 *		
	* 1.2994 *	* 1.1853 *	* 1.3452 *	* 1.2475 *	* 1.2436 *	* 1.9567 *		
13	* 1.1334 *	* 1.2272 *	* 1.4047 *	* 1.3846 *	* 0.8283 *			
	* 1.4693 *	* 1.3587 *	* 1.1819 *	* 1.1884 *	* 1.9589 *			
14	* 1.3981 *	* 1.3939 *	* 0.9763 *	* 0.7251 *				
	* 1.2005 *	* 1.2047 *	* 1.6954 *	* 2.2413 *				
15	* 0.7789 *	* 0.7078 *	F-DEL-H					
	* 2.0938 *	* 2.3145 *	M-DEL-H					

AT 100% POWER, 275 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3563 *	* 1.1366 *	* 1.1434 *	* 1.4402 *	* 1.2331 *	* 1.0337 *	* 1.2414 *	* 0.6946 *
	* 1.2390 *	* 1.4663 *	* 1.4665 *	* 1.1683 *	* 1.3476 *	* 1.5736 *	* 1.2943 *	* 2.2642 *
9	* 1.1366 *	* 1.2558 *	* 1.4272 *	* 1.2201 *	* 1.4719 *	* 1.1520 *	* 1.2269 *	* 0.6435 *
	* 1.4663 *	* 1.3386 *	* 1.1912 *	* 1.3807 *	* 1.1409 *	* 1.4290 *	* 1.3202 *	* 2.4544 *
10	* 1.1434 *	* 1.4268 *	* 1.1604 *	* 1.4428 *	* 1.2287 *	* 1.3778 *	* 0.8910 *	
	* 1.4665 *	* 1.1915 *	* 1.4498 *	* 1.1731 *	* 1.3538 *	* 1.2006 *	* 1.8164 *	
11	* 1.4402 *	* 1.2184 *	* 1.4399 *	* 1.1552 *	* 1.3929 *	* 1.3485 *	* 0.7005 *	
	* 1.1683 *	* 1.3828 *	* 1.1753 *	* 1.4585 *	* 1.1935 *	* 1.2151 *	* 2.2872 *	
12	* 1.2331 *	* 1.4652 *	* 1.2247 *	* 1.3914 *	* 1.3549 *	* 0.8425 *		
	* 1.3476 *	* 1.1459 *	* 1.3580 *	* 1.1946 *	* 1.2167 *	* 1.9148 *		
13	* 1.0337 *	* 1.1446 *	* 1.3729 *	* 1.3468 *	* 0.8422 *			
	* 1.5736 *	* 1.4374 *	* 1.2045 *	* 1.2164 *	* 1.9156 *			
14	* 1.2414 *	* 1.2236 *	* 0.8877 *	* 0.6980 *				
	* 1.2943 *	* 1.3235 *	* 1.8229 *	* 2.2948 *				
15	* 0.6946 *	* 0.6344 *	F-DEL-H					
	* 2.2642 *	* 2.4876 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 244 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 100% POWER, 375 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3793	* 1.1197	* 1.1242	* 1.4072	* 1.2062	* 1.0225	* 1.2088	* 0.7011 *
	* 1.2051	* 1.4709	* 1.4640	* 1.1767	* 1.3613	* 1.5931	* 1.3420	* 2.2733 *
9	* 1.1197	* 1.2303	* 1.4107	* 1.1951	* 1.4572	* 1.1374	* 1.1995	* 0.6512 *
	* 1.4709	* 1.3423	* 1.1762	* 1.3762	* 1.1367	* 1.4398	* 1.3638	* 2.4563 *
10	* 1.1242	* 1.4110	* 1.1398	* 1.4149	* 1.2070	* 1.3733	* 0.8924	*
	* 1.4640	* 1.1760	* 1.4337	* 1.1708	* 1.3625	* 1.1983	* 1.8200	*
11	* 1.4072	* 1.1944	* 1.4145	* 1.1416	* 1.3945	* 1.3360	* 0.7188	*
	* 1.1767	* 1.3771	* 1.1714	* 1.4462	* 1.1837	* 1.2210	* 2.2185	*
12	* 1.2062	* 1.4549	* 1.2054	* 1.3948	* 1.3958	* 0.8679	*	
	* 1.3613	* 1.1387	* 1.3647	* 1.1836	* 1.1717	* 1.8429	*	
13	* 1.0225	* 1.1331	* 1.3722	* 1.3364	* 0.8682	*		
	* 1.5931	* 1.4453	* 1.1986	* 1.2209	* 1.8428	*		
14	* 1.2088	* 1.1978	* 0.8909	* 0.7175	*			
	* 1.3420	* 1.3658	* 1.8236	* 2.2226	*			
15	* 0.7011	* 0.6431	* F-DEL-H					
	* 2.2733	* 2.4863	* M-DEL-H					

AT 100% POWER, 475 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3511	* 1.1049	* 1.1039	* 1.3593	* 1.1828	* 1.0323	* 1.2282	* 0.7456 *
	* 1.2352	* 1.4951	* 1.4955	* 1.2221	* 1.3931	* 1.5835	* 1.3239	* 2.1448 *
9	* 1.1049	* 1.2001	* 1.3601	* 1.1642	* 1.4146	* 1.1332	* 1.2196	* 0.6939 *
	* 1.4951	* 1.3761	* 1.2208	* 1.4142	* 1.1736	* 1.4518	* 1.3434	* 2.3116 *
10	* 1.1039	* 1.3604	* 1.1149	* 1.3659	* 1.1816	* 1.3568	* 0.9151	*
	* 1.4955	* 1.2206	* 1.4655	* 1.2153	* 1.3961	* 1.2187	* 1.7802	*
11	* 1.3593	* 1.1638	* 1.3660	* 1.1221	* 1.3596	* 1.3209	* 0.7452	*
	* 1.2221	* 1.4147	* 1.2153	* 1.4649	* 1.2055	* 1.2294	* 2.1371	*
12	* 1.1828	* 1.4135	* 1.1806	* 1.3601	* 1.3795	* 0.8824	*	
	* 1.3931	* 1.1747	* 1.3975	* 1.2054	* 1.1770	* 1.8025	*	
13	* 1.0323	* 1.1302	* 1.3567	* 1.3216	* 0.8829	*		
	* 1.5835	* 1.4556	* 1.2185	* 1.2291	* 1.8027	*		
14	* 1.2282	* 1.2186	* 0.9142	* 0.7444	*			
	* 1.3239	* 1.3447	* 1.7824	* 2.1399	*			
15	* 0.7456	* 0.6858	* F-DEL-H					
	* 2.1447	* 2.3375	* M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 245 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4667 *	* 1.3468 *	* 1.2363 *	* 1.4584 *	* 1.4195 *	* 1.2504 *	* 1.3405 *	* 0.7107 *
	* 1.3862 *	* 1.5066 *	* 1.6501 *	* 1.4156 *	* 1.4552 *	* 1.6409 *	* 1.5063 *	* 2.7277 *
9	* 1.3468 *	* 1.3579 *	* 1.3360 *	* 1.3068 *	* 1.4808 *	* 1.3263 *	* 1.3422 *	* 0.6608 *
	* 1.5066 *	* 1.4894 *	* 1.5471 *	* 1.5726 *	* 1.4099 *	* 1.5628 *	* 1.5207 *	* 2.9759 *
10	* 1.2363 *	* 1.3394 *	* 1.1872 *	* 1.3962 *	* 1.3271 *	* 1.4373 *	* 1.0205 *	
	* 1.6501 *	* 1.5443 *	* 1.6783 *	* 1.4829 *	* 1.5426 *	* 1.4249 *	* 2.0029 *	
11	* 1.4584 *	* 1.2983 *	* 1.3908 *	* 1.1922 *	* 1.3060 *	* 1.3601 *	* 0.7060 *	
	* 1.4156 *	* 1.5814 *	* 1.4871 *	* 1.7072 *	* 1.5525 *	* 1.4752 *	* 2.7522 *	
12	* 1.4195 *	* 1.4631 *	* 1.3180 *	* 1.3016 *	* 1.3006 *	* 0.7861 *		
	* 1.4552 *	* 1.4249 *	* 1.5511 *	* 1.5580 *	* 1.5362 *	* 2.4430 *		
13	* 1.2504 *	* 1.3103 *	* 1.4257 *	* 1.3525 *	* 0.7843 *			
	* 1.6409 *	* 1.5795 *	* 1.4341 *	* 1.4819 *	* 2.4488 *			
14	* 1.3405 *	* 1.3338 *	* 1.0109 *	* 0.7002 *				
	* 1.5063 *	* 1.5289 *	* 2.0194 *	* 2.7711 *				
15	* 0.7107 *	* 0.6478 *	F-DEL-H					
	* 2.7277 *	* 3.0280 *	M-DEL-H					

AT 75% POWER, 75 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3543 *	* 1.2112 *	* 1.1476 *	* 1.4177 *	* 1.3541 *	* 1.1930 *	* 1.3500 *	* 0.7362 *
	* 1.4861 *	* 1.6616 *	* 1.7736 *	* 1.4544 *	* 1.5249 *	* 1.7154 *	* 1.4824 *	* 2.6380 *
9	* 1.2112 *	* 1.2552 *	* 1.2787 *	* 1.2493 *	* 1.4602 *	* 1.2957 *	* 1.3850 *	* 0.6871 *
	* 1.6616 *	* 1.6041 *	* 1.6028 *	* 1.6410 *	* 1.4214 *	* 1.5994 *	* 1.4783 *	* 2.8686 *
10	* 1.1476 *	* 1.2775 *	* 1.1193 *	* 1.3860 *	* 1.2925 *	* 1.4532 *	* 1.0135 *	
	* 1.7736 *	* 1.6043 *	* 1.7616 *	* 1.4971 *	* 1.5794 *	* 1.4127 *	* 2.0236 *	
11	* 1.4177 *	* 1.2408 *	* 1.3799 *	* 1.1589 *	* 1.3353 *	* 1.3977 *	* 0.7284 *	
	* 1.4544 *	* 1.6506 *	* 1.5029 *	* 1.7693 *	* 1.5147 *	* 1.4401 *	* 2.6876 *	
12	* 1.3541 *	* 1.4375 *	* 1.2843 *	* 1.3312 *	* 1.3338 *	* 0.8202 *		
	* 1.5249 *	* 1.4407 *	* 1.5877 *	* 1.5189 *	* 1.4985 *	* 2.3557 *		
13	* 1.1930 *	* 1.2819 *	* 1.4427 *	* 1.3908 *	* 0.8186 *			
	* 1.7154 *	* 1.6145 *	* 1.4210 *	* 1.4458 *	* 2.3591 *			
14	* 1.3500 *	* 1.3761 *	* 1.0053 *	* 0.7229 *				
	* 1.4824 *	* 1.4862 *	* 2.0382 *	* 2.7049 *				
15	* 0.7362 *	* 0.6744 *	F-DEL-H					
	* 2.6380 *	* 2.9163 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 246 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* 1.2983	* 1.1322	* 1.1058	* 1.3972	* 1.2976	* 1.1364	* 1.3286	* 0.7419 *
	* 1.5428	* 1.7695	* 1.8381	* 1.4657	* 1.5786	* 1.7903	* 1.4527	* 2.5982 *
9	* 1.1322	* 1.2018	* 1.2784	* 1.2130	* 1.4523	* 1.2553	* 1.3966	* 0.6935 *
	* 1.7695	* 1.6811	* 1.6009	* 1.6818	* 1.4201	* 1.6439	* 1.4544	* 2.8214 *
10	* 1.1058	* 1.2776	* 1.0840	* 1.3833	* 1.2615	* 1.4428	* 0.9875	*
	* 1.8381	* 1.6023	* 1.8137	* 1.5034	* 1.6035	* 1.4096	* 2.0671	*
11	* 1.3972	* 1.2056	* 1.3777	* 1.1394	* 1.3527	* 1.4227	* 0.7347	*
	* 1.4657	* 1.6913	* 1.5088	* 1.7732	* 1.4804	* 1.3964	* 2.6495	*
12	* 1.2976	* 1.4347	* 1.2543	* 1.3480	* 1.3475	* 0.8399	*	
	* 1.5786	* 1.4306	* 1.6119	* 1.4847	* 1.4762	* 2.2912	*	
13	* 1.1364	* 1.2433	* 1.4344	* 1.4175	* 0.8386	*		
	* 1.7903	* 1.6578	* 1.4164	* 1.4006	* 2.2950	*		
14	* 1.3286	* 1.3896	* 0.9808	* 0.7301	*			
	* 1.4527	* 1.4608	* 2.0796	* 2.6643	*			
15	* 0.7419	* 0.6814	* F-DEL-H					
	* 2.5982	* 2.8662	* M-DEL-H					

AT 75% POWER, 275 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3695	* 1.1374	* 1.1470	* 1.4653	* 1.2492	* 1.0303	* 1.1298	* 0.6373 *
	* 1.4832	* 1.7813	* 1.7853	* 1.3941	* 1.6019	* 1.9499	* 1.6041	* 2.8646 *
9	* 1.1374	* 1.2508	* 1.4238	* 1.2195	* 1.5011	* 1.1613	* 1.1949	* 0.6006 *
	* 1.7813	* 1.6361	* 1.4650	* 1.6680	* 1.3568	* 1.7183	* 1.6361	* 3.1096 *
10	* 1.1470	* 1.4239	* 1.1208	* 1.4619	* 1.2467	* 1.4045	* 0.8863	*
	* 1.7853	* 1.4653	* 1.7631	* 1.4316	* 1.6043	* 1.4073	* 2.2393	*
11	* 1.4653	* 1.2172	* 1.4585	* 1.1581	* 1.4256	* 1.3853	* 0.7046	*
	* 1.3941	* 1.6752	* 1.4350	* 1.7240	* 1.4048	* 1.4011	* 2.6906	*
12	* 1.2492	* 1.4934	* 1.2421	* 1.4238	* 1.3918	* 0.8590	*	
	* 1.6019	* 1.3631	* 1.6099	* 1.4066	* 1.4106	* 2.2174	*	
13	* 1.0303	* 1.1530	* 1.3989	* 1.3833	* 0.8586	*		
	* 1.9499	* 1.7297	* 1.4110	* 1.4033	* 2.2195	*		
14	* 1.1298	* 1.1912	* 0.8826	* 0.7019	*			
	* 1.6041	* 1.6409	* 2.2485	* 2.7007	*			
15	* 0.6373	* 0.5917	* F-DEL-H					
	* 2.8646	* 3.1526	* M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 247 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 75% POWER, 375 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3969	* 1.1187	* 1.1264	* 1.4329	* 1.2237	* 1.0209	* 1.0963	* 0.6305 *
	* 1.4366	* 1.7879	* 1.7815	* 1.3914	* 1.6114	* 1.9749	* 1.6942	* 2.9351 *
9	* 1.1187	* 1.2189	* 1.4047	* 1.1927	* 1.4898	* 1.1493	* 1.1601	* 0.5995 *
	* 1.7879	* 1.6630	* 1.4504	* 1.6708	* 1.3376	* 1.7260	* 1.7142	* 3.1682 *
10	* 1.1264	* 1.4053	* 1.0890	* 1.4342	* 1.2274	* 1.4115	* 0.8891	*
	* 1.7815	* 1.4502	* 1.8016	* 1.4196	* 1.6031	* 1.3852	* 2.2303	*
11	* 1.4329	* 1.1909	* 1.4336	* 1.1598	* 1.4367	* 1.3825	* 0.7278	*
	* 1.3914	* 1.6756	* 1.4201	* 1.6826	* 1.3608	* 1.3966	* 2.6059	*
12	* 1.2237	* 1.4870	* 1.2255	* 1.4370	* 1.4504	* 0.8937	*	
	* 1.6114	* 1.3405	* 1.6061	* 1.3608	* 1.3420	* 2.1230	*	
13	* 1.0209	* 1.1444	* 1.4113	* 1.3828	* 0.8941	*		
	* 1.9749	* 1.7335	* 1.3863	* 1.3971	* 2.1241	*		
14	* 1.0963	* 1.1582	* 0.8874	* 0.7264	*			
	* 1.6942	* 1.7172	* 2.2354	* 2.6117	*			
15	* 0.6305	* 0.5918	* F-DEL-H					
	* 2.9351	* 3.2072	* M-DEL-H					

AT 75% POWER, 475 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3691	* 1.1033	* 1.1052	* 1.3840	* 1.2006	* 1.0266	* 1.1143	* 0.6675 *
	* 1.4623	* 1.8132	* 1.8132	* 1.4362	* 1.6405	* 1.9726	* 1.6774	* 2.7805 *
9	* 1.1033	* 1.1854	* 1.3534	* 1.1636	* 1.4476	* 1.1471	* 1.1794	* 0.6376 *
	* 1.8132	* 1.7170	* 1.5128	* 1.7074	* 1.3680	* 1.7312	* 1.6934	* 2.9931 *
10	* 1.1052	* 1.3539	* 1.0563	* 1.3839	* 1.2027	* 1.3987	* 0.9139	*
	* 1.8132	* 1.5125	* 1.8458	* 1.4574	* 1.6278	* 1.3903	* 2.1752	*
11	* 1.3840	* 1.1622	* 1.3839	* 1.1511	* 1.4104	* 1.3723	* 0.7575	*
	* 1.4362	* 1.7110	* 1.4573	* 1.6850	* 1.3668	* 1.4000	* 2.5066	*
12	* 1.2006	* 1.4463	* 1.2015	* 1.4107	* 1.4403	* 0.9134	*	
	* 1.6405	* 1.3696	* 1.6291	* 1.3667	* 1.3328	* 2.0655	*	
13	* 1.0266	* 1.1437	* 1.3993	* 1.3730	* 0.9139	*		
	* 1.9726	* 1.7364	* 1.3903	* 1.3998	* 2.0657	*		
14	* 1.1143	* 1.1781	* 0.9129	* 0.7566	*			
	* 1.6774	* 1.6953	* 2.1783	* 2.5102	*			
15	* 0.6675	* 0.6300	* F-DEL-H					
	* 2.7805	* 3.0268	* M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 248 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4852 *	* 1.3590 *	* 1.2410 *	* 1.4748 *	* 1.4405 *	* 1.2584 *	* 1.3284 *	* 0.6777 *
	* 1.8178 *	* 1.9627 *	* 2.1991 *	* 1.8730 *	* 1.9177 *	* 2.1940 *	* 1.9025 *	* 3.6906 *
9	* 1.3590 *	* 1.3597 *	* 1.3407 *	* 1.3182 *	* 1.4987 *	* 1.3436 *	* 1.3321 *	* 0.6367 *
	* 1.9627 *	* 1.9851 *	* 2.0830 *	* 2.0742 *	* 1.8689 *	* 2.0575 *	* 2.0393 *	* 4.0373 *
10	* 1.2410 *	* 1.3442 *	* 1.1670 *	* 1.4024 *	* 1.3414 *	* 1.4611 *	* 1.0227 *	
	* 2.1991 *	* 2.0795 *	* 2.2470 *	* 1.9639 *	* 2.0417 *	* 1.8879 *	* 2.7178 *	
11	* 1.4748 *	* 1.3090 *	* 1.3964 *	* 1.1929 *	* 1.3186 *	* 1.3782 *	* 0.7062 *	
	* 1.8730 *	* 2.0865 *	* 1.9735 *	* 2.2976 *	* 2.0769 *	* 1.9729 *	* 3.6917 *	
12	* 1.4405 *	* 1.4797 *	* 1.3313 *	* 1.3132 *	* 1.3111 *	* 0.7881 *		
	* 1.9177 *	* 1.8932 *	* 2.0549 *	* 2.0850 *	* 2.0653 *	* 3.2801 *		
13	* 1.2584 *	* 1.3262 *	* 1.4482 *	* 1.3697 *	* 0.7861 *			
	* 2.1940 *	* 2.0841 *	* 1.9010 *	* 1.9829 *	* 3.2895 *			
14	* 1.3284 *	* 1.3229 *	* 1.0123 *	* 0.6999 *				
	* 1.9025 *	* 2.0614 *	* 2.7398 *	* 3.7196 *				
15	* 0.6777 *	* 0.6236 *	F-DEL-H					
	* 3.6906 *	* 4.1054 *	M-DEL-H					

AT 50% POWER, 75 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3595 *	* 1.2111 *	* 1.1449 *	* 1.4313 *	* 1.3720 *	* 1.1982 *	* 1.3369 *	* 0.7025 *
	* 1.9596 *	* 2.1877 *	* 2.3616 *	* 1.9184 *	* 2.0018 *	* 2.2960 *	* 1.8618 *	* 3.5718 *
9	* 1.2111 *	* 1.2460 *	* 1.2771 *	* 1.2582 *	* 1.4801 *	* 1.3135 *	* 1.3790 *	* 0.6628 *
	* 2.1877 *	* 2.1504 *	* 2.1658 *	* 2.1571 *	* 1.8809 *	* 2.0912 *	* 1.9633 *	* 3.8941 *
10	* 1.1449 *	* 1.2758 *	* 1.1011 *	* 1.3955 *	* 1.3072 *	* 1.4810 *	* 1.0180 *	
	* 2.3616 *	* 2.1681 *	* 2.3527 *	* 1.9646 *	* 2.0770 *	* 1.8584 *	* 2.7406 *	
11	* 1.4313 *	* 1.2490 *	* 1.3885 *	* 1.1634 *	* 1.3523 *	* 1.4232 *	* 0.7319 *	
	* 1.9184 *	* 2.1706 *	* 1.9755 *	* 2.3411 *	* 2.0134 *	* 1.9155 *	* 3.5746 *	
12	* 1.3720 *	* 1.4556 *	* 1.2981 *	* 1.3478 *	* 1.3509 *	* 0.8274 *		
	* 2.0018 *	* 1.9032 *	* 2.0896 *	* 2.0197 *	* 2.0010 *	* 3.1329 *		
13	* 1.1982 *	* 1.2983 *	* 1.4692 *	* 1.4154 *	* 0.8255 *			
	* 2.2960 *	* 2.1196 *	* 1.8743 *	* 1.9241 *	* 3.1413 *			
14	* 1.3369 *	* 1.3692 *	* 1.0089 *	* 0.7260 *				
	* 1.8618 *	* 1.9804 *	* 2.7604 *	* 3.5996 *				
15	* 0.7025 *	* 0.6500 *	F-DEL-H					
	* 3.5718 *	* 3.9563 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 249 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 150 EFPD

	H	G	F	E	D	C	B	A
8	* 1.2975 *	* 1.1258 *	* 1.1002 *	* 1.4108 *	* 1.3123 *	* 1.1383 *	* 1.3049 *	* 0.7060 *
	* 2.0402 *	* 2.3448 *	* 2.4451 *	* 1.9366 *	* 2.0601 *	* 2.3970 *	* 1.8728 *	* 3.5107 *
9	* 1.1258 *	* 1.1879 *	* 1.2718 *	* 1.2205 *	* 1.4726 *	* 1.2718 *	* 1.3887 *	* 0.6677 *
	* 2.3448 *	* 2.2700 *	* 2.1621 *	* 2.2059 *	* 1.8635 *	* 2.1402 *	* 1.9307 *	* 3.8214 *
10	* 1.1002 *	* 1.2709 *	* 1.0662 *	* 1.3936 *	* 1.2764 *	* 1.4731 *	* 0.9920 *	
	* 2.4451 *	* 2.1637 *	* 2.4083 *	* 1.9489 *	* 2.0999 *	* 1.8464 *	* 2.7935 *	
11	* 1.4108 *	* 1.2121 *	* 1.3872 *	* 1.1453 *	* 1.3793 *	* 1.4566 *	* 0.7403 *	
	* 1.9366 *	* 2.2190 *	* 1.9589 *	* 2.3244 *	* 1.9523 *	* 1.8480 *	* 3.4928 *	
12	* 1.3123 *	* 1.4572 *	* 1.2682 *	* 1.3739 *	* 1.3706 *	* 0.8512 *		
	* 2.0601 *	* 1.8768 *	* 2.1116 *	* 1.9588 *	* 1.9621 *	* 3.0199 *		
13	* 1.1383 *	* 1.2587 *	* 1.4634 *	* 1.4506 *	* 0.8496 *			
	* 2.3970 *	* 2.1590 *	* 1.8601 *	* 1.8547 *	* 3.0271 *			
14	* 1.3049 *	* 1.3809 *	* 0.9846 *	* 0.7352 *				
	* 1.8728 *	* 1.9434 *	* 2.8110 *	* 3.5145 *				
15	* 0.7060 *	* 0.6555 *	F-DEL-H					
	* 3.5107 *	* 3.8805 *	M-DEL-H					

AT 50% POWER, 275 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3779 *	* 1.1354 *	* 1.1479 *	* 1.4875 *	* 1.2656 *	* 1.0329 *	* 1.0903 *	* 0.5845 *
	* 1.9592 *	* 2.3568 *	* 2.3640 *	* 1.8212 *	* 2.0747 *	* 2.5431 *	* 2.1346 *	* 3.8511 *
9	* 1.1354 *	* 1.2410 *	* 1.4259 *	* 1.2274 *	* 1.5289 *	* 1.1727 *	* 1.1634 *	* 0.5612 *
	* 2.3568 *	* 2.2109 *	* 1.8596 *	* 2.1753 *	* 1.7751 *	* 2.2159 *	* 2.1869 *	* 4.1935 *
10	* 1.1479 *	* 1.4259 *	* 1.1004 *	* 1.4789 *	* 1.2653 *	* 1.4350 *	* 0.8839 *	
	* 2.3640 *	* 1.8594 *	* 2.2805 *	* 1.7955 *	* 2.0878 *	* 1.8255 *	* 2.9551 *	
11	* 1.4875 *	* 1.2226 *	* 1.4749 *	* 1.1703 *	* 1.4588 *	* 1.4252 *	* 0.7111 *	
	* 1.8212 *	* 2.1856 *	* 1.8003 *	* 2.2403 *	* 1.8523 *	* 1.8131 *	* 3.5102 *	
12	* 1.2656 *	* 1.5202 *	* 1.2601 *	* 1.4567 *	* 1.4329 *	* 0.8779 *		
	* 2.0747 *	* 1.7866 *	* 2.0961 *	* 1.8547 *	* 1.8674 *	* 2.8868 *		
13	* 1.0329 *	* 1.1636 *	* 1.4305 *	* 1.4227 *	* 0.8774 *			
	* 2.5431 *	* 2.2318 *	* 1.8314 *	* 1.8321 *	* 2.8916 *			
14	* 1.0903 *	* 1.1592 *	* 0.8798 *	* 0.7080 *				
	* 2.1346 *	* 2.1940 *	* 2.9696 *	* 3.5259 *				
15	* 0.5845 *	* 0.5525 *	F-DEL-H					
	* 3.8511 *	* 4.2514 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 250 of 306

TABLE A-3 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - NORMAL OPERATION

AT 50% POWER, 375 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4201 *	* 1.1164 *	* 1.1178 *	* 1.4747 *	* 1.2611 *	* 1.0329 *	* 0.9915 *	* 0.5198 *
	* 1.8618 *	* 2.3728 *	* 2.3524 *	* 1.8027 *	* 2.0829 *	* 2.5589 *	* 2.1751 *	* 4.0669 *
9	* 1.1164 *	* 1.1850 *	* 1.3943 *	* 1.2172 *	* 1.5445 *	* 1.1803 *	* 1.1116 *	* 0.5121 *
	* 2.3728 *	* 2.1718 *	* 1.8291 *	* 2.1672 *	* 1.7214 *	* 2.2269 *	* 2.2573 *	* 4.3602 *
10	* 1.1178 *	* 1.3948 *	* 1.0290 *	* 1.4633 *	* 1.2700 *	* 1.4923 *	* 0.8931 *	
	* 2.3524 *	* 1.8280 *	* 2.2557 *	* 1.8008 *	* 2.0720 *	* 1.7714 *	* 2.9536 *	
11	* 1.4747 *	* 1.2135 *	* 1.4632 *	* 1.2160 *	* 1.5261 *	* 1.4745 *	* 0.7594 *	
	* 1.8027 *	* 2.1743 *	* 1.8000 *	* 2.1601 *	* 1.7367 *	* 1.7906 *	* 3.4117 *	
12	* 1.2611 *	* 1.5412 *	* 1.2677 *	* 1.5263 *	* 1.5360 *	* 0.9506 *		
	* 2.0829 *	* 1.7264 *	* 2.0757 *	* 1.7371 *	* 1.7247 *	* 2.7463 *		
13	* 1.0329 *	* 1.1749 *	* 1.4918 *	* 1.4747 *	* 0.9508 *			
	* 2.5589 *	* 2.2378 *	* 1.7737 *	* 1.7919 *	* 2.7488 *			
14	* 0.9915 *	* 1.1091 *	* 0.8911 *	* 0.7578 *				
	* 2.1751 *	* 2.2610 *	* 2.9623 *	* 3.4208 *				
15	* 0.5198 *	* 0.5063 *	F-DEL-H					
	* 4.0669 *	* 4.4496 *	M-DEL-H					

AT 50% POWER, 475 EFPD

	H	G	F	E	D	C	B	A
8	* 1.3900 *	* 1.0985 *	* 1.0920 *	* 1.4233 *	* 1.2373 *	* 1.0385 *	* 1.0080 *	* 0.5545 *
	* 1.9065 *	* 2.4125 *	* 2.4004 *	* 1.8606 *	* 2.1174 *	* 2.5499 *	* 2.1190 *	* 3.7885 *
9	* 1.0985 *	* 1.1506 *	* 1.3413 *	* 1.1883 *	* 1.5026 *	* 1.1795 *	* 1.1341 *	* 0.5483 *
	* 2.4125 *	* 2.2389 *	* 1.9105 *	* 2.2143 *	* 1.7536 *	* 2.2260 *	* 2.1985 *	* 4.0454 *
10	* 1.0920 *	* 1.3418 *	* 1.0006 *	* 1.4178 *	* 1.2467 *	* 1.4812 *	* 0.9197 *	
	* 2.4004 *	* 1.9095 *	* 2.3311 *	* 1.8777 *	* 2.0883 *	* 1.7659 *	* 2.8694 *	
11	* 1.4233 *	* 1.1856 *	* 1.4181 *	* 1.2086 *	* 1.5021 *	* 1.4651 *	* 0.7911 *	
	* 1.8606 *	* 2.2198 *	* 1.8766 *	* 2.1518 *	* 1.7331 *	* 1.7842 *	* 3.2668 *	
12	* 1.2373 *	* 1.5008 *	* 1.2458 *	* 1.5025 *	* 1.5245 *	* 0.9722 *		
	* 2.1174 *	* 1.7565 *	* 2.0902 *	* 1.7331 *	* 1.6943 *	* 2.6508 *		
13	* 1.0385 *	* 1.1757 *	* 1.4817 *	* 1.4658 *	* 0.9727 *			
	* 2.5499 *	* 2.2336 *	* 1.7664 *	* 1.7843 *	* 2.6524 *			
14	* 1.0080 *	* 1.1325 *	* 0.9185 *	* 0.7901 *				
	* 2.1190 *	* 2.2007 *	* 2.8738 *	* 3.2725 *				
15	* 0.5545 *	* 0.5426 *	F-DEL-H					
	* 3.7885 *	* 4.1270 *	M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 251 of 306

TABLE A-4

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6686	* 0.6193	* 0.5837	* 0.6431	* 0.5936	* 0.5122	* 0.3962	* 0.2377
	* 2.8315	* 3.0420	* 3.1671	* 2.9089	* 3.1584	* 3.5951	* 3.8571	* 5.9812
9	* 0.6193	* 0.6009	* 0.6314	* 0.5898	* 0.6245	* 0.5407	* 0.4280	* 0.2400
	* 3.0420	* 3.0505	* 2.8662	* 3.1479	* 2.9972	* 3.4309	* 3.9604	* 6.3491
10	* 0.5837	* 0.6319	* 0.5359	* 0.6038	* 0.5700	* 0.5392	* 0.4095	
	* 3.1671	* 2.8650	* 3.1047	* 2.9794	* 3.2509	* 3.4815	* 4.4620	
11	* 0.6431	* 0.5868	* 0.6031	* 0.5294	* 0.5594	* 0.4894	* 0.3116	
	* 2.9089	* 3.1492	* 2.9800	* 3.3318	* 3.3619	* 3.8758	* 6.0611	
12	* 0.5936	* 0.6220	* 0.5688	* 0.5589	* 0.4934	* 0.3724		
	* 3.1584	* 3.0095	* 3.2573	* 3.3643	* 3.8432	* 5.1061		
13	* 0.5122	* 0.5383	* 0.5378	* 0.4884	* 0.3709			
	* 3.5951	* 3.4474	* 3.4906	* 3.8833	* 5.1272			
14	* 0.3962	* 0.4266	* 0.4080	* 0.3103				
	* 3.8571	* 3.9701	* 4.4782	* 6.0863				
15	* 0.2377	* 0.2386	* F-SUB-Q					
	* 5.9812	* 6.3825	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3704	* 1.2028	* 1.1030	* 1.2708	* 1.1728	* 0.9997	* 0.9359	* 0.5298
	* 1.3979	* 1.5887	* 1.7096	* 1.4957	* 1.6210	* 1.8632	* 1.7683	* 3.0249
9	* 1.2028	* 1.1888	* 1.2485	* 1.1437	* 1.2974	* 1.0686	* 0.9774	* 0.5129
	* 1.5887	* 1.5599	* 1.4934	* 1.6506	* 1.4641	* 1.7644	* 1.8077	* 3.2675
10	* 1.1030	* 1.2495	* 1.0620	* 1.2116	* 1.1133	* 1.1594	* 0.8110	
	* 1.7096	* 1.4927	* 1.6810	* 1.5297	* 1.7015	* 1.6407	* 2.2994	
11	* 1.2708	* 1.1411	* 1.2102	* 1.0181	* 1.1229	* 1.0629	* 0.6116	
	* 1.4957	* 1.6519	* 1.5300	* 1.7769	* 1.6993	* 1.8057	* 3.1266	
12	* 1.1728	* 1.2907	* 1.1113	* 1.1220	* 1.0642	* 0.6978		
	* 1.6210	* 1.4715	* 1.7045	* 1.7007	* 1.8045	* 2.7677		
13	* 0.9997	* 1.0642	* 1.1565	* 1.0610	* 0.6958			
	* 1.8632	* 1.7736	* 1.6449	* 1.8091	* 2.7760			
14	* 0.9359	* 0.9748	* 0.8079	* 0.6089				
	* 1.7683	* 1.8120	* 2.3081	* 3.1402				
15	* 0.5298	* 0.5058	* F-SUB-Q					
	* 3.0249	* 3.3122	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 252 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4371	* 1.3730	* 1.2665	* 1.3708	* 1.3375	* 1.1930	* 1.1793	* 0.6975 *
	* 1.3573	* 1.4182	* 1.5290	* 1.4140	* 1.4489	* 1.6036	* 1.5634	* 2.5798 *
9	* 1.3730	* 1.3675	* 1.3091	* 1.3012	* 1.3829	* 1.2394	* 1.1812	* 0.6536 *
	* 1.4182	* 1.4129	* 1.4710	* 1.4861	* 1.4017	* 1.5483	* 1.5777	* 2.7781 *
10	* 1.2665	* 1.3114	* 1.2505	* 1.3166	* 1.2818	* 1.2903	* 0.9822	*
	* 1.5290	* 1.4691	* 1.5153	* 1.4529	* 1.5076	* 1.5008	* 1.9466	*
11	* 1.3708	* 1.2984	* 1.3154	* 1.2040	* 1.2058	* 1.2362	* 0.7251	*
	* 1.4140	* 1.4871	* 1.4542	* 1.5783	* 1.6130	* 1.5780	* 2.6824	*
12	* 1.3375	* 1.3729	* 1.2787	* 1.2043	* 1.2121	* 0.8000	*	
	* 1.4489	* 1.4122	* 1.5113	* 1.6149	* 1.6119	* 2.4371	*	
13	* 1.1930	* 1.2321	* 1.2857	* 1.2336	* 0.7983	*		
	* 1.6036	* 1.5576	* 1.5062	* 1.5814	* 2.4426	*		
14	* 1.1793	* 1.1778	* 0.9781	* 0.7218	*			
	* 1.5634	* 1.5822	* 1.9548	* 2.6945	*			
15	* 0.6975	* 0.6463	* F-SUB-Q					
	* 2.5798	* 2.8088	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6024	* 1.5073	* 1.3902	* 1.5330	* 1.4820	* 1.3407	* 1.3931	* 0.8029 *
	* 1.2456	* 1.3200	* 1.4303	* 1.2956	* 1.3339	* 1.4682	* 1.3852	* 2.3711 *
9	* 1.5073	* 1.5107	* 1.4709	* 1.4285	* 1.5544	* 1.3890	* 1.3891	* 0.7355 *
	* 1.3200	* 1.3175	* 1.3511	* 1.3897	* 1.2779	* 1.4191	* 1.3967	* 2.5992 *
10	* 1.3902	* 1.4734	* 1.3548	* 1.4812	* 1.4156	* 1.4705	* 1.0923	*
	* 1.4303	* 1.3488	* 1.4544	* 1.3341	* 1.4023	* 1.3485	* 1.8002	*
11	* 1.5330	* 1.4239	* 1.4794	* 1.3172	* 1.3564	* 1.4005	* 0.7801	*
	* 1.2956	* 1.3943	* 1.3358	* 1.4975	* 1.4678	* 1.4234	* 2.5485	*
12	* 1.4820	* 1.5425	* 1.4116	* 1.3544	* 1.3588	* 0.8500	*	
	* 1.3339	* 1.2880	* 1.4064	* 1.4698	* 1.4698	* 2.3110	*	
13	* 1.3407	* 1.3790	* 1.4643	* 1.3970	* 0.8485	*		
	* 1.4682	* 1.4294	* 1.3542	* 1.4270	* 2.3151	*		
14	* 1.3931	* 1.3847	* 1.0868	* 0.7760	*			
	* 1.3852	* 1.4011	* 1.8092	* 2.5619	*			
15	* 0.8029	* 0.7249	* F-SUB-Q					
	* 2.3711	* 2.6370	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 253 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6592	* 1.5461	* 1.4272	* 1.5983	* 1.5439	* 1.3956	* 1.4827	* 0.8540 *
	* 1.2320	* 1.3197	* 1.4302	* 1.2734	* 1.3126	* 1.4493	* 1.3488	* 2.3240 *
9	* 1.5461	* 1.5490	* 1.5204	* 1.4733	* 1.6193	* 1.4465	* 1.4744	* 0.7818 *
	* 1.3197	* 1.3140	* 1.3425	* 1.3818	* 1.2569	* 1.3987	* 1.3606	* 2.5454 *
10	* 1.4272	* 1.5232	* 1.4091	* 1.5467	* 1.4676	* 1.5420	* 1.1525	*
	* 1.4302	* 1.3399	* 1.4428	* 1.3135	* 1.3843	* 1.3140	* 1.7515	*
11	* 1.5983	* 1.4678	* 1.5444	* 1.3760	* 1.4183	* 1.4695	* 0.8164	*
	* 1.2734	* 1.3870	* 1.3155	* 1.4762	* 1.4292	* 1.3695	* 2.4592	*
12	* 1.5439	* 1.6057	* 1.4626	* 1.4159	* 1.4201	* 0.8860	*	
	* 1.3126	* 1.2678	* 1.3892	* 1.4317	* 1.4186	* 2.2317	*	
13	* 1.3956	* 1.4356	* 1.5345	* 1.4653	* 0.8846	*		
	* 1.4493	* 1.4102	* 1.3206	* 1.3738	* 2.2356	*		
14	* 1.4827	* 1.4691	* 1.1463	* 0.8121	*			
	* 1.3488	* 1.3655	* 1.7611	* 2.4727	*			
15	* 0.8540	* 0.7720	* F-SUB-Q					
	* 2.3240	* 2.5775	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6900	* 1.5689	* 1.4494	* 1.6407	* 1.5862	* 1.4315	* 1.5386	* 0.8854 *
	* 1.2227	* 1.3186	* 1.4295	* 1.2543	* 1.2936	* 1.4356	* 1.3286	* 2.3018 *
9	* 1.5689	* 1.5781	* 1.5481	* 1.5029	* 1.6618	* 1.4862	* 1.5280	* 0.8115 *
	* 1.3186	* 1.3121	* 1.3398	* 1.3714	* 1.2384	* 1.3773	* 1.3392	* 2.5129 *
10	* 1.4494	* 1.5513	* 1.4417	* 1.5884	* 1.5039	* 1.5898	* 1.1926	*
	* 1.4295	* 1.3370	* 1.4381	* 1.2995	* 1.3644	* 1.2860	* 1.7165	*
11	* 1.6407	* 1.4968	* 1.5857	* 1.4150	* 1.4602	* 1.5164	* 0.8419	*
	* 1.2543	* 1.3773	* 1.3018	* 1.4601	* 1.3969	* 1.3326	* 2.3924	*
12	* 1.5862	* 1.6468	* 1.4979	* 1.4574	* 1.4625	* 0.9129	*	
	* 1.2936	* 1.2499	* 1.3699	* 1.4003	* 1.3821	* 2.1830	*	
13	* 1.4315	* 1.4752	* 1.5812	* 1.5115	* 0.9113	*		
	* 1.4356	* 1.3879	* 1.2921	* 1.3371	* 2.1869	*		
14	* 1.5386	* 1.5220	* 1.1855	* 0.8372	*			
	* 1.3286	* 1.3446	* 1.7270	* 2.4063	*			
15	* 0.8854	* 0.8018	* F-SUB-Q					
	* 2.3018	* 2.5429	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 254 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7358	* 1.6042	* 1.4820	* 1.6962	* 1.6389	* 1.4758	* 1.6046	* 0.9102 *
	* 1.2004	* 1.3023	* 1.4126	* 1.2238	* 1.2641	* 1.4055	* 1.2912	* 2.2732 *
9	* 1.6042	* 1.6185	* 1.5938	* 1.5428	* 1.7216	* 1.5369	* 1.5937	* 0.8306 *
	* 1.3023	* 1.2931	* 1.3141	* 1.3484	* 1.2057	* 1.3437	* 1.2995	* 2.4894 *
10	* 1.4820	* 1.5972	* 1.4646	* 1.6426	* 1.5493	* 1.6547	* 1.2230	*
	* 1.4126	* 1.3113	* 1.4329	* 1.2680	* 1.3343	* 1.2433	* 1.6871	*
11	* 1.6962	* 1.5359	* 1.6393	* 1.4449	* 1.5149	* 1.5769	* 0.8561	*
	* 1.2238	* 1.3547	* 1.2706	* 1.4440	* 1.3536	* 1.2918	* 2.3693	*
12	* 1.6389	* 1.7056	* 1.5426	* 1.5117	* 1.5184	* 0.9314	*	
	* 1.2641	* 1.2173	* 1.3404	* 1.3569	* 1.3412	* 2.1639	*	
13	* 1.4758	* 1.5243	* 1.6449	* 1.5713	* 0.9299	*		
	* 1.4055	* 1.3550	* 1.2498	* 1.2965	* 2.1673	*		
14	* 1.6046	* 1.5870	* 1.2152	* 0.8506	*			
	* 1.2912	* 1.3051	* 1.6980	* 2.3845	*			
15	* 0.9102	* 0.8190	* F-SUB-Q					
	* 2.2732	* 2.5244	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7517	* 1.6182	* 1.4949	* 1.7219	* 1.6675	* 1.4988	* 1.6389	* 0.9249 *
	* 1.2062	* 1.3064	* 1.4155	* 1.2200	* 1.2553	* 1.3985	* 1.2816	* 2.2632 *
9	* 1.6182	* 1.6362	* 1.6099	* 1.5611	* 1.7490	* 1.5645	* 1.6274	* 0.8442 *
	* 1.3064	* 1.2940	* 1.3148	* 1.3472	* 1.2007	* 1.3326	* 1.2888	* 2.4795 *
10	* 1.4949	* 1.6135	* 1.4785	* 1.6675	* 1.5730	* 1.6870	* 1.2442	*
	* 1.4155	* 1.3119	* 1.4373	* 1.2615	* 1.3288	* 1.2327	* 1.6727	*
11	* 1.7219	* 1.5535	* 1.6638	* 1.4651	* 1.5417	* 1.6077	* 0.8683	*
	* 1.2200	* 1.3539	* 1.2644	* 1.4392	* 1.3474	* 1.2857	* 2.3677	*
12	* 1.6675	* 1.7320	* 1.5655	* 1.5381	* 1.5459	* 0.9458	*	
	* 1.2553	* 1.2127	* 1.3353	* 1.3505	* 1.3366	* 2.1669	*	
13	* 1.4988	* 1.5507	* 1.6762	* 1.6015	* 0.9443	*		
	* 1.3985	* 1.3444	* 1.2396	* 1.2906	* 2.1702	*		
14	* 1.6389	* 1.6199	* 1.2357	* 0.8623	*			
	* 1.2816	* 1.2948	* 1.6841	* 2.3838	*			
15	* 0.9249	* 0.8325	* F-SUB-Q					
	* 2.2632	* 2.5139	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 255 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7938	* 1.6504	* 1.5233	* 1.7720	* 1.7136	* 1.5360	* 1.6954	* 0.9407 *
	* 1.2041	* 1.3085	* 1.4183	* 1.2106	* 1.2461	* 1.3896	* 1.2535	* 2.2474 *
9	* 1.6504	* 1.6723	* 1.6524	* 1.5945	* 1.8032	* 1.6078	* 1.6839	* 0.8547 *
	* 1.3085	* 1.2906	* 1.3073	* 1.3464	* 1.1888	* 1.3216	* 1.2622	* 2.4725 *
10	* 1.5233	* 1.6561	* 1.4902	* 1.7159	* 1.6122	* 1.7451	* 1.2635	*
	* 1.4183	* 1.3044	* 1.4427	* 1.2491	* 1.3235	* 1.2172	* 1.6762	*
11	* 1.7720	* 1.5863	* 1.7118	* 1.4847	* 1.5898	* 1.6604	* 0.8736	*
	* 1.2106	* 1.3535	* 1.2521	* 1.4461	* 1.3340	* 1.2722	* 2.4027	*
12	* 1.7136	* 1.7851	* 1.6037	* 1.5859	* 1.5949	* 0.9568	*	
	* 1.2461	* 1.2010	* 1.3305	* 1.3379	* 1.3244	* 2.1916	*	
13	* 1.5360	* 1.5929	* 1.7331	* 1.6536	* 0.9554	*		
	* 1.3896	* 1.3340	* 1.2244	* 1.2773	* 2.1946	*		
14	* 1.6954	* 1.6759	* 1.2540	* 0.8681	*			
	* 1.2535	* 1.2682	* 1.6886	* 2.4174	*			
15	* 0.9407	* 0.8395	* F-SUB-Q					
	* 2.2474	* 2.5166	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7497	* 1.6198	* 1.5001	* 1.7352	* 1.6918	* 1.5155	* 1.6635	* 0.9394 *
	* 1.2712	* 1.3727	* 1.4807	* 1.2721	* 1.2980	* 1.4472	* 1.3087	* 2.2995 *
9	* 1.6198	* 1.6427	* 1.6070	* 1.5799	* 1.7620	* 1.5866	* 1.6503	* 0.8650 *
	* 1.3727	* 1.3517	* 1.3833	* 1.3988	* 1.2515	* 1.3767	* 1.3199	* 2.4969 *
10	* 1.5001	* 1.6110	* 1.4941	* 1.6800	* 1.5953	* 1.7097	* 1.2715	*
	* 1.4807	* 1.3798	* 1.4885	* 1.3116	* 1.3805	* 1.2730	* 1.7097	*
11	* 1.7352	* 1.5649	* 1.6757	* 1.4899	* 1.5586	* 1.6275	* 0.8884	*
	* 1.2721	* 1.4122	* 1.3150	* 1.4818	* 1.4006	* 1.3351	* 2.4287	*
12	* 1.6918	* 1.7431	* 1.5865	* 1.5545	* 1.5618	* 0.9705	*	
	* 1.2980	* 1.2652	* 1.3881	* 1.4041	* 1.3915	* 2.2235	*	
13	* 1.5155	* 1.5710	* 1.6987	* 1.6203	* 0.9686	*		
	* 1.4472	* 1.3901	* 1.2809	* 1.3408	* 2.2274	*		
14	* 1.6635	* 1.6417	* 1.2617	* 0.8818	*			
	* 1.3087	* 1.3267	* 1.7225	* 2.4459	*			
15	* 0.9394	* 0.8523	* F-SUB-Q					
	* 2.2995	* 2.5335	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 256 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8067	* 1.6615	* 1.5317	* 1.7990	* 1.7473	* 1.5602	* 1.7350	* 0.9529 *
	* 1.2755	* 1.3869	* 1.5044	* 1.2705	* 1.3011	* 1.4545	* 1.2958	* 2.3367 *
9	* 1.6615	* 1.6884	* 1.6662	* 1.6107	* 1.8336	* 1.6400	* 1.7229	* 0.8672 *
	* 1.3869	* 1.3624	* 1.3818	* 1.4203	* 1.2450	* 1.3778	* 1.3060	* 2.5676 *
10	* 1.5317	* 1.6701	* 1.5027	* 1.7417	* 1.6375	* 1.7836	* 1.2844	*
	* 1.5044	* 1.3785	* 1.5226	* 1.3083	* 1.3879	* 1.2644	* 1.7495	*
11	* 1.7990	* 1.6013	* 1.7368	* 1.5035	* 1.6199	* 1.6952	* 0.8843	*
	* 1.2705	* 1.4285	* 1.3124	* 1.5203	* 1.3931	* 1.3260	* 2.5218	*
12	* 1.7473	* 1.8138	* 1.6276	* 1.6153	* 1.6247	* 0.9713	*	
	* 1.3011	* 1.2586	* 1.3961	* 1.3979	* 1.3840	* 2.2978	*	
13	* 1.5602	* 1.6228	* 1.7696	* 1.6872	* 0.9698	*		
	* 1.4545	* 1.3920	* 1.2727	* 1.3319	* 2.3008	*		
14	* 1.7350	* 1.7137	* 1.2737	* 0.8781	*			
	* 1.2958	* 1.3129	* 1.7634	* 2.5383	*			
15	* 0.9529	* 0.8516	* F-SUB-Q					
	* 2.3367	* 2.6139	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8077	* 1.6620	* 1.5318	* 1.8085	* 1.7592	* 1.5676	* 1.7502	* 0.9572 *
	* 1.2702	* 1.3814	* 1.4975	* 1.2692	* 1.3066	* 1.4657	* 1.3163	* 2.3957 *
9	* 1.6620	* 1.6922	* 1.6678	* 1.6146	* 1.8430	* 1.6514	* 1.7371	* 0.8723 *
	* 1.3814	* 1.3576	* 1.3761	* 1.4211	* 1.2455	* 1.3907	* 1.3247	* 2.6269 *
10	* 1.5318	* 1.6718	* 1.5054	* 1.7508	* 1.6459	* 1.7970	* 1.2929	*
	* 1.4975	* 1.3727	* 1.5259	* 1.3107	* 1.3936	* 1.2772	* 1.7723	*
11	* 1.8085	* 1.6048	* 1.7455	* 1.5116	* 1.6311	* 1.7081	* 0.8896	*
	* 1.2692	* 1.4296	* 1.3146	* 1.5169	* 1.4036	* 1.3401	* 2.5634	*
12	* 1.7592	* 1.8224	* 1.6354	* 1.6256	* 1.6356	* 0.9777	*	
	* 1.3066	* 1.2594	* 1.4025	* 1.4082	* 1.3973	* 2.3298	*	
13	* 1.5676	* 1.6331	* 1.7829	* 1.6995	* 0.9761	*		
	* 1.4657	* 1.4060	* 1.2870	* 1.3467	* 2.3334	*		
14	* 1.7502	* 1.7272	* 1.2819	* 0.8828	*			
	* 1.3163	* 1.3321	* 1.7873	* 2.5828	*			
15	* 0.9572	* 0.8584	* F-SUB-Q					
	* 2.3957	* 2.6687	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 257 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7667	* 1.6311	* 1.5053	* 1.7737	* 1.7366	* 1.5464	* 1.7217	* 0.9515 *
	* 1.2856	* 1.3922	* 1.5065	* 1.2797	* 1.3084	* 1.4685	* 1.3216	* 2.3803 *
9	* 1.6311	* 1.6622	* 1.6269	* 1.5957	* 1.8057	* 1.6299	* 1.7076	* 0.8761 *
	* 1.3922	* 1.3667	* 1.3952	* 1.4218	* 1.2572	* 1.3929	* 1.3313	* 2.5834 *
10	* 1.5053	* 1.6313	* 1.4955	* 1.7171	* 1.6228	* 1.7689	* 1.2924	*
	* 1.5065	* 1.3915	* 1.5182	* 1.3210	* 1.3978	* 1.2828	* 1.7528	*
11	* 1.7737	* 1.5788	* 1.7118	* 1.5061	* 1.6020	* 1.6785	* 0.8947	*
	* 1.2797	* 1.4369	* 1.3256	* 1.5057	* 1.4136	* 1.3488	* 2.5212	*
12	* 1.7366	* 1.7843	* 1.6118	* 1.5969	* 1.6058	* 0.9825	*	
	* 1.3084	* 1.2721	* 1.4073	* 1.4181	* 1.4081	* 2.2942	*	
13	* 1.5464	* 1.6109	* 1.7552	* 1.6695	* 0.9807	*		
	* 1.4685	* 1.4091	* 1.2926	* 1.3560	* 2.2984	*		
14	* 1.7217	* 1.6972	* 1.2807	* 0.8869	*			
	* 1.3216	* 1.3393	* 1.7685	* 2.5432	*			
15	* 0.9515	* 0.8625	* F-SUB-Q					
	* 2.3803	* 2.6233	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8037	* 1.6524	* 1.5217	* 1.8145	* 1.7722	* 1.5738	* 1.7744	* 0.9547 *
	* 1.2514	* 1.3657	* 1.4807	* 1.2428	* 1.2734	* 1.4328	* 1.2717	* 2.3472 *
9	* 1.6524	* 1.6872	* 1.6654	* 1.6104	* 1.8552	* 1.6656	* 1.7619	* 0.8692 *
	* 1.3657	* 1.3377	* 1.3537	* 1.3995	* 1.2156	* 1.3537	* 1.2803	* 2.5764 *
10	* 1.5217	* 1.6696	* 1.4992	* 1.7584	* 1.6509	* 1.8202	* 1.2908	*
	* 1.4807	* 1.3503	* 1.5018	* 1.2807	* 1.3648	* 1.2383	* 1.7402	*
11	* 1.8145	* 1.5994	* 1.7515	* 1.5011	* 1.6459	* 1.7273	* 0.8801	*
	* 1.2428	* 1.4089	* 1.2856	* 1.4984	* 1.3653	* 1.3004	* 2.5362	*
12	* 1.7722	* 1.8329	* 1.6388	* 1.6388	* 1.6499	* 0.9738	*	
	* 1.2734	* 1.2301	* 1.3745	* 1.3710	* 1.3587	* 2.2904	*	
13	* 1.5738	* 1.6449	* 1.8051	* 1.7176	* 0.9722	*		
	* 1.4328	* 1.3705	* 1.2483	* 1.3075	* 2.2938	*		
14	* 1.7744	* 1.7508	* 1.2783	* 0.8731	*			
	* 1.2717	* 1.2882	* 1.7567	* 2.5559	*			
15	* 0.9547	* 0.8524	* F-SUB-Q					
	* 2.3472	* 2.6259	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 258 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8029	* 1.6461	* 1.5155	* 1.8180	* 1.7770	* 1.5749	* 1.7873	* 0.9512 *
	* 1.2314	* 1.3484	* 1.4623	* 1.2199	* 1.2495	* 1.4075	* 1.2404	* 2.3133 *
9	* 1.6461	* 1.6838	* 1.6647	* 1.6070	* 1.8617	* 1.6716	* 1.7750	* 0.8644 *
	* 1.3484	* 1.3180	* 1.3319	* 1.3792	* 1.1912	* 1.3263	* 1.2487	* 2.5445 *
10	* 1.5155	* 1.6690	* 1.4951	* 1.7634	* 1.6517	* 1.8326	* 1.2859	*
	* 1.4623	* 1.3285	* 1.4799	* 1.2558	* 1.3413	* 1.2093	* 1.7171	*
11	* 1.8180	* 1.5954	* 1.7561	* 1.4983	* 1.6541	* 1.7378	* 0.8719	*
	* 1.2199	* 1.3889	* 1.2609	* 1.4755	* 1.3362	* 1.2712	* 2.5181	*
12	* 1.7770	* 1.8387	* 1.6390	* 1.6466	* 1.6578	* 0.9679	*	
	* 1.2495	* 1.2058	* 1.3514	* 1.3421	* 1.3303	* 2.2674	*	
13	* 1.5749	* 1.6497	* 1.8162	* 1.7275	* 0.9660	*		
	* 1.4075	* 1.3434	* 1.2197	* 1.2786	* 2.2717	*		
14	* 1.7873	* 1.7632	* 1.2729	* 0.8648	*			
	* 1.2404	* 1.2567	* 1.7342	* 2.5382	*			
15	* 0.9512	* 0.8467	* F-SUB-Q					
	* 2.3133	* 2.5968	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7808	* 1.6272	* 1.4970	* 1.8018	* 1.7650	* 1.5612	* 1.7754	* 0.9435 *
	* 1.2312	* 1.3469	* 1.4618	* 1.2151	* 1.2414	* 1.4010	* 1.2313	* 2.2997 *
9	* 1.6272	* 1.6663	* 1.6450	* 1.5897	* 1.8451	* 1.6595	* 1.7627	* 0.8599 *
	* 1.3469	* 1.3148	* 1.3304	* 1.3764	* 1.1865	* 1.3182	* 1.2400	* 2.5224 *
10	* 1.4970	* 1.6494	* 1.4778	* 1.7488	* 1.6381	* 1.8214	* 1.2789	*
	* 1.4618	* 1.3276	* 1.4780	* 1.2500	* 1.3350	* 1.2005	* 1.7036	*
11	* 1.8018	* 1.5778	* 1.7412	* 1.4837	* 1.6414	* 1.7251	* 0.8680	*
	* 1.2151	* 1.3866	* 1.2553	* 1.4710	* 1.3294	* 1.2642	* 2.4971	*
12	* 1.7650	* 1.8216	* 1.6249	* 1.6336	* 1.6445	* 0.9641	*	
	* 1.2414	* 1.2016	* 1.3456	* 1.3356	* 1.3241	* 2.2479	*	
13	* 1.5612	* 1.6369	* 1.8049	* 1.7144	* 0.9625	*		
	* 1.4010	* 1.3359	* 1.2111	* 1.2718	* 2.2514	*		
14	* 1.7754	* 1.7506	* 1.2654	* 0.8605	*			
	* 1.2313	* 1.2484	* 1.7212	* 2.5182	*			
15	* 0.9435	* 0.8429	* F-SUB-Q					
	* 2.2997	* 2.5725	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 259 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7219	* 1.5849	* 1.4586	* 1.7516	* 1.7251	* 1.5248	* 1.7263	* 0.9302
	* 1.2618	* 1.3701	* 1.4867	* 1.2380	* 1.2575	* 1.4201	* 1.2529	* 2.3077
9	* 1.5849	* 1.6245	* 1.5912	* 1.5555	* 1.7892	* 1.6205	* 1.7118	* 0.8573
	* 1.3701	* 1.3361	* 1.3619	* 1.3929	* 1.2119	* 1.3362	* 1.2634	* 2.5032
10	* 1.4586	* 1.5952	* 1.4528	* 1.7008	* 1.6004	* 1.7739	* 1.2696	*
	* 1.4867	* 1.3601	* 1.4886	* 1.2729	* 1.3532	* 1.2201	* 1.6985	*
11	* 1.7516	* 1.5389	* 1.6930	* 1.4697	* 1.5954	* 1.6766	* 0.8702	*
	* 1.2380	* 1.4082	* 1.2786	* 1.4714	* 1.3543	* 1.2878	* 2.4660	*
12	* 1.7251	* 1.7653	* 1.5871	* 1.5875	* 1.5977	* 0.9623	*	
	* 1.2575	* 1.2281	* 1.3643	* 1.3609	* 1.3496	* 2.2301	*	
13	* 1.5248	* 1.5978	* 1.7571	* 1.6658	* 0.9604	*		
	* 1.4201	* 1.3547	* 1.2314	* 1.2959	* 2.2343	*		
14	* 1.7263	* 1.6995	* 1.2560	* 0.8614	*			
	* 1.2529	* 1.2724	* 1.7163	* 2.4906	*			
15	* 0.9302	* 0.8434	* F-SUB-Q					
	* 2.3077	* 2.5436	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7647	* 1.6031	* 1.4731	* 1.7894	* 1.7523	* 1.5424	* 1.7709	* 0.9243
	* 1.2107	* 1.3320	* 1.4479	* 1.1930	* 1.2191	* 1.3831	* 1.2043	* 2.2948
9	* 1.6031	* 1.6470	* 1.6298	* 1.5672	* 1.8357	* 1.6469	* 1.7584	* 0.8409
	* 1.3320	* 1.2963	* 1.3088	* 1.3614	* 1.1632	* 1.2958	* 1.2127	* 2.5218
10	* 1.4731	* 1.6341	* 1.4549	* 1.7379	* 1.6206	* 1.8175	* 1.2549	*
	* 1.4479	* 1.3063	* 1.4642	* 1.2271	* 1.3163	* 1.1740	* 1.6949	*
11	* 1.7894	* 1.5546	* 1.7297	* 1.4649	* 1.6342	* 1.7191	* 0.8454	*
	* 1.1930	* 1.3723	* 1.2329	* 1.4539	* 1.3038	* 1.2388	* 2.5077	*
12	* 1.7523	* 1.8111	* 1.6065	* 1.6258	* 1.6363	* 0.9437	*	
	* 1.2191	* 1.1788	* 1.3278	* 1.3104	* 1.3002	* 2.2464	*	
13	* 1.5424	* 1.6228	* 1.7997	* 1.7076	* 0.9416	*		
	* 1.3831	* 1.3148	* 1.1854	* 1.2470	* 2.2512	*		
14	* 1.7709	* 1.7454	* 1.2407	* 0.8377	*			
	* 1.2043	* 1.2216	* 1.7140	* 2.5303	*			
15	* 0.9243	* 0.8228	* F-SUB-Q					
	* 2.2948	* 2.5765	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 260 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7417	* 1.5814	* 1.4514	* 1.7630	* 1.7295	* 1.5190	* 1.7444	* 0.9054 *
	* 1.2005	* 1.3212	* 1.4381	* 1.1849	* 1.2083	* 1.3741	* 1.1961	* 2.2932 *
9	* 1.5814	* 1.6253	* 1.6069	* 1.5437	* 1.8102	* 1.6240	* 1.7327	* 0.8245 *
	* 1.3212	* 1.2854	* 1.3000	* 1.3526	* 1.1544	* 1.2857	* 1.2040	* 2.5176 *
10	* 1.4514	* 1.6113	* 1.4314	* 1.7115	* 1.5972	* 1.7923	* 1.2324	*
	* 1.4381	* 1.2965	* 1.4567	* 1.2195	* 1.3071	* 1.1648	* 1.6890	*
11	* 1.7630	* 1.5309	* 1.7032	* 1.4418	* 1.6094	* 1.6936	* 0.8284	*
	* 1.1849	* 1.3638	* 1.2254	* 1.4458	* 1.2958	* 1.2307	* 2.5059	*
12	* 1.7295	* 1.7854	* 1.5828	* 1.6009	* 1.6107	* 0.9269	*	
	* 1.2083	* 1.1702	* 1.3188	* 1.3025	* 1.2930	* 2.2397	*	
13	* 1.5190	* 1.5995	* 1.7742	* 1.6819	* 0.9248	*		
	* 1.3741	* 1.3051	* 1.1765	* 1.2391	* 2.2445	*		
14	* 1.7444	* 1.7194	* 1.2180	* 0.8207	*			
	* 1.1960	* 1.2132	* 1.7088	* 2.5291	*			
15	* 0.9054	* 0.8061	* F-SUB-Q					
	* 2.2932	* 2.5744	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7159	* 1.5538	* 1.4236	* 1.7200	* 1.6913	* 1.4833	* 1.6925	* 0.8775 *
	* 1.1972	* 1.3211	* 1.4408	* 1.1932	* 1.2135	* 1.3824	* 1.2110	* 2.3250 *
9	* 1.5538	* 1.5940	* 1.5816	* 1.5120	* 1.7766	* 1.5844	* 1.6903	* 0.8188 *
	* 1.3211	* 1.2875	* 1.2978	* 1.3569	* 1.1556	* 1.2944	* 1.2122	* 2.4913 *
10	* 1.4236	* 1.5860	* 1.3999	* 1.6673	* 1.5623	* 1.7530	* 1.2016	*
	* 1.4408	* 1.2942	* 1.4637	* 1.2299	* 1.3128	* 1.1702	* 1.7020	*
11	* 1.7200	* 1.4993	* 1.6592	* 1.4078	* 1.5663	* 1.6539	* 0.8072	*
	* 1.1932	* 1.3682	* 1.2358	* 1.4550	* 1.3081	* 1.2381	* 2.5276	*
12	* 1.6913	* 1.7519	* 1.5482	* 1.5596	* 1.5725	* 0.9231	*	
	* 1.2135	* 1.1718	* 1.3246	* 1.3140	* 1.3014	* 2.2104	*	
13	* 1.4833	* 1.5603	* 1.7329	* 1.6424	* 0.9209	*		
	* 1.3824	* 1.3142	* 1.1836	* 1.2467	* 2.2155	*		
14	* 1.6925	* 1.6775	* 1.1875	* 0.7995	*			
	* 1.2110	* 1.2214	* 1.7220	* 2.5516	*			
15	* 0.8775	* 0.7838	* F-SUB-Q					
	* 2.3250	* 2.6018	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 261 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6713	* 1.5089	* 1.3811	* 1.6478	* 1.6265	* 1.4253	* 1.6162	* 0.8335 *
	* 1.2122	* 1.3415	* 1.4648	* 1.2282	* 1.2440	* 1.4184	* 1.2500	* 2.4143 *
9	* 1.5089	* 1.5436	* 1.5400	* 1.4654	* 1.7215	* 1.5183	* 1.6156	* 0.7767 *
	* 1.3415	* 1.3110	* 1.3145	* 1.3805	* 1.1759	* 1.3315	* 1.2504	* 2.5904 *
10	* 1.3811	* 1.5443	* 1.3545	* 1.5912	* 1.5082	* 1.6879	* 1.1534	*
	* 1.4648	* 1.3109	* 1.4921	* 1.2708	* 1.3407	* 1.1981	* 1.7485	*
11	* 1.6478	* 1.4534	* 1.5835	* 1.3617	* 1.5123	* 1.5878	* 0.7772	*
	* 1.2282	* 1.3918	* 1.2769	* 1.4833	* 1.3363	* 1.2715	* 2.5891	*
12	* 1.6265	* 1.6980	* 1.4949	* 1.5067	* 1.5112	* 0.8880	*	
	* 1.2440	* 1.1921	* 1.3525	* 1.3413	* 1.3353	* 2.2662	*	
13	* 1.4253	* 1.4955	* 1.6687	* 1.5768	* 0.8858	*		
	* 1.4184	* 1.3516	* 1.2117	* 1.2803	* 2.2716	*		
14	* 1.6162	* 1.6030	* 1.1398	* 0.7697	*			
	* 1.2500	* 1.2601	* 1.7692	* 2.6143	*			
15	* 0.8335	* 0.7493	* F-SUB-Q					
	* 2.4143	* 2.6845	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5708	* 1.4339	* 1.3152	* 1.5575	* 1.5340	* 1.3324	* 1.4737	* 0.7645 *
	* 1.2761	* 1.3967	* 1.5221	* 1.2851	* 1.3044	* 1.5010	* 1.3558	* 2.6044 *
9	* 1.4339	* 1.4784	* 1.4518	* 1.4036	* 1.6238	* 1.4244	* 1.4731	* 0.7164 *
	* 1.3967	* 1.3541	* 1.3790	* 1.4258	* 1.2331	* 1.4038	* 1.3562	* 2.7793 *
10	* 1.3152	* 1.4558	* 1.2945	* 1.5044	* 1.4357	* 1.5697	* 1.0692	*
	* 1.5221	* 1.3759	* 1.5446	* 1.3298	* 1.3929	* 1.2742	* 1.8660	*
11	* 1.5575	* 1.3926	* 1.4982	* 1.2964	* 1.4167	* 1.4757	* 0.7309	*
	* 1.2851	* 1.4370	* 1.3353	* 1.5416	* 1.4111	* 1.3531	* 2.7247	*
12	* 1.5340	* 1.6022	* 1.4236	* 1.4116	* 1.4164	* 0.8427	*	
	* 1.3044	* 1.2497	* 1.4047	* 1.4161	* 1.4093	* 2.3627	*	
13	* 1.3324	* 1.4037	* 1.5523	* 1.4656	* 0.8406	*		
	* 1.5010	* 1.4243	* 1.2882	* 1.3623	* 2.3686	*		
14	* 1.4737	* 1.4620	* 1.0570	* 0.7236	*			
	* 1.3558	* 1.3664	* 1.8874	* 2.7518	*			
15	* 0.7645	* 0.6935	* F-SUB-Q					
	* 2.6044	* 2.8701	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 262 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 100% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4157	* 1.2092	* 1.1268	* 1.3928	* 1.2906	* 1.0906	* 1.2050	* 0.6219 *
	* 1.4041	* 1.6434	* 1.7617	* 1.4254	* 1.5379	* 1.8195	* 1.6439	* 3.1784 *
9	* 1.2092	* 1.2766	* 1.3176	* 1.2081	* 1.4466	* 1.1982	* 1.1848	* 0.5858 *
	* 1.6434	* 1.5557	* 1.5071	* 1.6430	* 1.3723	* 1.6552	* 1.6716	* 3.3743 *
10	* 1.1268	* 1.3184	* 1.1280	* 1.3543	* 1.2264	* 1.3355	* 0.8733	*
	* 1.7617	* 1.5062	* 1.7598	* 1.4651	* 1.6176	* 1.4844	* 2.2669	*
11	* 1.3928	* 1.1980	* 1.3474	* 1.1112	* 1.2437	* 1.2108	* 0.6177	*
	* 1.4254	* 1.6572	* 1.4725	* 1.7846	* 1.5934	* 1.6357	* 3.2006	*
12	* 1.2906	* 1.4263	* 1.2168	* 1.2392	* 1.1879	* 0.7197	*	
	* 1.5379	* 1.3919	* 1.6303	* 1.5991	* 1.6667	* 2.7460	*	
13	* 1.0906	* 1.1819	* 1.3225	* 1.2028	* 0.7176	*		
	* 1.8195	* 1.6779	* 1.4988	* 1.6464	* 2.7538	*		
14	* 1.2050	* 1.1755	* 0.8638	* 0.6115	*			
	* 1.6439	* 1.6848	* 2.2914	* 3.2326	*			
15	* 0.6219	* 0.5743	* F-SUB-Q					
	* 3.1784	* 3.4407	* M-SUB-Q					

AT 100% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.6097	* 0.5455	* 0.5347	* 0.6201	* 0.5767	* 0.5021	* 0.4780	* 0.2827 *
	* 3.2441	* 3.6251	* 3.6956	* 3.1861	* 3.4251	* 3.9316	* 4.1248	* 6.9649 *
9	* 0.5455	* 0.5670	* 0.6002	* 0.5557	* 0.6134	* 0.5307	* 0.4677	* 0.2634 *
	* 3.6251	* 3.4855	* 3.2924	* 3.5548	* 3.2197	* 3.7183	* 4.2157	* 7.4737 *
10	* 0.5347	* 0.6003	* 0.5342	* 0.6004	* 0.5486	* 0.5437	* 0.3962	*
	* 3.6956	* 3.2916	* 3.6976	* 3.2886	* 3.5983	* 3.6288	* 4.9734	*
11	* 0.6201	* 0.5519	* 0.5985	* 0.5163	* 0.5451	* 0.4742	* 0.2816	*
	* 3.1861	* 3.5792	* 3.2990	* 3.8220	* 3.6181	* 4.1553	* 6.9915	*
12	* 0.5767	* 0.6066	* 0.5444	* 0.5432	* 0.4740	* 0.3401	*	
	* 3.4251	* 3.2551	* 3.6258	* 3.6309	* 4.1566	* 5.7874	*	
13	* 0.5021	* 0.5244	* 0.5386	* 0.4714	* 0.3389	*		
	* 3.9316	* 3.7628	* 3.6627	* 4.1796	* 5.8067	*		
14	* 0.4780	* 0.4642	* 0.3923	* 0.2790	*			
	* 4.1248	* 4.2472	* 5.0231	* 7.0580	*			
15	* 0.2827	* 0.2623	* F-SUB-Q					
	* 6.9649	* 7.5026	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 263 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.7554	* 0.6970	* 0.6506	* 0.7236	* 0.6698	* 0.5752	* 0.4447	* 0.2586
	* 3.0654	* 3.3393	* 3.6210	* 3.2226	* 3.4762	* 4.0984	* 4.3855	* 7.0092
9	* 0.6970	* 0.6761	* 0.7067	* 0.6617	* 0.7060	* 0.6075	* 0.4798	* 0.2608
	* 3.3393	* 3.4749	* 3.2824	* 3.5264	* 3.2990	* 3.8520	* 4.5072	* 7.4561
10	* 0.6506	* 0.7073	* 0.5954	* 0.6784	* 0.6382	* 0.6085	* 0.4532	*
	* 3.6210	* 3.2808	* 3.5746	* 3.4002	* 3.6754	* 3.7774	* 5.1589	*
11	* 0.7236	* 0.6578	* 0.6771	* 0.5872	* 0.6236	* 0.5454	* 0.3387	*
	* 3.2226	* 3.5482	* 3.4021	* 3.8419	* 3.6441	* 4.1200	* 6.6212	*
12	* 0.6698	* 0.7019	* 0.6363	* 0.6228	* 0.5455	* 0.4043	*	*
	* 3.4762	* 3.3202	* 3.6873	* 3.6491	* 4.0632	* 5.3995	*	*
13	* 0.5752	* 0.6040	* 0.6061	* 0.5439	* 0.4025	*	*	*
	* 4.0984	* 3.8736	* 3.7930	* 4.1323	* 5.4239	*	*	*
14	* 0.4447	* 0.4776	* 0.4510	* 0.3369	*	*	*	*
	* 4.3855	* 4.5220	* 5.1830	* 6.6560	*	*	*	*
15	* 0.2586	* 0.2591	* F-SUB-Q					
	* 7.0092	* 7.4994	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5886	* 1.3915	* 1.2620	* 1.4666	* 1.3609	* 1.1519	* 1.0751	* 0.5883
	* 1.5084	* 1.7306	* 1.9239	* 1.6428	* 1.7682	* 2.0771	* 1.9712	* 3.4862
9	* 1.3915	* 1.3731	* 1.4295	* 1.3177	* 1.5023	* 1.2349	* 1.1228	* 0.5689
	* 1.7306	* 1.7365	* 1.6776	* 1.8420	* 1.6035	* 1.9617	* 2.0183	* 3.7742
10	* 1.2620	* 1.4308	* 1.2094	* 1.3934	* 1.2823	* 1.3403	* 0.9189	*
	* 1.9239	* 1.6766	* 1.8950	* 1.7122	* 1.8756	* 1.7727	* 2.6060	*
11	* 1.4666	* 1.3135	* 1.3908	* 1.1572	* 1.2798	* 1.2115	* 0.6783	*
	* 1.6428	* 1.8484	* 1.7131	* 2.0063	* 1.8368	* 1.9160	* 3.4172	*
12	* 1.3609	* 1.4916	* 1.2787	* 1.2781	* 1.2019	* 0.7732	*	*
	* 1.7682	* 1.6155	* 1.8820	* 1.8396	* 1.9221	* 2.9156	*	*
13	* 1.1519	* 1.2279	* 1.3352	* 1.2081	* 0.7707	*	*	*
	* 2.0771	* 1.9742	* 1.7801	* 1.9216	* 2.9254	*	*	*
14	* 1.0751	* 1.1188	* 0.9143	* 0.6747	*	*	*	*
	* 1.9712	* 2.0249	* 2.6188	* 3.4361	*	*	*	*
15	* 0.5883	* 0.5607	* F-SUB-Q					
	* 3.4862	* 3.8282	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 264 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6605	* 1.5874	* 1.4511	* 1.5798	* 1.5474	* 1.3747	* 1.3555	* 0.7758 *
	* 1.4877	* 1.5621	* 1.7187	* 1.5717	* 1.6036	* 1.7912	* 1.7483	* 2.9785 *
9	* 1.5874	* 1.5804	* 1.4995	* 1.4970	* 1.5933	* 1.4308	* 1.3565	* 0.7258 *
	* 1.5621	* 1.5783	* 1.6574	* 1.6647	* 1.5619	* 1.7265	* 1.7666	* 3.2139 *
10	* 1.4511	* 1.5024	* 1.4229	* 1.5077	* 1.4704	* 1.4868	* 1.1134	*
	* 1.7187	* 1.6551	* 1.7139	* 1.6327	* 1.6905	* 1.6475	* 2.2097	*
11	* 1.5798	* 1.4917	* 1.5054	* 1.3673	* 1.3721	* 1.4070	* 0.8044	*
	* 1.5717	* 1.6706	* 1.6350	* 1.7879	* 1.7661	* 1.6957	* 2.9654	*
12	* 1.5474	* 1.5795	* 1.4655	* 1.3697	* 1.3668	* 0.8859	*	
	* 1.6036	* 1.5761	* 1.6971	* 1.7704	* 1.7397	* 2.6135	*	
13	* 1.3747	* 1.4202	* 1.4796	* 1.4028	* 0.8837	*		
	* 1.7912	* 1.7393	* 1.6543	* 1.7013	* 2.6204	*		
14	* 1.3555	* 1.3516	* 1.1074	* 0.8000	*			
	* 1.7483	* 1.7728	* 2.2215	* 2.9823	*			
15	* 0.7758	* 0.7170	* F-SUB-Q					
	* 2.9785	* 3.2521	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8363	* 1.7288	* 1.5802	* 1.7521	* 1.7090	* 1.5335	* 1.5914	* 0.8886 *
	* 1.3893	* 1.4815	* 1.6241	* 1.4632	* 1.4934	* 1.6560	* 1.5633	* 2.7599 *
9	* 1.7288	* 1.7319	* 1.6720	* 1.6299	* 1.7764	* 1.5919	* 1.5853	* 0.8126 *
	* 1.4815	* 1.4843	* 1.5340	* 1.5722	* 1.4434	* 1.5978	* 1.5781	* 3.0313 *
10	* 1.5802	* 1.6752	* 1.5291	* 1.6827	* 1.6154	* 1.6819	* 1.2300	*
	* 1.6241	* 1.5310	* 1.6627	* 1.5152	* 1.5861	* 1.5053	* 2.0620	*
11	* 1.7521	* 1.6233	* 1.6798	* 1.4843	* 1.5322	* 1.5829	* 0.8604	*
	* 1.4632	* 1.5786	* 1.5177	* 1.7143	* 1.6307	* 1.5548	* 2.8618	*
12	* 1.7090	* 1.7604	* 1.6092	* 1.5291	* 1.5214	* 0.9354	*	
	* 1.4934	* 1.4567	* 1.5922	* 1.6352	* 1.6134	* 2.5513	*	
13	* 1.5335	* 1.5782	* 1.6726	* 1.5776	* 0.9335	*		
	* 1.6560	* 1.6117	* 1.5123	* 1.5604	* 2.5568	*		
14	* 1.5914	* 1.5791	* 1.2225	* 0.8552	*			
	* 1.5633	* 1.5842	* 2.0746	* 2.8802	*			
15	* 0.8886	* 0.8002	* F-SUB-Q					
	* 2.7599	* 3.0776	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 265 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8791	* 1.7514	* 1.6036	* 1.8057	* 1.7597	* 1.5786	* 1.6765	* 0.9373 *
	* 1.4087	* 1.5085	* 1.6472	* 1.4582	* 1.4908	* 1.6574	* 1.5425	* 2.7372 *
9	* 1.7514	* 1.7531	* 1.7085	* 1.6616	* 1.8296	* 1.6394	* 1.6654	* 0.8565 *
	* 1.5085	* 1.5052	* 1.5459	* 1.5857	* 1.4392	* 1.5968	* 1.5576	* 3.0035 *
10	* 1.6036	* 1.7121	* 1.5729	* 1.7375	* 1.6560	* 1.7444	* 1.2852	*
	* 1.6472	* 1.5426	* 1.6726	* 1.5126	* 1.5861	* 1.5009	* 2.0315	*
11	* 1.8057	* 1.6542	* 1.7341	* 1.5339	* 1.5853	* 1.6439	* 0.8926	*
	* 1.4582	* 1.5929	* 1.5156	* 1.7130	* 1.6321	* 1.5499	* 2.8586	*
12	* 1.7597	* 1.8118	* 1.6489	* 1.5818	* 1.5743	* 0.9664	*	
	* 1.4908	* 1.4536	* 1.5931	* 1.6371	* 1.6145	* 2.5552	*	
13	* 1.5786	* 1.6247	* 1.7338	* 1.6378	* 0.9644	*		
	* 1.6574	* 1.6119	* 1.5087	* 1.5561	* 2.5606	*		
14	* 1.6765	* 1.6583	* 1.2769	* 0.8871	*			
	* 1.5425	* 1.5644	* 2.0448	* 2.8771	*			
15	* 0.9373	* 0.8451	* F-SUB-Q					
	* 2.7372	* 3.0436	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8883	* 1.7532	* 1.6072	* 1.8297	* 1.7842	* 1.5988	* 1.7187	* 0.9617 *
	* 1.4201	* 1.5313	* 1.6720	* 1.4580	* 1.4913	* 1.6667	* 1.5420	* 2.7476 *
9	* 1.7532	* 1.7598	* 1.7172	* 1.6732	* 1.8535	* 1.6633	* 1.7053	* 0.8800 *
	* 1.5313	* 1.5271	* 1.5666	* 1.5970	* 1.4392	* 1.5947	* 1.5557	* 3.0047 *
10	* 1.6072	* 1.7211	* 1.5891	* 1.7619	* 1.6749	* 1.7761	* 1.3148	*
	* 1.6720	* 1.5630	* 1.6926	* 1.5191	* 1.5868	* 1.4894	* 2.0175	*
11	* 1.8297	* 1.6650	* 1.7580	* 1.5581	* 1.6125	* 1.6764	* 0.9109	*
	* 1.4580	* 1.6050	* 1.5225	* 1.7192	* 1.6325	* 1.5492	* 2.8510	*
12	* 1.7842	* 1.8345	* 1.6669	* 1.6086	* 1.6026	* 0.9852	*	
	* 1.4913	* 1.4543	* 1.5947	* 1.6379	* 1.6198	* 2.5742	*	
13	* 1.5988	* 1.6487	* 1.7644	* 1.6696	* 0.9832	*		
	* 1.6667	* 1.6090	* 1.4981	* 1.5558	* 2.5797	*		
14	* 1.7187	* 1.6974	* 1.3056	* 0.9049	*			
	* 1.5420	* 1.5631	* 2.0319	* 2.8703	*			
15	* 0.9617	* 0.8688	* F-SUB-Q					
	* 2.7476	* 3.0429	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 266 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9114	* 1.7665	* 1.6200	* 1.8654	* 1.8175	* 1.6255	* 1.7687	* 0.9769 *
	* 1.4198	* 1.5404	* 1.6814	* 1.4477	* 1.4835	* 1.6592	* 1.5234	* 2.7557 *
9	* 1.7665	* 1.7790	* 1.7430	* 1.6936	* 1.8938	* 1.6965	* 1.7552	* 0.8901 *
	* 1.5404	* 1.5314	* 1.5632	* 1.5982	* 1.4258	* 1.5831	* 1.5344	* 3.0225 *
10	* 1.6200	* 1.7470	* 1.5921	* 1.7972	* 1.7025	* 1.8238	* 1.3311	*
	* 1.6814	* 1.5595	* 1.7148	* 1.5068	* 1.5789	* 1.4645	* 2.0153	*
11	* 1.8654	* 1.6847	* 1.7928	* 1.5697	* 1.6510	* 1.7208	* 0.9151	*
	* 1.4477	* 1.6068	* 1.5105	* 1.7280	* 1.6116	* 1.5327	* 2.8780	*
12	* 1.8175	* 1.8739	* 1.6936	* 1.6467	* 1.6429	* 0.9934	*	
	* 1.4836	* 1.4413	* 1.5875	* 1.6170	* 1.6037	* 2.6015	*	
13	* 1.6255	* 1.6803	* 1.8108	* 1.7133	* 0.9915	*		
	* 1.6592	* 1.5982	* 1.4738	* 1.5395	* 2.6065	*		
14	* 1.7687	* 1.7466	* 1.3212	* 0.9085	*			
	* 1.5234	* 1.5421	* 2.0303	* 2.8992	*			
15	* 0.9769	* 0.8770	* F-SUB-Q					
	* 2.7557	* 3.0673	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8988	* 1.7535	* 1.6091	* 1.8649	* 1.8205	* 1.6261	* 1.7799	* 0.9797 *
	* 1.4551	* 1.5764	* 1.7184	* 1.4715	* 1.5026	* 1.6837	* 1.5420	* 2.7908 *
9	* 1.7535	* 1.7705	* 1.7338	* 1.6878	* 1.8951	* 1.7011	* 1.7660	* 0.8929 *
	* 1.5764	* 1.5638	* 1.5953	* 1.6278	* 1.4474	* 1.6004	* 1.5519	* 3.0621 *
10	* 1.6091	* 1.7380	* 1.5834	* 1.7973	* 1.7025	* 1.8318	* 1.3352	*
	* 1.7184	* 1.5914	* 1.7540	* 1.5284	* 1.6030	* 1.4804	* 2.0356	*
11	* 1.8649	* 1.6784	* 1.7925	* 1.5684	* 1.6560	* 1.7294	* 0.9161	*
	* 1.4715	* 1.6370	* 1.5325	* 1.7554	* 1.6324	* 1.5517	* 2.9201	*
12	* 1.8205	* 1.8744	* 1.6929	* 1.6514	* 1.6495	* 0.9957	*	
	* 1.5026	* 1.4636	* 1.6121	* 1.6383	* 1.6241	* 2.6506	*	
13	* 1.6261	* 1.6839	* 1.8180	* 1.7214	* 0.9938	*		
	* 1.6837	* 1.6165	* 1.4902	* 1.5590	* 2.6555	*		
14	* 1.7799	* 1.7568	* 1.3248	* 0.9090	*			
	* 1.5420	* 1.5601	* 2.0516	* 2.9426	*			
15	* 0.9797	* 0.8798	* F-SUB-Q					
	* 2.7908	* 3.1069	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 267 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9140	* 1.7600	* 1.6144	* 1.8899	* 1.8417	* 1.6410	* 1.8137	* 0.9828 *
	* 1.4803	* 1.6118	* 1.7568	* 1.4896	* 1.5225	* 1.7069	* 1.5382	* 2.8257 *
9	* 1.7600	* 1.7814	* 1.7524	* 1.6974	* 1.9242	* 1.7218	* 1.8000	* 0.8917 *
	* 1.6118	* 1.5914	* 1.6181	* 1.6599	* 1.4621	* 1.6196	* 1.5499	* 3.1130 *
10	* 1.6144	* 1.7566	* 1.5732	* 1.8217	* 1.7185	* 1.8664	* 1.3363	*
	* 1.7568	* 1.6142	* 1.7925	* 1.5435	* 1.6267	* 1.4865	* 2.0798	*
11	* 1.8899	* 1.6875	* 1.8165	* 1.5659	* 1.6828	* 1.7603	* 0.9092	*
	* 1.4896	* 1.6697	* 1.5479	* 1.7985	* 1.6386	* 1.5592	* 3.0030	*
12	* 1.8417	* 1.9028	* 1.7081	* 1.6779	* 1.6776	* 0.9938	*	
	* 1.5225	* 1.4787	* 1.6366	* 1.6447	* 1.6326	* 2.7244	*	
13	* 1.6410	* 1.7036	* 1.8515	* 1.7517	* 0.9920	*		
	* 1.7069	* 1.6367	* 1.4969	* 1.5667	* 2.7289	*		
14	* 1.8137	* 1.7903	* 1.3250	* 0.9027	*			
	* 1.5382	* 1.5583	* 2.0972	* 3.0238	*			
15	* 0.9828	* 0.8752	* F-SUB-Q					
	* 2.8257	* 3.1708	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8361	* 1.6988	* 1.5604	* 1.8205	* 1.7880	* 1.5932	* 1.7509	* 0.9672 *
	* 1.5894	* 1.7187	* 1.8687	* 1.5894	* 1.6122	* 1.8096	* 1.6417	* 2.9506 *
9	* 1.6988	* 1.7209	* 1.6767	* 1.6546	* 1.8498	* 1.6715	* 1.7358	* 0.8895 *
	* 1.7187	* 1.6974	* 1.7407	* 1.7516	* 1.5620	* 1.7126	* 1.6570	* 3.2081 *
10	* 1.5604	* 1.6813	* 1.5516	* 1.7551	* 1.6698	* 1.8007	* 1.3244	*
	* 1.8687	* 1.7360	* 1.8839	* 1.6428	* 1.7218	* 1.5797	* 2.1544	*
11	* 1.8205	* 1.6375	* 1.7498	* 1.5472	* 1.6240	* 1.6984	* 0.9115	*
	* 1.5894	* 1.7698	* 1.6484	* 1.8718	* 1.7493	* 1.6650	* 3.0813	*
12	* 1.7880	* 1.8281	* 1.6593	* 1.6190	* 1.6179	* 0.9936	*	
	* 1.6122	* 1.5812	* 1.7326	* 1.7559	* 1.7444	* 2.8129	*	
13	* 1.5932	* 1.6531	* 1.7874	* 1.6896	* 0.9914	*		
	* 1.8096	* 1.7312	* 1.5911	* 1.6732	* 2.8187	*		
14	* 1.7509	* 1.7258	* 1.3130	* 0.9040	*			
	* 1.6417	* 1.6664	* 2.1726	* 3.1054	*			
15	* 0.9672	* 0.8758	* F-SUB-Q					
	* 2.9506	* 3.2573	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 268 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8649	* 1.7137	* 1.5713	* 1.8571	* 1.8164	* 1.6133	* 1.7968	* 0.9666 *
	* 1.6264	* 1.7700	* 1.9289	* 1.6173	* 1.6460	* 1.8497	* 1.6491	* 3.0389 *
9	* 1.7137	* 1.7399	* 1.7107	* 1.6598	* 1.8943	* 1.6998	* 1.7833	* 0.8786 *
	* 1.7700	* 1.7406	* 1.7702	* 1.8109	* 1.5833	* 1.7453	* 1.6620	* 3.3414 *
10	* 1.5713	* 1.7150	* 1.5368	* 1.7908	* 1.6898	* 1.8468	* 1.3170	*
	* 1.9289	* 1.7657	* 1.9552	* 1.6679	* 1.7638	* 1.5990	* 2.2399	*
11	* 1.8571	* 1.6491	* 1.7850	* 1.5368	* 1.6622	* 1.7417	* 0.8939	*
	* 1.6173	* 1.8224	* 1.6738	* 1.9519	* 1.7737	* 1.6864	* 3.2575	*
12	* 1.8164	* 1.8719	* 1.6783	* 1.6562	* 1.6576	* 0.9800	*	
	* 1.6460	* 1.6021	* 1.7754	* 1.7805	* 1.7690	* 2.9644	*	
13	* 1.6133	* 1.6800	* 1.8310	* 1.7323	* 0.9782	*		
	* 1.8497	* 1.7651	* 1.6109	* 1.6949	* 2.9691	*		
14	* 1.7968	* 1.7727	* 1.3049	* 0.8870	*			
	* 1.6491	* 1.6716	* 2.2595	* 3.2809	*			
15	* 0.9666	* 0.8621	* F-SUB-Q					
	* 3.0389	* 3.4039	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8347	* 1.6853	* 1.5456	* 1.8359	* 1.7975	* 1.5940	* 1.7824	* 0.9562 *
	* 1.6210	* 1.7638	* 1.9205	* 1.6191	* 1.6581	* 1.8691	* 1.6795	* 3.1193 *
9	* 1.6853	* 1.7146	* 1.6843	* 1.6365	* 1.8726	* 1.6831	* 1.7682	* 0.8706 *
	* 1.7638	* 1.7348	* 1.7635	* 1.8156	* 1.5881	* 1.7695	* 1.6906	* 3.4233 *
10	* 1.5456	* 1.6887	* 1.5148	* 1.7707	* 1.6704	* 1.8304	* 1.3048	*
	* 1.9205	* 1.7590	* 1.9617	* 1.6771	* 1.7779	* 1.6256	* 2.2793	*
11	* 1.8359	* 1.6255	* 1.7646	* 1.5204	* 1.6473	* 1.7268	* 0.8860	*
	* 1.6191	* 1.8277	* 1.6831	* 1.9512	* 1.7981	* 1.7164	* 3.3349	*
12	* 1.7975	* 1.8499	* 1.6585	* 1.6402	* 1.6427	* 0.9720	*	
	* 1.6581	* 1.6073	* 1.7906	* 1.8057	* 1.7991	* 3.0315	*	
13	* 1.5940	* 1.6625	* 1.8153	* 1.7170	* 0.9702	*		
	* 1.8691	* 1.7910	* 1.6389	* 1.7261	* 3.0371	*		
14	* 1.7824	* 1.7572	* 1.2926	* 0.8786	*			
	* 1.6795	* 1.7011	* 2.3007	* 3.3627	*			
15	* 0.9562	* 0.8560	* F-SUB-Q					
	* 3.1193	* 3.4800	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 269 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7626	* 1.6258	* 1.4919	* 1.7703	* 1.7439	* 1.5460	* 1.7237	* 0.9359 *
	* 1.6443	* 1.7817	* 1.9377	* 1.6365	* 1.6672	* 1.8793	* 1.6954	* 3.1095 *
9	* 1.6258	* 1.6557	* 1.6157	* 1.5905	* 1.8039	* 1.6329	* 1.7088	* 0.8609 *
	* 1.7817	* 1.7509	* 1.7907	* 1.8209	* 1.6068	* 1.7782	* 1.7081	* 3.3760 *
10	* 1.4919	* 1.6204	* 1.4796	* 1.7084	* 1.6194	* 1.7722	* 1.2831	*
	* 1.9377	* 1.7858	* 1.9538	* 1.6917	* 1.7862	* 1.6362	* 2.2581	*
11	* 1.7703	* 1.5725	* 1.7020	* 1.4904	* 1.5915	* 1.6692	* 0.8775	*
	* 1.6365	* 1.8412	* 1.6986	* 1.9370	* 1.8105	* 1.7273	* 3.2698	*
12	* 1.7439	* 1.7810	* 1.6073	* 1.5849	* 1.5871	* 0.9620	*	
	* 1.6672	* 1.6270	* 1.7994	* 1.8176	* 1.8092	* 2.9704	*	
13	* 1.5460	* 1.6122	* 1.7569	* 1.6592	* 0.9599	*		
	* 1.8793	* 1.8005	* 1.6501	* 1.7375	* 2.9767	*		
14	* 1.7237	* 1.6976	* 1.2706	* 0.8693	*			
	* 1.6954	* 1.7192	* 2.2801	* 3.3005	*			
15	* 0.9359	* 0.8470	* F-SUB-Q					
	* 3.1095	* 3.4300	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7685	* 1.6186	* 1.4845	* 1.7807	* 1.7489	* 1.5464	* 1.7465	* 0.9243 *
	* 1.5831	* 1.7286	* 1.8795	* 1.5714	* 1.6060	* 1.8123	* 1.6109	* 3.0127 *
9	* 1.6186	* 1.6520	* 1.6264	* 1.5779	* 1.8225	* 1.6402	* 1.7336	* 0.8409 *
	* 1.7286	* 1.6941	* 1.7172	* 1.7712	* 1.5361	* 1.7091	* 1.6212	* 3.3077 *
10	* 1.4845	* 1.6308	* 1.4594	* 1.7207	* 1.6195	* 1.7928	* 1.2607	*
	* 1.8795	* 1.7128	* 1.9088	* 1.6216	* 1.7249	* 1.5625	* 2.2132	*
11	* 1.7807	* 1.5663	* 1.7132	* 1.4610	* 1.6086	* 1.6899	* 0.8499	*
	* 1.5714	* 1.7838	* 1.6284	* 1.9041	* 1.7273	* 1.6450	* 3.2396	*
12	* 1.7489	* 1.7991	* 1.6067	* 1.6009	* 1.6049	* 0.9390	*	
	* 1.6060	* 1.5553	* 1.7381	* 1.7352	* 1.7227	* 2.9185	*	
13	* 1.5464	* 1.6183	* 1.7766	* 1.6794	* 0.9373	*		
	* 1.8123	* 1.7314	* 1.5761	* 1.6549	* 2.9235	*		
14	* 1.7465	* 1.7219	* 1.2475	* 0.8426	*			
	* 1.6109	* 1.6319	* 2.2358	* 3.2665	*			
15	* 0.9243	* 0.8241	* F-SUB-Q					
	* 3.0127	* 3.3726	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 270 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7377	* 1.5848	* 1.4536	* 1.7542	* 1.7232	* 1.5211	* 1.7294	* 0.9067 *
	* 1.5137	* 1.6581	* 1.8016	* 1.4990	* 1.5323	* 1.7305	* 1.5276	* 2.8793 *
9	* 1.5848	* 1.6209	* 1.5988	* 1.5480	* 1.7984	* 1.6181	* 1.7171	* 0.8234 *
	* 1.6581	* 1.6214	* 1.6402	* 1.6957	* 1.4630	* 1.6282	* 1.5373	* 3.1677 *
10	* 1.4536	* 1.6031	* 1.4314	* 1.6970	* 1.5932	* 1.7743	* 1.2355	*
	* 1.8016	* 1.6359	* 1.8247	* 1.5442	* 1.6473	* 1.4842	* 2.1196	*
11	* 1.7542	* 1.5361	* 1.6893	* 1.4352	* 1.5901	* 1.6725	* 0.8292	*
	* 1.4990	* 1.7082	* 1.5509	* 1.8179	* 1.6433	* 1.5635	* 3.1217	*
12	* 1.7232	* 1.7747	* 1.5800	* 1.5822	* 1.5869	* 0.9192	*	
	* 1.5323	* 1.4816	* 1.6605	* 1.6511	* 1.6391	* 2.8076	*	
13	* 1.5211	* 1.5954	* 1.7575	* 1.6616	* 0.9171	*		
	* 1.7305	* 1.6503	* 1.4976	* 1.5732	* 2.8136	*		
14	* 1.7294	* 1.7050	* 1.2221	* 0.8219	*			
	* 1.5276	* 1.5477	* 2.1419	* 3.1482	*			
15	* 0.9067	* 0.8059	* F-SUB-Q					
	* 2.8793	* 3.2339	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6891	* 1.5415	* 1.4134	* 1.7109	* 1.6835	* 1.4837	* 1.6902	* 0.8860 *
	* 1.4763	* 1.6156	* 1.7563	* 1.4570	* 1.4860	* 1.6808	* 1.4788	* 2.7871 *
9	* 1.5415	* 1.5784	* 1.5549	* 1.5072	* 1.7541	* 1.5805	* 1.6778	* 0.8071 *
	* 1.6156	* 1.5776	* 1.5985	* 1.6513	* 1.4222	* 1.5800	* 1.4891	* 3.0577 *
10	* 1.4134	* 1.5593	* 1.3930	* 1.6565	* 1.5549	* 1.7353	* 1.2098	*
	* 1.7563	* 1.5943	* 1.7775	* 1.5003	* 1.6009	* 1.4389	* 2.0517	*
11	* 1.7109	* 1.4953	* 1.6487	* 1.3993	* 1.5533	* 1.6343	* 0.8135	*
	* 1.4570	* 1.6639	* 1.5071	* 1.7687	* 1.5969	* 1.5189	* 3.0213	*
12	* 1.6835	* 1.7305	* 1.5415	* 1.5453	* 1.5502	* 0.9024	*	
	* 1.4860	* 1.4408	* 1.6142	* 1.6047	* 1.5937	* 2.7184	*	
13	* 1.4837	* 1.5576	* 1.7183	* 1.6232	* 0.9007	*		
	* 1.6808	* 1.6021	* 1.4524	* 1.5286	* 2.7231	*		
14	* 1.6902	* 1.6656	* 1.1962	* 0.8060	*			
	* 1.4788	* 1.4995	* 2.0740	* 3.0481	*			
15	* 0.8860	* 0.7906	* F-SUB-Q					
	* 2.7871	* 3.1194	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 271 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6083	* 1.4782	* 1.3563	* 1.6373	* 1.6192	* 1.4265	* 1.6174	* 0.8611 *
	* 1.4835	* 1.6113	* 1.7509	* 1.4560	* 1.4770	* 1.6711	* 1.4760	* 2.7404 *
9	* 1.4782	* 1.5148	* 1.4805	* 1.4528	* 1.6754	* 1.5190	* 1.6037	* 0.7932 *
	* 1.6113	* 1.5719	* 1.6044	* 1.6393	* 1.4249	* 1.5716	* 1.4882	* 2.9732 *
10	* 1.3563	* 1.4850	* 1.3492	* 1.5862	* 1.4957	* 1.6633	* 1.1830	*
	* 1.7509	* 1.6012	* 1.7557	* 1.4989	* 1.5921	* 1.4355	* 2.0064	*
11	* 1.6373	* 1.4361	* 1.5785	* 1.3651	* 1.4868	* 1.5640	* 0.8041	*
	* 1.4560	* 1.6573	* 1.5059	* 1.7353	* 1.5966	* 1.5186	* 2.9263	*
12	* 1.6192	* 1.6511	* 1.4824	* 1.4788	* 1.4837	* 0.8881	*	
	* 1.4770	* 1.4444	* 1.6057	* 1.6048	* 1.5942	* 2.6459	*	
13	* 1.4265	* 1.4965	* 1.6464	* 1.5531	* 0.8862	*		
	* 1.6711	* 1.5942	* 1.4494	* 1.5287	* 2.6513	*		
14	* 1.6174	* 1.5914	* 1.1696	* 0.7955	*			
	* 1.4760	* 1.4992	* 2.0284	* 2.9567	*			
15	* 0.8611	* 0.7798	* F-SUB-Q					
	* 2.7404	* 3.0221	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6228	* 1.4721	* 1.3491	* 1.6474	* 1.6189	* 1.4205	* 1.6337	* 0.8434 *
	* 1.4112	* 1.5534	* 1.6913	* 1.3917	* 1.4209	* 1.6153	* 1.4063	* 2.6938 *
9	* 1.4721	* 1.5124	* 1.4944	* 1.4409	* 1.6921	* 1.5198	* 1.6221	* 0.7671 *
	* 1.5534	* 1.5121	* 1.5291	* 1.5892	* 1.3567	* 1.5123	* 1.4162	* 2.9608 *
10	* 1.3491	* 1.4986	* 1.3308	* 1.5967	* 1.4914	* 1.6780	* 1.1521	*
	* 1.6913	* 1.5249	* 1.7132	* 1.4337	* 1.5371	* 1.3702	* 1.9843	*
11	* 1.6474	* 1.4287	* 1.5887	* 1.3405	* 1.5004	* 1.5800	* 0.7703	*
	* 1.3917	* 1.6022	* 1.4407	* 1.7018	* 1.5247	* 1.4486	* 2.9446	*
12	* 1.6189	* 1.6685	* 1.4776	* 1.4921	* 1.4976	* 0.8590	*	
	* 1.4209	* 1.3753	* 1.5509	* 1.5327	* 1.5226	* 2.6384	*	
13	* 1.4205	* 1.4964	* 1.6605	* 1.5686	* 0.8569	*		
	* 1.6153	* 1.5350	* 1.3840	* 1.4585	* 2.6443	*		
14	* 1.6337	* 1.6095	* 1.1383	* 0.7629	*			
	* 1.4063	* 1.4268	* 2.0072	* 2.9719	*			
15	* 0.8434	* 0.7501	* F-SUB-Q					
	* 2.6938	* 3.0257	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 272 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5788	* 1.4313	* 1.3106	* 1.5999	* 1.5743	* 1.3787	* 1.5858	* 0.8153 *
	* 1.3836	* 1.5237	* 1.6610	* 1.3676	* 1.3941	* 1.5886	* 1.3841	* 2.6736 *
9	* 1.4313	* 1.4713	* 1.4529	* 1.3991	* 1.6449	* 1.4767	* 1.5753	* 0.7424 *
	* 1.5237	* 1.4828	* 1.5007	* 1.5620	* 1.3322	* 1.4858	* 1.3931	* 2.9359 *
10	* 1.3106	* 1.4570	* 1.2912	* 1.5502	* 1.4488	* 1.6308	* 1.1158	*
	* 1.6610	* 1.4965	* 1.6858	* 1.4098	* 1.5104	* 1.3464	* 1.9594	*
11	* 1.5999	* 1.3870	* 1.5422	* 1.3011	* 1.4570	* 1.5347	* 0.7450	*
	* 1.3676	* 1.5753	* 1.4169	* 1.6744	* 1.5007	* 1.4259	* 2.9211	*
12	* 1.5743	* 1.6215	* 1.4351	* 1.4488	* 1.4541	* 0.8329	*	
	* 1.3941	* 1.3509	* 1.5244	* 1.5090	* 1.5007	* 2.6105	*	
13	* 1.3787	* 1.4535	* 1.6133	* 1.5235	* 0.8309	*		
	* 1.5886	* 1.5089	* 1.3605	* 1.4361	* 2.6166	*		
14	* 1.5858	* 1.5627	* 1.1021	* 0.7377	*			
	* 1.3841	* 1.4041	* 1.9832	* 2.9493	*			
15	* 0.8153	* 0.7253	* F-SUB-Q					
	* 2.6736	* 3.0030	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5359	* 1.3886	* 1.2697	* 1.5409	* 1.5192	* 1.3291	* 1.5191	* 0.7809 *
	* 1.3681	* 1.5105	* 1.6497	* 1.3661	* 1.3896	* 1.5861	* 1.3913	* 2.6916 *
9	* 1.3886	* 1.4246	* 1.4122	* 1.3532	* 1.5936	* 1.4220	* 1.5168	* 0.7286 *
	* 1.5105	* 1.4728	* 1.4854	* 1.5542	* 1.3232	* 1.4850	* 1.3929	* 2.8847 *
10	* 1.2697	* 1.4163	* 1.2473	* 1.4911	* 1.3990	* 1.5741	* 1.0745	*
	* 1.6497	* 1.4812	* 1.6798	* 1.4107	* 1.5053	* 1.3421	* 1.9601	*
11	* 1.5409	* 1.3415	* 1.4834	* 1.2548	* 1.4001	* 1.4798	* 0.7176	*
	* 1.3661	* 1.5675	* 1.4178	* 1.6714	* 1.5037	* 1.4240	* 2.9245	*
12	* 1.5192	* 1.5707	* 1.3858	* 1.3930	* 1.4021	* 0.8199	*	
	* 1.3896	* 1.3420	* 1.5193	* 1.5096	* 1.4990	* 2.5570	*	
13	* 1.3291	* 1.3995	* 1.5552	* 1.4689	* 0.8179	*		
	* 1.5861	* 1.5083	* 1.3581	* 1.4343	* 2.5633	*		
14	* 1.5191	* 1.5048	* 1.0613	* 0.7104	*			
	* 1.3913	* 1.4037	* 1.9840	* 2.9535	*			
15	* 0.7809	* 0.6971	* F-SUB-Q					
	* 2.6916	* 3.0133	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 273 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4789	* 1.3334	* 1.2183	* 1.4600	* 1.4436	* 1.2625	* 1.4333	* 0.7340 *
	* 1.3776	* 1.5253	* 1.6676	* 1.3990	* 1.4177	* 1.6199	* 1.4305	* 2.7836 *
9	* 1.3334	* 1.3640	* 1.3596	* 1.2968	* 1.5263	* 1.3467	* 1.4326	* 0.6837 *
	* 1.5253	* 1.4914	* 1.4962	* 1.5729	* 1.3396	* 1.5208	* 1.4309	* 2.9875 *
10	* 1.2183	* 1.3635	* 1.1938	* 1.4067	* 1.3352	* 1.4976	* 1.0199	*
	* 1.6676	* 1.4919	* 1.7029	* 1.4502	* 1.5296	* 1.3681	* 2.0050	*
11	* 1.4600	* 1.2858	* 1.3995	* 1.2004	* 1.3355	* 1.4043	* 0.6837	*
	* 1.3990	* 1.5861	* 1.4575	* 1.6940	* 1.5276	* 1.4560	* 2.9824	*
12	* 1.4436	* 1.5048	* 1.3229	* 1.3303	* 1.3322	* 0.7802	*	
	* 1.4177	* 1.3584	* 1.5436	* 1.5335	* 1.5311	* 2.6097	*	
13	* 1.2625	* 1.3258	* 1.4798	* 1.3940	* 0.7782	*		
	* 1.6199	* 1.5443	* 1.3842	* 1.4665	* 2.6165	*		
14	* 1.4333	* 1.4211	* 1.0073	* 0.6767	*			
	* 1.4305	* 1.4424	* 2.0296	* 3.0127	*			
15	* 0.7340	* 0.6594	* F-SUB-Q					
	* 2.7836	* 3.0963	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3752	* 1.2534	* 1.1480	* 1.3639	* 1.3462	* 1.1673	* 1.2924	* 0.6666 *
	* 1.4470	* 1.5847	* 1.7289	* 1.4608	* 1.4842	* 1.7117	* 1.5501	* 2.9997 *
9	* 1.2534	* 1.2922	* 1.2681	* 1.2286	* 1.4237	* 1.2493	* 1.2919	* 0.6245 *
	* 1.5847	* 1.5369	* 1.5667	* 1.6211	* 1.4020	* 1.6008	* 1.5506	* 3.2019 *
10	* 1.1480	* 1.2717	* 1.1288	* 1.3151	* 1.2569	* 1.3770	* 0.9355	*
	* 1.7289	* 1.5624	* 1.7590	* 1.5135	* 1.5864	* 1.4528	* 2.1373	*
11	* 1.3639	* 1.2187	* 1.3094	* 1.1308	* 1.2375	* 1.2908	* 0.6366	*
	* 1.4608	* 1.6341	* 1.5199	* 1.7566	* 1.6102	* 1.5473	* 3.1342	*
12	* 1.3463	* 1.4042	* 1.2459	* 1.2328	* 1.2352	* 0.7330	*	
	* 1.4842	* 1.4212	* 1.6003	* 1.6162	* 1.6132	* 2.7165	*	
13	* 1.1673	* 1.2306	* 1.3612	* 1.2815	* 0.7310	*		
	* 1.7117	* 1.6249	* 1.4695	* 1.5583	* 2.7239	*		
14	* 1.2924	* 1.2818	* 0.9244	* 0.6300	*			
	* 1.5501	* 1.5627	* 2.1627	* 3.1666	*			
15	* 0.6666	* 0.6044	* F-SUB-Q					
	* 2.9997	* 3.3070	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 274 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 75% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2265	* 1.0456	* 0.9736	* 1.2062	* 1.1195	* 0.9454	* 1.0449	* 0.5370 *
	* 1.5931	* 1.8672	* 2.0043	* 1.6218	* 1.7522	* 2.0781	* 1.8849	* 3.6674 *
9	* 1.0456	* 1.1033	* 1.1381	* 1.0468	* 1.2549	* 1.0391	* 1.0274	* 0.5058 *
	* 1.8672	* 1.7683	* 1.7138	* 1.8702	* 1.5626	* 1.8913	* 1.9170	* 3.8939 *
10	* 0.9736	* 1.1387	* 0.9740	* 1.1714	* 1.0619	* 1.1582	* 0.7562	*
	* 2.0043	* 1.7128	* 2.0018	* 1.6695	* 1.8436	* 1.6968	* 2.6013	*
11	* 1.2062	* 1.0368	* 1.1652	* 0.9591	* 1.0744	* 1.0477	* 0.5329	*
	* 1.6218	* 1.8871	* 1.6783	* 2.0356	* 1.8223	* 1.8732	* 3.6867	*
12	* 1.1195	* 1.2369	* 1.0533	* 1.0703	* 1.0251	* 0.6201	*	*
	* 1.7522	* 1.5852	* 1.8585	* 1.8292	* 1.9102	* 3.1608	*	*
13	* 0.9454	* 1.0246	* 1.1465	* 1.0405	* 0.6182	*	*	*
	* 2.0781	* 1.9179	* 1.7140	* 1.8861	* 3.1704	*	*	*
14	* 1.0449	* 1.0191	* 0.7478	* 0.5274	*	*	*	*
	* 1.8849	* 1.9326	* 2.6305	* 3.7251	*	*	*	*
15	* 0.5370	* 0.4958	* F-SUB-Q					
	* 3.6674	* 3.9709	* M-SUB-Q					

AT 75% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.5196	* 0.4649	* 0.4551	* 0.5284	* 0.4922	* 0.4288	* 0.4080	* 0.2407 *
	* 3.7038	* 4.1416	* 4.2291	* 3.6464	* 3.9243	* 4.5183	* 4.7609	* 8.0790 *
9	* 0.4649	* 0.4826	* 0.5106	* 0.4739	* 0.5235	* 0.4533	* 0.3992	* 0.2244 *
	* 4.1416	* 3.9859	* 3.7663	* 4.0717	* 3.6914	* 4.2727	* 4.8650	* 8.6689 *
10	* 0.4551	* 0.5107	* 0.4547	* 0.5109	* 0.4677	* 0.4639	* 0.3381	*
	* 4.2291	* 3.7654	* 4.2293	* 3.7706	* 4.1300	* 4.1754	* 5.7410	*
11	* 0.5284	* 0.4705	* 0.5093	* 0.4393	* 0.4638	* 0.4037	* 0.2397	*
	* 3.6464	* 4.0998	* 3.7830	* 4.3842	* 4.1634	* 4.7946	* 8.0944	*
12	* 0.4922	* 0.5176	* 0.4641	* 0.4621	* 0.4028	* 0.2890	*	*
	* 3.9243	* 3.7331	* 4.1627	* 4.1788	* 4.7978	* 6.6959	*	*
13	* 0.4288	* 0.4477	* 0.4594	* 0.4012	* 0.2879	*	*	*
	* 4.5183	* 4.3254	* 4.2160	* 4.8241	* 6.7194	*	*	*
14	* 0.4080	* 0.3962	* 0.3346	* 0.2373	*	*	*	*
	* 4.7609	* 4.9026	* 5.8005	* 8.1744	*	*	*	*
15	* 0.2407	* 0.2234	* F-SUB-Q					
	* 8.0790	* 8.7033	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 275 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8295	* 0.7631	* 0.7064	* 0.7932	* 0.7357	* 0.6290	* 0.4869	* 0.2755
	* 3.4012	* 3.7258	* 4.0969	* 3.5674	* 3.8337	* 4.5620	* 4.8598	* 7.9639
9	* 0.7631	* 0.7397	* 0.7696	* 0.7223	* 0.7762	* 0.6648	* 0.5244	* 0.2776
	* 3.7258	* 3.8774	* 3.6749	* 3.9167	* 3.6309	* 4.2556	* 5.0036	* 8.4906
10	* 0.7064	* 0.7702	* 0.6442	* 0.7414	* 0.6955	* 0.6685	* 0.4899	*
	* 4.0969	* 3.6731	* 4.0233	* 3.7962	* 4.0789	* 4.1509	* 5.8168	*
11	* 0.7932	* 0.7175	* 0.7396	* 0.6346	* 0.6772	* 0.5925	* 0.3601	*
	* 3.5674	* 3.9441	* 3.7994	* 4.3302	* 4.0624	* 4.5829	* 7.5231	*
12	* 0.7357	* 0.7705	* 0.6930	* 0.6761	* 0.5882	* 0.4291	*	*
	* 3.8337	* 3.6596	* 4.0967	* 4.0698	* 4.6091	* 6.2022	*	*
13	* 0.6290	* 0.6602	* 0.6652	* 0.5904	* 0.4271	*	*	*
	* 4.5620	* 4.2845	* 4.1726	* 4.6001	* 6.2329	*	*	*
14	* 0.4869	* 0.5216	* 0.4870	* 0.3580	*	*	*	*
	* 4.8598	* 5.0237	* 5.8493	* 7.5690	*	*	*	*
15	* 0.2755	* 0.2757	* F-SUB-Q					
	* 7.9639	* 8.5440	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7917	* 1.5663	* 1.4067	* 1.6485	* 1.5366	* 1.2939	* 1.2056	* 0.6403
	* 1.6439	* 1.8907	* 2.1301	* 1.7863	* 1.9143	* 2.2781	* 2.1543	* 3.9191
9	* 1.5663	* 1.5426	* 1.5937	* 1.4779	* 1.6936	* 1.3909	* 1.2591	* 0.6186
	* 1.8907	* 1.9058	* 1.8545	* 2.0094	* 1.7375	* 2.1258	* 2.2110	* 4.2532
10	* 1.4067	* 1.5953	* 1.3416	* 1.5599	* 1.4389	* 1.5101	* 1.0176	*
	* 2.1301	* 1.8533	* 2.1016	* 1.8862	* 2.0401	* 1.9181	* 2.8988	*
11	* 1.6485	* 1.4722	* 1.5561	* 1.2814	* 1.4219	* 1.3475	* 0.7368	*
	* 1.7863	* 2.0179	* 1.8879	* 2.2287	* 2.0163	* 2.0998	* 3.8346	*
12	* 1.5366	* 1.6792	* 1.4331	* 1.4194	* 1.3250	* 0.8386	*	*
	* 1.9143	* 1.7530	* 2.0491	* 2.0203	* 2.1317	* 3.2880	*	*
13	* 1.2939	* 1.3810	* 1.5025	* 1.3427	* 0.8355	*	*	*
	* 2.2781	* 2.1419	* 1.9284	* 2.1077	* 3.3003	*	*	*
14	* 1.2056	* 1.2535	* 1.0114	* 0.7323	*	*	*	*
	* 2.1543	* 2.2201	* 2.9161	* 3.8593	*	*	*	*
15	* 0.6403	* 0.6092	* F-SUB-Q					
	* 3.9191	* 4.3164	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 276 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8705 *	* 1.7888 *	* 1.6216 *	* 1.7750 *	* 1.7480 *	* 1.5470 *	* 1.5234 *	* 0.8470 *
	* 1.6338 *	* 1.7148 *	* 1.9145 *	* 1.7232 *	* 1.7487 *	* 1.9786 *	* 1.9272 *	* 3.3721 *
9	* 1.7888 *	* 1.7801 *	* 1.6755 *	* 1.6797 *	* 1.7910 *	* 1.6128 *	* 1.5233 *	* 0.7912 *
	* 1.7148 *	* 1.7432 *	* 1.8489 *	* 1.8299 *	* 1.7118 *	* 1.9049 *	* 1.9513 *	* 3.6470 *
10	* 1.6216 *	* 1.6790 *	* 1.5796 *	* 1.6839 *	* 1.6486 *	* 1.6731 *	* 1.2357 *	
	* 1.9145 *	* 1.8458 *	* 1.9172 *	* 1.8161 *	* 1.8534 *	* 1.8018 *	* 2.4754 *	
11	* 1.7750 *	* 1.6725 *	* 1.6806 *	* 1.5155 *	* 1.5251 *	* 1.5656 *	* 0.8755 *	
	* 1.7232 *	* 1.8456 *	* 1.8195 *	* 2.0033 *	* 1.9508 *	* 1.8719 *	* 3.3487 *	
12	* 1.7480 *	* 1.7733 *	* 1.6418 *	* 1.5217 *	* 1.5070 *	* 0.9619 *		
	* 1.7487 *	* 1.7295 *	* 1.8625 *	* 1.9568 *	* 1.9385 *	* 2.9578 *		
13	* 1.5470 *	* 1.5988 *	* 1.6629 *	* 1.5596 *	* 0.9591 *			
	* 1.9786 *	* 1.9217 *	* 1.8112 *	* 1.8795 *	* 2.9667 *			
14	* 1.5234 *	* 1.5167 *	* 1.2277 *	* 0.8700 *				
	* 1.9272 *	* 1.9595 *	* 2.4912 *	* 3.3708 *				
15	* 0.8470 *	* 0.7810 *	F-SUB-Q					
	* 3.3721 *	* 3.6929 *	M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0553 *	* 1.9358 *	* 1.7546 *	* 1.9558 *	* 1.9243 *	* 1.7156 *	* 1.7800 *	* 0.9668 *
	* 1.5499 *	* 1.6514 *	* 1.8425 *	* 1.6353 *	* 1.6699 *	* 1.8614 *	* 1.7517 *	* 3.1732 *
9	* 1.9358 *	* 1.9381 *	* 1.8571 *	* 1.8170 *	* 1.9842 *	* 1.7841 *	* 1.7717 *	* 0.8827 *
	* 1.6514 *	* 1.6703 *	* 1.7397 *	* 1.7766 *	* 1.6159 *	* 1.7936 *	* 1.7719 *	* 3.4932 *
10	* 1.7546 *	* 1.8610 *	* 1.6868 *	* 1.8678 *	* 1.8013 *	* 1.8817 *	* 1.3584 *	
	* 1.8425 *	* 1.7360 *	* 1.8948 *	* 1.7167 *	* 1.7755 *	* 1.6738 *	* 2.3488 *	
11	* 1.9558 *	* 1.8084 *	* 1.8637 *	* 1.6353 *	* 1.6934 *	* 1.7520 *	* 0.9328 *	
	* 1.6353 *	* 1.7851 *	* 1.7203 *	* 1.9563 *	* 1.8307 *	* 1.7441 *	* 3.2815 *	
12	* 1.9243 *	* 1.9641 *	* 1.7929 *	* 1.6892 *	* 1.6688 *	* 1.0110 *		
	* 1.6699 *	* 1.6332 *	* 1.7853 *	* 1.8369 *	* 1.8256 *	* 2.9302 *		
13	* 1.7156 *	* 1.7665 *	* 1.8693 *	* 1.7448 *	* 1.0086 *			
	* 1.8614 *	* 1.8116 *	* 1.6833 *	* 1.7519 *	* 2.9376 *			
14	* 1.7800 *	* 1.7637 *	* 1.3487 *	* 0.9263 *				
	* 1.7517 *	* 1.7799 *	* 2.3656 *	* 3.3054 *				
15	* 0.9669 *	* 0.8686 *	F-SUB-Q					
	* 3.1732 *	* 3.5488 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 277 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0824 *	* 1.9401 *	* 1.7634 *	* 1.9967 *	* 1.9624 *	* 1.7498 *	* 1.8593 *	* 1.0131 *
	* 1.6102 *	* 1.7362 *	* 1.9151 *	* 1.6831 *	* 1.7067 *	* 1.9088 *	* 1.7705 *	* 3.2191 *
9	* 1.9401 *	* 1.9421 *	* 1.8797 *	* 1.8345 *	* 2.0244 *	* 1.8205 *	* 1.8455 *	* 0.9243 *
	* 1.7362 *	* 1.7404 *	* 1.7962 *	* 1.8342 *	* 1.6608 *	* 1.8364 *	* 1.7913 *	* 3.5400 *
10	* 1.7634 *	* 1.8839 *	* 1.7195 *	* 1.9110 *	* 1.8297 *	* 1.9341 *	* 1.4080 *	
	* 1.9151 *	* 1.7921 *	* 1.9535 *	* 1.7561 *	* 1.8324 *	* 1.7032 *	* 2.3682 *	
11	* 1.9967 *	* 1.8250 *	* 1.9064 *	* 1.6751 *	* 1.7371 *	* 1.8043 *	* 0.9609 *	
	* 1.6831 *	* 1.8439 *	* 1.7604 *	* 2.0029 *	* 1.8746 *	* 1.7761 *	* 3.3333 *	
12	* 1.9624 *	* 2.0025 *	* 1.8203 *	* 1.7325 *	* 1.7128 *	* 1.0372 *		
	* 1.7067 *	* 1.6793 *	* 1.8421 *	* 1.8815 *	* 1.8701 *	* 3.0014 *		
13	* 1.7498 *	* 1.8017 *	* 1.9202 *	* 1.7963 *	* 1.0347 *			
	* 1.9088 *	* 1.8549 *	* 1.7138 *	* 1.7846 *	* 3.0088 *			
14	* 1.8593 *	* 1.8364 *	* 1.3975 *	* 0.9541 *				
	* 1.7705 *	* 1.8002 *	* 2.3860 *	* 3.3579 *				
15	* 1.0131 *	* 0.9113 *	F-SUB-Q					
	* 3.2191 *	* 3.5895 *	M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0687 *	* 1.9196 *	* 1.7479 *	* 2.0010 *	* 1.9674 *	* 1.7532 *	* 1.8867 *	* 1.0305 *
	* 1.6825 *	* 1.8145 *	* 1.9949 *	* 1.7294 *	* 1.7547 *	* 1.9748 *	* 1.8230 *	* 3.3278 *
9	* 1.9196 *	* 1.9226 *	* 1.8683 *	* 1.8273 *	* 2.0287 *	* 1.8274 *	* 1.8704 *	* 0.9416 *
	* 1.8145 *	* 1.8170 *	* 1.8682 *	* 1.8978 *	* 1.7065 *	* 1.8837 *	* 1.8415 *	* 3.6455 *
10	* 1.7479 *	* 1.8729 *	* 1.7189 *	* 1.9174 *	* 1.8307 *	* 1.9486 *	* 1.4265 *	
	* 1.9949 *	* 1.8635 *	* 2.0355 *	* 1.8143 *	* 1.8837 *	* 1.7598 *	* 2.4164 *	
11	* 2.0010 *	* 1.8172 *	* 1.9123 *	* 1.6842 *	* 1.7490 *	* 1.8218 *	* 0.9721 *	
	* 1.7294 *	* 1.9087 *	* 1.8192 *	* 2.0683 *	* 1.9567 *	* 1.8502 *	* 3.4733 *	
12	* 1.9674 *	* 2.0058 *	* 1.8205 *	* 1.7440 *	* 1.7271 *	* 1.0483 *		
	* 1.7547 *	* 1.7264 *	* 1.8946 *	* 1.9643 *	* 1.9482 *	* 3.1154 *		
13	* 1.7532 *	* 1.8091 *	* 1.9336 *	* 1.8131 *	* 1.0458 *			
	* 1.9748 *	* 1.9031 *	* 1.7722 *	* 1.8596 *	* 3.1233 *			
14	* 1.8867 *	* 1.8606 *	* 1.4152 *	* 0.9650 *				
	* 1.8230 *	* 1.8514 *	* 2.4361 *	* 3.5000 *				
15	* 1.0305 *	* 0.9289 *	F-SUB-Q					
	* 3.3278 *	* 3.6942 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 278 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0677	* 1.9096	* 1.7400	* 2.0157	* 1.9795	* 1.7609	* 1.9190	* 1.0362 *
	* 1.7468	* 1.8900	* 2.0746	* 1.7791	* 1.8050	* 2.0286	* 1.8604	* 3.4478 *
9	* 1.9096	* 1.9197	* 1.8734	* 1.8271	* 2.0482	* 1.8415	* 1.9030	* 0.9429 *
	* 1.8900	* 1.8811	* 1.9271	* 1.9650	* 1.7509	* 1.9333	* 1.8753	* 3.7868 *
10	* 1.7400	* 1.8781	* 1.7018	* 1.9328	* 1.8389	* 1.9774	* 1.4283	*
	* 2.0746	* 1.9223	* 2.1280	* 1.8562	* 1.9421	* 1.7968	* 2.4903	*
11	* 2.0157	* 1.8164	* 1.9273	* 1.6772	* 1.7708	* 1.8494	* 0.9666	*
	* 1.7791	* 1.9768	* 1.8616	* 2.1443	* 2.0052	* 1.9141	* 3.6512	*
12	* 1.9795	* 2.0245	* 1.8278	* 1.7655	* 1.7515	* 1.0464	*	
	* 1.8050	* 1.7717	* 1.9541	* 2.0122	* 2.0208	* 3.3032	*	
13	* 1.7609	* 1.8218	* 1.9613	* 1.8401	* 1.0441	*		
	* 2.0286	* 1.9542	* 1.8101	* 1.9238	* 3.3109	*		
14	* 1.9190	* 1.8926	* 1.4164	* 0.9589	*			
	* 1.8604	* 1.8858	* 2.5113	* 3.6804	*			
15	* 1.0362	* 0.9282	* F-SUB-Q					
	* 3.4478	* 3.8457	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0258	* 1.8693	* 1.7052	* 1.9886	* 1.9558	* 1.7383	* 1.9064	* 1.0272 *
	* 1.8625	* 2.0190	* 2.2145	* 1.8850	* 1.9115	* 2.1539	* 1.9550	* 3.6169 *
9	* 1.8693	* 1.8844	* 1.8387	* 1.7969	* 2.0228	* 1.8224	* 1.8902	* 0.9351 *
	* 2.0190	* 2.0072	* 2.0542	* 2.0891	* 1.8530	* 2.0425	* 1.9728	* 3.9737 *
10	* 1.7052	* 1.8435	* 1.6707	* 1.9080	* 1.8148	* 1.9605	* 1.4153	*
	* 2.2145	* 2.0488	* 2.2732	* 1.9665	* 2.0548	* 1.8896	* 2.6319	*
11	* 1.9886	* 1.7858	* 1.9022	* 1.6548	* 1.7540	* 1.8357	* 0.9568	*
	* 1.8850	* 2.1024	* 1.9737	* 2.2754	* 2.1074	* 2.0080	* 3.8424	*
12	* 1.9558	* 1.9987	* 1.8032	* 1.7484	* 1.7375	* 1.0373	*	
	* 1.9115	* 1.8757	* 2.0683	* 2.1160	* 2.1191	* 3.5271	*	
13	* 1.7383	* 1.8020	* 1.9449	* 1.8260	* 1.0350	*		
	* 2.1539	* 2.0657	* 1.9043	* 2.0188	* 3.5348	*		
14	* 1.9064	* 1.8793	* 1.4030	* 0.9487	*			
	* 1.9550	* 1.9843	* 2.6552	* 3.8750	*			
15	* 1.0272	* 0.9207	* F-SUB-Q					
	* 3.6169	* 4.0346	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 279 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0138	* 1.8500	* 1.6875	* 1.9883	* 1.9515	* 1.7304	* 1.9167	* 1.0182 *
	* 1.9641	* 2.1367	* 2.3419	* 1.9738	* 2.0035	* 2.2577	* 2.0334	* 3.8213 *
9	* 1.8500	* 1.8701	* 1.8335	* 1.7828	* 2.0265	* 1.8199	* 1.9012	* 0.9227 *
	* 2.1367	* 2.1131	* 2.1549	* 2.2032	* 1.9356	* 2.1376	* 2.0498	* 4.2145 *
10	* 1.6875	* 1.8382	* 1.6394	* 1.9085	* 1.8076	* 1.9711	* 1.3985	*
	* 2.3419	* 2.1493	* 2.3985	* 2.0530	* 2.1596	* 1.9691	* 2.7781	*
11	* 1.9883	* 1.7713	* 1.9024	* 1.6307	* 1.7609	* 1.8447	* 0.9383	*
	* 1.9738	* 2.2176	* 2.0608	* 2.4092	* 2.2001	* 2.0951	* 4.1030	*
12	* 1.9515	* 2.0021	* 1.7953	* 1.7539	* 1.7453	* 1.0231	*	
	* 2.0035	* 1.9594	* 2.1744	* 2.2093	* 2.2126	* 3.7544	*	
13	* 1.7304	* 1.7987	* 1.9534	* 1.8345	* 1.0210	*		
	* 2.2577	* 2.1628	* 1.9849	* 2.1067	* 3.7619	*		
14	* 1.9167	* 1.8899	* 1.3854	* 0.9310	*			
	* 2.0334	* 2.0621	* 2.8039	* 4.1346	*			
15	* 1.0182	* 0.9050	* F-SUB-Q					
	* 3.8213	* 4.2958	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9037	* 1.7597	* 1.6072	* 1.8879	* 1.8669	* 1.6564	* 1.8240	* 0.9891 *
	* 2.2067	* 2.3862	* 2.6111	* 2.2052	* 2.2204	* 2.4984	* 2.2543	* 4.1340 *
9	* 1.7597	* 1.7804	* 1.7295	* 1.7135	* 1.9209	* 1.7417	* 1.8074	* 0.9088 *
	* 2.3862	* 2.3548	* 2.4245	* 2.4354	* 2.1595	* 2.3670	* 2.2764	* 4.4997 *
10	* 1.6072	* 1.7345	* 1.5937	* 1.8131	* 1.7294	* 1.8763	* 1.3674	*
	* 2.6111	* 2.4175	* 2.6328	* 2.2894	* 2.3944	* 2.1892	* 3.0053	*
11	* 1.8879	* 1.6946	* 1.8069	* 1.5897	* 1.6750	* 1.7556	* 0.9290	*
	* 2.2052	* 2.4626	* 2.2982	* 2.6199	* 2.4532	* 2.3348	* 4.3892	*
12	* 1.8669	* 1.8963	* 1.7171	* 1.6691	* 1.6609	* 1.0104	*	
	* 2.2204	* 2.1939	* 2.4113	* 2.4638	* 2.4665	* 4.0326	*	
13	* 1.6564	* 1.7207	* 1.8607	* 1.7454	* 1.0078	*		
	* 2.4984	* 2.3954	* 2.2072	* 2.3480	* 4.0423	*		
14	* 1.8241	* 1.7960	* 1.3545	* 0.9208	*			
	* 2.2543	* 2.2906	* 3.0332	* 4.4269	*			
15	* 0.9891	* 0.8942	* F-SUB-Q					
	* 4.1340	* 4.5718	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 280 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9053	* 1.7485	* 1.5958	* 1.8986	* 1.8686	* 1.6525	* 1.8450	* 0.9754 *
	* 2.3326	* 2.5400	* 2.7805	* 2.3379	* 2.3675	* 2.6721	* 2.3813	* 4.4739 *
9	* 1.7485	* 1.7741	* 1.7394	* 1.6939	* 1.9388	* 1.7453	* 1.8303	* 0.8858 *
	* 2.5400	* 2.5055	* 2.5521	* 2.6219	* 2.2858	* 2.5164	* 2.4006	* 4.9235 *
10	* 1.5958	* 1.7440	* 1.5573	* 1.8240	* 1.7273	* 1.8957	* 1.3408	*
	* 2.7805	* 2.5454	* 2.8502	* 2.4189	* 2.5516	* 2.3051	* 3.2618	*
11	* 1.8986	* 1.6821	* 1.8174	* 1.5568	* 1.6921	* 1.7755	* 0.8991	*
	* 2.3379	* 2.6403	* 2.4285	* 2.8470	* 2.5765	* 2.4482	* 4.7997	*
12	* 1.8686	* 1.9142	* 1.7144	* 1.6843	* 1.6788	* 0.9837	*	
	* 2.3675	* 2.3157	* 2.5701	* 2.5877	* 2.5832	* 4.3730	*	
13	* 1.6525	* 1.7232	* 1.8792	* 1.7648	* 0.9816	*		
	* 2.6721	* 2.5477	* 2.3244	* 2.4622	* 4.3813	*		
14	* 1.8450	* 1.8185	* 1.3274	* 0.8915	*			
	* 2.3813	* 2.4157	* 3.2932	* 4.8378	*			
15	* 0.9754	* 0.8685	* F-SUB-Q					
	* 4.4739	* 5.0188	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8463	* 1.6936	* 1.5468	* 1.8490	* 1.8210	* 1.6086	* 1.8031	* 0.9518 *
	* 2.3507	* 2.5602	* 2.7998	* 2.3458	* 2.3897	* 2.7060	* 2.4295	* 4.6005 *
9	* 1.6936	* 1.7220	* 1.6874	* 1.6457	* 1.8885	* 1.7024	* 1.7880	* 0.8659 *
	* 2.5602	* 2.5200	* 2.5680	* 2.6354	* 2.2992	* 2.5566	* 2.4466	* 5.0534 *
10	* 1.5468	* 1.6920	* 1.5129	* 1.7774	* 1.6822	* 1.8521	* 1.3096	*
	* 2.7998	* 2.5611	* 2.8667	* 2.4376	* 2.5778	* 2.3485	* 3.3275	*
11	* 1.8490	* 1.6338	* 1.7708	* 1.5185	* 1.6530	* 1.7353	* 0.8794	*
	* 2.3458	* 2.6545	* 2.4481	* 2.8537	* 2.6182	* 2.4982	* 4.9282	*
12	* 1.8210	* 1.8640	* 1.6691	* 1.6451	* 1.6406	* 0.9629	*	
	* 2.3897	* 2.3291	* 2.5982	* 2.6310	* 2.6341	* 4.4858	*	
13	* 1.6086	* 1.6800	* 1.8354	* 1.7244	* 0.9608	*		
	* 2.7060	* 2.5906	* 2.3700	* 2.5141	* 4.4956	*		
14	* 1.8031	* 1.7760	* 1.2964	* 0.8715	*			
	* 2.4295	* 2.4631	* 3.3618	* 4.9733	*			
15	* 0.9518	* 0.8508	* F-SUB-Q					
	* 4.6005	* 5.1407	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 281 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7468	* 1.6089	* 1.4709	* 1.7562	* 1.7395	* 1.5366	* 1.7170	* 0.9187 *
	* 2.4163	* 2.6208	* 2.8620	* 2.4023	* 2.4353	* 2.7574	* 2.4875	* 4.6474 *
9	* 1.6089	* 1.6378	* 1.5945	* 1.5761	* 1.7944	* 1.6264	* 1.7017	* 0.8444 *
	* 2.6208	* 2.5772	* 2.6420	* 2.6790	* 2.3570	* 2.6038	* 2.5057	* 5.0501 *
10	* 1.4709	* 1.5993	* 1.4559	* 1.6903	* 1.6066	* 1.7661	* 1.2692	*
	* 2.8620	* 2.6343	* 2.8942	* 2.4908	* 2.6238	* 2.3955	* 3.3401	*
11	* 1.7562	* 1.5573	* 1.6828	* 1.4671	* 1.5735	* 1.6526	* 0.8591	*
	* 2.4023	* 2.7095	* 2.5021	* 2.8687	* 2.6702	* 2.5467	* 4.8931	*
12	* 1.7395	* 1.7678	* 1.5936	* 1.5656	* 1.5624	* 0.9400	*	*
	* 2.4353	* 2.3887	* 2.6452	* 2.6833	* 2.6823	* 4.4497	*	*
13	* 1.5366	* 1.6044	* 1.7495	* 1.6418	* 0.9378	*	*	*
	* 2.7574	* 2.6395	* 2.4182	* 2.5636	* 4.4607	*	*	*
14	* 1.7170	* 1.6897	* 1.2558	* 0.8505	*	*	*	*
	* 2.4875	* 2.5235	* 3.3757	* 4.9430	*	*	*	*
15	* 0.9187	* 0.8302	* F-SUB-Q					
	* 4.6474	* 5.1342	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7249	* 1.5767	* 1.4412	* 1.7397	* 1.7170	* 1.5130	* 1.7130	* 0.8942 *
	* 2.3305	* 2.5474	* 2.7768	* 2.3075	* 2.3497	* 2.6577	* 2.3564	* 4.4565 *
9	* 1.5767	* 1.6090	* 1.5808	* 1.5392	* 1.7828	* 1.6085	* 1.7000	* 0.8131 *
	* 2.5474	* 2.4968	* 2.5344	* 2.6044	* 2.2531	* 2.5016	* 2.3720	* 4.8962 *
10	* 1.4412	* 1.5852	* 1.4148	* 1.6771	* 1.5820	* 1.7593	* 1.2285	*
	* 2.7768	* 2.5276	* 2.8195	* 2.3837	* 2.5317	* 2.2851	* 3.2552	*
11	* 1.7397	* 1.5271	* 1.6692	* 1.4170	* 1.5669	* 1.6485	* 0.8203	*
	* 2.3075	* 2.6239	* 2.3943	* 2.8092	* 2.5397	* 2.4165	* 4.8061	*
12	* 1.7170	* 1.7587	* 1.5685	* 1.5588	* 1.5572	* 0.9049	*	*
	* 2.3497	* 2.2824	* 2.5523	* 2.5522	* 2.5408	* 4.3352	*	*
13	* 1.5130	* 1.5856	* 1.7421	* 1.6374	* 0.9030	*	*	*
	* 2.6577	* 2.5360	* 2.3064	* 2.4321	* 4.3436	*	*	*
14	* 1.7130	* 1.6878	* 1.2149	* 0.8128	*	*	*	*
	* 2.3564	* 2.3883	* 3.2901	* 4.8488	*	*	*	*
15	* 0.8942	* 0.7963	* F-SUB-Q					
	* 4.4565	* 4.9949	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 282 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6687	* 1.5200	* 1.3897	* 1.6878	* 1.6654	* 1.4651	* 1.6702	* 0.8648 *
	* 2.1550	* 2.3629	* 2.5735	* 2.1300	* 2.1700	* 2.4578	* 2.1650	* 4.1310 *
9	* 1.5200	* 1.5545	* 1.5304	* 1.4870	* 1.7325	* 1.5622	* 1.6580	* 0.7849 *
	* 2.3629	* 2.3100	* 2.3403	* 2.4130	* 2.0770	* 2.3086	* 2.1794	* 4.5473 *
10	* 1.3897	* 1.5347	* 1.3672	* 1.6292	* 1.5327	* 1.7146	* 1.1862	*
	* 2.5735	* 2.3340	* 2.6082	* 2.1981	* 2.3419	* 2.1032	* 3.0229	*
11	* 1.6878	* 1.4749	* 1.6212	* 1.3718	* 1.5260	* 1.6074	* 0.7891	*
	* 2.1300	* 2.4318	* 2.2084	* 2.5975	* 2.3379	* 2.2225	* 4.4820	*
12	* 1.6654	* 1.7085	* 1.5191	* 1.5178	* 1.5175	* 0.8736	*	
	* 2.1700	* 2.1047	* 2.3618	* 2.3499	* 2.3362	* 4.0222	*	
13	* 1.4651	* 1.5391	* 1.6971	* 1.5961	* 0.8714	*		
	* 2.4578	* 2.3417	* 2.1236	* 2.2374	* 4.0317	*		
14	* 1.6702	* 1.6456	* 1.1726	* 0.7817	*			
	* 2.1650	* 2.1950	* 3.0566	* 4.5227	*			
15	* 0.8648	* 0.7678	* F-SUB-Q					
	* 4.1310	* 4.6445	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5986	* 1.4570	* 1.3323	* 1.6224	* 1.6030	* 1.4085	* 1.6085	* 0.8336 *
	* 2.0055	* 2.1971	* 2.3935	* 1.9788	* 2.0151	* 2.2866	* 2.0143	* 3.8437 *
9	* 1.4570	* 1.4919	* 1.4673	* 1.4273	* 1.6656	* 1.5037	* 1.5965	* 0.7591 *
	* 2.1971	* 2.1463	* 2.1768	* 2.2450	* 1.9304	* 2.1452	* 2.0275	* 4.2175 *
10	* 1.3323	* 1.4716	* 1.3119	* 1.5677	* 1.4743	* 1.6523	* 1.1454	*
	* 2.3935	* 2.1708	* 2.4257	* 2.0402	* 2.1747	* 1.9517	* 2.8021	*
11	* 1.6224	* 1.4154	* 1.5598	* 1.3188	* 1.4696	* 1.5485	* 0.7639	*
	* 1.9788	* 2.2629	* 2.0500	* 2.4119	* 2.1723	* 2.0658	* 4.1477	*
12	* 1.6030	* 1.6421	* 1.4608	* 1.4615	* 1.4620	* 0.8464	*	
	* 2.0151	* 1.9566	* 2.1938	* 2.1838	* 2.1730	* 3.7190	*	
13	* 1.4085	* 1.4809	* 1.6350	* 1.5372	* 0.8446	*		
	* 2.2866	* 2.1768	* 1.9713	* 2.0801	* 3.7264	*		
14	* 1.6085	* 1.5842	* 1.1318	* 0.7565	*			
	* 2.0143	* 2.0425	* 2.8343	* 4.1869	*			
15	* 0.8336	* 0.7431	* F-SUB-Q					
	* 3.8437	* 4.3044	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 283 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5016 *	* 1.3779 *	* 1.2612 *	* 1.5310 *	* 1.5197 *	* 1.3354 *	* 1.5171 *	* 0.7995 *
	* 1.9115 *	* 2.0790 *	* 2.2635 *	* 1.8788 *	* 1.9062 *	* 2.1652 *	* 1.9233 *	* 3.6200 *
9	* 1.3779 *	* 1.4121 *	* 1.3781 *	* 1.3580 *	* 1.5717 *	* 1.4247 *	* 1.5042 *	* 0.7362 *
	* 2.0790 *	* 2.0311 *	* 2.0751 *	* 2.1167 *	* 1.8382 *	* 2.0310 *	* 1.9369 *	* 3.9258 *
10	* 1.2612 *	* 1.3824 *	* 1.2545 *	* 1.4805 *	* 1.3987 *	* 1.5611 *	* 1.1047 *	
	* 2.2634 *	* 2.0692 *	* 2.2746 *	* 1.9361 *	* 2.0541 *	* 1.8521 *	* 2.6094 *	
11	* 1.5310 *	* 1.3407 *	* 1.4728 *	* 1.2695 *	* 1.3875 *	* 1.4614 *	* 0.7455 *	
	* 1.8788 *	* 2.1405 *	* 1.9457 *	* 2.2474 *	* 2.0560 *	* 1.9540 *	* 3.8005 *	
12	* 1.5197 *	* 1.5451 *	* 1.3855 *	* 1.3795 *	* 1.3804 *	* 0.8224 *		
	* 1.9062 *	* 1.8640 *	* 2.0726 *	* 2.0672 *	* 2.0510 *	* 3.4085 *		
13	* 1.3354 *	* 1.4026 *	* 1.5443 *	* 1.4505 *	* 0.8204 *			
	* 2.1652 *	* 2.0616 *	* 1.8712 *	* 1.9680 *	* 3.4164 *			
14	* 1.5171 *	* 1.4922 *	* 1.0916 *	* 0.7371 *				
	* 1.9233 *	* 1.9519 *	* 2.6397 *	* 3.8424 *				
15	* 0.7995 *	* 0.7234 *	F-SUB-Q					
	* 3.6200 *	* 3.9919 *	M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4940 *	* 1.3532 *	* 1.2374 *	* 1.5196 *	* 1.4980 *	* 1.3110 *	* 1.5112 *	* 0.7729 *
	* 1.7148 *	* 1.8896 *	* 2.0603 *	* 1.6931 *	* 1.7296 *	* 1.9735 *	* 1.7321 *	* 3.3644 *
9	* 1.3532 *	* 1.3906 *	* 1.3723 *	* 1.3273 *	* 1.5629 *	* 1.4055 *	* 1.5004 *	* 0.7029 *
	* 1.8896 *	* 1.8429 *	* 1.8625 *	* 1.9340 *	* 1.6501 *	* 1.8421 *	* 1.7412 *	* 3.6950 *
10	* 1.2374 *	* 1.3763 *	* 1.2200 *	* 1.4704 *	* 1.3753 *	* 1.5532 *	* 1.0615 *	
	* 2.0603 *	* 1.8573 *	* 2.0923 *	* 1.7441 *	* 1.8676 *	* 1.6655 *	* 2.4323 *	
11	* 1.5196 *	* 1.3157 *	* 1.4625 *	* 1.2297 *	* 1.3814 *	* 1.4567 *	* 0.7050 *	
	* 1.6931 *	* 1.9503 *	* 1.7530 *	* 2.0723 *	* 1.8508 *	* 1.7590 *	* 3.6053 *	
12	* 1.4980 *	* 1.5402 *	* 1.3620 *	* 1.3733 *	* 1.3753 *	* 0.7854 *		
	* 1.7296 *	* 1.6732 *	* 1.8850 *	* 1.8612 *	* 1.8489 *	* 3.2142 *		
13	* 1.3110 *	* 1.3830 *	* 1.5361 *	* 1.4456 *	* 0.7833 *			
	* 1.9735 *	* 1.8709 *	* 1.6832 *	* 1.7718 *	* 3.2222 *			
14	* 1.5112 *	* 1.4883 *	* 1.0482 *	* 0.6979 *				
	* 1.7321 *	* 1.7549 *	* 2.4620 *	* 3.6407 *				
15	* 0.7729 *	* 0.6869 *	F-SUB-Q					
	* 3.3644 *	* 3.7773 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 284 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4349	* 1.2990	* 1.1871	* 1.4571	* 1.4376	* 1.2559	* 1.4477	* 0.7383 *
	* 1.6248	* 1.7904	* 1.9536	* 1.6082	* 1.6400	* 1.8729	* 1.6380	* 3.1873 *
9	* 1.2990	* 1.3358	* 1.3175	* 1.2724	* 1.4998	* 1.3478	* 1.4381	* 0.6721 *
	* 1.7904	* 1.7436	* 1.7647	* 1.8370	* 1.5663	* 1.7491	* 1.6475	* 3.4989 *
10	* 1.1871	* 1.3214	* 1.1692	* 1.4096	* 1.3191	* 1.4898	* 1.0152	*
	* 1.9536	* 1.7598	* 1.9850	* 1.6577	* 1.7752	* 1.5836	* 2.3157	*
11	* 1.4571	* 1.2610	* 1.4019	* 1.1788	* 1.3246	* 1.3971	* 0.6738	*
	* 1.6082	* 1.8529	* 1.6662	* 1.9698	* 1.7635	* 1.6763	* 3.4503	*
12	* 1.4376	* 1.4778	* 1.3061	* 1.3167	* 1.3189	* 0.7526	*	
	* 1.6400	* 1.5887	* 1.7921	* 1.7735	* 1.7639	* 3.0750	*	
13	* 1.2559	* 1.3258	* 1.4731	* 1.3862	* 0.7506	*		
	* 1.8729	* 1.7770	* 1.6007	* 1.6887	* 3.0826	*		
14	* 1.4477	* 1.4262	* 1.0022	* 0.6669	*			
	* 1.6380	* 1.6608	* 2.3446	* 3.4848	*			
15	* 0.7383	* 0.6562	* F-SUB-Q					
	* 3.1873	* 3.5797	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3804	* 1.2462	* 1.1377	* 1.3874	* 1.3709	* 1.1970	* 1.3709	* 0.6994 *
	* 1.5679	* 1.7318	* 1.8928	* 1.5679	* 1.5956	* 1.8242	* 1.6035	* 3.1196 *
9	* 1.2462	* 1.2788	* 1.2666	* 1.2171	* 1.4366	* 1.2828	* 1.3686	* 0.6525 *
	* 1.7318	* 1.6893	* 1.7039	* 1.7840	* 1.5186	* 1.7068	* 1.6054	* 3.3432 *
10	* 1.1377	* 1.2703	* 1.1172	* 1.3405	* 1.2592	* 1.4209	* 0.9667	*
	* 1.8928	* 1.6991	* 1.9293	* 1.6194	* 1.7277	* 1.5417	* 2.2598	*
11	* 1.3874	* 1.2062	* 1.3332	* 1.1244	* 1.2585	* 1.3318	* 0.6421	*
	* 1.5679	* 1.7995	* 1.6278	* 1.9194	* 1.7265	* 1.6363	* 3.3732	*
12	* 1.3709	* 1.4153	* 1.2468	* 1.2510	* 1.2576	* 0.7331	*	
	* 1.5956	* 1.5405	* 1.7441	* 1.7334	* 1.7225	* 2.9444	*	
13	* 1.1970	* 1.2618	* 1.4031	* 1.3214	* 0.7311	*		
	* 1.8242	* 1.7341	* 1.5604	* 1.6485	* 2.9519	*		
14	* 1.3709	* 1.3574	* 0.9544	* 0.6353	*			
	* 1.6035	* 1.6182	* 2.2879	* 3.4075	*			
15	* 0.6994	* 0.6240	* F-SUB-Q					
	* 3.1196	* 3.4927	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 285 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3161	* 1.1852	* 1.0811	* 1.3019	* 1.2893	* 1.1255	* 1.2796	* 0.6509 *
	* 1.5533	* 1.7203	* 1.8819	* 1.5797	* 1.6020	* 1.8326	* 1.6213	* 3.1685 *
9	* 1.1852	* 1.2124	* 1.2075	* 1.1548	* 1.3617	* 1.2023	* 1.2790	* 0.6061 *
	* 1.7203	* 1.6827	* 1.6881	* 1.7761	* 1.5127	* 1.7201	* 1.6218	* 3.4006 *
10	* 1.0811	* 1.2110	* 1.0591	* 1.2518	* 1.1898	* 1.3375	* 0.9082	*
	* 1.8819	* 1.6833	* 1.9236	* 1.6382	* 1.7279	* 1.5467	* 2.2736	*
11	* 1.3019	* 1.1448	* 1.2452	* 1.0655	* 1.1873	* 1.2507	* 0.6057	*
	* 1.5797	* 1.7911	* 1.6466	* 1.9144	* 1.7263	* 1.6471	* 3.3844	*
12	* 1.2893	* 1.3421	* 1.1784	* 1.1824	* 1.1826	* 0.6906	*	
	* 1.6019	* 1.5341	* 1.7439	* 1.7331	* 1.7319	* 2.9580	*	
13	* 1.1255	* 1.1831	* 1.3210	* 1.2410	* 0.6886	*		
	* 1.8326	* 1.7471	* 1.5652	* 1.6593	* 2.9659	*		
14	* 1.2796	* 1.2684	* 0.8967	* 0.5993	*			
	* 1.6213	* 1.6350	* 2.3019	* 3.4194	*			
15	* 0.6509	* 0.5845	* F-SUB-Q					
	* 3.1685	* 3.5247	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2122	* 1.1034	* 1.0093	* 1.2039	* 1.1903	* 1.0304	* 1.1420	* 0.5856 *
	* 1.6156	* 1.7699	* 1.9316	* 1.6331	* 1.6608	* 1.9176	* 1.7394	* 3.3771 *
9	* 1.1034	* 1.1377	* 1.1156	* 1.0836	* 1.2575	* 1.1041	* 1.1416	* 0.5484 *
	* 1.7699	* 1.7167	* 1.7501	* 1.8124	* 1.5675	* 1.7930	* 1.7400	* 3.6049 *
10	* 1.0093	* 1.1188	* 0.9919	* 1.1585	* 1.1089	* 1.2173	* 0.8250	*
	* 1.9316	* 1.7452	* 1.9669	* 1.6923	* 1.7746	* 1.6267	* 2.3992	*
11	* 1.2039	* 1.0746	* 1.1533	* 0.9942	* 1.0894	* 1.1380	* 0.5587	*
	* 1.6331	* 1.8270	* 1.6996	* 1.9652	* 1.8018	* 1.7335	* 3.5205	*
12	* 1.1903	* 1.2400	* 1.0988	* 1.0851	* 1.0856	* 0.6426	*	
	* 1.6608	* 1.5891	* 1.7903	* 1.8087	* 1.8069	* 3.0482	*	
13	* 1.0304	* 1.0871	* 1.2028	* 1.1294	* 0.6408	*		
	* 1.9176	* 1.8202	* 1.6455	* 1.7460	* 3.0567	*		
14	* 1.1420	* 1.1324	* 0.8149	* 0.5527	*			
	* 1.7394	* 1.7537	* 2.4281	* 3.5575	*			
15	* 0.5856	* 0.5307	* F-SUB-Q					
	* 3.3771	* 3.7235	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 286 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 50% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0714	* 0.9116	* 0.8486	* 1.0537	* 0.9794	* 0.8264	* 0.9136	* 0.4672 *
	* 1.7702	* 2.0757	* 2.2293	* 1.8041	* 1.9502	* 2.3166	* 2.1053	* 4.1056 *
9	* 0.9116	* 0.9615	* 0.9914	* 0.9151	* 1.0982	* 0.9088	* 0.8983	* 0.4400 *
	* 2.0757	* 1.9658	* 1.9053	* 2.0813	* 1.7390	* 2.1082	* 2.1410	* 4.3590 *
10	* 0.8486	* 0.9920	* 0.8483	* 1.0221	* 0.9276	* 1.0132	* 0.6604	*
	* 2.2293	* 1.9042	* 2.2261	* 1.8576	* 2.0522	* 1.8914	* 2.9052	*
11	* 1.0537	* 0.9051	* 1.0165	* 0.8352	* 0.9362	* 0.9145	* 0.4634	*
	* 1.8041	* 2.0996	* 1.8675	* 2.2658	* 2.0299	* 2.0884	* 4.1189	*
12	* 0.9794	* 1.0821	* 0.9199	* 0.9324	* 0.8923	* 0.5386	*	
	* 1.9502	* 1.7644	* 2.0690	* 2.0378	* 2.1290	* 3.5279	*	
13	* 0.8264	* 0.8957	* 1.0026	* 0.9079	* 0.5368	*		
	* 2.3166	* 2.1382	* 1.9108	* 2.1029	* 3.5389	*		
14	* 0.9136	* 0.8908	* 0.6528	* 0.4584	*			
	* 2.1053	* 2.1587	* 2.9382	* 4.1623	*			
15	* 0.4672	* 0.4312	* F-SUB-Q					
	* 4.1056	* 4.4455	* M-SUB-Q					

AT 50% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.4467	* 0.3996	* 0.3909	* 0.4543	* 0.4239	* 0.3695	* 0.3510	* 0.2065 *
	* 4.1088	* 4.5962	* 4.6952	* 4.0490	* 4.3609	* 5.0285	* 5.3077	* 9.0220 *
9	* 0.3996	* 0.4144	* 0.4382	* 0.4078	* 0.4508	* 0.3905	* 0.3435	* 0.1925 *
	* 4.5962	* 4.4239	* 4.1801	* 4.5233	* 4.1026	* 4.7543	* 5.4229	* 9.6809 *
10	* 0.3909	* 0.4383	* 0.3905	* 0.4387	* 0.4024	* 0.3993	* 0.2909	*
	* 4.6952	* 4.1791	* 4.6952	* 4.1885	* 4.5909	* 4.6463	* 6.3990	*
11	* 0.4543	* 0.4048	* 0.4372	* 0.3773	* 0.3981	* 0.3465	* 0.2055	*
	* 4.0490	* 4.5545	* 4.2024	* 4.8716	* 4.6297	* 5.3369	* 9.0233	*
12	* 0.4239	* 0.4456	* 0.3991	* 0.3965	* 0.3451	* 0.2475	*	
	* 4.3609	* 4.1494	* 4.6276	* 4.6472	* 5.3389	* 7.4580	*	
13	* 0.3695	* 0.3857	* 0.3953	* 0.3442	* 0.2465	*		
	* 5.0285	* 4.8133	* 4.6920	* 5.3702	* 7.4846	*		
14	* 0.3510	* 0.3408	* 0.2878	* 0.2034	*			
	* 5.3077	* 5.4652	* 6.4660	* 9.1135	*			
15	* 0.2065	* 0.1916	* F-SUB-Q					
	* 9.0220	* 9.7196	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 287 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.8833	* 0.8108	* 0.7456	* 0.8436	* 0.7835	* 0.6680	* 0.5176	* 0.2868
	* 3.4012	* 3.7258	* 4.0969	* 3.5674	* 3.8337	* 4.5620	* 4.8598	* 7.9639
9	* 0.8108	* 0.7854	* 0.8142	* 0.7657	* 0.8272	* 0.7062	* 0.5565	* 0.2888
	* 3.7258	* 3.8774	* 3.6749	* 3.9167	* 3.6309	* 4.2556	* 5.0036	* 8.4906
10	* 0.7456	* 0.8149	* 0.6784	* 0.7863	* 0.7363	* 0.7120	* 0.5156	*
	* 4.0969	* 3.6731	* 4.0233	* 3.7962	* 4.0789	* 4.1509	* 5.8168	*
11	* 0.8436	* 0.7602	* 0.7841	* 0.6673	* 0.7147	* 0.6258	* 0.3742	*
	* 3.5674	* 3.9441	* 3.7994	* 4.3302	* 4.0624	* 4.5829	* 7.5231	*
12	* 0.7835	* 0.8203	* 0.7332	* 0.7133	* 0.6174	* 0.4452	*	*
	* 3.8337	* 3.6596	* 4.0967	* 4.0698	* 4.6091	* 6.2022	*	*
13	* 0.6680	* 0.7007	* 0.7079	* 0.6232	* 0.4429	*	*	*
	* 4.5620	* 4.2845	* 4.1726	* 4.6001	* 6.2329	*	*	*
14	* 0.5176	* 0.5532	* 0.5123	* 0.3718	*	*	*	*
	* 4.8598	* 5.0237	* 5.8493	* 7.5690	*	*	*	*
15	* 0.2868	* 0.2867	* F-SUB-Q					
	* 7.9639	* 8.5440	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9541	* 1.7053	* 1.5207	* 1.7937	* 1.6772	* 1.4070	* 1.3100	* 0.6799
	* 1.6439	* 1.8907	* 2.1301	* 1.7863	* 1.9143	* 2.2781	* 2.1543	* 3.9191
9	* 1.7053	* 1.6784	* 1.7224	* 1.6046	* 1.8465	* 1.5155	* 1.3677	* 0.6563
	* 1.8907	* 1.9058	* 1.8545	* 2.0094	* 1.7375	* 2.1258	* 2.2110	* 4.2532
10	* 1.5207	* 1.7242	* 1.4444	* 1.6908	* 1.5628	* 1.6457	* 1.0951	*
	* 2.1301	* 1.8533	* 2.1016	* 1.8862	* 2.0401	* 1.9181	* 2.8988	*
11	* 1.7937	* 1.5975	* 1.6858	* 1.3777	* 1.5323	* 1.4542	* 0.7812	*
	* 1.7863	* 2.0179	* 1.8879	* 2.2287	* 2.0163	* 2.0998	* 3.8346	*
12	* 1.6772	* 1.8291	* 1.5554	* 1.5290	* 1.4195	* 0.8874	*	*
	* 1.9143	* 1.7530	* 2.0491	* 2.0203	* 2.1317	* 3.2880	*	*
13	* 1.4070	* 1.5032	* 1.6359	* 1.4481	* 0.8839	*	*	*
	* 2.2781	* 2.1419	* 1.9284	* 2.1077	* 3.3003	*	*	*
14	* 1.3100	* 1.3609	* 1.0875	* 0.7759	*	*	*	*
	* 2.1543	* 2.2201	* 2.9161	* 3.8593	*	*	*	*
15	* 0.6799	* 0.6461	* F-SUB-Q					
	* 3.9191	* 4.3164	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 288 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0426 *	* 1.9533 *	* 1.7591 *	* 1.9336 *	* 1.9131 *	* 1.6882 *	* 1.6612 *	* 0.9036 *
	* 1.6338 *	* 1.7148 *	* 1.9145 *	* 1.7232 *	* 1.7487 *	* 1.9786 *	* 1.9272 *	* 3.3721 *
9	* 1.9533 *	* 1.9428 *	* 1.8177 *	* 1.8282 *	* 1.9527 *	* 1.7623 *	* 1.6602 *	* 0.8430 *
	* 1.7148 *	* 1.7432 *	* 1.8489 *	* 1.8299 *	* 1.7118 *	* 1.9049 *	* 1.9513 *	* 3.6470 *
10	* 1.7591 *	* 1.8218 *	* 1.7049 *	* 1.8256 *	* 1.7936 *	* 1.8261 *	* 1.3348 *	
	* 1.9145 *	* 1.8458 *	* 1.9172 *	* 1.8161 *	* 1.8534 *	* 1.8018 *	* 2.4754 *	
11	* 1.9336 *	* 1.8194 *	* 1.8214 *	* 1.6333 *	* 1.6475 *	* 1.6936 *	* 0.9316 *	
	* 1.7232 *	* 1.8456 *	* 1.8195 *	* 2.0033 *	* 1.9508 *	* 1.8719 *	* 3.3487 *	
12	* 1.9131 *	* 1.9317 *	* 1.7850 *	* 1.6432 *	* 1.6181 *	* 1.0210 *		
	* 1.7487 *	* 1.7295 *	* 1.8625 *	* 1.9568 *	* 1.9385 *	* 2.9578 *		
13	* 1.6882 *	* 1.7453 *	* 1.8134 *	* 1.6860 *	* 1.0177 *			
	* 1.9786 *	* 1.9217 *	* 1.8112 *	* 1.8795 *	* 2.9667 *			
14	* 1.6612 *	* 1.6522 *	* 1.3251 *	* 0.9252 *				
	* 1.9272 *	* 1.9595 *	* 2.4912 *	* 3.3708 *				
15	* 0.9036 *	* 0.8316 *	F-SUB-Q					
	* 3.3721 *	* 3.6929 *	M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2364 *	* 2.1061 *	* 1.8966 *	* 2.1235 *	* 2.1031 *	* 1.8664 *	* 1.9371 *	* 1.0304 *
	* 1.5499 *	* 1.6514 *	* 1.8425 *	* 1.6353 *	* 1.6699 *	* 1.8614 *	* 1.7517 *	* 3.1732 *
9	* 2.1061 *	* 2.1076 *	* 2.0085 *	* 1.9706 *	* 2.1563 *	* 1.9438 *	* 1.9271 *	* 0.9395 *
	* 1.6514 *	* 1.6703 *	* 1.7397 *	* 1.7766 *	* 1.6159 *	* 1.7936 *	* 1.7719 *	* 3.4932 *
10	* 1.8966 *	* 2.0130 *	* 1.8145 *	* 2.0187 *	* 1.9540 *	* 2.0481 *	* 1.4641 *	
	* 1.8425 *	* 1.7360 *	* 1.8948 *	* 1.7167 *	* 1.7755 *	* 1.6738 *	* 2.3488 *	
11	* 2.1235 *	* 1.9602 *	* 2.0136 *	* 1.7569 *	* 1.8245 *	* 1.8908 *	* 0.9912 *	
	* 1.6353 *	* 1.7851 *	* 1.7203 *	* 1.9563 *	* 1.8307 *	* 1.7441 *	* 3.2815 *	
12	* 2.1031 *	* 2.1326 *	* 1.9436 *	* 1.8193 *	* 1.7877 *	* 1.0713 *		
	* 1.6699 *	* 1.6332 *	* 1.7853 *	* 1.8369 *	* 1.8256 *	* 2.9302 *		
13	* 1.8664 *	* 1.9228 *	* 2.0327 *	* 1.8818 *	* 1.0684 *			
	* 1.8614 *	* 1.8116 *	* 1.6833 *	* 1.7519 *	* 2.9376 *			
14	* 1.9371 *	* 1.9174 *	* 1.4525 *	* 0.9836 *				
	* 1.7517 *	* 1.7799 *	* 2.3656 *	* 3.3054 *				
15	* 1.0304 *	* 0.9240 *	F-SUB-Q					
	* 3.1732 *	* 3.5488 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 289 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2515	* 2.0960	* 1.8944	* 2.1549	* 2.1315	* 1.8925	* 2.0130	* 1.0757 *
	* 1.6102	* 1.7362	* 1.9151	* 1.6831	* 1.7067	* 1.9088	* 1.7705	* 3.2191 *
9	* 2.0960	* 2.0980	* 2.0206	* 1.9776	* 2.1870	* 1.9718	* 1.9970	* 0.9802 *
	* 1.7362	* 1.7404	* 1.7962	* 1.8342	* 1.6608	* 1.8364	* 1.7913	* 3.5400 *
10	* 1.8944	* 2.0254	* 1.8391	* 2.0537	* 1.9733	* 2.0933	* 1.5104	*
	* 1.9151	* 1.7921	* 1.9535	* 1.7561	* 1.8324	* 1.7032	* 2.3682	*
11	* 2.1549	* 1.9664	* 2.0480	* 1.7900	* 1.8618	* 1.9375	* 1.0170	*
	* 1.6831	* 1.8439	* 1.7604	* 2.0029	* 1.8746	* 1.7761	* 3.3333	*
12	* 2.1315	* 2.1616	* 1.9619	* 1.8562	* 1.8261	* 1.0946	*	
	* 1.7067	* 1.6793	* 1.8421	* 1.8815	* 1.8701	* 3.0014	*	
13	* 1.8925	* 1.9497	* 2.0765	* 1.9277	* 1.0917	*		
	* 1.9088	* 1.8549	* 1.7138	* 1.7846	* 3.0088	*		
14	* 2.0130	* 1.9862	* 1.4980	* 1.0092	*			
	* 1.7705	* 1.8002	* 2.3860	* 3.3579	*			
15	* 1.0757	* 0.9659	* F-SUB-Q					
	* 3.2191	* 3.5895	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.2190	* 2.0569	* 1.8634	* 2.1436	* 2.1208	* 1.8824	* 2.0285	* 1.0880 *
	* 1.6825	* 1.8145	* 1.9949	* 1.7294	* 1.7547	* 1.9748	* 1.8230	* 3.3278 *
9	* 2.0569	* 2.0568	* 1.9933	* 1.9553	* 2.1756	* 1.9650	* 2.0101	* 0.9930 *
	* 1.8145	* 1.8170	* 1.8682	* 1.8978	* 1.7065	* 1.8837	* 1.8415	* 3.6455 *
10	* 1.8634	* 1.9984	* 1.8255	* 2.0458	* 1.9603	* 2.0940	* 1.5204	*
	* 1.9949	* 1.8635	* 2.0355	* 1.8143	* 1.8837	* 1.7598	* 2.4164	*
11	* 2.1436	* 1.9435	* 2.0398	* 1.7876	* 1.8621	* 1.9433	* 1.0230	*
	* 1.7294	* 1.9087	* 1.8192	* 2.0683	* 1.9567	* 1.8502	* 3.4733	*
12	* 2.1208	* 2.1493	* 1.9482	* 1.8561	* 1.8296	* 1.1002	*	
	* 1.7547	* 1.7264	* 1.8946	* 1.9643	* 1.9482	* 3.1154	*	
13	* 1.8824	* 1.9437	* 2.0762	* 1.9329	* 1.0973	*		
	* 1.9748	* 1.9031	* 1.7722	* 1.8596	* 3.1233	*		
14	* 2.0285	* 1.9986	* 1.5073	* 1.0149	*			
	* 1.8230	* 1.8514	* 2.4361	* 3.5000	*			
15	* 1.0880	* 0.9791	* F-SUB-Q					
	* 3.3278	* 3.6942	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 290 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.1978	* 2.0274	* 1.8386	* 2.1410	* 2.1150	* 1.8743	* 2.0463	* 1.0862 *
	* 1.7468	* 1.8900	* 2.0746	* 1.7791	* 1.8050	* 2.0286	* 1.8604	* 3.4478 *
9	* 2.0274	* 2.0352	* 1.9811	* 1.9382	* 2.1779	* 1.9635	* 2.0283	* 0.9873 *
	* 1.8900	* 1.8811	* 1.9271	* 1.9650	* 1.7509	* 1.9333	* 1.8753	* 3.7868 *
10	* 1.8386	* 1.9863	* 1.7922	* 2.0452	* 1.9524	* 2.1074	* 1.5104	*
	* 2.0746	* 1.9223	* 2.1280	* 1.8562	* 1.9421	* 1.7968	* 2.4903	*
11	* 2.1410	* 1.9260	* 2.0387	* 1.7656	* 1.8701	* 1.9572	* 1.0100	*
	* 1.7791	* 1.9768	* 1.8616	* 2.1443	* 2.0052	* 1.9141	* 3.6512	*
12	* 2.1150	* 2.1511	* 1.9395	* 1.8638	* 1.8414	* 1.0906	*	
	* 1.8050	* 1.7717	* 1.9541	* 2.0122	* 2.0208	* 3.3032	*	
13	* 1.8743	* 1.9407	* 2.0889	* 1.9463	* 1.0878	*		
	* 2.0286	* 1.9542	* 1.8101	* 1.9238	* 3.3109	*		
14	* 2.0463	* 2.0163	* 1.4968	* 1.0013	*			
	* 1.8604	* 1.8858	* 2.5113	* 3.6804	*			
15	* 1.0861	* 0.9714	* F-SUB-Q					
	* 3.4478	* 3.8457	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.1313	* 1.9642	* 1.7839	* 2.0916	* 2.0688	* 1.8321	* 2.0132	* 1.0676 *
	* 1.8625	* 2.0190	* 2.2145	* 1.8850	* 1.9115	* 2.1539	* 1.9550	* 3.6169 *
9	* 1.9642	* 1.9778	* 1.9252	* 1.8875	* 2.1299	* 1.9241	* 1.9953	* 0.9709 *
	* 2.0190	* 2.0072	* 2.0542	* 2.0891	* 1.8530	* 2.0425	* 1.9728	* 3.9737 *
10	* 1.7839	* 1.9304	* 1.7428	* 1.9997	* 1.9082	* 2.0698	* 1.4831	*
	* 2.2145	* 2.0488	* 2.2732	* 1.9665	* 2.0548	* 1.8896	* 2.6319	*
11	* 2.0916	* 1.8749	* 1.9930	* 1.7260	* 1.8365	* 1.9250	* 0.9913	*
	* 1.8850	* 2.1024	* 1.9737	* 2.2754	* 2.1074	* 2.0080	* 3.8424	*
12	* 2.0688	* 2.1030	* 1.8949	* 1.8289	* 1.8105	* 1.0721	*	
	* 1.9115	* 1.8757	* 2.0683	* 2.1160	* 2.1191	* 3.5271	*	
13	* 1.8321	* 1.9011	* 2.0525	* 1.9137	* 1.0694	*		
	* 2.1539	* 2.0657	* 1.9043	* 2.0188	* 3.5348	*		
14	* 2.0132	* 1.9829	* 1.4692	* 0.9823	*			
	* 1.9550	* 1.9843	* 2.6552	* 3.8750	*			
15	* 1.0676	* 0.9554	* F-SUB-Q					
	* 3.6169	* 4.0346	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 291 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 2.0962	* 1.9232	* 1.7470	* 2.0699	* 2.0424	* 1.8048	* 2.0035	* 1.0483
	* 1.9641	* 2.1367	* 2.3419	* 1.9738	* 2.0035	* 2.2577	* 2.0334	* 3.8213
9	* 1.9232	* 1.9421	* 1.9000	* 1.8535	* 2.1121	* 1.9018	* 1.9866	* 0.9493
	* 2.1367	* 2.1131	* 2.1549	* 2.2032	* 1.9356	* 2.1376	* 2.0498	* 4.2145
10	* 1.7470	* 1.9051	* 1.6934	* 1.9802	* 1.8812	* 2.0593	* 1.4512	*
	* 2.3419	* 2.1493	* 2.3985	* 2.0530	* 2.1596	* 1.9691	* 2.7781	*
11	* 2.0699	* 1.8407	* 1.9733	* 1.6842	* 1.8258	* 1.9156	* 0.9633	*
	* 1.9738	* 2.2176	* 2.0608	* 2.4092	* 2.2001	* 2.0951	* 4.1030	*
12	* 2.0424	* 2.0851	* 1.8673	* 1.8173	* 1.8014	* 1.0480	*	*
	* 2.0035	* 1.9594	* 2.1744	* 2.2093	* 2.2126	* 3.7544	*	*
13	* 1.8048	* 1.8781	* 2.0401	* 1.9039	* 1.0455	*	*	*
	* 2.2577	* 2.1628	* 1.9849	* 2.1067	* 3.7619	*	*	*
14	* 2.0035	* 1.9739	* 1.4367	* 0.9552	*	*	*	*
	* 2.0334	* 2.0621	* 2.8039	* 4.1346	*	*	*	*
15	* 1.0483	* 0.9304	* F-SUB-Q					
	* 3.8213	* 4.2958	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9591	* 1.8088	* 1.6460	* 1.9437	* 1.9319	* 1.7088	* 1.8853	* 1.0081
	* 2.2067	* 2.3862	* 2.6111	* 2.2052	* 2.2204	* 2.4984	* 2.2543	* 4.1340
9	* 1.8088	* 1.8286	* 1.7725	* 1.7626	* 1.9843	* 1.7999	* 1.8675	* 0.9255
	* 2.3862	* 2.3548	* 2.4245	* 2.4354	* 2.1595	* 2.3670	* 2.2764	* 4.4997
10	* 1.6460	* 1.7777	* 1.6285	* 1.8608	* 1.7803	* 1.9395	* 1.4040	*
	* 2.6111	* 2.4175	* 2.6328	* 2.2894	* 2.3944	* 2.1892	* 3.0053	*
11	* 1.9437	* 1.7422	* 1.8539	* 1.6248	* 1.7182	* 1.8033	* 0.9443	*
	* 2.2052	* 2.4626	* 2.2982	* 2.6199	* 2.4532	* 2.3348	* 4.3892	*
12	* 1.9319	* 1.9533	* 1.7667	* 1.7104	* 1.6963	* 1.0247	*	*
	* 2.2204	* 2.1939	* 2.4113	* 2.4638	* 2.4665	* 4.0326	*	*
13	* 1.7088	* 1.7768	* 1.9220	* 1.7919	* 1.0218	*	*	*
	* 2.4984	* 2.3954	* 2.2072	* 2.3480	* 4.0423	*	*	*
14	* 1.8853	* 1.8550	* 1.3898	* 0.9354	*	*	*	*
	* 2.2543	* 2.2906	* 3.0332	* 4.4269	*	*	*	*
15	* 1.0081	* 0.9101	* F-SUB-Q					
	* 4.1340	* 4.5718	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 292 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.9379	* 1.7759	* 1.6153	* 1.9322	* 1.9107	* 1.6846	* 1.8849	* 0.9832
	* 2.3326	* 2.5400	* 2.7805	* 2.3379	* 2.3675	* 2.6721	* 2.3813	* 4.4739
9	* 1.7759	* 1.8007	* 1.7621	* 1.7217	* 1.9755	* 1.7825	* 1.8693	* 0.8923
	* 2.5400	* 2.5055	* 2.5521	* 2.6219	* 2.2858	* 2.5164	* 2.4006	* 4.9235
10	* 1.6153	* 1.7670	* 1.5736	* 1.8508	* 1.7574	* 1.9369	* 1.3612	*
	* 2.7805	* 2.5454	* 2.8502	* 2.4189	* 2.5516	* 2.3051	* 3.2618	*
11	* 1.9322	* 1.7090	* 1.8437	* 1.5734	* 1.7163	* 1.8035	* 0.9040	*
	* 2.3379	* 2.6403	* 2.4285	* 2.8470	* 2.5765	* 2.4482	* 4.7997	*
12	* 1.9107	* 1.9492	* 1.7434	* 1.7077	* 1.6960	* 0.9871	*	*
	* 2.3675	* 2.3157	* 2.5701	* 2.5877	* 2.5832	* 4.3730	*	*
13	* 1.6846	* 1.7585	* 1.9187	* 1.7917	* 0.9848	*	*	*
	* 2.6721	* 2.5477	* 2.3244	* 2.4622	* 4.3813	*	*	*
14	* 1.8849	* 1.8565	* 1.3467	* 0.8959	*	*	*	*
	* 2.3813	* 2.4157	* 3.2932	* 4.8378	*	*	*	*
15	* 0.9832	* 0.8744	* F-SUB-Q					
	* 4.4739	* 5.0188	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.8549	* 1.6989	* 1.5469	* 1.8592	* 1.8391	* 1.6198	* 1.8194	* 0.9486
	* 2.3507	* 2.5602	* 2.7998	* 2.3458	* 2.3897	* 2.7060	* 2.4295	* 4.6005
9	* 1.6989	* 1.7268	* 1.6890	* 1.6526	* 1.9020	* 1.7174	* 1.8038	* 0.8625
	* 2.5602	* 2.5200	* 2.5680	* 2.6354	* 2.2992	* 2.5566	* 2.4466	* 5.0534
10	* 1.5469	* 1.6938	* 1.5109	* 1.7829	* 1.6911	* 1.8693	* 1.3140	*
	* 2.7998	* 2.5611	* 2.8667	* 2.4376	* 2.5778	* 2.3485	* 3.3275	*
11	* 1.8592	* 1.6400	* 1.7752	* 1.5169	* 1.6569	* 1.7417	* 0.8744	*
	* 2.3458	* 2.6545	* 2.4481	* 2.8537	* 2.6182	* 2.4982	* 4.9282	*
12	* 1.8391	* 1.8752	* 1.6770	* 1.6483	* 1.6383	* 0.9556	*	*
	* 2.3897	* 2.3291	* 2.5982	* 2.6310	* 2.6341	* 4.4858	*	*
13	* 1.6198	* 1.6935	* 1.8512	* 1.7299	* 0.9533	*	*	*
	* 2.7060	* 2.5906	* 2.3700	* 2.5141	* 4.4956	*	*	*
14	* 1.8194	* 1.7911	* 1.2999	* 0.8660	*	*	*	*
	* 2.4295	* 2.4631	* 3.3618	* 4.9733	*	*	*	*
15	* 0.9486	* 0.8470	* F-SUB-Q					
	* 4.6005	* 5.1407	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 293 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.7327	* 1.5937	* 1.4531	* 1.7438	* 1.7343	* 1.5281	* 1.7105	* 0.9046 *
	* 2.4163	* 2.6208	* 2.8620	* 2.4023	* 2.4353	* 2.7574	* 2.4875	* 4.6474 *
9	* 1.5937	* 1.6218	* 1.5763	* 1.5642	* 1.7872	* 1.6200	* 1.6949	* 0.8311 *
	* 2.6208	* 2.5772	* 2.6420	* 2.6790	* 2.3570	* 2.6038	* 2.5057	* 5.0501 *
10	* 1.4531	* 1.5812	* 1.4371	* 1.6746	* 1.5950	* 1.7597	* 1.2579	*
	* 2.8620	* 2.6343	* 2.8942	* 2.4908	* 2.6238	* 2.3955	* 3.3401	*
11	* 1.7438	* 1.5449	* 1.6666	* 1.4481	* 1.5579	* 1.6383	* 0.8442	*
	* 2.4023	* 2.7095	* 2.5021	* 2.8687	* 2.6702	* 2.5467	* 4.8931	*
12	* 1.7343	* 1.7563	* 1.5812	* 1.5495	* 1.5414	* 0.9222	*	
	* 2.4353	* 2.3887	* 2.6452	* 2.6833	* 2.6823	* 4.4497	*	
13	* 1.5281	* 1.5969	* 1.7420	* 1.6268	* 0.9197	*		
	* 2.7574	* 2.6395	* 2.4182	* 2.5636	* 4.4607	*		
14	* 1.7105	* 1.6824	* 1.2439	* 0.8353	*			
	* 2.4875	* 2.5235	* 3.3757	* 4.9430	*			
15	* 0.9046	* 0.8167	* F-SUB-Q					
	* 4.6474	* 5.1342	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6881	* 1.5413	* 1.4051	* 1.7053	* 1.6892	* 1.4844	* 1.6842	* 0.8695 *
	* 2.3305	* 2.5474	* 2.7768	* 2.3075	* 2.3497	* 2.6577	* 2.3564	* 4.4565 *
9	* 1.5413	* 1.5726	* 1.5426	* 1.5067	* 1.7506	* 1.5810	* 1.6711	* 0.7903 *
	* 2.5474	* 2.4968	* 2.5344	* 2.6044	* 2.2531	* 2.5016	* 2.3720	* 4.8962 *
10	* 1.4051	* 1.5471	* 1.3780	* 1.6404	* 1.5502	* 1.7303	* 1.2020	*
	* 2.7768	* 2.5276	* 2.8195	* 2.3837	* 2.5317	* 2.2851	* 3.2552	*
11	* 1.7053	* 1.4943	* 1.6322	* 1.3809	* 1.5316	* 1.6136	* 0.7962	*
	* 2.3075	* 2.6239	* 2.3943	* 2.8092	* 2.5397	* 2.4165	* 4.8061	*
12	* 1.6892	* 1.7248	* 1.5362	* 1.5231	* 1.5171	* 0.8769	*	
	* 2.3497	* 2.2824	* 2.5523	* 2.5522	* 2.5408	* 4.3352	*	
13	* 1.4844	* 1.5574	* 1.7123	* 1.6018	* 0.8749	*		
	* 2.6577	* 2.5360	* 2.3064	* 2.4321	* 4.3436	*		
14	* 1.6842	* 1.6585	* 1.1879	* 0.7884	*			
	* 2.3564	* 2.3883	* 3.2901	* 4.8488	*			
15	* 0.8696	* 0.7736	* F-SUB-Q					
	* 4.4565	* 4.9949	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 294 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.6114	* 1.4659	* 1.3372	* 1.6326	* 1.6163	* 1.4183	* 1.6201	* 0.8303
	* 2.1550	* 2.3629	* 2.5735	* 2.1300	* 2.1700	* 2.4578	* 2.1650	* 4.1310
9	* 1.4659	* 1.4993	* 1.4739	* 1.4365	* 1.6778	* 1.5149	* 1.6081	* 0.7533
	* 2.3629	* 2.3100	* 2.3403	* 2.4130	* 2.0770	* 2.3086	* 2.1794	* 4.5473
10	* 1.3372	* 1.4782	* 1.3144	* 1.5728	* 1.4820	* 1.6638	* 1.1457	*
	* 2.5735	* 2.3340	* 2.6082	* 2.1981	* 2.3419	* 2.1032	* 3.0229	*
11	* 1.6326	* 1.4243	* 1.5646	* 1.3194	* 1.4723	* 1.5529	* 0.7564	*
	* 2.1300	* 2.4318	* 2.2084	* 2.5975	* 2.3379	* 2.2225	* 4.4820	*
12	* 1.6163	* 1.6535	* 1.4681	* 1.4638	* 1.4597	* 0.8362	*	*
	* 2.1700	* 2.1047	* 2.3618	* 2.3499	* 2.3362	* 4.0222	*	*
13	* 1.4183	* 1.4915	* 1.6459	* 1.5412	* 0.8339	*	*	*
	* 2.4578	* 2.3417	* 2.1236	* 2.2374	* 4.0317	*	*	*
14	* 1.6201	* 1.5956	* 1.1318	* 0.7489	*	*	*	*
	* 2.1650	* 2.1950	* 3.0566	* 4.5227	*	*	*	*
15	* 0.8303	* 0.7365	* F-SUB-Q					
	* 4.1310	* 4.6445	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.5240	* 1.3874	* 1.2660	* 1.5494	* 1.5356	* 1.3460	* 1.5398	* 0.7905
	* 2.0055	* 2.1971	* 2.3935	* 1.9788	* 2.0151	* 2.2866	* 2.0143	* 3.8437
9	* 1.3874	* 1.4207	* 1.3954	* 1.3614	* 1.5942	* 1.4394	* 1.5283	* 0.7196
	* 2.1971	* 2.1463	* 2.1768	* 2.2450	* 1.9304	* 2.1452	* 2.0275	* 4.2175
10	* 1.2660	* 1.3996	* 1.2457	* 1.4944	* 1.4075	* 1.5826	* 1.0923	*
	* 2.3935	* 2.1708	* 2.4257	* 2.0402	* 2.1747	* 1.9517	* 2.8021	*
11	* 1.5494	* 1.3496	* 1.4864	* 1.2528	* 1.4001	* 1.4770	* 0.7233	*
	* 1.9788	* 2.2629	* 2.0500	* 2.4119	* 2.1723	* 2.0658	* 4.1477	*
12	* 1.5356	* 1.5691	* 1.3939	* 1.3918	* 1.3888	* 0.8004	*	*
	* 2.0151	* 1.9566	* 2.1938	* 2.1838	* 2.1730	* 3.7190	*	*
13	* 1.3460	* 1.4165	* 1.5651	* 1.4656	* 0.7985	*	*	*
	* 2.2866	* 2.1768	* 1.9713	* 2.0801	* 3.7264	*	*	*
14	* 1.5398	* 1.5161	* 1.0787	* 0.7159	*	*	*	*
	* 2.0143	* 2.0425	* 2.8343	* 4.1869	*	*	*	*
15	* 0.7905	* 0.7040	* F-SUB-Q					
	* 3.8437	* 4.3044	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 295 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.4143	* 1.2959	* 1.1839	* 1.4438	* 1.4372	* 1.2602	* 1.4337	* 0.7489 *
	* 1.9115	* 2.0790	* 2.2635	* 1.8788	* 1.9062	* 2.1652	* 1.9233	* 3.6200 *
9	* 1.2959	* 1.3280	* 1.2945	* 1.2807	* 1.4860	* 1.3464	* 1.4215	* 0.6894 *
	* 2.0790	* 2.0311	* 2.0751	* 2.1167	* 1.8382	* 2.0310	* 1.9369	* 3.9258 *
10	* 1.1839	* 1.2986	* 1.1777	* 1.3937	* 1.3186	* 1.4759	* 1.0404	*
	* 2.2634	* 2.0692	* 2.2746	* 1.9361	* 2.0541	* 1.8521	* 2.6094	*
11	* 1.4438	* 1.2635	* 1.3860	* 1.1919	* 1.3053	* 1.3764	* 0.6974	*
	* 1.8788	* 2.1405	* 1.9457	* 2.2474	* 2.0560	* 1.9540	* 3.8005	*
12	* 1.4372	* 1.4579	* 1.3056	* 1.2974	* 1.2952	* 0.7684	*	
	* 1.9062	* 1.8640	* 2.0726	* 2.0672	* 2.0510	* 3.4085	*	
13	* 1.2602	* 1.3247	* 1.4591	* 1.3655	* 0.7663	*		
	* 2.1652	* 2.0616	* 1.8712	* 1.9680	* 3.4164	*		
14	* 1.4337	* 1.4097	* 1.0275	* 0.6892	*			
	* 1.9233	* 1.9519	* 2.6397	* 3.8424	*			
15	* 0.7489	* 0.6771	* F-SUB-Q					
	* 3.6200	* 3.9919	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3891	* 1.2567	* 1.1471	* 1.4154	* 1.3985	* 1.2212	* 1.4098	* 0.7151 *
	* 1.7148	* 1.8896	* 2.0603	* 1.6931	* 1.7296	* 1.9735	* 1.7321	* 3.3644 *
9	* 1.2567	* 1.2916	* 1.2735	* 1.2348	* 1.4571	* 1.3112	* 1.3998	* 0.6501 *
	* 1.8896	* 1.8429	* 1.8625	* 1.9340	* 1.6501	* 1.8421	* 1.7412	* 3.6950 *
10	* 1.1471	* 1.2771	* 1.1304	* 1.3671	* 1.2803	* 1.4499	* 0.9872	*
	* 2.0603	* 1.8573	* 2.0923	* 1.7441	* 1.8676	* 1.6655	* 2.4323	*
11	* 1.4154	* 1.2236	* 1.3594	* 1.1397	* 1.2835	* 1.3549	* 0.6515	*
	* 1.6931	* 1.9503	* 1.7530	* 2.0723	* 1.8508	* 1.7590	* 3.6053	*
12	* 1.3985	* 1.4353	* 1.2673	* 1.2756	* 1.2746	* 0.7251	*	
	* 1.7296	* 1.6732	* 1.8850	* 1.8612	* 1.8489	* 3.2142	*	
13	* 1.2212	* 1.2894	* 1.4331	* 1.3440	* 0.7230	*		
	* 1.9735	* 1.8709	* 1.6832	* 1.7718	* 3.2222	*		
14	* 1.4098	* 1.3881	* 0.9744	* 0.6446	*			
	* 1.7321	* 1.7549	* 2.4620	* 3.6407	*			
15	* 0.7151	* 0.6351	* F-SUB-Q					
	* 3.3644	* 3.7773	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 296 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.3186	* 1.1922	* 1.0878	* 1.3411	* 1.3258	* 1.1558	* 1.3341	* 0.6751 *
	* 1.6248	* 1.7904	* 1.9536	* 1.6082	* 1.6400	* 1.8729	* 1.6380	* 3.1873 *
9	* 1.1922	* 1.2261	* 1.2083	* 1.1699	* 1.3818	* 1.2421	* 1.3254	* 0.6144 *
	* 1.7904	* 1.7436	* 1.7647	* 1.8370	* 1.5663	* 1.7491	* 1.6475	* 3.4989 *
10	* 1.0878	* 1.2119	* 1.0708	* 1.2951	* 1.2133	* 1.3738	* 0.9330	*
	* 1.9536	* 1.7598	* 1.9850	* 1.6577	* 1.7752	* 1.5836	* 2.3157	*
11	* 1.3411	* 1.1590	* 1.2878	* 1.0798	* 1.2162	* 1.2841	* 0.6155	*
	* 1.6082	* 1.8529	* 1.6662	* 1.9698	* 1.7635	* 1.6763	* 3.4503	*
12	* 1.3258	* 1.3608	* 1.2008	* 1.2085	* 1.2081	* 0.6869	*	
	* 1.6400	* 1.5887	* 1.7921	* 1.7735	* 1.7639	* 3.0750	*	
13	* 1.1558	* 1.2211	* 1.3576	* 1.2735	* 0.6849	*		
	* 1.8729	* 1.7770	* 1.6007	* 1.6887	* 3.0826	*		
14	* 1.3341	* 1.3140	* 0.9206	* 0.6089	*			
	* 1.6380	* 1.6608	* 2.3446	* 3.4848	*			
15	* 0.6751	* 0.5997	* F-SUB-Q					
	* 3.1873	* 3.5797	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.2551	* 1.1319	* 1.0318	* 1.2633	* 1.2505	* 1.0897	* 1.2494	* 0.6327 *
	* 1.5679	* 1.7318	* 1.8928	* 1.5679	* 1.5956	* 1.8242	* 1.6035	* 3.1196 *
9	* 1.1319	* 1.1615	* 1.1494	* 1.1071	* 1.3091	* 1.1691	* 1.2472	* 0.5901 *
	* 1.7318	* 1.6893	* 1.7039	* 1.7840	* 1.5186	* 1.7068	* 1.6054	* 3.3432 *
10	* 1.0318	* 1.1528	* 1.0126	* 1.2184	* 1.1458	* 1.2956	* 0.8787	*
	* 1.8928	* 1.6991	* 1.9293	* 1.6194	* 1.7277	* 1.5417	* 2.2598	*
11	* 1.2633	* 1.0969	* 1.2115	* 1.0191	* 1.1429	* 1.2106	* 0.5803	*
	* 1.5679	* 1.7995	* 1.6278	* 1.9194	* 1.7265	* 1.6363	* 3.3732	*
12	* 1.2505	* 1.2893	* 1.1340	* 1.1357	* 1.1394	* 0.6620	*	
	* 1.5956	* 1.5405	* 1.7441	* 1.7334	* 1.7225	* 2.9444	*	
13	* 1.0897	* 1.1493	* 1.2787	* 1.2006	* 0.6600	*		
	* 1.8242	* 1.7341	* 1.5604	* 1.6485	* 2.9519	*		
14	* 1.2494	* 1.2366	* 0.8671	* 0.5739	*			
	* 1.6035	* 1.6182	* 2.2879	* 3.4075	*			
15	* 0.6327	* 0.5641	* F-SUB-Q					
	* 3.1196	* 3.4927	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 297 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.1852 *	* 1.0664 *	* 0.9715 *	* 1.1742 *	* 1.1642 *	* 1.0145 *	* 1.1539 *	* 0.5828 *
	* 1.5533 *	* 1.7203 *	* 1.8819 *	* 1.5797 *	* 1.6020 *	* 1.8326 *	* 1.6213 *	* 3.1685 *
9	* 1.0664 *	* 1.0908 *	* 1.0854 *	* 1.0405 *	* 1.2285 *	* 1.0848 *	* 1.1534 *	* 0.5425 *
	* 1.7203 *	* 1.6827 *	* 1.6881 *	* 1.7761 *	* 1.5127 *	* 1.7201 *	* 1.6218 *	* 3.4006 *
10	* 0.9715 *	* 1.0886 *	* 0.9508 *	* 1.1266 *	* 1.0719 *	* 1.2069 *	* 0.8172 *	
	* 1.8819 *	* 1.6833 *	* 1.9236 *	* 1.6382 *	* 1.7279 *	* 1.5467 *	* 2.2736 *	
11	* 1.1742 *	* 1.0312 *	* 1.1203 *	* 0.9571 *	* 1.0671 *	* 1.1251 *	* 0.5419 *	
	* 1.5797 *	* 1.7911 *	* 1.6466 *	* 1.9144 *	* 1.7263 *	* 1.6471 *	* 3.3844 *	
12	* 1.1642 *	* 1.2103 *	* 1.0613 *	* 1.0625 *	* 1.0606 *	* 0.6173 *		
	* 1.6019 *	* 1.5341 *	* 1.7439 *	* 1.7331 *	* 1.7319 *	* 2.9580 *		
13	* 1.0145 *	* 1.0668 *	* 1.1914 *	* 1.1160 *	* 0.6154 *			
	* 1.8326 *	* 1.7471 *	* 1.5652 *	* 1.6593 *	* 2.9659 *			
14	* 1.1539 *	* 1.1435 *	* 0.8063 *	* 0.5359 *				
	* 1.6213 *	* 1.6350 *	* 2.3019 *	* 3.4194 *				
15	* 0.5828 *	* 0.5230 *	F-SUB-Q					
	* 3.1685 *	* 3.5247 *	M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 1.0818 *	* 0.9837 *	* 0.8987 *	* 1.0755 *	* 1.0645 *	* 0.9199 *	* 1.0195 *	* 0.5192 *
	* 1.6156 *	* 1.7699 *	* 1.9316 *	* 1.6331 *	* 1.6608 *	* 1.9176 *	* 1.7394 *	* 3.3771 *
9	* 0.9837 *	* 1.0143 *	* 0.9937 *	* 0.9672 *	* 1.1237 *	* 0.9863 *	* 1.0191 *	* 0.4861 *
	* 1.7699 *	* 1.7167 *	* 1.7501 *	* 1.8124 *	* 1.5675 *	* 1.7930 *	* 1.7400 *	* 3.6049 *
10	* 0.8987 *	* 0.9966 *	* 0.8825 *	* 1.0327 *	* 0.9895 *	* 1.0876 *	* 0.7350 *	
	* 1.9316 *	* 1.7452 *	* 1.9669 *	* 1.6923 *	* 1.7746 *	* 1.6267 *	* 2.3992 *	
11	* 1.0755 *	* 0.9590 *	* 1.0278 *	* 0.8848 *	* 0.9697 *	* 1.0135 *	* 0.4951 *	
	* 1.6331 *	* 1.8270 *	* 1.6996 *	* 1.9652 *	* 1.8018 *	* 1.7335 *	* 3.5205 *	
12	* 1.0645 *	* 1.1077 *	* 0.9802 *	* 0.9656 *	* 0.9640 *	* 0.5688 *		
	* 1.6608 *	* 1.5891 *	* 1.7903 *	* 1.8087 *	* 1.8069 *	* 3.0482 *		
13	* 0.9199 *	* 0.9707 *	* 1.0742 *	* 1.0055 *	* 0.5670 *			
	* 1.9176 *	* 1.8202 *	* 1.6455 *	* 1.7460 *	* 3.0567 *			
14	* 1.0195 *	* 1.0106 *	* 0.7256 *	* 0.4895 *				
	* 1.7394 *	* 1.7537 *	* 2.4281 *	* 3.5575 *				
15	* 0.5192 *	* 0.4702 *	F-SUB-Q					
	* 3.3771 *	* 3.7235 *	M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 298 of 306

TABLE A-4 (CONTINUED)

F-SUB-Q & M-SUB-Q VALUES (F-SUB-Q OP MARGIN) - POWER ESCALATION

AT 30% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.9481	* 0.8051	* 0.7494	* 0.9322	* 0.8671	* 0.7308	* 0.8070	* 0.4100 *
	* 1.7702	* 2.0757	* 2.2293	* 1.8041	* 1.9502	* 2.3166	* 2.1053	* 4.1056 *
9	* 0.8051	* 0.8489	* 0.8749	* 0.8101	* 0.9726	* 0.8037	* 0.7933	* 0.3862 *
	* 2.0757	* 1.9658	* 1.9053	* 2.0813	* 1.7390	* 2.1082	* 2.1410	* 4.3590 *
10	* 0.7494	* 0.8754	* 0.7486	* 0.9029	* 0.8203	* 0.8960	* 0.5826	*
	* 2.2293	* 1.9042	* 2.2261	* 1.8576	* 2.0522	* 1.8914	* 2.9052	*
11	* 0.9322	* 0.8004	* 0.8977	* 0.7365	* 0.8250	* 0.8066	* 0.4067	*
	* 1.8041	* 2.0996	* 1.8675	* 2.2658	* 2.0299	* 2.0884	* 4.1189	*
12	* 0.8671	* 0.9580	* 0.8132	* 0.8215	* 0.7851	* 0.4723	*	
	* 1.9502	* 1.7644	* 2.0690	* 2.0378	* 2.1290	* 3.5279	*	
13	* 0.7308	* 0.7918	* 0.8862	* 0.8005	* 0.4707	*		
	* 2.3166	* 2.1382	* 1.9108	* 2.1029	* 3.5389	*		
14	* 0.8070	* 0.7864	* 0.5756	* 0.4021	*			
	* 2.1053	* 2.1587	* 2.9382	* 4.1623	*			
15	* 0.4100	* 0.3784	* F-SUB-Q					
	* 4.1056	* 4.4455	* M-SUB-Q					

AT 30% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8	* 0.3893	* 0.3483	* 0.3403	* 0.3959	* 0.3698	* 0.3221	* 0.3052	* 0.1787 *
	* 4.1088	* 4.5962	* 4.6952	* 4.0490	* 4.3609	* 5.0285	* 5.3077	* 9.0220 *
9	* 0.3483	* 0.3607	* 0.3812	* 0.3555	* 0.3931	* 0.3405	* 0.2988	* 0.1666 *
	* 4.5962	* 4.4239	* 4.1801	* 4.5233	* 4.1026	* 4.7543	* 5.4229	* 9.6809 *
10	* 0.3403	* 0.3813	* 0.3400	* 0.3817	* 0.3505	* 0.3476	* 0.2529	*
	* 4.6952	* 4.1791	* 4.6952	* 4.1885	* 4.5909	* 4.6463	* 6.3990	*
11	* 0.3959	* 0.3528	* 0.3803	* 0.3282	* 0.3457	* 0.3008	* 0.1779	*
	* 4.0490	* 4.5545	* 4.2024	* 4.8716	* 4.6297	* 5.3369	* 9.0233	*
12	* 0.3698	* 0.3885	* 0.3476	* 0.3443	* 0.2989	* 0.2141	*	
	* 4.3609	* 4.1494	* 4.6276	* 4.6472	* 5.3389	* 7.4580	*	
13	* 0.3221	* 0.3361	* 0.3440	* 0.2986	* 0.2132	*		
	* 5.0285	* 4.8133	* 4.6920	* 5.3702	* 7.4846	*		
14	* 0.3052	* 0.2963	* 0.2501	* 0.1760	*			
	* 5.3077	* 5.4652	* 6.4660	* 9.1135	*			
15	* 0.1787	* 0.1659	* F-SUB-Q					
	* 9.0220	* 9.7196	* M-SUB-Q					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 299 of 306

TABLE A-5

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 24 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	3.3476	3.3961	3.5166	3.4238	3.5012	3.9623	4.4597	6.4938
9*	3.3961	3.3986	3.3769	3.4985	3.5119	3.7972	4.5833	6.6308
10*	3.5166	3.3755	3.4386	3.4985	3.6071	4.0547	4.8940	
11*	3.4238	3.4996	3.4994	3.6855	3.9274	4.5201	6.1094	
12*	3.5012	3.5267	3.6147	3.9303	4.4917	5.2591		
13*	3.9623	3.8142	4.0658	4.5292	5.2688			
14*	4.4597	4.5948	4.9122	6.1300				
15 *	6.4938	6.6823						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 23 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6439	1.7639	1.9001	1.7522	1.7870	2.0426	2.0365	3.2746
9*	1.7639	1.7284	1.7532	1.8269	1.7088	1.9387	2.0827	3.4109
10*	1.9001	1.7523	1.8676	1.7891	1.8735	1.9037	2.5095	
11*	1.7522	1.8285	1.7895	1.9662	1.9782	2.0987	3.1706	
12*	1.7870	1.7184	1.8770	1.9799	2.1023	2.8635		
13*	2.0426	1.9478	1.9086	2.1027	2.8662			
14*	2.0365	2.0878	2.5193	3.1836				
15 *	3.2746	3.4676						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 22 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6124	1.5871	1.7114	1.6694	1.6110	1.7702	1.8158	2.8129
9*	1.5871	1.5788	1.7461	1.6568	1.6560	1.7138	1.8357	2.9207
10*	1.7114	1.7438	1.6991	1.7144	1.6800	1.7607	2.1397	
11*	1.6694	1.6617	1.7161	1.7619	1.8952	1.8485	2.7412	
12*	1.6110	1.6688	1.6843	1.8976	1.8940	2.5582		
13*	1.7703	1.7233	1.7672	1.8526	2.5588			
14*	1.8158	1.8410	2.1489	2.7530				
15 *	2.8129	2.9620						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 21 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.4983	1.4939	1.6217	1.5484	1.4931	1.6387	1.6249	2.6151
9*	1.4939	1.4915	1.6251	1.5674	1.5280	1.5878	1.6417	2.7649
10*	1.6217	1.6222	1.6531	1.5940	1.5750	1.5995	2.0016	
11*	1.5484	1.5729	1.5961	1.6935	1.7466	1.6868	2.6374	
12*	1.4931	1.5406	1.5799	1.7493	1.7485	2.4731		
13*	1.6387	1.5988	1.6067	1.6913	2.4728			
14*	1.6249	1.6470	2.0120	2.6508				
15 *	2.6151	2.8132						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 300 of 306

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 20 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5029	1.5166	1.6472	1.5444	1.4905	1.6414	1.6041	2.6007
9*	1.5166	1.5104	1.6402	1.5822	1.5252	1.5877	1.6222	2.7479
10*	1.6472	1.6369	1.6641	1.5935	1.5771	1.5808	1.9762	
11*	1.5444	1.5886	1.5961	1.6958	1.7242	1.6503	2.5901	
12*	1.4905	1.5391	1.5830	1.7274	1.7162	2.4191		
13*	1.6414	1.5997	1.5878	1.6555	2.4186			
14*	1.6041	1.6283	1.9873	2.6038				
15 *	2.6007	2.7909						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 19 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5144	1.5375	1.6713	1.5444	1.4914	1.6523	1.6079	2.6259
9*	1.5375	1.5337	1.6618	1.5942	1.5255	1.5869	1.6232	2.7646
10*	1.6713	1.6581	1.6851	1.6029	1.5786	1.5642	1.9690	
11*	1.5444	1.6014	1.6060	1.7063	1.7118	1.6336	2.5655	
12*	1.4914	1.5404	1.5854	1.7159	1.7023	2.4070		
13*	1.6523	1.5983	1.5721	1.6393	2.4067			
14*	1.6079	1.6300	1.9812	2.5800				
15 *	2.6259	2.8063						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 18 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5203	1.5481	1.6820	1.5368	1.4820	1.6438	1.5890	2.6412
9*	1.5481	1.5367	1.6594	1.5967	1.5141	1.5735	1.6012	2.7891
10*	1.6820	1.6556	1.7142	1.5898	1.5742	1.5440	1.9665	
11*	1.5368	1.6045	1.5933	1.7161	1.6971	1.6176	2.5982	
12*	1.4820	1.5294	1.5817	1.7019	1.6892	2.4353		
13*	1.6438	1.5861	1.5524	1.6237	2.4344			
14*	1.5890	1.6084	1.9796	2.6144				
15 *	2.6412	2.8374						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 17 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5698	1.5989	1.7365	1.5747	1.5131	1.6794	1.6067	2.6772
9*	1.5989	1.5812	1.7099	1.6414	1.5495	1.6037	1.6210	2.8284
10*	1.7365	1.7058	1.7644	1.6262	1.6118	1.5702	2.0036	
11*	1.5747	1.6500	1.6307	1.7586	1.7310	1.6471	2.6588	
12*	1.5131	1.5659	1.6201	1.7364	1.7209	2.4828		
13*	1.6794	1.6175	1.5795	1.6538	2.4819			
14*	1.6067	1.6287	2.0178	2.6767				
15 *	2.6772	2.8770						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 301 of 306

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 16 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5900	1.6264	1.7678	1.5870	1.5277	1.7009	1.6150	2.7381
9*	1.6264	1.6058	1.7281	1.6665	1.5583	1.6174	1.6281	2.9047
10*	1.7678	1.7240	1.7930	1.6360	1.6293	1.5738	2.0459	
11*	1.5870	1.6757	1.6409	1.7967	1.7365	1.6511	2.7342	
12*	1.5277	1.5751	1.6384	1.7421	1.7278	2.5452		
13*	1.7009	1.6322	1.5836	1.6581	2.5438			
14*	1.6150	1.6362	2.0617	2.7506				
15 *	2.7381	2.9664						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 15 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7071	1.7353	1.8812	1.6944	1.6157	1.7979	1.7098	2.8400
9*	1.7353	1.7103	1.8594	1.7615	1.6617	1.7096	1.7266	2.9737
10*	1.8812	1.8544	1.8847	1.7440	1.7258	1.6700	2.1166	
11*	1.6944	1.7793	1.7494	1.8729	1.8508	1.7581	2.8028	
12*	1.6157	1.6855	1.7358	1.8571	1.8425	2.6197		
13*	1.7979	1.7259	1.6810	1.7659	2.6194			
14*	1.7098	1.7358	2.1331	2.8224				
15 *	2.8400	3.0270						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 14 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7451	1.7866	1.9431	1.7226	1.6474	1.8379	1.7199	2.9313
9*	1.7866	1.7560	1.8920	1.8184	1.6847	1.7394	1.7356	3.1057
10*	1.9431	1.8872	1.9581	1.7701	1.7652	1.6857	2.2013	
11*	1.7226	1.8295	1.7758	1.9531	1.8714	1.7746	2.9577	
12*	1.6474	1.7060	1.7760	1.8780	1.8626	2.7460		
13*	1.8379	1.7570	1.6972	1.7827	2.7444			
14*	1.7199	1.7450	2.2194	2.9766				
15 *	2.9313	3.1724						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 13 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7803	1.8232	1.9785	1.7667	1.7044	1.9064	1.7895	3.0494
9*	1.8232	1.7932	1.9281	1.8663	1.7330	1.8090	1.8063	3.2252
10*	1.9785	1.9233	2.0082	1.8199	1.8205	1.7515	2.2882	
11*	1.7667	1.8778	1.8263	1.9974	1.9350	1.8409	3.0613	
12*	1.7044	1.7527	1.8322	1.9424	1.9268	2.8291		
13*	1.9064	1.8279	1.7636	1.8494	2.8266			
14*	1.7895	1.8164	2.3068	3.0800				
15 *	3.0494	3.2872						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 302 of 306

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 12 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7895	1.8249	1.9721	1.7690	1.6957	1.8972	1.7977	3.0476
9*	1.8249	1.7932	1.9405	1.8561	1.7371	1.7998	1.8124	3.1882
10*	1.9721	1.9352	1.9830	1.8188	1.8118	1.7497	2.2505	
11*	1.7690	1.8746	1.8255	1.9652	1.9302	1.8367	2.9921	
12*	1.6957	1.7578	1.8240	1.9380	1.9201	2.7701		
13*	1.8972	1.8197	1.7630	1.8462	2.7697			
14*	1.7977	1.8233	2.2707	3.0172				
15 *	3.0476	3.2477						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 11 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7054	1.7557	1.8971	1.6838	1.6177	1.8133	1.6954	2.9450
9*	1.7557	1.7194	1.8385	1.7891	1.6463	1.7131	1.7078	3.1158
10*	1.8971	1.8344	1.9191	1.7293	1.7345	1.6546	2.1902	
11*	1.6838	1.8013	1.7360	1.9122	1.8304	1.7385	2.9610	
12*	1.6177	1.6662	1.7470	1.8381	1.8217	2.7240		
13*	1.8133	1.7332	1.6679	1.7480	2.7227			
14*	1.6954	1.7184	2.2112	2.9831				
15 *	2.9450	3.1859						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 10 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6621	1.7171	1.8557	1.6387	1.5725	1.7649	1.6363	2.8670
9*	1.7171	1.6776	1.7902	1.7481	1.5993	1.6629	1.6485	3.0392
10*	1.8557	1.7877	1.8736	1.6808	1.6900	1.6011	2.1389	
11*	1.6387	1.7607	1.6876	1.8642	1.7749	1.6833	2.9090	
12*	1.5725	1.6192	1.7028	1.7827	1.7662	2.6698		
13*	1.7649	1.6834	1.6146	1.6930	2.6697			
14*	1.6363	1.6591	2.1602	2.9314				
15 *	2.8670	3.1117						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 9 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6470	1.6999	1.8391	1.6188	1.5488	1.7415	1.6086	2.8225
9*	1.6999	1.6585	1.7720	1.7307	1.5786	1.6381	1.6215	2.9837
10*	1.8391	1.7710	1.8549	1.6592	1.6682	1.5749	2.1029	
11*	1.6188	1.7437	1.6663	1.8437	1.7508	1.6594	2.8596	
12*	1.5488	1.6002	1.6815	1.7589	1.7432	2.6245		
13*	1.7415	1.6592	1.5888	1.6693	2.6234			
14*	1.6086	1.6324	2.1247	2.8828				
15 *	2.8225	3.0528						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 303 of 306

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 8 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.6736	1.7143	1.8528	1.6387	1.5580	1.7530	1.6242	2.8105
9*	1.7143	1.6708	1.7990	1.7407	1.5984	1.6486	1.6395	2.9385
10*	1.8528	1.7993	1.8514	1.6785	1.6795	1.5889	2.0812	
11*	1.6387	1.7594	1.6860	1.8302	1.7713	1.6782	2.8036	
12*	1.5580	1.6247	1.6934	1.7798	1.7645	2.5854		
13*	1.7530	1.6705	1.6035	1.6887	2.5851			
14*	1.6242	1.6512	2.1030	2.8307				
15 *	2.8105	2.9954						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 7 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5912	1.6510	1.7901	1.5668	1.5000	1.6963	1.5510	2.7816
9*	1.6510	1.6061	1.7138	1.6860	1.5244	1.5881	1.5633	2.9466
10*	1.7901	1.7128	1.8060	1.6074	1.6230	1.5185	2.0642	
11*	1.5668	1.6989	1.6149	1.7928	1.6948	1.6044	2.8384	
12*	1.5000	1.5482	1.6373	1.7036	1.6902	2.5889		
13*	1.6963	1.6107	1.5335	1.6152	2.5889			
14*	1.5510	1.5749	2.0878	2.8635				
15 *	2.7816	3.0206						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 6 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5577	1.6166	1.7556	1.5338	1.4641	1.6600	1.5168	2.7393
9*	1.6166	1.5721	1.6817	1.6534	1.4897	1.5517	1.5284	2.8991
10*	1.7556	1.6785	1.7741	1.5734	1.5874	1.4833	2.0262	
11*	1.5338	1.6665	1.5811	1.7602	1.6590	1.5697	2.7953	
12*	1.4641	1.5145	1.6019	1.6678	1.6558	2.5466		
13*	1.6600	1.5746	1.4985	1.5806	2.5473			
14*	1.5168	1.5403	2.0503	2.8208				
15 *	2.7393	2.9746						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 5 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5351	1.5972	1.7386	1.5216	1.4486	1.6456	1.5140	2.7387
9*	1.5972	1.5558	1.6605	1.6343	1.4707	1.5390	1.5161	2.8291
10*	1.7386	1.6560	1.7620	1.5633	1.5708	1.4747	2.0121	
11*	1.5216	1.6484	1.5711	1.7483	1.6501	1.5557	2.7802	
12*	1.4486	1.4940	1.5852	1.6591	1.6422	2.4778		
13*	1.6456	1.5620	1.4920	1.5667	2.4788			
14*	1.5140	1.5278	2.0362	2.8063				
15 *	2.7387	2.9642						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 304 of 306

TABLE A-5 (CONTINUED)

M-SUB-C VALUES (F-SUB-Q RPS MARGIN) POWER ESCALATION

AT 118% POWER, 4 EFPD, THIS IS LEVEL 4 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5374	1.6042	1.7486	1.5426	1.4639	1.6652	1.5417	2.8075
9*	1.6042	1.5666	1.6637	1.6392	1.4769	1.5610	1.5420	2.9037
10*	1.7486	1.6591	1.7766	1.5923	1.5816	1.4885	2.0387	
11*	1.5426	1.6531	1.6002	1.7641	1.6703	1.5752	2.8107	
12*	1.4639	1.4979	1.5959	1.6766	1.6616	2.5066		
13*	1.6652	1.5840	1.5058	1.5864	2.5080			
14*	1.5417	1.5543	2.0634	2.8378				
15 *	2.8075	3.0188						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 3 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.5999	1.6500	1.7982	1.5947	1.5156	1.7411	1.6525	2.9949
9*	1.6500	1.5981	1.7235	1.6715	1.5287	1.6259	1.6529	3.0811
10*	1.7982	1.7232	1.8162	1.6475	1.6224	1.5631	2.1508	
11*	1.5947	1.6850	1.6554	1.8127	1.7415	1.6555	2.9238	
12*	1.5156	1.5500	1.6364	1.7479	1.7315	2.5817		
13*	1.7411	1.6488	1.5809	1.6670	2.5834			
14*	1.6525	1.6656	2.1760	2.9526				
15 *	2.9949	3.1924						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 2 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	1.7435	1.9240	2.0583	1.7536	1.7743	2.0967	1.9855	3.6333
9*	1.9240	1.8198	1.8661	1.9132	1.6820	1.9048	2.0180	3.7198
10*	2.0583	1.8650	2.0557	1.7994	1.8792	1.8007	2.5969	
11*	1.7536	1.9280	1.8088	2.0804	1.9436	1.9870	3.4132	
12*	1.7743	1.7068	1.8944	1.9508	2.0322	2.9800		
13*	2.0967	1.9304	1.8187	2.0004	2.9830			
14*	1.9855	2.0343	2.6257	3.4472				
15 *	3.6333	3.8048						

AT 118% POWER, 4 EFPD, THIS IS LEVEL 1 OF 24
(LEVEL 24 = TOP OF CORE, LEVEL 1 = BOTTOM)

	H	G	F	E	D	C	B	A
8*	3.9799	4.1965	4.2703	3.9011	3.9589	4.5400	5.0296	7.9431
9*	4.1965	4.0290	4.0300	4.1077	3.9407	4.3017	5.1402	8.2147
10*	4.2703	4.0289	4.2716	4.0194	4.1522	4.4322	5.7237	
11*	3.9011	4.1355	4.0316	4.4041	4.4127	5.0607	7.4234	
12*	3.9589	3.9832	4.1830	4.4276	5.0554	6.2403		
13*	4.5400	4.3492	4.4722	5.0890	6.2458			
14*	5.0296	5.1797	5.7790	7.4831				
15 *	7.9431	8.2689						

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 305 of 306

TABLE A-6

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 100% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4479	* 1.3339	* 1.2311	* 1.4418	* 1.3973	* 1.2407	* 1.3481	* 0.7421 *
	* 1.1578	* 1.2449	* 1.3516	* 1.1682	* 1.2016	* 1.3475	* 1.2419	* 2.1781 *
9	* 1.3339	* 1.3569	* 1.3306	* 1.2951	* 1.4627	* 1.3085	* 1.3483	* 0.6839 *
	* 1.2449	* 1.2249	* 1.2650	* 1.2897	* 1.1540	* 1.2750	* 1.2500	* 2.3720 *
10	* 1.2311	* 1.3338	* 1.2072	* 1.3930	* 1.3131	* 1.4152	* 1.0177	*
	* 1.3516	* 1.2629	* 1.3693	* 1.2107	* 1.2764	* 1.1749	* 1.6227	*
11	* 1.4418	* 1.2874	* 1.3889	* 1.2055	* 1.2953	* 1.3436	* 0.7066	*
	* 1.1682	* 1.2964	* 1.2143	* 1.3900	* 1.2862	* 1.2287	* 2.2756	*
12	* 1.3973	* 1.4464	* 1.3049	* 1.2914	* 1.2921	* 0.7858	*	
	* 1.2016	* 1.1664	* 1.2833	* 1.2894	* 1.2780	* 2.0488	*	
13	* 1.2407	* 1.2940	* 1.4039	* 1.3369	* 0.7842	*		
	* 1.3475	* 1.2876	* 1.1823	* 1.2339	* 2.0525	*		
14	* 1.3481	* 1.3406	* 1.0089	* 0.7012	*			
	* 1.2419	* 1.2563	* 1.6353	* 2.2908	*			
15	* 0.7421	* 0.6710	* F-DEL-H					
	* 2.1781	* 2.4129	* M-DEL-H					

AT 75% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4611	* 1.3454	* 1.2358	* 1.4515	* 1.4140	* 1.2505	* 1.3557	* 0.7344 *
	* 1.3862	* 1.5066	* 1.6501	* 1.4156	* 1.4552	* 1.6409	* 1.5063	* 2.7277 *
9	* 1.3454	* 1.3657	* 1.3348	* 1.3038	* 1.4726	* 1.3202	* 1.3557	* 0.6762 *
	* 1.5066	* 1.4894	* 1.5471	* 1.5726	* 1.4099	* 1.5628	* 1.5207	* 2.9759 *
10	* 1.2358	* 1.3381	* 1.2076	* 1.3966	* 1.3212	* 1.4252	* 1.0181	*
	* 1.6501	* 1.5443	* 1.6783	* 1.4829	* 1.5426	* 1.4249	* 2.0029	*
11	* 1.4515	* 1.2954	* 1.3921	* 1.2039	* 1.2948	* 1.3438	* 0.6989	*
	* 1.4156	* 1.5814	* 1.4871	* 1.7072	* 1.5525	* 1.4752	* 2.7522	*
12	* 1.4140	* 1.4551	* 1.3122	* 1.2905	* 1.2847	* 0.7750	*	
	* 1.4552	* 1.4249	* 1.5511	* 1.5580	* 1.5362	* 2.4430	*	
13	* 1.2505	* 1.3045	* 1.4138	* 1.3364	* 0.7733	*		
	* 1.6409	* 1.5795	* 1.4341	* 1.4819	* 2.4488	*		
14	* 1.3557	* 1.3474	* 1.0087	* 0.6932	*			
	* 1.5063	* 1.5289	* 2.0194	* 2.7711	*			
15	* 0.7344	* 0.6633	* F-DEL-H					
	* 2.7277	* 3.0280	* M-DEL-H					

Harris Unit 1 Cycle 23 Core Operating Limits Report

HNEI-0400-0016
Appendix A, Rev. 2
Page 306 of 306

TABLE A-6 (CONTINUED)

F-DEL-H & M-DEL-H VALUES - POWER ESCALATION

AT 50% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4724 *	* 1.3549 *	* 1.2387 *	* 1.4600 *	* 1.4296 *	* 1.2598 *	* 1.3641 *	* 0.7280 *
	* 1.8178 *	* 1.9627 *	* 2.1991 *	* 1.8730 *	* 1.9177 *	* 2.1940 *	* 1.9025 *	* 3.6906 *
9	* 1.3549 *	* 1.3724 *	* 1.3372 *	* 1.3112 *	* 1.4817 *	* 1.3316 *	* 1.3637 *	* 0.6697 *
	* 1.9627 *	* 1.9851 *	* 2.0830 *	* 2.0742 *	* 1.8689 *	* 2.0575 *	* 2.0393 *	* 4.0373 *
10	* 1.2387 *	* 1.3407 *	* 1.2066 *	* 1.3992 *	* 1.3284 *	* 1.4363 *	* 1.0192 *	
	* 2.1991 *	* 2.0795 *	* 2.2470 *	* 1.9639 *	* 2.0417 *	* 1.8879 *	* 2.7178 *	
11	* 1.4600 *	* 1.3023 *	* 1.3943 *	* 1.2013 *	* 1.2940 *	* 1.3446 *	* 0.6921 *	
	* 1.8730 *	* 2.0865 *	* 1.9735 *	* 2.2976 *	* 2.0769 *	* 1.9729 *	* 3.6917 *	
12	* 1.4296 *	* 1.4631 *	* 1.3188 *	* 1.2894 *	* 1.2779 *	* 0.7653 *		
	* 1.9177 *	* 1.8932 *	* 2.0549 *	* 2.0850 *	* 2.0653 *	* 3.2801 *		
13	* 1.2598 *	* 1.3148 *	* 1.4239 *	* 1.3365 *	* 0.7634 *			
	* 2.1940 *	* 2.0841 *	* 1.9010 *	* 1.9829 *	* 3.2895 *			
14	* 1.3641 *	* 1.3549 *	* 1.0092 *	* 0.6861 *				
	* 1.9025 *	* 2.0614 *	* 2.7398 *	* 3.7196 *				
15	* 0.7280 *	* 0.6568 *	F-DEL-H					
	* 3.6906 *	* 4.1054 *	M-DEL-H					

AT 30% POWER, 4 EFPD

	H	G	F	E	D	C	B	A
8	* 1.4821 *	* 1.3626 *	* 1.2410 *	* 1.4671 *	* 1.4426 *	* 1.2678 *	* 1.3714 *	* 0.7227 *
	* 1.8178 *	* 1.9627 *	* 2.1991 *	* 1.8730 *	* 1.9177 *	* 2.1940 *	* 1.9025 *	* 3.6906 *
9	* 1.3626 *	* 1.3776 *	* 1.3393 *	* 1.3174 *	* 1.4912 *	* 1.3411 *	* 1.3708 *	* 0.6644 *
	* 1.9627 *	* 1.9851 *	* 2.0830 *	* 2.0742 *	* 1.8689 *	* 2.0575 *	* 2.0393 *	* 4.0373 *
10	* 1.2410 *	* 1.3430 *	* 1.2059 *	* 1.4012 *	* 1.3342 *	* 1.4456 *	* 1.0204 *	
	* 2.1991 *	* 2.0795 *	* 2.2470 *	* 1.9639 *	* 2.0417 *	* 1.8879 *	* 2.7178 *	
11	* 1.4671 *	* 1.3081 *	* 1.3959 *	* 1.1991 *	* 1.2930 *	* 1.3450 *	* 0.6866 *	
	* 1.8730 *	* 2.0865 *	* 1.9735 *	* 2.2976 *	* 2.0769 *	* 1.9729 *	* 3.6917 *	
12	* 1.4426 *	* 1.4702 *	* 1.3240 *	* 1.2880 *	* 1.2717 *	* 0.7570 *		
	* 1.9177 *	* 1.8932 *	* 2.0549 *	* 2.0850 *	* 2.0653 *	* 3.2801 *		
13	* 1.2678 *	* 1.3235 *	* 1.4323 *	* 1.3363 *	* 0.7549 *			
	* 2.1940 *	* 2.0841 *	* 1.9010 *	* 1.9829 *	* 3.2895 *			
14	* 1.3714 *	* 1.3615 *	* 1.0098 *	* 0.6802 *				
	* 1.9025 *	* 2.0614 *	* 2.7398 *	* 3.7196 *				
15	* 0.7227 *	* 0.6514 *	F-DEL-H					
	* 3.6906 *	* 4.1054 *	M-DEL-H					