

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
1	F	1												N	U	With provided reference the question is a direct lookup. Also makes it fundamental instead of listed higher cog. Replaced with bank Question.
2	F	3												N	S	
3	H	2												B	S	
4	F	3												N	S	
5	F	2												B	S	
6	F	3												N	S	
7	H	2												N	S	
8	H	3					X							N	U	B is a second correct answer. Per AB.BOP-006 these are the actions. Stem needs to be more specific. Asks what actions are required. B is partially correct and the stem says you entered BOP-6. Changed B to be incorrect.

Refer to Section D of ES-401 and Appendix B for additional information regarding each of the following concepts:

- Enter the level of knowledge (LOK) of each question as either (F)undamental or (H)igher cognitive level.
- Enter the level of difficulty (LOD) of each question a 1 (easy) to 5 (difficult); questions with a difficulty between 2 and 4 are acceptable.
- Check the appropriate box if a psychometric flaw is identified:
 - "Stem Focus": The stem lacks sufficient focus to elicit the correct answer (e.g., unclear intent, more information is needed, or too much needless information).
 - "Cues": The stem or distractors contain cues (e.g., clues, specific determiners, phrasing, length).
 - "T/F": The answer choices are a collection of unrelated true/false statements.
 - "Cred. Dist.": The distractors are not credible; single implausible distractors should be repaired, and more than one is unacceptable.
 - "Partial": One or more distractors are partially correct (e.g., if the applicant can make unstated assumptions that are not contradicted by the stem).
- Check the appropriate box if a job content flaw is identified:
 - "Job Link": The question is not linked to the job requirements (i.e., the question has a valid K/A but, as written, is not operational in content).
 - "Minutia": The question requires the recall of knowledge that is too specific for the closed-reference test mode (i.e., it is not required to be known from memory).
 - "#/Units": The question contains data with an unrealistic level of accuracy or inconsistent units (e.g., panel meter in percent with question in gallons).
 - "Backward": The question requires reverse logic or application compared to the job requirements.
- Check questions that are sampled for conformance with the approved K/A and those K/As that are designated "SRO-only." (K/A and license-level mismatches are unacceptable.)
- Enter question's source: (B)ank, (M)odified, or (N)ew. Verify that (M)odified questions meet the criteria of Form ES-401, Section D.2.f.
- Based on the reviewer's judgment, is the question, as written, (U)nsatisfactory (requiring repair or replacement), in need of (E)ditorial enhancement, or (S)atisfactory?
- At a minimum, explain any "U" status ratings (e.g., how the Appendix B psychometric attributes are not being met).

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
22	H	3				X								B	E	A is not plausible. Nothing in stem says inerting. At 100% power may be adding nitrogen, but not inerting. Changed a to lock the mode switch to shutdown.
23	F	3												B	S	
24	H	2												N	S	
25	H	3												N	S	
26	H	3												B	S	
27	H	3												B	S	
28	H	2												B	S	
29	H	2												B	S	
30	F	3												B	S	
31	F	3												N	S	
32	F	3												B	E	B answer description says shutoff head is 380 psig. Stem says at 300 psig. Check what flow would be at 300 psig. The answers all sound like design flow for a dba loca i.e. 0 psig. Changed answers to pump combinations running instead of flows.
33	H	2												B	S	
34	F	2												B	S	
35	H	3												N	S	
36	F	3												B	S	
37	F	3												B	S	

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist.	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
38	F	2												B	S	
39	H	4												N	S	
40	H	3												B	S	
41	F	2												B	S	
42	F	3												B	E	D, add the word only to the end of the sentence. Made change.
43	H	3												B	S	
44	F	3												B	S	
45	H	2												B	E	No explanation for b and c incorrect or plausibility. Added statement for why incorrect.
46	H	3										X		B	U	KA Mismatch. Q does not test knowledge of loss or malfunction of SGTS. Randomly selected new ka same system. Replaced with a bank question.
47	H	2												B	E	All answers have 2 parts but question only asks what A RHR is powered from. Add a second part to question to ask second part. Added second part.
48	F	2												N	S	
49	H	3												B	S	
50	H	3												N	S	
51	H	3												B	S	
52	H	3												N	S	
53	F	3												B	S	
54	F	2												B	S	

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
55	H	3												B	S	
56	F	3												B	E	B answer description about why correct states failure of the pipe does not compromise the ability to have two thirds core coverage. Reword to clarify that it does effect core coverage. Used suggested fix.
57	H	3												B	S	
58	H	3												N	S	
59	F	3												B	S	
60	H	3												N	S	
61	H	3												B	S	
62	H	3												B	S	
63	H	3												B	S	
64	H	3												B	S	
65	H	3												B	S	
66	H	3												B	S	
67	F	2	X											B	E	The question states "The desired plant lineup requires ..." Need to define what plant lineup. Added at 100% power.
68	F	2												B	S	
69	F	3												B	S	
70	F	2												B	S	

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
71	F	2												B	U	KA Mismatch. MSL rad monitors are a separate system in ka catalogue. This is a tier 3 ka is talking about use of rad monitors. Replaced with bank.
72	F	3												N	S	
73	F	3												B	S	
74	F	2												B	S	
75	F	3												B	S	
76	H	3												N	S	
77	H	3												B	U	Not SRO only. Can answer purely with system knowledge. MSIV's close and CRD valves fail closed. Can't use crd or condenser. Changed all answers to make SRO knowledge.
78	H	2	X											N	E	Need to say in stem assuming heat up rate remains constant. Fixed.
79	F	3	X											B	E	Stem says at 100% power. Also says irradiated fuel is being moved into the fuel pool. Where did this fuel come from? Do you mean fuel is being moved in the fuel pool? Used suggested fix.
80	H	2												M	S	
81	F	2												B	S	
82	H	3												M	S	
83	H	2										X		B	U	KA mismatch. Does not test the ability to determine reactor power as it applies to high pressure. Replaced with a bank question.
84	H	2				X								B	E	C not plausible. Why would I open turbine bypass valves when controlling with SRV's. changed C to srvs.
85	H	3					X							B	E	B is partially correct. It is a subset of C. changed B distractor.
86	H	2												B	S	

Q	1. LOK (F/H)	2. LOD (1-5)	3. Psychometric Flaws					4. Job Content Flaws				5. Other		6. Source (B/M/N)	7. Status (U/E/S)	8. Explanation
			Stem Focus	Cues	T/F	Cred. Dist	Partial	Job-Link	Minutia	#/Units	Backward	Q – K/A	SRO Only			
87	H	3												B	S	
88	H	3												M	S	
89	H	3												B	S	
90	H	3												B	S	
91	H	3												B	S	
92	H	3												B	S	
93	H	2												B	S	
94	F	2												B	S	
95	F	3												B	S	
96	F	2												B	S	
97	F	3												M	S	
98	H	3												B	S	
99	F	2												B	S	
100	F	2												B	S	