



**UNITED STATES  
NUCLEAR REGULATORY COMMISSION**  
WASHINGTON, D.C. 20555-0001

January 9, 2020

Mr. Bryan C. Hanson  
Senior Vice President  
Exelon Generation Company, LLC  
President and Chief Nuclear Officer  
Exelon Nuclear  
LaSalle County Station  
4300 Winfield Road  
Warrenville, IL 60555

**SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR  
CONFORMING LICENSE AMENDMENTS TO INCORPORATE THE  
MITIGATION STRATEGIES REQUIRED BY SECTION B.5.b. OF COMMISSION  
ORDER EA-02-026 AND THE RADIOLOGICAL PROTECTION MITIGATION  
STRATEGIES REQUIRED BY COMMISSION ORDER EA-06-137 (TAC NOS.  
MD4506 AND MD4507)**

Dear Mr. Hanson:

By letter dated August 9, 2007 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML072200022), the U.S. Nuclear Regulatory Commission (NRC) staff issued license conditions to Renewed Facility Operating License (RFOL) Nos. NPF-11 and NPF-18 for the LaSalle County Station, Units 1 and 2, respectively. The conforming amendments were to incorporate the mitigation strategies required by Section B.5.b. of Commission Order EA-02-026, "Order for Interim Safeguards and Security Compensatory Measures."

The NRC staff identified the following editorial errors:

- On page 8 of the RFOL No. NPF-11, in paragraph (44)(b)5, and page 7 of the RFOL No. NPF-18, in paragraph (28)(b)5, the word "equipment" should have completed the phrase.


These errors were inadvertently introduced during the administrative processing of the conforming license amendment. The corrections do not change any of the conclusions associated with the issuance of conforming amendment and do not affect the associated notice to the public. Please replace RFOL pages with the enclosed corrected pages. We regret any inconvenience caused by these errors.

B. Hanson

- 2 -

If you have any questions, please contact me at 301-415-3308 or via e-mail at [Bhalchandra.Vaidya@nrc.gov](mailto:Bhalchandra.Vaidya@nrc.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "B.K. Vaidya", with a horizontal line underneath.

Bhalchandra K. Vaidya, Project Manager  
Plant Licensing Branch III  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-373 and 50-374

Enclosure:  
As stated

cc: Listserv

ENCLOSURE

LASALLE COUNTY STATION, UNITS 1 AND 2

REVISED LICENSE PAGES

DOCKET NOS. 50-373 AND 50-374

Enclosure

(43) DELETED

Letter dated  
08/09/07

(44) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

(a) Fire fighting response strategy with the following elements:

1. Pre-defined coordination fire response strategy and guidance
2. Assessment of mutual aid fire fighting assets
3. Designated staging areas for equipment and materials
4. Command and control
5. Training of response personnel

(b) Operations to mitigate fuel damage considering the following:

1. Protection and use of personnel assets
2. Communications
3. Minimizing fire spread
4. Procedures for implementing integrated fire response strategy
5. Identification of readily-available pre-staged equipment
6. Training or integrated fire response strategy
7. Spent fuel pool mitigation measures

(c) Actions to minimize release to include consideration of:

1. Water spray scrubbing
2. Dose to onsite responders

Am. 186  
10/31/07

(45) Upon implementation of Amendment No. 186 adopting TSTF-448, Revision 3, the determination of control room envelope (CRE) unfiltered air leakage as required by SR 3.7.4.5, in accordance with TS 5.5.15.c.(i), the assessment of CRE habitability as required by Specification 5.5.15.c.(ii), and the measurement of CRE pressure as required by Specification 5.5.15.d, shall be considered met. Following Implementation:

(a) The first performance of SR 3.7.4.5, in accordance with Specification 5.5.15.c.(i), shall be within the specified Frequency of 6 years, plus the 18-month allowance of SR 3.0.2, as measured from 1998, the date of the most recent successful tracer gas test, as stated in the December 9, 2003 letter response to Generic Letter 2003-01, or within the next 18 months if the time period since the most recent successful tracer gas test is greater than 6 years.

- (e) The appropriate section of the decommissioning trust agreement shall state that the trustee, investment advisor, or anyone else directing the investments made in the trust shall adhere to a "prudent investor" standard, as specified in 18 CFR 35.32(a)(3) of the Federal Energy Regulatory Commission's regulations.

Am. 132  
01/12/01

- (25) EGC shall take all necessary steps to ensure that the decommissioning trust is maintained in accordance with the application for approval of the transfer of the LaSalle, Unit 2, license and the requirements of the Order approving the transfer, and consistent with the safety evaluation supporting the Order.

(26) DELETED

(27) DELETED

Letter dated  
08/09/07

- (28) Mitigation Strategy License Condition

Develop and maintain strategies for addressing large fires and explosions and that include the following key areas:

- (a) Fire fighting response strategy with the following elements:

1. Pre-defined coordination fire response strategy and guidance
2. Assessment of mutual aid fire fighting assets
3. Designated staging areas for equipment and materials
4. Command and control
5. Training of response personnel

- (b) Operations to mitigate fuel damage considering the following:

1. Protection and use of personnel assets
2. Communications
3. Minimizing fire spread
4. Procedures for implementing integrated fire response strategy
5. Identification of readily-available pre-staged equipment
6. Training or integrated fire response strategy
7. Spent fuel pool mitigation measures

SUBJECT: LASALLE COUNTY STATION, UNITS 1 AND 2 – CORRECTION LETTER FOR CONFORMING LICENSE AMENDMENTS TO INCORPORATE THE MITIGATION STRATEGIES REQUIRED BY SECTION B.5.b. OF COMMISSION ORDER EA-02-026 AND THE RADIOLOGICAL PROTECTION MITIGATION STRATEGIES REQUIRED BY COMMISSION ORDER EA-06-137 (TAC NOS. MD4506 AND MD4507) DATED JANUARY 9, 2020

**DISTRIBUTION:**

PUBLIC

PM File Copy

RidsACRS\_MailCTR Resource

RidsNrrDorLpl3 Resource

RidsNrrDssStsb Resource

RidsNrrLASRohrer Resource

RidsNrrPMLaSalle Resource

RidsRgn3MailCenter Resource

**ADAMS Accession No.: ML19365A015**

\*via e-mail

OFFICE	NRR/DORL/LPL3/PM	NRR/DORL/LPL3/LA	NRR/DORL/LPL3/BC	NRR/DORL/LPL3/PM
NAME	BVaidya	SRohrer	NSalgado	BVaidya
DATE	01/07/2020	01/07/2020	01/09/2020	01/09/2020

**OFFICIAL RECORD COPY**