



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

January 13, 2020

Vice President, Operations
Entergy Nuclear Operations, Inc.
Indian Point Energy Center
450 Broadway, GSB
P.O. Box 249
Buchanan, NY 10511-0249

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 – INDIVIDUAL NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO RENEWED FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY TO REQUEST A HEARING (EPID L-2019-LLA-0262)

Dear Sir or Madam:

The U.S. Nuclear Regulatory Commission has forwarded the enclosed notice of consideration of issuance of amendment to Renewed Facility Operating License No. DPR-64 for Indian Point Nuclear Generating Station Unit No. 3 (Indian Point Unit 3), proposed no significant hazards consideration determination, and opportunity to request a hearing to the Office of the Federal Register for publication.

This notice relates to Entergy Nuclear Operations, Inc.'s (the licensee's) application dated November 21, 2019 (Agencywide Documents Access and Management System Accession No. ML19325E913), to modify Technical Specification (TS) 3.7.7, "City Water (CW)," Surveillance Requirement (SR) 3.7.7.2, and TS 3.7.6, "Condensate Storage Tank (CST)," Required Action A.1.

Specifically, the proposed amendment would revise TS SR 3.7.7.2 to allow one of the backflow preventer isolation valves on the Indian Point Unit 3 city water header supply to be maintained closed when in the modes of applicability for TS Limiting Condition for Operation (LCO) 3.7.7 (i.e., during Modes 1, 2, and 3, and Mode 4 when the steam generators are relied upon for heat removal), provided that the requirements of TS LCO 3.7.6 are met.

The proposed change would eliminate intrusion of CW into the auxiliary feedwater (AFW) system and the CST due to leak-by past a downstream isolation valve and allow removal of a temporary modification that provides continuous flushing of the 33 AFW pump suction line. In addition, the proposed amendment would revise TS 3.7.6 Required Action A.1 to require the closed backflow preventer isolation valve on the Indian Point Unit 3 CW header supply to be reopened immediately in the event that the CST is declared inoperable.

If you have any questions, please contact me at 301-415-1030 or by e-mail to Richard.Guzman@nrc.gov.

Sincerely,



Richard V. Guzman, Senior Project Manager
Plant Licensing Branch I
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-286

Enclosure:
Notice of Consideration

cc: Listserv

NUCLEAR REGULATORY COMMISSION

[Docket No. 50-286; NRC-2020-0019]

Entergy Nuclear Operations, Inc.

Indian Point Nuclear Generating Unit No. 3

Revise Technical Specifications 3.7.6 and 3.7.7

AGENCY: Nuclear Regulatory Commission.

ACTION: License amendment application; opportunity to comment, request a hearing, and petition for leave to intervene.

SUMMARY: The U.S. Nuclear Regulatory Commission (NRC) is considering issuance of an amendment to Renewed Facility Operating License No. DPR-64, issued to Entergy Nuclear Operations, Inc. (the licensee), for operation of Indian Point Nuclear Generating Unit No. 3 (Indian Point Unit 3 or IP3). The proposed amendment would modify Technical Specification (TS) 3.7.7, "City Water (CW)," Surveillance Requirement (SR) 3.7.7.2, and TS 3.7.6, "Condensate Storage Tank (CST)," Required Action A.1.

DATES: Submit comments by **[INSERT DATE 30 DAYS FROM DATE OF PUBLICATION IN THE FEDERAL REGISTER]**. Requests for a hearing or petition for leave to intervene must be filed by **[INSERT DATE 60 DAYS FROM DATE OF PUBLICATION IN THE FEDERAL REGISTER]**.

ADDRESSES: You may submit comments by any of the following methods:

- **Federal Rulemaking Web Site:** Go to <https://www.regulations.gov> and search for Docket ID **NRC-2020-0019**. Address questions about NRC docket IDs in [Regulations.gov](https://www.regulations.gov) to Jennifer Borges; telephone: 301-287-9127; e-mail:

Jennifer.Borges@nrc.gov. For technical questions, contact the individual listed in the

FOR FURTHER INFORMATION CONTACT section of this document.

- **Mail comments to:** Office of Administration, Mail Stop: TWFN-7-A60M, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, ATTN: Program Management, Announcements and Editing Staff.

For additional direction on obtaining information and submitting comments, see “Obtaining Information and Submitting Comments” in the SUPPLEMENTARY INFORMATION section of this document.

FOR FURTHER INFORMATION CONTACT: Richard V. Guzman, Office of Nuclear Reactor Regulation, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001; telephone: 301-415-1030; e-mail: Richard.Guzman@nrc.gov.

SUPPLEMENTARY INFORMATION:

I. Obtaining Information and Submitting Comments

A. Obtaining Information

Please refer to Docket ID **NRC-2020-0019** when contacting the NRC about the availability of information for this action. You may obtain publicly-available information related to this action by any of the following methods:

- **Federal Rulemaking Web Site:** Go to <https://www.regulations.gov> and search for Docket ID **NRC-2020-0019**.

- **NRC’s Agencywide Documents Access and Management System (ADAMS):** You may obtain publicly-available documents online in the ADAMS Public Documents collection at <https://www.nrc.gov/reading-rm/adams.html>. To begin the search, select “[Begin Web-based ADAMS Search.](#)” For problems with ADAMS, please contact the NRC’s Public Document Room (PDR) reference staff at 1-800-397-4209, 301-415-4737, or by e-mail to pdr.resource@nrc.gov. The license amendment request

dated November 21, 2019, is available in ADAMS under Accession No. ML19325E913.

- **NRC's PDR:** You may examine and purchase copies of public documents at the NRC's PDR, Room O1-F21, One White Flint North, 11555 Rockville Pike, Rockville, Maryland 20852.

B. Submitting Comments

Please include Docket ID **NRC-2020-0019** in your comment submission.

The NRC cautions you not to include identifying or contact information that you do not want to be publicly disclosed in your comment submission. The NRC will post all comment submissions at <https://www.regulations.gov> as well as enter the comment submissions into ADAMS. The NRC does not routinely edit comment submissions to remove identifying or contact information.

If you are requesting or aggregating comments from other persons for submission to the NRC, then you should inform those persons not to include identifying or contact information that they do not want to be publicly disclosed in their comment submission. Your request should state that the NRC does not routinely edit comment submissions to remove such information before making the comment submissions available to the public or entering the comment into ADAMS.

II. Introduction

The NRC is considering issuance of an amendment to Renewed Facility Operating License No. DPR-64 issued to Entergy Nuclear Operations, Inc., for operation of Indian Point Unit 3, located in Westchester County, New York. Specifically, the proposed amendment would revise TS SR 3.7.7.2 to allow one of the backflow preventer isolation valves on the Indian Point Unit 3 city water (CW) header supply to be maintained closed when in the modes of applicability for TS Limiting Condition for Operation (LCO) 3.7.7 (i.e., during Modes 1, 2, and 3, and Mode 4 when the steam

generators are relied upon for heat removal), provided that the requirements of TS LCO 3.7.6 are met. The proposed change would eliminate intrusion of CW into the auxiliary feedwater (AFW) system and the CST due to leak-by past a downstream isolation valve and allow removal of a temporary modification that provides continuous flushing of the 33 AFW pump suction line. In addition, the proposed amendment would revise TS 3.7.6 Required Action A.1 to require the closed backflow preventer isolation valve on the Indian Point Unit 3 CW header supply to be reopened immediately in the event that the CST is declared inoperable.

Before any issuance of the proposed license amendment, the NRC will need to make the findings required by the Atomic Energy Act of 1954, as amended (the Act), and NRC regulations.

The NRC has made a proposed determination that the license amendment request involves no significant hazards consideration. Under the NRC's regulations in section 50.92 of title 10 of the *Code of Federal Regulations* (10 CFR), this means that operation of the facility in accordance with the proposed amendment would not (1) involve a significant increase in the probability or consequences of an accident previously evaluated; or (2) create the possibility of a new or different kind of accident from any accident previously evaluated; or (3) involve a significant reduction in a margin of safety. As required by 10 CFR 50.91(a), the licensee has provided its analysis of the issue of no significant hazards consideration, which is presented below:

1. Does the proposed amendment involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed amendment does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed amendment would modify IP3 TS SR 3.7.7.2 to allow one of the backflow preventer isolation valves on the IP3 CW Header Supply to be maintained closed, provided the requirements of TS LCO 3.7.6 are met. In addition, the proposed change to TS 3.7.6 Required Action A.1 would require the closed backflow preventer isolation valve to be re-opened immediately in the event the CST is declared inoperable. The proposed changes to SR 3.7.7.2 and TS 3.7.6, Required Action 1 do not affect any initiator or precursor of any accident previously evaluated. Therefore, the proposed change does not involve a significant increase in the probability of an accident previously evaluated.

The CST is the preferred source of water for the AFW System, and this remains unchanged. The consequences of accidents or events in which the AFW is credited or required are normally mitigated by operation of the AFW System. The CW system can be used as a backup to the CST in the event the CST is unavailable for any reason, including due to CST damage from a tornado-generated missile.

In order to place the CW System in service, the proposed changes will add a field action by a nuclear plant operator to open one of the backflow preventer isolation valves on the IP3 CW Header Supply, in addition to the already required manual action to open the individual AFW pump suction valves from the control room. The proposed changes will also require the closed backflow preventer isolation valve on the IP3 CW Header Supply to be re-opened immediately in the event the CST is declared inoperable. As a result, the CW system will continue to provide a reliable means of backup cooling to the AFW pumps. Therefore, the proposed amendment does not involve a significant increase in the consequences of an accident previously evaluated.

2. Does the proposed amendment create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed amendment would modify IP3 TS SR 3.7.7.2 to allow one of the backflow preventer isolation valves on the IP3 CW Header Supply to be maintained closed, provided the requirements of TS LCO 3.7.6 are met. In addition, the proposed changes to TS 3.7.6, Required Action A.1 would require the closed backflow preventer isolation valve to be re-opened immediately in the event the CST is declared inoperable.

The proposed amendment will not involve any physical changes to the existing plant, so no new malfunctions could create the possibility of a new or different kind of accident. The proposed amendment makes no changes to conditions external to the plant that could create the possibility of a new or different kind of accident. The proposed change will not create the possibility of a new or different kind of accident as no new accident initiators, precursors, failure mechanisms, or malfunctions are being introduced by the proposed changes.

The AFW System, the CST, and the CW System will continue to perform their design basis cooling functions for previously evaluated accidents or events for which the AFW System is credited or required. The normal source of CST cooling water for the AFW pumps is unaffected by the proposed changes. The AFW System is provided sufficient redundancy of water supplies such that the alternate source of water from the CW System is available in the event the CST is unavailable.

Therefore, the proposed amendment does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Does the proposed amendment involve a significant reduction in the margin of safety?

The proposed amendment does not involve a significant reduction in the margin of safety.

The proposed amendment would modify IP3 TS SR 3.7.7.2 to allow one of the backflow preventer isolation valves on the IP3 CW Header Supply to be maintained closed, provided the requirements of TS LCO 3.7.6 are met. In addition, the proposed changes to TS 3.7.6, Required Action A.1 would require the closed backflow preventer isolation valve to be re-opened immediately in the event the CST is declared inoperable.

The change does not exceed or alter any controlling numerical value for a parameter established in the FSAR [Final Safety Analysis Report] or elsewhere in the IP3 licensing basis related to design basis or safety limits. Entergy has performed a risk assessment in support of the proposed amendment and concluded that this change is not risk significant.

The proposed changes only affect the manual actions required to place the CW system in service. No automatic actions are affected by the proposed changes. This request does not replace an automatic action with a manual action, isolate a safety related

source of water that was previously unisolated, or close a valve that was previously required to be locked open. The CW system will continue to provide a reliable means of backup cooling to the AFW pumps.

Therefore, the proposed amendment does not involve a significant reduction in the margin of safety.

The NRC staff has reviewed the licensee's analysis and, based on this review, it appears that the three standards of 10 CFR 50.92(c) are satisfied. Therefore, the NRC staff proposes to determine that the license amendment request involves no significant hazards consideration.

The NRC is seeking public comments on this proposed determination that the license amendment request involves no significant hazards consideration. Any comments received within 30 days after the date of publication of this notice will be considered in making any final determination.

Normally, the Commission will not issue the amendment until the expiration of 60 days after the date of publication of this notice. The Commission may issue the license amendment before expiration of the 60-day notice period if the Commission concludes the amendment involves no significant hazards consideration. In addition, the Commission may issue the amendment prior to the expiration of the 30-day comment period if circumstances change during the 30-day comment period such that failure to act in a timely way would result, for example, in derating or shutdown of the facility. If the Commission takes action prior to the expiration of either the comment period or the notice period, it will publish in the *Federal Register* a notice of issuance. If the Commission makes a final no significant hazards consideration determination, any hearing will take place after issuance. The Commission expects that the need to take this action will occur very infrequently.

III. Opportunity to Request a Hearing and Petition for Leave to Intervene

Within 60 days after the date of publication of this notice, any persons (petitioner) whose interest may be affected by this action may file a request for a hearing and petition for leave to intervene (petition) with respect to the action. Petitions shall be filed in accordance with the Commission's "Agency Rules of Practice and Procedure" in 10 CFR part 2. Interested persons should consult a current copy of 10 CFR 2.309. The NRC's regulations are accessible electronically from the NRC Library on the NRC's Web site at <https://www.nrc.gov/reading-rm/doc-collections/cfr/>. Alternatively, a copy of the regulations is available at the NRC's Public Document Room, located at One White Flint North, Room O1-F21, 11555 Rockville Pike (first floor), Rockville, Maryland 20852. If a petition is filed, the Commission or a presiding officer will rule on the petition and, if appropriate, a notice of a hearing will be issued.

As required by 10 CFR 2.309(d) the petition should specifically explain the reasons why intervention should be permitted with particular reference to the following general requirements for standing: (1) the name, address, and telephone number of the petitioner; (2) the nature of the petitioner's right to be made a party to the proceeding; (3) the nature and extent of the petitioner's property, financial, or other interest in the proceeding; and (4) the possible effect of any decision or order which may be entered in the proceeding on the petitioner's interest.

In accordance with 10 CFR 2.309(f), the petition must also set forth the specific contentions which the petitioner seeks to have litigated in the proceeding. Each contention must consist of a specific statement of the issue of law or fact to be raised or controverted. In addition, the petitioner must provide a brief explanation of the bases for the contention and a concise statement of the alleged facts or expert opinion which support the contention and on which the petitioner intends to rely in proving the

contention at the hearing. The petitioner must also provide references to the specific sources and documents on which the petitioner intends to rely to support its position on the issue. The petition must include sufficient information to show that a genuine dispute exists with the applicant or licensee on a material issue of law or fact. Contentions must be limited to matters within the scope of the proceeding. The contention must be one which, if proven, would entitle the petitioner to relief. A petitioner who fails to satisfy the requirements at 10 CFR 2.309(f) with respect to at least one contention will not be permitted to participate as a party.

Those permitted to intervene become parties to the proceeding, subject to any limitations in the order granting leave to intervene. Parties have the opportunity to participate fully in the conduct of the hearing with respect to resolution of that party's admitted contentions, including the opportunity to present evidence, consistent with the NRC's regulations, policies, and procedures.

Petitions must be filed no later than 60 days from the date of publication of this notice. Petitions and motions for leave to file new or amended contentions that are filed after the deadline will not be entertained absent a determination by the presiding officer that the filing demonstrates good cause by satisfying the three factors in 10 CFR 2.309(c)(1)(i) through (iii). The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document.

If a hearing is requested, and the Commission has not made a final determination on the issue of no significant hazards consideration, the Commission will make a final determination on the issue of no significant hazards consideration. The final determination will serve to establish when the hearing is held. If the final determination is that the amendment request involves no significant hazards consideration, the Commission may issue the amendment and make it immediately

effective, notwithstanding the request for a hearing. Any hearing would take place after issuance of the amendment. If the final determination is that the amendment request involves a significant hazards consideration, then any hearing held would take place before the issuance of the amendment unless the Commission finds an imminent danger to the health or safety of the public, in which case it will issue an appropriate order or rule under 10 CFR part 2.

A State, local governmental body, Federally-recognized Indian Tribe, or agency thereof, may submit a petition to the Commission to participate as a party under 10 CFR 2.309(h)(1). The petition should state the nature and extent of the petitioner's interest in the proceeding. The petition should be submitted to the Commission no later than 60 days from the date of publication of this notice. The petition must be filed in accordance with the filing instructions in the "Electronic Submissions (E-Filing)" section of this document, and should meet the requirements for petitions set forth in this section, except that under 10 CFR 2.309(h)(2) a State, local governmental body, or Federally-recognized Indian Tribe, or agency thereof does not need to address the standing requirements in 10 CFR 2.309(d) if the facility is located within its boundaries. Alternatively, a State, local governmental body, Federally-recognized Indian Tribe, or agency thereof may participate as a non-party under 10 CFR 2.315(c).

If a hearing is granted, any person who is not a party to the proceeding and is not affiliated with or represented by a party may, at the discretion of the presiding officer, be permitted to make a limited appearance pursuant to the provisions of 10 CFR 2.315(a). A person making a limited appearance may make an oral or written statement of his or her position on the issues but may not otherwise participate in the proceeding. A limited appearance may be made at any session of the hearing or at any prehearing conference, subject to the limits and conditions as may be imposed by the presiding

officer. Details regarding the opportunity to make a limited appearance will be provided by the presiding officer if such sessions are scheduled.

IV. Electronic Submissions (E-Filing)

All documents filed in NRC adjudicatory proceedings, including a request for hearing and petition for leave to intervene (petition), any motion or other document filed in the proceeding prior to the submission of a request for hearing or petition to intervene, and documents filed by interested governmental entities that request to participate under 10 CFR 2.315(c), must be filed in accordance with the NRC's E-Filing rule (72 FR 49139; August 28, 2007, as amended at 77 FR 46562; August 3, 2012). The E-Filing process requires participants to submit and serve all adjudicatory documents over the internet, or in some cases to mail copies on electronic storage media. Detailed guidance on making electronic submissions may be found in the Guidance for Electronic Submissions to the NRC and on the NRC Web site at <https://www.nrc.gov/site-help/e-submittals.html>. Participants may not submit paper copies of their filings unless they seek an exemption in accordance with the procedures described below.

To comply with the procedural requirements of E-Filing, at least 10 days prior to the filing deadline, the participant should contact the Office of the Secretary by e-mail at hearing.docket@nrc.gov, or by telephone at 301-415-1677, to (1) request a digital identification (ID) certificate, which allows the participant (or its counsel or representative) to digitally sign submissions and access the E-Filing system for any proceeding in which it is participating; and (2) advise the Secretary that the participant will be submitting a petition or other adjudicatory document (even in instances in which the participant, or its counsel or representative, already holds an NRC-issued digital ID certificate). Based upon this information, the Secretary will establish an electronic

docket for the hearing in this proceeding if the Secretary has not already established an electronic docket.

Information about applying for a digital ID certificate is available on the NRC's public Web site at <https://www.nrc.gov/site-help/e-submittals/getting-started.html>. Once a participant has obtained a digital ID certificate and a docket has been created, the participant can then submit adjudicatory documents. Submissions must be in Portable Document Format (PDF). Additional guidance on PDF submissions is available on the NRC's public Web site at <https://www.nrc.gov/site-help/electronic-sub-ref-mat.html>. A filing is considered complete at the time the document is submitted through the NRC's E-Filing system. To be timely, an electronic filing must be submitted to the E-Filing system no later than 11:59 p.m. Eastern Time on the due date. Upon receipt of a transmission, the E-Filing system time-stamps the document and sends the submitter an e-mail notice confirming receipt of the document. The E-Filing system also distributes an e-mail notice that provides access to the document to the NRC's Office of the General Counsel and any others who have advised the Office of the Secretary that they wish to participate in the proceeding, so that the filer need not serve the document on those participants separately. Therefore, applicants and other participants (or their counsel or representative) must apply for and receive a digital ID certificate before adjudicatory documents are filed so that they can obtain access to the documents via the E-Filing system.

A person filing electronically using the NRC's adjudicatory E-Filing system may seek assistance by contacting the NRC's Electronic Filing Help Desk through the "Contact Us" link located on the NRC's public Web site at <https://www.nrc.gov/site-help/e-submittals.html>, by e-mail to MSHD.Resource@nrc.gov, or by a toll-free call at

1-866-672-7640. The NRC Electronic Filing Help Desk is available between 9 a.m. and 6 p.m., Eastern Time, Monday through Friday, excluding government holidays.

Participants who believe that they have a good cause for not submitting documents electronically must file an exemption request, in accordance with 10 CFR 2.302(g), with their initial paper filing stating why there is good cause for not filing electronically and requesting authorization to continue to submit documents in paper format. Such filings must be submitted by: (1) First class mail addressed to the Office of the Secretary of the Commission, U.S. Nuclear Regulatory Commission, Washington, DC 20555-0001, Attention: Rulemaking and Adjudications Staff; or (2) courier, express mail, or expedited delivery service to the Office of the Secretary, 11555 Rockville Pike, Rockville, Maryland 20852, Attention: Rulemaking and Adjudications Staff. Participants filing adjudicatory documents in this manner are responsible for serving the document on all other participants. Filing is considered complete by first-class mail as of the time of deposit in the mail, or by courier, express mail, or expedited delivery service upon depositing the document with the provider of the service. A presiding officer, having granted an exemption request from using E-Filing, may require a participant or party to use E-Filing if the presiding officer subsequently determines that the reason for granting the exemption from use of E-Filing no longer exists.

Documents submitted in adjudicatory proceedings will appear in the NRC's electronic hearing docket which is available to the public at <https://adams.nrc.gov/ehd>, unless excluded pursuant to an order of the Commission or the presiding officer. If you do not have an NRC-issued digital ID certificate as described above, click "Cancel" when the link requests certificates and you will be automatically directed to the NRC's electronic hearing dockets where you will be able to access any publicly available documents in a particular hearing docket. Participants are requested not to include

personal privacy information, such as social security numbers, home addresses, or personal phone numbers in their filings, unless an NRC regulation or other law requires submission of such information. For example, in some instances, individuals provide home addresses in order to demonstrate proximity to a facility or site. With respect to copyrighted works, except for limited excerpts that serve the purpose of the adjudicatory filings and would constitute a Fair Use application, participants are requested not to include copyrighted materials in their submission.

For further details with respect to this action, see the licensee's application dated November 21, 2019 (ADAMS Accession No. ML19325E913).

Attorney for licensee: Bill Glew, Associate General Counsel, Entergy Services, Inc., 639 Loyola Avenue, 22nd Floor, New Orleans, LA 70113.

NRC Branch Chief: James G. Danna.

Dated at Rockville, Maryland, this 13th day of January, 2020.

For the Nuclear Regulatory Commission.

/RA/

Richard V. Guzman, Sr. Project Manager,
Plant Licensing Branch I,
Division of Operating Reactor Licensing,
Office of Nuclear Reactor Regulation.

SUBJECT: INDIAN POINT NUCLEAR GENERATING UNIT NO. 3 – INDIVIDUAL NOTICE OF CONSIDERATION OF ISSUANCE OF AMENDMENT TO RENEWED FACILITY OPERATING LICENSE, PROPOSED NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION, AND OPPORTUNITY TO REQUEST A HEARING (EPID L-2019-LLA-0262) DATED JANUARY 13, 2020

DISTRIBUTION:

Public
 PM File Copy
 RidsACRS_MailCTR Resource
 RidsRgn1MailCenter Resource
 RidsNrrDorlLpl1 Resource
 RidsNrrPMIndianPoint Resource
 RidsNrrLALRonewicz Resource

ADAMS Accession No.: ML20003D088 (Letter) ML20009D089 (FRN) *by e-mail

OFFICE	NRR/DORL/LPL1/PM	NRR/DORL/LPL1/LA	OGC – NLO (w/edits)*
NAME	RGuzman	LRonewicz	JWachutka
DATE	01/06/2020	01/06/2020	01/08/2020
OFFICE	NRR/DORL/LPL1/BC	NRR/DORL/LPL1/PM	
NAME	JDanna	RGuzman	
DATE	01/9/2020	01/13/2020	

OFFICIAL RECORD COPY