

OL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

8 9 A L J M F 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
 LICENSEE CODE 14 15 LICEN NUMBER 25 26 LICENSE TYPE 30 37 CAT 58

CONT  
 0 1 REPORT SOURCE L 6 0 5 0 0 0 3 6 4 7 0 4 2 7 8 1 8 0 5 2 9 8 1 9  
 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10  
 0 2 At 0830 on 4-27-81, during initial performance of surveillance test FNP-2-STP-22 0  
 0 3 (Turbine Driven Auxiliary Feedwater Pump Operability Test), the TDAFW pump was declared in-  
 0 4 operable when the speed could not be automatically controlled (manual speed control  
 0 5 functioned properly). Tech. Spec. 3.7.1.2, in part, requires the TDAFW pump to be oper-  
 0 6 able. Tech. Spec. 3.7.1.2 action statement requirements were met. Health/safety of  
 0 7 the public was not affected.

8 9  
 0 5 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE  
 W G 11 B 12 C 13 7 7 7 7 7 7 14 7 15 7 16  
 9 10 11 12 13 18 19 20  
 17 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.  
 8 1 1 0 1 2 0 3 1 0  
 21 22 23 24 26 27 28 29 30 31 32  
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRO-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
 X 18 Z 19 Z 20 Z 21 0 0 0 0 N 23 N 24 Z 25 7 9 9 9 26  
 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27  
 1 0 Incident is attributable to an installation wiring error in the manual potentiometer  
 1 1 circuit. The wiring error was corrected and the TDAFW pump was returned to service at  
 1 2 approximately 0830 on 4-28-81.  
 1 3  
 1 4

8 9  
 1 5 FACILITY STATUS % POWER OTHER STATUS 30 METHOD OF DISCOVERY DISCOVERY DESCRIPTION 32  
 G 28 0 0 0 29 NA B 31 Performance of surveillance tests  
 8 9 10 12 13 44 45 46 80  
 1 6 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36  
 Z 33 Z 34 NA NA  
 8 9 10 11 12 13 44 45 80  
 1 7 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39  
 0 0 0 37 Z 38 NA  
 8 9 11 12 13 44 45 80  
 1 8 PERSONNEL INJURIES NUMBER DESCRIPTION 41  
 0 0 0 40 NA  
 8 9 11 12 13 44 45 80  
 1 9 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION 43  
 Z 42 NA  
 8 9 10 11 12 13 44 45 80  
 2 0 PUBLICITY ISSUED DESCRIPTION 45  
 N 44 NA  
 8 9 10 11 12 13 44 45 80

8106030247

NAME OF PREPARER W. G. Hairston, III PHONE: (205) 899-5156