

## LICENSEE EVENT REPORT

CONTROL BLOCY 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 C O F S V 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 2 0 4 5  
LICNSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 37 CAT 38

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 2 6 7 7 0 3 1 6 8 1 3 0 4 0 9 8 1 9  
DOCKET NUMBER 60 61 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During a greater than 10 gpm release of the reactor building sump, the sump pump ef-

0 3 fluent discharge proportional sampler was discovered to be inoperable. Degraded mode

0 4 of LCO 4.8.3(b). Reportable per Fort St. Vrain Technical Specification AC 7.5.2(b)2.

0 5 No accompanying occurrence. No effect on safety or health of public. No observable

0 6 activity indicated on in-service activity monitors or recorder.

0 7

0 8

0 9

SYSTEM CODE X X 11 CAUSE CODE A 12 CAUSE SUBCODE D 13 COMPONENT CODE Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16

17 LER/RC REPORT NUMBER 8 11 EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 24 25 OCCURRENCE CODE 27 28 REPORT TYPE 30 31 REVISION NO. 32

ACTION TAKEN X 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 22 ATTACHMENT SUBMITTED Y 23 NPD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The necessity to provide an energizing signal to solenoid valves discharging to the

1 1 proportional sampler when a temporary sump pump was installed was overlooked, resulting

1 2 in isolation of the proportional sampler during a greater than 10 gpm sump release.

1 3 Upon discovery, release was terminated. Instructions issued to assure proportional

1 4 sampler operability when using temporary sump pump. Instructions to be issued to as-

sure proper review of temporary changes.

FACILITY STATUS E 28 % POWER 0 6 9 29 OTHER STATUS N/A 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Personnel Observation 32

ITY CONTENT 33 REL ID OF RELEASE 34 AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36

1 6 Z 33 Z 34 N/A 35 N/A 36

PE. NEL EXPOSURES 37 TYPE 38 DESCRIPTION 39

1 7 0 0 37 Z 38 N/A 39

PERSONNEL INJURIES 40 DESCRIPTION 41

1 8 0 0 0 40 N/A 41

LOSS OF OR DAMAGE TO FACILITY 42 DESCRIPTION 43

1 9 Z 42 N/A 43

PUBLICITY 44 DESCRIPTION 45

2 0 N 44 N/A 45

NAME OF PREPARER J. W. Yeh PHONE: (303) 785-2224

8106030296

NRC USE ONLY

GPO 51-1-926