

TABLE 3.3-11

FIRE DETECTION INSTRUMENTS

<u>INSTRUMENT LOCATION</u>	<u>MINIMUM INSTRUMENTS OPERABLE</u>	
	<u>HEAT</u>	<u>SMOKE</u>
1. Containment		
North Penetration Area-Upper	2/Area	2/Area
North Penetration Area-Lower	2/Area	2/Area
South Penetration Area-Upper	2/Area	2/Area
South Penetration Area-Lower	2/Area	2/Area
2. Cable Spreading	Portective Wire	4
3. Switchgear Room		
Room 2100-Elev. 372		2
Room 2101-Elev. 372		2
4. Remote Shutdown Panels		1
5. Emergency Diesel Generator Rooms		
Room 2093-Elev. 369	1	2
Room 2094-Elev. 369	1	2
6. Diesel Fuel Storage Vaults		1/Vault
7. Penetration Rooms		
North Penetration Area-Upper		2/Room
North Penetration Area-Lower		2/Room
South Penetration Area-Upper		2/Room
South Penetration Area-Lower		2/Room