

LICENSEE EVENT REPORT

CONTROL BLOCK:

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | T N S N P I | 2 | 0 0 - 0 0 0 0 0 0 - 0 0 | 3 | 4 | 1 1 1 1 1 | 4 | | 5

7 8 9 14 15 25 26 30 37 CAT NO

LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CONT

REPORT SOURCE L 6 0 5 0 0 0 3 2 7 7 0 5 0 3 8 1 8 0 5 2 9 8 1 9

50 61 DICKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 With Unit 1 at 30% RTP, liquid radwaste effluent monitor 0-RM-90-122 would not source
0 3 check. The plant entered action statement 30 of LCO 3.3.3.9 until the monitor was
0 4 returned to service on 5/14/81. There was no effect on public health or safety. For
0 5 previous occurrences refer to SQRO-50-327/81013 and SQRO-50-327/81034.
0 6
0 7
0 8

SYSTEM CODE M C 11		CAUSE CODE E 12		CAUSE SUBCODE E 13		COMPONENT CODE I N S T R U 14				COMP. SUBCODE C 15		VALVE SUBCODE Z 16			
EVENT YEAR 8 1 21 22		SEQUENTIAL REPORT NO. 0 5 3 23 24 26		OCCURRENCE CODE 0 3 27 28 29		REPORT TYPE L 30 31		REVISION NO. 0 32							
ACTION TAKEN C 13 18		FUTURE ACTION F 19 20		EFFECT ON PLANT Z 21 22		SHUTDOWN METHOD Z 23 24		HOURS 0 0 0 0 22 37 40		ATTACHMENT SUBMITTED N 23 24		PRIME COMP. SUPPLIER L 25 26		COMPONENT MANUFACTURER G 0 6 3 44 47	

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS: (27)

1 0 The monitor failed due to the high background accumulation in the sample chamber. The

1 1 sample chamber was replaced and the monitor was returned to service. DCR-1109 has been

1 2 submitted to install another monitoring system. DCR-908 has been submitted to provide

1 3 a flushing capability for the present monitoring system.

1 4

FACILITY STATUS		POWER		OTHER STATUS		METHOD OF DISCOVERY		DISCOVERY DESCRIPTION	
1	5	0	3	0	NA	B	Failed to source check		
ACTIVITY CONTENT		RELEASED OF RELEASE		AMOUNT OF ACTIVITY		LOCATION OF RELEASE			
1	6	Z	Z	NA	NA				
PERSONNEL EXPOSURES		PERSONNEL INJURIES							
1	7	0	0	0	0				
LOSS OF OR DAMAGE TO FACILITY		PUBLICITY							
1	9	2	8106080 279						
ISSUED		NRC USE ONLY							

Name of Preparer: M. R. Harding/A. M. Wilkey

Phone: (615) 842-3317