

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 2 3 4 5 6 7 8 9 10										(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)									
0 1 N E C P R 1 2 0 0 - 0 0 0 0 - 0 0 0 3 4 1 1 1 1 4 5										7 8 9 14 15 25 26 30 37 CAT 38									
CON'T 0 1 REPORT SOURCE L 6 0 5 0 0 0 2 9 8 7 0 4 2 6 8 0 8 0 5 2 6 8 1 9										60 61 68 69 74 75 80									
EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10																			
0 2 During performance of Surveillance Procedure 6.5.12.1 with the reactor in cold																			
0 3 shutdown, #1 diesel generator cylinder temperature increased. Redundant #2 diesel																			
0 4 generator was operable. There were no adverse affects to the public health and																			
0 5 safety.																			
0 6																			
0 7																			
0 8																			
0 9																			
SYSTEM CODE E E 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE E N G I N E 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16										9 10 11 12 13 18 19 20									
17 LER/RO REPORT NUMBER 8 1 21 22 0 0 7 24 26 0 3 28 29 L 30 31 0 32																			
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS 22 ATTACHMENT SUBMITTED NPD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER										33 34 35 36 37 40 41 42 43 44 47									
A 18 H 19 Z 20 Z 21 0 0 0 0 23 24 A 25 C 6 3 4 26																			
CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27																			
1 0 A temporary pressure test gauge installed in a CB KSV diesel engine fell off in-																			
1 1 itiating decreased control air pressure and allowing the inlet air dampers to																			
1 2 partially close. Connection port capped. Engine tested satisfactorily. Personnel																			
1 3 advised not to leave test gauges installed.																			
1 4																			
FACILITY STATUS H 28 POWER 0 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION Surveillance Test 32										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
ACTIVITY CONTENT RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
PERSONNEL EXPOSURES NUMBER 0 0 0 17 TYPE Z 38 DESCRIPTION NA 39										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
PUBICITY N 44 DESCRIPTION NA 45										7 8 9 10 11 12 13 14 15 16 17 18 19 20									
8106090 737																			
NAME OF PREPARER C. R. Noyes										PHONE 402-825-3811									