

## LICENSEE EVENT REPORT

CONTROL BLOCK: 1

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N J S G S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

J 1 REPORT SOURCE L 6 0 5 0 0 0 3 1 1 7 0 5 2 2 8 1 8 0 6 0 2 8 1 9  
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 During the performance of Start-up Test (Sup-53) the Main Steam Isolation Valves  
0 3 failed to close within the required 5 seconds. The closing time was verified as  
0 4 8.63 seconds.  
0 5  
0 6  
0 7  
0 8

0 9 SYSTEM CODE C D 11 CAUSE CODE B 12 CAUSE SUBCODE A 13 COMPONENT CODE V A L V E X 14 COMP SUBCODE E 15 VALVE SUBCODE C 16  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
17 LER NO REPORT NUMBER 8 1 23 — 24 0 2 3 27 / 28 0 1 29 30 T 31 — 32 0  
ACTION TAKEN F 18 F 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPRD-4 FORM SUB Y 24 PRIME COMP SUPPLIER L 25 COMPONENT MANUFACTURER Z 9 9 9 9 26  
33 34 35 36 37 40 41 42 43 44 45 46 47

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 The change over from normal hydraulic closing to emergency steam closing had not  
1 1 allowed for this interaction. A time delay relay was installed for Unit 2 by  
1 2 DCR-2EC-1229 and the valves were retested satisfactorily at 3.9 seconds. DCR-1EC-1230  
1 3 will be incorporated in Unit 1 prior to the next plant start-up.  
1 4

1 5 FACILITY STATUS B 28 POWER 0 0 0 29 OTHER STATUS 30 Not Applicable METHOD OF DISCOVERY C 31 DISCOVERY DESCRIPTION 32 Start-up Testing  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
1 6 ACTIVITY CONTENT Z 33 Z 34 NA AMOUNT OF ACTIVITY 35 NA LOCATION OF RELEASE 36  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION 39 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
1 8 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION 41 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20  
1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION 43 NA  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

2 0 PUBLICITY ISSUED N 44 DESCRIPTION 45  
7 8 9 10 11 12 13 14 15 16 17 18 19 20

NRC USE ONLY

8106150144

NAME OF PREPARER

J. J. Espey

PHONE 609-935-0998