

VALLEY AUTHORITY

1750 Chestnut Street Tower II

June 9, 1981

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/81058

The enclosed report provides details concerning the setpoint for steam generator level bistable 1-LS-3-38B being outside the acceptable technical specification limits. This event placed the unit in action statement 7 of limiting condition for operation 3.3.1.1 and action statement 16 of limiting condition for operation 3.3.2.2 and is reported under Sequoyah unit 1 Technical Specification 6.9.1.13.a.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

NRC Inspector, Sequoyah



Handwritten:
IE-12
5/11

8106160

547

S