LICENSEE EVENT REPORT

CONTROL BLOCK: [| | | | |] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	LICENSEE CODE: T N S N P 1 (2)	LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3)	LICENSE TYPE: 4 1 1 1 1 (4)	CAT (5)

CON'T

0 1	REPORT SOURCE: L (6)	DOCKET NUMBER: 0 5 0 0 0 3 2 7 (7)	EVENT DATE: 0 5 2 2 8 1 (8)	REPORT DATE: 0 6 0 9 8 1 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 At 1400 CDT with unit 1 at 99.5% RTP, surveillance testing on S/G level channel

0 3 1-L-3-38 identified that the lo-lo level bistable setpoints for reactor trip

0 4 and safety features actuation were .1432 volts (allowable limit is ≥ .168 volts).

0 5 The bistable was tripped to comply with action statement 7 of LCO 3.3.1.1 and

0 6 action statement 16 of LCO 3.3.2.1. There was no effect on public health or

0 7 safety. No previous occurrences.

0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE
	I A (11)	E (12)	E (13)	I N S T R U (14)	S (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 1	—	0 5 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	F 1 8 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The event was caused by a component failure. The bistable was replaced,

1 1 calibration was completed and the instrument loop was returned to service at

1 2 1800 EDT on 05/22/81.

1 3

1 4

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	E (28)	0 9 9 (29)	NA	B (31)	Surveillance testing

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	NA

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

Name of Preparer M. R. Harding/A. M. Wilkey   Phone (615) 842-8317

8106160 558