



CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203

ARTHUR E. LUNDVALL, JR.
VICE PRESIDENT
SUPPLY

June 5, 1981

U.S. Nuclear Regulatory Commission
Region I
631 Park Avenue
King of Prussia, PA 19406


ATTENTION: R. R. Keimig, Chief
Projects Branch #2, Division of
Resident and Project Inspection

Gentlemen:

This refers to your Inspection Report 50-317/81-07; 50-318/81-07, which transmitted one item of apparent noncompliance with NRC requirements. Enclosure (1) to this letter is a written statement in reply to that item in your letter of May 14, 1981.

Should you have further questions regarding this reply, we will be pleased to discuss them with you.

Very truly yours,


Vice President-Supply

AEL/RED/gla

Enclosure (1)

8106180294

June 5, 1981

STATE OF MARYLAND:
: TO WIT:
CITY OF BALTIMORE:

Arthur E. Lundvall, Jr., being duly sworn states that he is Vice President of the Baltimore Gas and Electric Company, a corporation of the State of Maryland; that he provides the foregoing response for the purposes therein set forth; that the statements are true and correct to the best of his knowledge, information, and belief; and that he was authorized to provide the response on behalf of said Corporation.

WITNESS my Hand and Notarial Seal:

Carol A. Green
Notary Public

My Commission Expires:

July 1, 1982

cc: J. A. Biddison, Esquire
G. F. Trowbridge, Esquire
Director, Office of Inspection & Enforcement
R. E. Architzel, NRC Resident Inspector

ENCLOSURE (1)

REPLY TO APPENDIX A OF NRC INSPECTION

REPORT 50-317/81-07; 50-318/81-07

To prevent recurrence of this event, a Shift Supervisor Assistant (SSA) Turnover Checklist will be developed and implemented by July 1, 1981. In the interim, all SSA's have been instructed by the General Supervisor-Operations to complete and sign a Senior Control Room Operator Turnover Checklist prior to relieving the shift. Additionally, all licensed personnel have been informed of this violation.