

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEX. 75201

Log # TXX-3331


File # 823

June 12, 1981

DUCKET Nos 50-445

and 50-446

Mr. Spottswood Burwell
U. S. Nuclear Regulatory Commission
Licensing Project Manager
Office of Nuclear Reactor Regulation
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
INTERNALLY GENERATED MISSILES IN SAFETY CHILLED
WATER CHILLER ROOMS

Dear Mr. Burwell:

We are evaluating the possibility of internally generated missiles in Safety-Chilled Water Chiller rooms 115A and 115B and their impact on safety equipment in those rooms. We shall provide missile barriers if the results of the evaluation indicates their necessity.

Sincerely,

H. C. Schmidt

AND:tls

cc: R. E. Ballard
J. T. Merritt
R.-D. Calder

Boo
S/p

8106190 242

A