

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3330
File # 823

June 12, 1981

Docket Nos 50-445
and 50-446

Mr. Spottswood Burwell
U. S. Nuclear Regulatory Commission
Licensing Project Manager
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
PMF FLOODING OF SAFETY CHILLED WATER
CHILLER ROOMS



Dear Mr. Burwell:

Because it is possible that a postulated Probable Maximum Flood could cause flooding of Safety-Chilled Water Chiller Rooms 115A and 115B we shall provide:

- 1) Water tight seals on electrical and mechanical penetrations below elevation 790 ft. between rooms 115A & B and 113 and rooms 114 and 115.
- 2) Backwater valves in the floor drains of sump number 10 (see drawing M1-0236-01)

If you have questions please call.

Sincerely

A handwritten signature in dark ink, appearing to read 'H. C. Schmidt'. The signature is fluid and cursive, with a prominent 'H' and 'S'.

H. C. Schmidt

Handwritten initials in dark ink, possibly 'MS' or 'MB', written in a stylized, cursive manner.

AND:tlb

cc: R. E. Ballard
J. T. Merritt
R. D. Calder

Boo
s/p

8106190246

A