

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

1 N I C M G S 1 2 0 1 0 1 0 1 0 1 0 1 0 1 1 1 1 1 4 5  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

CONF 0 1  
 REPORT SOURCE L 8 0 1 5 1 0 1 0 1 3 6 1 9 7 0 4 1 1 8 1 1 8 0 5 1 1 8 8 1 1 9  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While in Mode 3, initial fuel loading, water from the settling pond  
 0 3 was being released when it was noticed that the Conventional Waste  
 0 4 water discharge flow meter's strip chart recorder did not  
 0 5 correspond with the digital readout of the meter. This is in violation  
 0 6 of T.S. 3.3.3.8 and is reportable per T.S. 6.9.1.13(b). Since there  
 0 7 is only new, unirradiated fuel in the core, the health and  
 0 8 safety of the public were not affected.

0 9 SYSTEM CODE M A 11 CAUSE CODE A 12 CAUSE SUBCODE C 13 COMPONENT CODE 1 N S T R U 14 COMP SUBCODE R 15 VALVE SUBCODE 2 16  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 17 LEAD/NO REPORT NUMBER 8 1 21 22 SEQUENTIAL REPORT NO. 0 5 9 23 24 OCCURRENCE CODE 0 3 25 26 REPORT TYPE L 27 28 REVISION NO. 0 29 30  
 ACTION TAKEN E 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 1 0 0 0 22 ATTACHMENT SUBMITTED Y 23 NPROG FORM SUB. N 24 PRIME COMP. SUPPLIER L 25 COMPONENT MANUFACTURER 1 0 9 3 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The flow rate measuring device Mode rotary switch was set to the  
 1 1 Device Number 4 position instead of the Level position. Flow was  
 1 2 estimated during the release. The flow meter was set in the correct  
 1 3 mode, recalibrated and returned to service.

1 4  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 FACILITY STATUS X 28 5 POWER 0 0 0 29 OTHER STATUS Mode 3 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Personnel Observation 32  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 ACTIVITY CONTENT RELEASED OF RELEASE Z 33 AMOUNT OF ACTIVITY NA 34 LOCATION OF RELEASE NA 35  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30  
 PUBLICITY ISSUED N 44 DESCRIPTION NA 45  
 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30

NAME OF PREPARER R. W. Ouellette

PHONE: (704) 373-7530