

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	T	N	S	N	P	1	2	0	0	-	0	0	0	0	0	-	0	0	3	4	1	1	1	1	4			5				
7	8	9	LICENSEE CODE						14	15	LICENSE NUMBER										25	26	LICENSE TYPE					30	57 CAT 5H				

COM 1

REPORT SOURCE L 6 0 5 0 0 0 3 2 7 7 0 5 2 5 8 1 8 0 6 2 3 8 1 9

60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

## EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 With unit 1 at 99% at 1420 CDT on 5/25/81, containment hydrogen analyzer 1-43-210 was

0 3 found out of tolerance during performance of its scheduled surveillance test. The

0 4 plant entered the action statement of LCO 3.6.4.1. There was no effect on public

0 5 health or safety. Two previous occurrences - SQRO-50-327/80182 and SQRO-50-327/81039.

0 6

0 7

0 8

SYSTEM CODE S 9 E 11		CAUSE CODE B 12		CAUSE SUBCODE A 13		COMPONENT CODE I 14 N 15 S 16 T 17 R 18 U 19		COMP. SUBCODE E 20		VALVE SUBCODE Z 21	
LER/RO REPORT NUMBER 17		EVENT YEAR 8 21 1 22		SEQUENTIAL REPORT NO. 0 24 6 25 3 26		OCCURRENCE CODE 0 28 3 29		REPORT TYPE L 30		REVISION NO. 0 32	
ACTION TAKEN E 18		FUTURE ACTION F 19		EFFECT ON PLANT Z 20		SHUTDOWN METHOD Z 21		HOURS 0 22 0 23 0 24		ATTACHMENT SUBMITTED N 25	
NPRD-4 FORM SUB. N 26		PRIME COMP. SUPPLIER L 27		COMPONENT MANUFACTURER D 28 0 29 9 30 6 31							

## CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The analyzer required readjustment of the reagent flow to bring it into tolerance. A

1 1 modification (WP 9184) is scheduled to be performed during the next unit outage which

1 2 will improve reagent air flow regulation and therefore prevent recurrence of this

1 3 problem.

1 4

1 5 28 0 9 9 29 NA 30 44  
FACILITY STATUS % POWER OTHER STATUS  
2 8 9 10 12 13 44

1 6 33 2 34 NA 35 44  
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY  
7 9 10 11 12 13 44

B 31 Surveillance testing 32 46  
METHOD OF DISCOVERY DISCOVERY DESCRIPTION

NA 36 46  
LOCATION OF RELEASE

PERSONNEL EXPOSURES

NUMBER				TYPE		DESCRIPTION
1	7	0	0	0	Z	NA

PERSONNEL INJURIES  
NUMBER DESCRIPTION (41)

1	14	0	0	0	(41)	NA
---	----	---	---	---	------	----

1		2		3		4		5		6		7		8		9		10	
LOSS OF OR DAMAGE TO FACILITY (43)																			
TYPE		DESCRIPTION																	
1 9		2 42		NA															

PUBLICITY		(45)		NRC USE ONLY
ISSUED	DESCRIPTION	NA		
2	0	(44)		
7	8	9	10	68
				69

M. R. Harding/A. M. Wilkey

PHONE (815) 842-8317

810630 0430