

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3348

File # 839

June 23, 1981

Mr. Spottswood Burwell  
Licensing Project Manager  
U. S. Nuclear Regulatory Commission  
Office of Nuclear Reactor Regulation  
Washington, D.C. 20555



SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
CONTAINMENT HIGH RANGE RADIATION MONITOR  
(TMI ACTION PLAN ITEM II.F.1)

Dear Mr. Burwell:

CPSES is currently evaluating the inclusion of Containment High Range Radiation Monitors into the existing plant radiation monitoring system.

Based on the preliminary results of this on-going evaluation, the following commitments will be met:

1. Two high range monitors will be installed in containment. The monitors will be unshielded and physically separated on opposite sides of the reactor vessel.
2. The monitors will have separate read-out via safety related remote display devices mounted on the main control board in the Control Room.
3. The monitors will meet the specifications of NUREG-0737, Table II.F.1-3; with the possible exception of the "Special Calibration" and "Special Environmental Qualification" requirements.

Upon completion of our engineering evaluation (expected within 90 days) CPSES will either commit to all the NUREG-0737 specifications or take exception to the pending items in (3) above, and provide a justification to support such a position. We will also provide the exact location of the monitors in a future amendment to the SAR.

Sincerely,

A handwritten signature in dark ink, appearing to read "H. C. Schmidt", with a stylized flourish at the end.

H. C. Schmidt

8106800 453

VA

Boo!  
5/10

JPS:tlb

cc: R. E. Ballard  
J. T. Merritt  
R. D. Calder  
J. C. Kuykendall