

TEXAS UTILITIES SERVICES INC.

2001 BRYAN TOWER - DALLAS, TEXAS 75201

Log # TXX-3355
File # 10010

June 29, 1981

Mr. Spottswood Burwell
U. S. Nuclear Regulatory Commission
Licensing Project Manager
Office of Nuclear Reactor Regulation
Washington, D.C. 20555


SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
COMMITMENT ON LOW TEMPERATURE OVER PRESSURE
CONTROL LOGIC

Dear Mr. Burwell:

The low temperature, over pressure control logic for the pressurizer
PORV's will be modified to replace the automatic permissive with
a manual arming device.

If you have any questions, please call.

Sincerely,



H. C. Schmidt

DRW:tls

cc: ARMS

R. D. Calder
J. T. Merritt
J. C. Kuykendall
R. A. Jones

Boo1
51/0