

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

1750 Chestnut Street Tower II

June 29, 1981

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 3 - DOCKET
NO. 50-296 - FACILITY OPERATING LICENSE DPR-68 - REPORTABLE OCCURRENCE
REPORT BFRO-50-296/81030

The enclosed report provides details concerning turbine first stage
permissive switches PS-1-81A and B and PS-1-91A and B which were found
to be an average of 10.7 percent above the limits of Technical
Specification 3.1.A while performing turbine first stage pressure
permissive test. This report is submitted in accordance with
Browns Ferry unit 3 Technical Specification 6.7.2.A(5).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. J. Green
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)

Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20535

Director (40)

Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavallee
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. R. F. Sullivan, NRC Inspector, Browns Ferry

8107060341 810629
PDR ADOCK 05000296
S PDR

An Equal Opportunity Employer

TE22
5
1/1