

**BEFORE THE UNITED STATES  
NUCLEAR REGULATORY COMMISSION**

In the Matter of  
**NEW YORK POWER AUTHORITY**  
James A. FitzPatrick Nuclear Power Plant

)  
)  
)  
Docket No. 50-333

**APPLICATION FOR AMENDMENT TO OPERATING LICENSE**


Pursuant to Section 50.90 of the regulations of the Nuclear Regulatory Commission, the New York Power Authority, as holder of Facility Operating License No. DPR-59, hereby applies for an Amendment to the Technical Specifications contained in Appendix A of this license.

This application for an amendment to the James A. FitzPatrick Technical Specifications changes Specifications 4.9.C, "Diesel Fuel" and 4.12.A.1.i, "High Pressure Water Fire Protection System" on pages 218 and 244c. These changes revise the diesel fuel quality values for water and sediment and ash to reflect the current industry standards provided in ASTM D975-81.

An additional change is also proposed to Bases 3.9.C, "Diesel Fuel," on page 224 to clarify the design basis of the Diesel Fuel Oil Day Tanks and Storage Tanks. This change is purely administrative in nature and improves the clarity of the Technical Specifications by deleting extraneous information.


The proposed changes to the Technical Specifications are Attachment I to this Application for Amendment to the Operating License. The Safety Evaluation for the proposed changes is included as Attachment II.

**New York Power Authority**

  
John C. Brons  
Executive Vice President  
Nuclear Generation

**STATE OF NEW YORK  
COUNTY OF WESTCHESTER**

Subscribed and sworn to before me  
this 14th day of December 1989.

  
\_\_\_\_\_  
Notary Public

MINA HOLDEN  
NOTARY PUBLIC, State of New York  
Westchester County  
My Commission Expires Aug. 31, 1991

9001030173 891215  
PDR ADOCK 05000333  
P PNU

ATTACHMENT I

**PROPOSED TECHNICAL SPECIFICATION  
CHANGES REGARDING DIESEL FUEL QUALITY  
LIMITS AND DAY TANK CAPACITY**

(JPTS-89-018 & 89-020)

**New York Power Authority**

**JAMES A. FITZPATRICK NUCLEAR POWER PLANT**

Docket No. 50-333

DPR-59