

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004

JOHN D. SIEBER
Vice President - Nuclear Group

(412) 643-5255

December 21, 1989

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Proposed Operating License Change Request No. 172/33


Gentlemen:

Enclosed are:

1. An Application for Amendment to the above operating licenses to revise the Safety Injection System Accumulators surveillance requirements. The proposed amendment would delete surveillance requirement 4.5.1.d. This surveillance requirement verifies that the accumulator isolation valves automatically open upon receipt of a safety injection signal and when the Reactor Coolant System pressure exceeds the P=11 interlock setpoint. This amendment also corrects a typographical error in surveillance requirement 4.5.1.c.
2. Documents designated Attachments A, B and C which set forth the change in the Technical Specifications, the safety analysis and the no significant hazards evaluation.

This proposed change was reviewed by the OSC and ORC and determined to be safe and does not involve an unreviewed safety question.

Very truly yours,


J. D. Sieber
Vice President
Nuclear Group

9001040084 891221
PDR ADCK 05000334
PDC

Adol

Beaver Valley Power Station, Unit Nos. 1 & 2
Docket No. 50-334, License No. DPR-66
Docket No. 50-412, License No. NPF-73
Page 2

cc: Mr. J. Beall, Sr. Resident Inspector
Mr. W. T. Russell, NRC Region I Administrator
Mr. P. Tam, Sr. Project Manager
Mr. T. M. Gerusky, Director BRP/DER
Mr. R. Janati, BRP/DER
Mr. R. Saunders (VEPCO)