

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

| | | | |
|------------------------------|---|--------------------|--------------------|
| In the Matter of |) | UNIT NO. 1 | UNIT NO. 2 |
| |) | Docket No. 50-334 | Docket No. 50-412 |
| Duquesne Light Company |) | License No. DPR-66 | License No. NPF-73 |
| Beaver Valley Power Station) | | | |

APPLICATION FOR AMENDMENT
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U. S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A to these licenses be amended to delete Safety Injection System Accumulators surveillance requirement 4.5.1.d and correct a typographical error in surveillance requirement 4.5.1.c.

The proposed technical specification changes are set forth in Attachments A to this Application. A Safety Evaluation is set forth in Attachment B. A No Significant Hazard Evaluation is set forth in Attachment C. Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.


WHEREFORE, Applicant respectfully requests that Appendix A to these Operating Licenses be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber
J. D. Sieber
Vice President, Nuclear

Subscribed and sworn to before me
on this 21st day of December

Tracey A. Baczek



Member, Pennsylvania Association of Notaries

9001040085 891221
PDR ADCK 05000334
P FDC