



A Centenor Energy Company

DONALD C. SHELTON
Vice President -- Nuclear
(419) 249-2300

Docket Number 50-346

License Number NPF-3

Serial Number 1737

December 22, 1989

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Subject: License Amendment Application to Remove Technical Specification
Table 3.6-2, Containment Isolation Valves (TAC Number 75235)

Gentlemen:

The enclosed application requests that the Davis-Besse Nuclear Power Station (DBNPS), Unit Number 1 Operating License, Appendix A, Technical Specifications be revised to reflect the changes attached. The proposed changes involve Technical Specification (TS) 3/4.6.3.1, Containment Isolation Valves, Table 3.6-2, Containment Isolation Valves, TS 3/4.6.1.1 Containment Integrity, TS Definition 1.8, Containment Integrity and TS Bases 3/4.6.3, Containment Isolation Valves. This request proposes to remove TS Table 3.6-2 from the TS and relocate the list of containment isolation valves and associated information to the Updated Safety Analysis Report (USAR). This change would allow changes to be made to the table in accordance with 10CFR50.59 while maintaining the test requirements for containment isolation valves in the TS.

This request is similar to the license amendment issued by the NRC on May 22, 1989 that deleted the Containment Isolation Valve table from the Operating License Technical Specifications for the Crystal River Unit Number 3 Nuclear Generating Plant.

Toledo Edison requests that this amendment be issued by the NRC by March 30, 1990 to facilitate restart from the sixth refueling outage. During the sixth refueling outage plant modifications will be performed which will require changes to TS Table 3.6-2 under the 10CFR50.92 license amendment process if the table is not removed from the TS to allow revision under the 10CFR50.59 process. Approval of this application, as requested herein, will also eliminate the need for NRC review and approval of license amendment applications previously submitted under letter Serial Number 1415, dated August 31, 1988 (TAC Number 66008) and letter Serial Number 1667, dated June 13, 1989 (TAC Number 73244).


9001110086 891222
FDR ADOCK 05000346
F PDC

A001
11

Docket Number 50-346
License Number NPF-3
Serial Number 1737
Page 2

Should further information be required, please contact Mr. R. W. Schrauder,
Nuclear Licensing Manager, at (419) 249-2366.

Very truly yours,



GBK/ssg

cc: P. M. Byron, DB-1 NRC Senior Resident Inspector
A. B. Davis, Regional Administrator, NRC Region III
T. V. Wambach, DB-1 NRC Senior Project Manager
State of Ohio