



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 97 PERRY, OHIO 44081 TELEPHONE (216) 259-3737 ADDRESS-10 CENTER ROAD
FROM CLEVELAND: 479-1280 TELEX: 241599
ANSWERBACK: CEI PRYO

Al Kaplan

VICE PRESIDENT
NUCLEAR GROUP

Serving The Best Location in the Nation
PERRY NUCLEAR POWER PLANT

January 9, 1990
PY-CEI/NRR-1118 L

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Perry Nuclear Power Plant
Docket No. 50-440
Request for Additional Information
NRC Bulletin 88-04 (TAC No. 69954)

Gentlemen:

Our letter PY-CEI/NRR-1081L dated December 13, 1989 provided the following information on RCIC pump minimum flow limitations from PNPP operating instructions, however, the inequality signs were inadvertently omitted:

"Maintain the RCIC Pump flow greater than or equal to the following limitations:

RPM	Continuous Duty	30 minutes in 24 hour period	10 minutes in 24 hour period
< 2250	140 GPM	85 GPM	NA
> 2250	345 GPM	225 GPM	120 GPM

NOTE: RCIC MIN FLOW VALVE, 1E51-F019, passes 120 GPM"

The RCIC pump manufacturer has confirmed that operation of the system within the limits of this table will not result in pump degradation. If you have any questions, please feel free to call.

Very truly yours,

Al Kaplan
Vice President
Nuclear Group

AK:njc

cc: T. Colburn
P. Hiland
USNRC, Region III

9001170408 900109
PDR ADOCK 05000440
Q PDC

TE37
1/0