



Arkansas Power & Light Company
425 West Capitol
P. O. Box 551
Little Rock, AR 72203
Tel 501 377 4000

January 23, 1990

1CAN019010

U. S. Nuclear Regulatory Commission
Document Control Desk
Mail Station P1-137
Washington, DC 20555

Subject: Arkansas Nuclear One - Unit 1
Docket No. 50-313
License No. DPR-51
Schedule of Completion for Items Identified
During NRC Bulletin 79-02 and 79-14
Follow-up Inspection for Arkansas
Nuclear One, Unit 1

Gentlemen:

Our correspondence of November 22, 1989 (1CAN118903) related the Arkansas Power and Light Company (AP&L) review of inspection report 50-313/89-200 concerning the activities undertaken to comply with NRC Bulletin (NRCB) 79-02 "Anchor Bolts and Baseplates", and NRCB 79-14, "Piping Analysis Consistency with Plant Configuration", on Arkansas Nuclear One, Unit 1 (ANO-1). Included in our correspondence was a discussion of our planned actions to respond to items identified in the Inspection Report and a commitment to provide the staff with our schedule for completing action on those open items identified in Appendices A and B of that report.

Attached to this letter is a schedule for completing the actions identified by AP&L to respond to each Inspection Report Appendix A and B items. These schedule dates reflect the completion of all activities required to respond to the primary items. If secondary issues are identified in the course of this effort or if modification work not previously identified results from these activities then additional time beyond what is currently projected in this schedule could be required.


9002050304 900123
PDR ADCK 05000313
Q PDC

LEO
1/1

U. S. NRC
Page 2
January 23, 1990

Should you have any questions regarding this matter, do not hesitate to contact my office.

Very truly yours,


James J. Fisicaro
Manager, Licensing

JJF/lw
Attachments

cc: Mr. Robert Martin
U. S. Nuclear Regulatory Commission
Region IV
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 75011

NRC Senior Resident Inspector
Arkansas Nuclear One - ANO-1 & 2
Number 1, Nuclear Plant Road
Russellville, AR 72801

Mr. C. Craig Harbuck
NRR Project Manager, Region IV/ANO-1
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-D-18
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Chester Poslusny
NRR Project Manager, Region IV/ANO-2
U. S. Nuclear Regulatory Commission
NRR Mail Stop 13-D-18
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852

ATTACHMENT
SCHEDULE OF ACTIONS

APPENDIX A - DISCREPANCIES

	<u>Page</u>	<u>Documentation To File Date</u>
1. Sample Size of Bolts to be Tested	A-1	Status Update on 3/30/90
<u>A. Piping Analysis Nonconservatism</u>		
1. Pump Nozzle Loadings	A-1	6/30/90
2. Seismic Anchor Motion (SAM)	A-2	6/30/90
3. Thermal Expansion for Varying Operating Modes	A-3	6/30/90
4. Zero Period Acceleration (ZPA)	A-4	6/30/90
5. Eccentric Mass of Valve Actuators	A-4	6/30/90
6. Containment Penetration Displacement	A-5	6/30/90
<u>B. As-Designed and As-Built Piping Differences</u>		
1. Nonfunctional Pipe Supports in Service Water System	A-5	6/30/90
2. Recently Reworked DHR Pipe Support Not In Agreement with Design	A-6	6/30/90
3. Spring Hangers	A-6	6/30/90
4. Snubber Settings	A-6	12/30/90
5. Main Feedwater Containment Isolation Valve Interaction with Structural Platform	A-7	6/30/90
<u>C. Additional Analyses To Justify Current Plant Configuration</u>		
1. Main Feedwater Water Hammer Analysis	A-7	9/30/90
2. Seismic Qualification of Main Feedwater Isolation Valve	A-8	3/30/90
3. Damaged DHR Piping	A-9	6/30/90
4. Code Reconciliation	A-10	6/30/90
5. Updating Stress Analysis Calculations	A-10	3/30/90

APPENDIX B DISCREPANCIES

Completion of all Appendix B discrepancies will be complete with documentation available for audit by 6/30/90.